
USACE / NAVFAC / AFCEA / NASA UFGS-28 33 00.00 40 (August 2008)

Preparing Activity: NASA Superseding
UFGS-28 33 00.00 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2010

SECTION TABLE OF CONTENTS

DIVISION 28 - ELECTRONIC SAFETY AND SECURITY

SECTION 28 33 00.00 40

FUEL-GAS DETECTION AND ALARM

08/08

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 SYSTEM DESCRIPTION
 - 1.3.1 Design Requirements
 - 1.3.1.1 Schematics
 - 1.3.1.2 Combustible Gas Environments
 - 1.3.1.3 Oxygen Deficient Atmospheres
 - 1.3.2 Performance Requirements

PART 2 PRODUCTS

- 2.1 GENERAL
- 2.2 ELECTROMAGNETIC COMPATIBILITY
- 2.3 CONTROL UNIT
 - 2.3.1 General Requirements
 - 2.3.2 Control Circuits
 - 2.3.3 Power Supply Component
 - 2.3.4 Indicator Light and Reset
 - 2.3.5 Malfunction Circuits
 - 2.3.6 Alarm
- 2.4 DETECTORS
 - 2.4.1 Circuit Design
 - 2.4.2 Combustible Gas Detector
 - 2.4.3 Oxygen Detector
- 2.5 POWER SUPPLY

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 Combustible Gas Systems
 - 3.1.2 Oxygen Deficiency Systems
- 3.2 GROUNDING
- 3.3 TESTS

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-28 33 00.00 40 (August 2008)

Preparing Activity: NASA Superseding
UFGS-28 33 00.00 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2010

SECTION 28 33 00.00 40

FUEL-GAS DETECTION AND ALARM 08/08

NOTE: This guide specification covers the requirements for equipment, performance, and testing of stationary electrical instruments used for sensing the presence of combustible gases, or the deficiency of oxygen, in ambient air.

Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the

Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

COMPRESSED GAS ASSOCIATION (CGA)

CGA P-39 (2008) Oxygen-Rich Atmospheres; 2nd Edition

CONSUMER ELECTRONICS ASSOCIATION (CEA)

CEA-310-E (2005) Racks, Panels, and Associated Equipment

ISA - INTERNATIONAL SOCIETY OF AUTOMATION (ISA)

ANSI/ISA 12.13.01 (2003) Performance Requirements for Combustible Gas Detectors

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 110 (2010; TIA 10-1) Standard for Emergency and Standby Power Systems

NFPA 70 (2008; TIA 08-1) National Electrical Code

NFPA 72 (2010; TIA 10-1; TIA 10-2; TIA 10-3; TIA 10-4) National Fire Alarm and Signaling Code

U.S. DEPARTMENT OF DEFENSE (DOD)

MIL-STD-461 (2007; Rev F) Requirements for the Control of Electromagnetic Interference Characteristics of Subsystems and Equipment

1.2 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the

submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.][for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Submit [Material, Equipment, and Fixture Lists](#) in accordance with paragraph entitled, "General," of this section.

SD-02 Shop Drawings

Submit the following in accordance with paragraph entitled, "General," of this section.

[Connection Diagrams](#)
[Record Drawings](#)

SD-03 Product Data

Submit [Manufacturer's Catalog Data](#) in accordance with paragraph entitled, "General," of this section.

SD-04 Samples

Submit [Samples](#) of detectors used in accordance with paragraph entitled, "Detectors," of this section.

SD-07 Certificates

Submit [Listing of Product Installations](#) in accordance with paragraph entitled, "Installation," of this section.

SD-10 Operation and Maintenance Data

Submit [Operation and Maintenance Manual](#) information in accordance

with paragraph entitled, "System Description," of this section.

1.3 SYSTEM DESCRIPTION

NOTE: If Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS is not included in the project specification, applicable requirements therefrom should be inserted and the following paragraph deleted.

Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS applies to work specified in this section.

Contractor shall furnish [_____] [four] copies of a [Operation and Maintenance Manual](#) giving complete instructions for the operation, inspection, testing, and maintenance of the system, including wiring diagrams and equipment malfunction checklist.

1.3.1 Design Requirements

1.3.1.1 Schematics

Schematics shall not be "typicals" but show the specific equipment to be furnished.

1.3.1.2 Combustible Gas Environments

System shall provide electrically supervised detection and [_____] [noncoded] alarm for combustible gas in Class I, Division 1, Group [_____] [C and D] locations. Design shall comply with applicable requirements of [NFPA 70](#), [NFPA 72](#), [and [_____]].

1.3.1.3 Oxygen Deficient Atmospheres

System shall provide electrically supervised detection and [_____] [noncoded] alarm of oxygen deficient atmospheres. [Design shall comply with applicable requirements of [_____]].

1.3.2 Performance Requirements

Performance shall conform to requirements of [_____] [[ANSI/ISA 12.13.01](#)].

Operation of any detection device shall result in control unit relays automatically activating [remote alarms] [, and lights].

PART 2 PRODUCTS

2.1 GENERAL

NOTE: Local policies may dictate more elaborate procedures for qualification or approval of detector samples.

When spot-type detectors are used, the Record Drawings required by Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS shall show by number

the detectors in the exact sequence in which they are installed in the circuit.

Name of the manufacturer and the serial numbers shall appear on all major components.

Submit [Connection Diagrams](#) showing a complete conduit and wiring layout for the equipment to be furnished, including AWG size and type of wire, and number of conductors and connections to the equipment.

[Record Drawings](#) shall provide current factual information including deviations and amendments to the drawings, and concealed and visible changes in the work.

Submit [Manufacturer's Catalog Data](#) for the [combustible gas] [oxygen deficient atmospheres] detection systems including special tools necessary for the maintenance of the equipment. Submit spare parts data consisting of one set of fuses of each type and size required, and a [_____] [hydrogen] gas calibration kit.

[Material, Equipment, and Fixture Lists](#) shall include manufacturer's style or catalog numbers, specification and drawing reference numbers, independent testing laboratory reports, and related descriptive matter on the devices to be installed.

2.2 ELECTROMAGNETIC COMPATIBILITY

Design electrical and electronic systems to operate without causing electromagnetic interference to, or malfunctioning due to electromagnetic interference from, other systems or equipment, and in accordance with applicable requirements of [[ANSI/ISA 12.13.01](#)], [_____] [[MIL-STD-461](#)].

2.3 CONTROL UNIT

2.3.1 General Requirements

Control unit shall be [_____] [dual] channel, operating over a temperature range of [_____] [[32 to 125](#)] [degrees F](#) [[0 to 51](#)] [degrees C](#). Each control unit shall be capable of monitoring [_____] [two] detectors.

House the control unit in a [_____] [weatherproof] cabinet suitable for [_____] [wall] mounting [in a Class I, Division 1, Group [_____] location]. Relays shall be [_____] [solid state] [plug-in] type. Rectifiers shall be solid state type.

2.3.2 Control Circuits

Circuits shall be solid state, with plug-in type circuit boards, in a housing [conforming to [CEA-310-E](#),] suitable for [Class 1, Group [_____] [non-hazardous] locations.

2.3.3 Power Supply Component

Transformer, rectifier, resistors, charger, batteries and other required power-supply components shall be incorporated in the control unit, or a separate power-supply unit may be furnished and installed as approved for the application.

2.3.4 Indicator Light and Reset

Each control unit shall have [buttons for test, and] indicator lights for Power, [Malfunction,] and Alarm. Indicator lamps shall be color coded as follows: Power (green), [Malfunction [(yellow)] [(____)],] and Alarm [(____)] [(red)]. Zero, Alarm, and Calibration settings shall be adjustable.

2.3.5 Malfunction Circuits

Sensing circuits shall be monitored by individual malfunction circuits. Open circuit shall activate malfunction light and operate relays for [remote] warning signal [and lights].

2.3.6 Alarm

NOTE: Exercise care to ensure options selected properly satisfy project requirements.

Arrange the unit to operate alarm relays, activating audible and visible alarms, and continue operation until [[reset by a keyed switch] [silenced by a switch] [in] [on] the unit cabinet] [or] [the atmosphere returns to set conditions].

[Reset key shall not be removable until conditions have returned to normal.] [Cabinet shall be locked by the same key used to reset the alarm relays.] [Operation of the silencing switch shall light an indicator lamp, which shall be plainly visible when the cabinet is closed.]

Provide audible alarm and [_____] [red] rotating alarm beacon [as indicated].

2.4 DETECTORS

If detectors have not been previously qualified and approved for installation, submit [samples](#) of detectors.

2.4.1 Circuit Design

Detector circuit design shall be suitable for the types and numbers of detectors, as approved, and detector circuit current shall not exceed ratings of the individual detectors and associated relays.

2.4.2 Combustible Gas Detector

Combustible gas detector shall be [_____] [diffusion] [sample draw] type [_____] [catalytic] sensor [meeting the requirements of [ANSI/ISA 12.13.01](#),] in a housing suitable for the environment, and shall be intrinsically safe for use in Class I, Division 1, Group [_____] locations.

Output signal shall be [_____] [4-20 mA]. Operating range shall be [_____] [[minus 40 to 165](#)] [degrees F](#) [[minus 40 to 74](#)] [degrees C](#).

2.4.3 Oxygen Detector

Oxygen detector shall be [_____] [a paramagnetic] [an electrochemical] cell [meeting the requirements of [CGA P-39](#)]. Minimum shelf life shall be

[_____] [6] months.

Output signal shall be [_____] [4-20 mA]. Operating range shall be [_____] [40 to 90] degrees F [4 to 33] degrees C, [_____] [10 to 100] percent relative humidity. Measurement shall be adjustable through a range of [_____] [0 to 25] percent oxygen-in-air, and actuation level shall be set at 19.5 percent oxygen.

2.5 POWER SUPPLY

Primary power supply shall be a [_____] [120]-volt, 60 Hz source. Provide an alternate source of power, arranged to become energized automatically within at least [ten] [_____] seconds upon loss of normal power, in accordance with NFPA 110.

PART 3 EXECUTION

3.1 INSTALLATION

Listing of Product Installations for combustible gas detection systems shall include identification of at least 5 units, include identification of at least 5 units, similar to those proposed for use, that have been in successful service for a minimum period of 5 years. List shall include such data as number of false alarms and malfunctions experienced while in service over a period of [_____] [2] years.

3.1.1 Combustible Gas Systems

Installation of combustible gas detection and alarm systems shall comply with NFPA 70 and applicable requirements of NFPA 72 [, and [_____]].

3.1.2 Oxygen Deficiency Systems

Installation of oxygen detection and alarm systems shall comply with NFPA 70 [and] [_____]].

3.2 GROUNDING

Grounding shall be in accordance with NFPA 70.

3.3 TESTS

Conduct performance tests in accordance with ANSI/ISA 12.13.01 [_____]].

Test operation of the entire system in operational and alarm modes. Each detector shall be activated by [_____] [a hydrogen gas bottle representing the adjusted Lower Flammable Limit (LFL)]. Test malfunction feature for each control unit.

-- End of Section --