

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-46 30 00 (August 2017)  
-----  
Preparing Activity: USACE Superseding  
UFGS-43 32 69 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2018

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 46 - WATER AND WASTEWATER EQUIPMENT

#### SECTION 46 30 00

#### WATER AND WASTEWATER CHEMICAL FEED SYSTEMS

08/17

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 MAINTENANCE MATERIAL SUBMITTALS
- 1.4 DELIVERY, STORAGE, AND HANDLING

#### PART 2 PRODUCTS

- 2.1 SYSTEM DESCRIPTION
  - 2.1.1 System Requirements
  - 2.1.2 Performance Requirements
  - 2.1.3 Submittal Data for Chemical Feed System
  - 2.1.4 Extended Warranty
- 2.2 EQUIPMENT
  - 2.2.1 Standard Products
  - 2.2.2 Nameplates
  - 2.2.3 Controlled Volume Pumps
    - 2.2.3.1 Acid Feed System
    - 2.2.3.2 Adsorption Agent Feed Systems
    - 2.2.3.3 Base Feed System
    - 2.2.3.4 Biocide Feed System
    - 2.2.3.5 Coagulant Aid Feed System
    - 2.2.3.6 Disinfecting Agent Feed Systems
    - 2.2.3.7 Miscellaneous Feed System
    - 2.2.3.8 Oxidant Feed System
    - 2.2.3.9 Precipitant Feed System
    - 2.2.3.10 Primary Coagulant Feed System
    - 2.2.3.11 Prophylaxis Feed System
    - 2.2.3.12 Sequestrant Feed Systems
  - 2.2.4 Controls
    - 2.2.4.1 Automatic Control
      - 2.2.4.1.1 Flow meter and Controller
      - 2.2.4.1.2 Oxidation-Reduction Potential Probe
      - 2.2.4.1.3 pH Probe
    - 2.2.4.2 Semiautomatic Control

- 2.2.4.3 Manual Control
- 2.2.5 Drives for Controlled Volume Pumps
  - 2.2.5.1 Water Pressure Drive
  - 2.2.5.2 Electric Motor Drive
  - 2.2.5.3 Gasoline Engine Drive
- 2.2.6 Calibration Standpipes
- 2.2.7 Valves
  - 2.2.7.1 Metering Pump Valves
  - 2.2.7.2 Suction and Discharge Valves
  - 2.2.7.3 Back Pressure Valve
  - 2.2.7.4 Pulsation Dampeners
- 2.2.8 Solution Tanks
  - 2.2.8.1 Acid Tank
  - 2.2.8.2 Adsorption Agent Tank
  - 2.2.8.3 Base Tank
  - 2.2.8.4 Biocide Tank
  - 2.2.8.5 Coagulant Aid Tank
  - 2.2.8.6 Disinfecting Agent Tank
  - 2.2.8.7 Miscellaneous Tanks
  - 2.2.8.8 Oxidant Tank
  - 2.2.8.9 Precipitant Tank
  - 2.2.8.10 Primary Coagulant Tank
  - 2.2.8.11 Prophylaxis Tank
  - 2.2.8.12 Sequestrant Tank
- 2.2.9 Pressure Gauges
- 2.2.10 Injectors
- 2.2.11 Piping
  - 2.2.11.1 Backflow Preventor
  - 2.2.11.2 Chemical Solution Piping
    - 2.2.11.2.1 Smaller than 40 mm1-1/2 inch Diameter
    - 2.2.11.2.2 Piping 40 mm1-1/2 inch Diameter or Greater
  - 2.2.11.3 Pipe Lining
  - 2.2.11.4 Pipe Fittings
  - 2.2.11.5 Plumbing
- 2.2.12 Electrical Work
  - 2.2.12.1 Motor Starters
  - 2.2.12.2 Control and Protective Devices
- 2.2.13 Equipment Appurtenances
- 2.2.14 Factory Painting
- 2.2.15 Factory Test Report
- 2.3 MATERIALS
  - 2.3.1 Acids
  - 2.3.2 Adsorption Agents
  - 2.3.3 Bases
  - 2.3.4 Biocides
  - 2.3.5 Coagulant Aids
  - 2.3.6 Disinfecting Agents
  - 2.3.7 Miscellaneous
  - 2.3.8 Oxidants
  - 2.3.9 Precipitants
  - 2.3.10 Primary Coagulants
  - 2.3.11 Prophylaxis
  - 2.3.12 Sequestrants

## PART 3 EXECUTION

- 3.1 EXAMINATION
- 3.2 INSTALLATION
  - 3.2.1 Chemical Feeding Equipment

- 3.2.2 Gasoline Engines
- 3.2.3 Pipe, Tubing, Hangers and Supports
- 3.2.4 Field Painting
- 3.2.5 Framed Instructions
- 3.3 FIELD QUALITY CONTROL
  - 3.3.1 Testing
    - 3.3.1.1 Tank Testing
    - 3.3.1.2 Controlled Volume Pumps - Operational Tests
    - 3.3.1.3 Controlled Volume Pumps - Time, Volume and Pumping Pressure Tests
    - 3.3.1.4 System Pressure Tests
    - 3.3.1.5 Flow Tests
    - 3.3.1.6 Synchronization Tests
  - 3.3.2 Chemical Waste
  - 3.3.3 Manufacturer Field Service
- 3.4 CLOSEOUT ACTIVITIES
  - 3.4.1 FIELD TRAINING
  - 3.4.2 Operating Instructions
  - 3.4.3 Maintenance Instructions

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-46 30 00 (August 2017)  
-----  
Preparing Activity: USACE Superseding  
UFGS-43 32 69 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2018

\*\*\*\*\*

### SECTION 46 30 00

#### WATER AND WASTEWATER CHEMICAL FEED SYSTEMS 08/17

\*\*\*\*\*

NOTE: This guide specification covers the requirements for chemicals and controlled volume pumps and appurtenances consider Specification 41 31 11 for CHLORINE GAS FEED. THIS SPECIFICATION IS PRIMARILY USED FOR WATER, WASTEWATER AND MECHANICAL PROCESS WATER TREATMENT SYSTEM..

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

#### PART 1 GENERAL

##### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also

use the Reference Wizard's Check Reference feature  
to update the issue dates.

References not used in the text will automatically  
be deleted from this section of the project  
specification when you choose to reconcile  
references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the  
extent referenced. The publications are referred to within the text by the  
basic designation only.

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

|                    |   |
|--------------------|---|
| ANSI Z400.1/Z129.1 | (2010) Hazardous Workplace Chemicals -<br>Hazard Evaluation and Safety Data Sheet<br>and Precautionary Labeling Preparation |
|--------------------|---|

AMERICAN WATER WORKS ASSOCIATION (AWWA)

|           |   |
|-----------|---|
| AWWA B201 | (2013) Soda Ash   |
| AWWA B300 | (2010; Addenda 2011) Hypochlorites                                |
| AWWA B302 | (2016) Ammonium Sulfate   |
| AWWA B303 | (2018) Sodium Chlorite  |
| AWWA B402 | (2012) Ferrous Sulfate  |
| AWWA B403 | (2016) Aluminum Sulfate - Liquid, Ground,<br>or Lump              |
| AWWA B404 | (2014) Liquid Sodium Silicate                                     |
| AWWA B405 | (2016) Sodium Aluminate   |
| AWWA B406 | (2014) Ferric Sulfate   |
| AWWA B407 | (2012) Liquid Ferric Chloride                                     |
| AWWA B408 | (2018) Liquid Polyaluminum Chloride                               |
| AWWA B451 | (2016) Poly(Diallyldimethylammonium<br>Chloride)                  |
| AWWA B452 | (2014) EPI-DMA Polyamines   |
| AWWA B453 | (2013) Polyacrylamide   |
| AWWA B501 | (2013) Sodium Hydroxide (Caustic Soda)                            |
| AWWA B502 | (2017) Sodium Polyphosphate, Glassy<br>(Sodium Hexametaphosphate) |
| AWWA B503 | (2017) Sodium Tripolyphosphate                                    |
| AWWA B504 | (2012) Monosodium Phosphate, Anhydrous                            |

|           |                                      |
|-----------|--------------------------------------|
| AWWA B505 | (2012) Disodium Phosphate, Anhydrous |
| AWWA B511 | (2017) Potassium Hydroxide           |
| AWWA B550 | (2017) Calcium Chloride              |
| AWWA B600 | (2016) Powdered Activated Carbon     |
| AWWA B601 | (2017) Sodium Metabisulfite          |
| AWWA B602 | (2017) Copper Sulfate                |
| AWWA B603 | (2016) Permanganates                 |
| AWWA B701 | (2011) Sodium Fluoride               |
| AWWA B702 | (2011) Sodium Fluorosilicate         |
| AWWA B703 | (2011) Fluorosilicic Acid            |

ASME INTERNATIONAL (ASME)

|             |  |
|-------------|--|
| ASME A13.1  | (2015) Scheme for the Identification of Piping Systems                               |
| ASME B16.1  | (2015) Gray Iron Pipe Flanges and Flanged Fittings Classes 25, 125, and 250          |
| ASME B16.11 | (2016) Forged Fittings, Socket-Welding and Threaded                                  |
| ASME B16.5  | (2017) Pipe Flanges and Flanged Fittings NPS 1/2 Through NPS 24 Metric/Inch Standard |

ASTM INTERNATIONAL (ASTM)

|                   |   |
|-------------------|---|
| ASTM D1785        | (2015; E 2018) Standard Specification for Poly(Vinyl Chloride) (PVC), Plastic Pipe, Schedules 40, 80, and 120         |
| ASTM D1998        | (2013) Polyethylene Upright Storage Tanks   |
| ASTM D3299        | (2010) Filament-Wound Glass-Fiber-Reinforced Thermoset Resin Corrosion-Resistant Tanks                                |
| ASTM D5421        | (2015) Contact Molded "Fiberglass" (Glass-Fiber-Reinforced Thermosetting Resin) Flanges                               |
| ASTM E1067/E1067M | (2018) Standard Practice for Acoustic Emission Examination of Fiberglass Reinforced Plastic Resin (FRP) Tanks/Vessels |
| ASTM F441/F441M   | (2013; E 2013) Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Plastic Pipe, Schedules 40 and 80   |

HYDRAULIC INSTITUTE (HI)

HI 7.1-7.5 (2006) Controlled Volume Metering Pumps

HI 9.1-9.5 (2000) Pumps - General Guidelines for Types, Applications, Definitions, Sound Measurements and Documentation

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA 250 (2014) Enclosures for Electrical Equipment (1000 Volts Maximum)

NEMA ICS 1 (2000; R 2015) Standard for Industrial Control and Systems: General Requirements

NEMA ICS 2 (2000; R 2005; Errata 2008) Industrial Control and Systems Controllers, Contactors, and Overload Relays Rated 600 V

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 37 (2018) Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines

NFPA 70 (2017; ERTA 1-2 2017; TIA 17-1; TIA 17-2; TIA 17-3; TIA 17-4; TIA 17-5; TIA 17-6; TIA 17-7; TIA 17-8; TIA 17-9; TIA 17-10; TIA 17-11; TIA 17-12; TIA 17-13; TIA 17-14) National Electrical Code

NSF INTERNATIONAL (NSF)

NSF/ANSI 60 (2017) Drinking Water Treatment Chemicals - Health Effects

PLUMBING-HEATING-COOLING CONTRACTORS ASSOCIATION (PHCC)

NAPHCC NSPC (2015) National Standard Plumbing Code Illustrated

UNDERWRITERS LABORATORIES (UL)

UL 50 (2015) UL Standard for Safety Enclosures for Electrical Equipment, Non-Environmental Considerations

1.2 SUBMITTALS

\*\*\*\*\*

**NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project.**

**The Guide Specification technical editors have designated those items that require Government**

approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

The "S" following a submittal item indicates that the submittal is required for the Sustainability eNotebook to fulfill federally mandated sustainable requirements in accordance with Section 01 33 29 SUSTAINABILITY REPORTING. Locate the "S" submittal under the SD number that best describes the submittal item.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.] [information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submittals with an "S" are for inclusion in the Sustainability eNotebook, in conformance to Section 01 33 29 SUSTAINABILITY REPORTING. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Detail Drawings; G[, [\_\_\_\_\_]]

SD-03 Product Data

Chemical Feed System; G[, [\_\_\_\_\_]]

Safety Data Sheets

Framed Instructions

Auxiliary Equipment and Spare Parts

Factory Test Report

SD-06 Test Reports



Operating Tests

Tank Testing

Controlled Volume Pumps - Operational Tests

Controlled Volume Pumps - Time, Volume And Pumping Pressure Tests

System Pressure Tests

Flow Tests

Synchronization Tests

SD-07 Certificates

Supplied Chemical

Service Organization

Certificates; G

SD-10 Operation and Maintenance Data

Operating Instructions; G[, [\_\_\_\_]]

Maintenance Instructions; G[, [\_\_\_\_]]

SD-11 Closeout Submittals

Extended Warranty; G

### 1.3 MAINTENANCE MATERIAL SUBMITTALS

\*\*\*\*\*

**NOTE: Designer shall specify any additional devices that are required to be provided by the contractor to ensure the system operator is able to accurately measure the desired analytes being distributed by this system. Delete items below which may not be required for specific project.**

\*\*\*\*\*

Concurrent with delivery and installation of the specified equipment, furnish auxiliary equipment and spare parts as follows:

- a. Spare parts for each different item of material and equipment specified including all of the parts recommended by the manufacturer to be replaced after [1][ and][ 3] [year][years] service.
- b. For each machine: one extra of each part used that is made from glass, hard rubber, or clear plastic; one extra set of solution-hose connections; one extra set of diaphragms, two filler plug seal washers; two ball checks; two seats; two complete sets of all gaskets; one spare diaphragm for each back pressure regulator; one hydraulic plunger assembly for each different size metering pump; one of each type of material back pressure regulator, with three spare springs and fluorocarbon resin diaphragms for each; one spare diaphragm and air

valve for pulsation dampener.

- c. For each different size of direct current motor one SCR circuit board with 12 drive motor fuses and 12 SCR controller fuses; overload replacement elements for each size and type of motor.
- d. One set of special tools for each type of equipment including calibration devices, and instruments required for adjustment, calibration, disassembly, operation, and maintenance of the equipment.
- e. Two pairs of safety goggles and/or face shields, two chemical resistant aprons, and two pairs of chemical resistant gloves in one or more wall mounted steel cases.
- f. One assembly tool for tubular diaphragm.
- g. One lever type grease gun or other lubricating device for each type of grease required.
- h. One or more steel tool cases mounted on the wall in a convenient location complete with flat key locks, two keys, and clips or hooks to hold each special tool.[
- i. [\_\_\_\_].]

#### 1.4 DELIVERY, STORAGE, AND HANDLING

Protect material and equipment delivered and placed in storage from the weather, excessive humidity and excessive temperature variation, dirt, dust, or other contaminants.

### PART 2 PRODUCTS

#### 2.1 SYSTEM DESCRIPTION

Provide a chemical feed system consisting of a chemical supply storage tank from which the chemical solution is pumped through piping or tubing, as appropriate, to the point of application. Include with each chemical feed system controlled volume pumps, tanks, mixers, gauges, back pressure regulators, strainers, pressure relief valves, sight glasses and flow metering devices, check valves, and hand valves.

##### 2.1.1 System Requirements

Select and fabricate the pumps in accordance with HI 7.1-7.5 and HI 9.1-9.5 except as modified herein. Provide pump stands and platforms adequate to support the pumping system.

##### 2.1.2 Performance Requirements

Capacity and features of the chemical feed systems and accessories must be suitable for 24-hour full load service in ambient, non-freezing conditions.

##### 2.1.3 Submittal Data for Chemical Feed System

Submit manufacturer's performance charts, and pump curves. List of materials, list of equipment, including a complete list of parts and supplies with current unit prices and source of supply. List of special tools for each type of equipment furnished including special tools

necessary for adjustment, operation, maintenance, and disassembly.

#### 2.1.4 Extended Warranty

provide Manufacturer's Extended Warranty to cover system components for [3][5][\_\_\_\_\_] years.

### 2.2 EQUIPMENT

#### 2.2.1 Standard Products

Provide materials and equipment which are the standard products of a manufacturer regularly engaged in the manufacture of the products and that essentially duplicate items that have been in satisfactory use for at least [2][5][ ] years prior to [bid opening][request for proposal]. Equipment must be supported by a service organization that is, in the opinion of the Contracting Officer, reasonably convenient to the site. Submit Service Organization Certificates outlining their location and qualifications to the Contracting Office.

#### 2.2.2 Nameplates

Secure a plate to each major item of equipment containing the manufacturer's name, address, type or style, model or serial number, and catalog number.

#### 2.2.3 Controlled Volume Pumps

\*\*\*\*\*  
NOTE: See HI 7.1-7.5 to determine the optimum type of metering pumps with capacities between 0.04 liters per hour 0.011 gph and 10,000 liters per hour 2500 gph. Materials for each pump shall be as recommended in Table 9.3 of HI 9.1-9.5 for the material to be pumped. If the system backpressure is not at least 5 psi 0.35 bar greater than the suction pressure, a backpressure valve must be installed in the discharge piping to prevent flow through (downhill pumping) which contributes to pump failure and undesired flow at pump shutdown. System backpressure must not exceed the rated discharge pressure of the pump.  
\*\*\*\*\*

Provide controlled volume pumps as defined by HI 7.1-7.5. Each pump must be capable of delivering chemical solution at any rate from the minimum flow rate to the maximum flow rate and be capable of continuous operation at rated capacity. Accuracy must be plus or minus 2 percent over a 100 to 1 range from the required maximum capacity to the minimum pumping rate. Net positive suction head required cannot exceed 90 percent of the net positive suction head available, as installed. Provide in a configuration as simple as practicable to provide equipment isolation, bypass and reliable service and to be readily accessible for inspection, cleaning, adjustment, repairs, and replacements.

#### 2.2.3.1 Acid Feed System

Provide the following for [hydrochloric][sulfuric][\_\_\_\_\_] acid solution delivery.

|   |   |
|---|---|
| Concentration of material on suction side of pump:  | Minimum [_____] percent; maximum [_____] percent.   |
| Number of pumps:                                    | [_____] .   |
| Type of pump:                                       | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].   |
| Configuration:                                      | [Simplex][Duplex][Multiplex].   |
| Controls:   | [Automatic][Semiautomatic][Manual] rate adjustment.   |
| Feed or flow rate:                                  | Minimum [_____] L/hourgph; maximum [_____] L/hour gph.  |
| Back pressure at point of injection:                | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.   |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.   |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][ hard rubber,][ and _____].  |

#### 2.2.3.2 Adsorption Agent Feed Systems

Provide the following for [powdered activated carbon][\_\_\_\_\_] slurry delivery.

|  |   |
|--|---|
| Concentration of material on suction side of pump: | Minimum [_____] percent; maximum [_____] percent.                                 |
| Number of pumps:                                   | [_____] .   |
| Type of pump:                                      | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm]. |
| Configuration:                                     | [Simplex][Duplex][Multiplex].   |
| Controls:  | [Automatic][Semiautomatic][Manual] rate adjustment.                               |
| Feed or flow rate:                                 | Minimum [_____] L/hourgph; maximum [_____] L/hour gph.                            |

|   |   |
|---|---|
| Back pressure at point of injection:                | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.   |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.   |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][hard rubber,][_____].   |

#### 2.2.3.3 Base Feed System

Provide the following for [sodium carbonate (soda ash)][sodium hydroxide (caustic soda)][\_\_\_\_\_] solution delivery.

|  |  |
|--|--|
| Concentration of material on suction side of pump: | Minimum [_____] percent; maximum [_____] percent.  |
| Number of pumps:                                   | [_____].   |
| Type of pump:                                      | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].  |
| Configuration:                                     | [Simplex][Duplex][Multiplex].  |
| Controls:  | [Automatic][Semiautomatic][Manual] rate adjustment.  |
| Feed or flow rate:                                 | Minimum [_____] L/hourgph; maximum L/hourgph.  |
| Back pressure at point of injection:               | kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at kPapsig. Regulators must be of construction with diaphragms. |
| Suction valve cartridge:                           | [Single][Double][Slurry type] ball check.  |
| Discharge valve cartridge:                         | [Single][Double][Slurry type] ball check.  |

|   |  |
|---|--|
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon] [nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][ hard rubber] [, ____]. |
|---|--|

#### 2.2.3.4 Biocide Feed System

Provide the following for [copper sulfate][\_\_\_\_] solution delivery.

|   |  |
|---|--|
| Concentration of material on suction side of pump:  | Minimum [____] percent; maximum [____] percent.  |
| Number of pumps:                                    | [____].  |
| Type of pump:                                       | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].  |
| Configuration:                                      | [Simplex][Duplex][Multiplex].  |
| Controls:   | [Automatic][Semiautomatic][Manual] rate adjustment.  |
| Feed or flow rate:                                  | Minimum [____] L/hourgph; maximum [____] L/hour gph.   |
| Back pressure at point of injection:                | [____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.  |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.  |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon] [nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][ hard rubber][, ____].  |

#### 2.2.3.5 Coagulant Aid Feed System

Provide the following for [photoelectron][\_\_\_\_][solution][slurry] delivery.

|   |   |
|---|---|
| Concentration of material on suction side of pumps: | Minimum [____] percent; maximum [____] percent. |
|---|---|

|   |  |
|---|--|
| Number of pumps:                                    | [____].  |
| Type of pump:                                       | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].  |
| Configuration:                                      | [Simplex][Duplex][Multiplex].  |
| Controls:   | [Automatic][Semiautomatic][Manual] rate adjustment.  |
| Feed or flow rate:                                  | Minimum [____] L/hourgph; maximum [____] L/hourgph.  |
| Back pressure at point of injection:                | [____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.  |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.  |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][hypalon] [nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][ hard rubber][, ____].   |

#### 2.2.3.6 Disinfecting Agent Feed Systems

Provide the following for [ammonium sulfate][hypochlorite][\_\_\_\_] solution delivery.

|  |   |
|--|---|
| Concentration of material on suction side of pump: | Minimum [____] percent; maximum [____] percent.                                   |
| Number of pumps:                                   | [____].   |
| Type of pump:                                      | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm]. |
| Configuration:                                     | [Simplex][Duplex][Multiplex].   |
| Controls:  | [Automatic][Semiautomatic][Manual] rate adjustment.                               |
| Feed or flow rate:                                 | Minimum [____] L/hourgph; maximum [____] L/hourgph.                               |

|   |   |
|---|---|
| Back pressure at point of injection:                | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.   |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.   |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][ hard rubber][, ____].   |

#### 2.2.3.7 Miscellaneous Feed System

Provide the following for [poly(diallyldimethylammonium chloride)][calcium chloride][sodium aluminate][sodium metabisulfite (sodium pyrosulfite)][sodium chlorite][sodium silicate][monosodium phosphate][disodium phosphate][\_\_\_\_\_] [solution][slurry] delivery.

|  |   |
|--|---|
| Concentration of material on suction side of pump: | Minimum [_____] percent; maximum [_____] percent.   |
| Number of pumps:                                   | [_____] .   |
| Type of pump:                                      | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].   |
| Configuration:                                     | [Simplex][Duplex][Multiplex].   |
| Controls:  | [Automatic][Semiautomatic][Manual] rate adjustment.   |
| Feed or flow rate:                                 | Minimum [_____] L/hourgph; maximum [_____] L/hourgph.   |
| Back pressure at point of injection:               | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |



|   |  |
|---|--|
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.  |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.  |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][hard rubber][, ____]. |

#### 2.2.3.8 Oxidant Feed System

Provide the following for [potassium permanganate][hydrogen peroxide][\_\_\_\_] solution delivery.

|   |  |
|---|--|
| Concentration of material on suction side of pump:  | Minimum [____] percent; maximum [____] percent.  |
| Number of pumps:                                    | [____].  |
| Type of pump:                                       | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].  |
| Configuration:                                      | [Simplex][Duplex][Multiplex].  |
| Controls:   | [Automatic][Semiautomatic][Manual] rate adjustment.  |
| Feed or flow rate:                                  | Minimum [____] L/hourgph; maximum [____] L/hour gph.   |
| Back pressure at point of injection:                | [____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.  |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.  |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][ hard rubber][, ____].  |

#### 2.2.3.9 Precipitant Feed System

Provide the following for [\_\_\_\_] solution delivery.

|   |  |
|---|--|
| Concentration of material on suction side of pump:  | Minimum [_____] percent; maximum [_____] percent.  |
| Number of pumps:                                    | [_____].   |
| Type of pump:                                       | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].  |
| Configuration:                                      | [Simplex][Duplex][Multiplex].  |
| Controls:   | [Automatic][Semiautomatic][Manual] rate adjustment.  |
| Feed or flow rate:                                  | Minimum [_____] L/hourgph; maximum [_____] L/hourgph.  |
| Back pressure at point of injection:                | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][ chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.  |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.  |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][hard rubber][, _____].  |

#### 2.2.3.10 Primary Coagulant Feed System

Provide the following for [aluminum sulfate][ferric chloride][ferric sulfate][ferrous sulfate][\_\_\_\_\_] solution delivery.

|  |   |
|--|---|
| Concentration of material on suction side of pump: | Minimum [_____] percent; maximum [_____] percent.                                 |
| Number of pumps:                                   | [_____].  |
| Type of pump:                                      | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm]. |
| Configuration:                                     | [Simplex][Duplex][Multiplex].   |
| Controls:  | [Automatic][Semiautomatic][Manual] rate adjustment.                               |
| Feed or flow rate:                                 | Minimum [_____] L/hourgph; maximum [_____] L/hourgph.                             |

|   |   |
|---|---|
| Back pressure at point of injection:                | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.   |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.   |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,] [hard rubber][, ____].   |

#### 2.2.3.11 Prophylaxis Feed System

Provide the following for [hydrofluosilicic acid][sodium fluoride][sodium silicofluoride][\_\_\_\_\_] solution delivery.

|  |   |
|--|---|
| Concentration of material on suction side of pump: | Minimum [_____] percent; maximum [_____] percent.   |
| Number of pumps:                                   | [_____] .   |
| Type of pump:                                      | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].   |
| Configuration:                                     | [Simplex][Duplex][Multiplex].   |
| Controls:  | [Automatic][Semiautomatic][Manual] rate adjustment.   |
| Feed or flow rate:                                 | Minimum [_____] L/hourgph; maximum [_____] L/hour gph.  |
| Back pressure at point of injection:               | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                           | [Single][Double][Slurry type] ball check.   |
| Discharge valve cartridge:                         | [Single][Double][Slurry type] ball check.   |

|   |  |
|---|--|
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][hard rubber][,_____]. |
|---|--|

#### 2.2.3.12 Sequestrant Feed Systems

Provide the following for [sodium polyphosphate, glassy (sodium hexametaphosphate)][sodium tripolyphosphate][\_\_\_\_\_] solution delivery.

|   |   |
|---|---|
| Concentration on suction side of pump:              | Minimum [_____] percent; maximum [_____] percent.   |
| Number of pumps:                                    | [_____].  |
| Type of pump:                                       | [Packed plunger][Packed piston][Mechanically or hydraulically coupled diaphragm].   |
| Configuration:                                      | [Simplex][Duplex][Multiplex].   |
| Controls:   | [Automatic][Semiautomatic][Manual] rate adjustment.   |
| Feed or flow rate:                                  | Minimum [_____] L/hourgph; maximum [_____] L/hour gph.  |
| Back pressure at point of injection:                | [_____] kPapsig. Install back pressure regulating valve on the pump discharge and factory adjust to crack open at [_____] kPapsig. Regulators must be of [polyvinyl chloride][ or ][_____] construction with [fluorocarbon resin][ or ][chlorosulphonated polyethylene] diaphragms. |
| Suction valve cartridge:                            | [Single][Double][Slurry type] ball check.   |
| Discharge valve cartridge:                          | [Single][Double][Slurry type] ball check.   |
| Materials of construction allowed for wetted parts: | [Type [304L][316][316L] stainless steel,][ PVC,][ hypalon][ nylon,][ fluorocarbon resin,][ chlorosulfonated polyethylene,][ hard rubber] [, _____].   |

#### 2.2.4 Controls

\*\*\*\*\*

**NOTE:** Proportional control is appropriate for variable flow systems. Batch systems should have manual, pH, ORP, or timer control. Constant pumping rate systems should respond to pump operation or a flow switch, if the pumps are remote from the feed system. Designer should delete any paragraphs below that are not necessary for this specific project.

\*\*\*\*\*

Provide the chemical metering equipment with the appurtenances and accessories, as required, for flow capacity adjustment. Provide manual range adjustment on all systems.

#### 2.2.4.1 Automatic Control

Provide automatic control with the capability to vary feed rate based on signals from a [flow], [oxidation-reduction potential (ORP)], [or] [pH] meter or controller.

##### 2.2.4.1.1 Flow meter and Controller

Provide flow meter and controller capable of varying the chemical dosage in proportion to the measured flow with the dosage per flow unit manually adjustable.

##### 2.2.4.1.2 Oxidation-Reduction Potential Probe

Provide oxidation-reduction potential probe located where indicated. Supply probe capable of varying the chemical feed rate in response to the deviation from set point.

##### 2.2.4.1.3 pH Probe

Provide pH probe and locate the pH probe where indicated. Supply probe capable of varying the chemical feed rate in response to the deviation from set point.

#### 2.2.4.2 Semiautomatic Control

Provide semiautomatic control with the capability to automatically start and stop the chemical metering equipments. The pump start and stop must respond to [flow switch][ or ][pump operation][ or ][timer] status. Install flow switch for semiautomatic operation in the pipe line upstream of chemical injectors.

#### 2.2.4.3 Manual Control

Provide nonautomatic control with the capability for starting or stopping the chemical metering equipment and adjustment of the solution feed rate by the operator.

#### 2.2.5 Drives for Controlled Volume Pumps

\*\*\*\*\*

**NOTE: Alternating current motors are preferred where a reliable power supply is accessible. Water power drives are feasible only when the take off can be located at a point with significantly higher pressure than the injection pressure. Designer should delete any paragraphs below that are not necessary for this specific project.**

\*\*\*\*\*

Provide with and drive the metering pumps by [water pressure][alternating current electric motor][direct current electric motor][plant air][gasoline engine] drives.

#### 2.2.5.1 Water Pressure Drive

Provide appropriate pressure regulation devices for water pressure drives operated off system water pressures.

#### 2.2.5.2 Electric Motor Drive

Electric motor must be of sufficient capacity to operate the chemical metering equipment under all operating conditions without exceeding their rated nameplate current or power, or their specified temperature limits. Provide motors having starting characteristics and ruggedness necessary under the actual conditions of operations or clean-up procedures used in the areas where they are located. Alternating current motors with power rating of 248.6 W1/3 hp or less must be 115 volts, single-phase, 60-Hz service; motors with power rating in excess of 248.6 W1/3 hp must be 460 volts, three-phase, 60-Hz service. Electrical features of direct current motors, including the ratings of the motors, must be compatible with the capabilities and ratings of the rectifier controllers with which they are used.

#### 2.2.5.3 Gasoline Engine Drive

Provide gasoline engines that develop sufficient horsepower to operate the chemical metering equipment continuously under the maximum operation conditions without overheating or overloading when operating at a speed not to exceed [\_\_\_\_\_] rpm. Provide 4-cycle, vertical, single cylinder, high tension magneto, air cooled type engines. Connect the engine to the pump or mechanical device by V-belts that are fully guarded.

#### 2.2.6 Calibration Standpipes

Provide chemical metering equipment with a calibration standpipe for measuring pump output. The standpipe must allow convenient observation of the change of fluid level for at least 1/2 minute at full stroke and maximum speed settings, and of Schedule 80, clear PVC pipe conforming to ASTM D1785 with Schedule 80 fittings equipped with a flanged connection to the pump manifold and an end cap fitted with a PVC vacuum breaker and ball valve for air venting. The standpipe must have a clear, observable length of at least [300 mm] [12 inches] [\_\_\_\_\_] and be permanently calibrated in liters, gallons and fractions thereof, to allow reading of the fluid contents with an accuracy of [1] [\_\_\_\_\_] percent.

#### 2.2.7 Valves

##### 2.2.7.1 Metering Pump Valves

Equip the metering pump with adjustable internal vacuum and pressure relief valve, hydraulic oil refill valve, and automatic air bleed valve. The relief valve must be adjustable over the full pressure range of the pump and preset at the factory.

##### 2.2.7.2 Suction and Discharge Valves

Fit suction and discharge valve cartridges with ball checks that open to full pipe diameter.

### 2.2.7.3 Back Pressure Valve

Install back pressure regulating valve on the pump discharge and factory adjust to crack open at the indicated pressure. Provide spring opposed diaphragms with loading pressures adjustable by means of a screw in the top works.

### 2.2.7.4 Pulsation Dampeners

\*\*\*\*\*

**NOTE:** The pulsation dampener should always be installed as close to the pumps as possible in order to reduce the length of pipe in which pulsating flow occurs. A pulsation dampener is a pneumatically charged diaphragm within a chamber that stores energy carried in the acceleration of the pumped fluid. On the discharge side it will protect sensitive equipment from pulsating flow spikes, and will translate pulsating flow to near linear flow by reducing the peak flow and pressure generated by the metering pump. When a pulsating dampener is used on the suction side of a metering pump, it will improve suction pressure conditions by reducing pressure losses associated with the acceleration of the fluid.

\*\*\*\*\*

Size pulsation dampeners for the displacement of each pump. Pulsation dampeners must have a diaphragm separating the upper chamber from the lower chamber. Charge the upper chamber with compressed air to 50 percent of the expected line pressure. Provide the diaphragm of molded construction and prevent the air charge from being dissolved in the process fluid. The lower chamber must be [plastic][ or ][lined with inert plastic material] to prevent corrosion by the process fluid. Equip the upper chamber with a tire valve type charging valve and air pressure gauge. Provide an air line and air hose with pressure regulator and hand-operated, lever-type valve suitable for charging the pulsation dampers.

### 2.2.8 Solution Tanks

\*\*\*\*\*

**NOTE:** This paragraph lists tank specifications. If single wall tanks are preferred, designer must ensure secondary containment is provided within the plans and that containment is separated from other tank containment areas to prevent mixing of chemicals during a spill event. Size dissolving baskets and tank mixers to provide initial mixing and maintain suspensions.

\*\*\*\*\*

Provide tanks that are fully resistant to the effects of the full-strength and fully diluted solution concentrations, and be pressure rated for 1.5 times the weight of solution at full capacity. Each tank must have the capacity listed in the following table and be equipped with a fill nozzle, vent, discharge, level instrument, drain, and two spare connections. Reinforce tanks to withstand all forces when full of solution. Tanks must be completely shop fabricated with no field assembly permitted. Provide drain connections permitting complete drainage of the tank. All gaskets must be fluorocarbon elastomer; nuts and bolts Type 316 stainless steel;

and steel supports either stainless or epoxy coated. Furnish each tank with a calibrated side wall strip to indicate volume. Attach a permanent plastic sign indicating the tank contents to the front of each tank. Fit tanks smaller than 900 mm36 inches in diameter with removable lids. Fit tanks larger than 900 mm36 inches in diameter with 600 mm24 inch manways. Manufacture polyethylene tanks in accordance with ASTM D1998. Manufacture fiberglass tanks in accordance with ASTM D3299 with flanged openings in accordance with ASTM D5421. Line steel tanks with [ceramic], [rubber] or [plastic], as indicated herein. Provide tanks designated to be double walled or provided with secondary containment, as indicated in the tables. Provide dissolving baskets and tank mixers as indicated. Provide floating seals as indicated.

#### 2.2.8.1 Acid Tank

Provide [hydrochloric][sulfuric] acid solution resistant tank and comply with the following:

|                        |  |
|------------------------|--|
| Number of tanks:       | [_____].   |
| Minimum tank capacity: | [_____] litersgal.                                 |
| Sign reading:          | "DANGER - [HYDROCHLORIC][SULFURIC] ACID SOLUTION." |
| Mixer:                 | [Constant][Variable] speed [_____] rpm, maximum.   |
| Dissolving basket:     | [_____].   |
| Floating seal:         | [_____].   |
| Containment:           | Double wall and secondary containment.             |

#### 2.2.8.2 Adsorption Agent Tank

Provide [powdered activated carbon][\_\_\_\_\_] slurry resistant tank and comply with the following:

|                        |  |
|------------------------|--|
| Number of tanks:       | [_____].   |
| Minimum tank capacity: | [_____] litersgal.                               |
| Sign reading:          | [_____]  |
| Mixer:                 | [Constant][Variable] speed [_____] rpm, maximum. |
| Dissolving basket:     | [_____].   |
| Floating seal:         | [_____].   |
| Containment:           | Double wall and secondary containment.           |

#### 2.2.8.3 Base Tank

Provide [sodium hydroxide (caustic soda)][\_\_\_\_\_] solution resistant tank and comply with the following:



|                        |   |
|------------------------|---|
| Number of tanks:       | [____].   |
| Minimum tank capacity: | [____] litersgal.                               |
| Sign reading:          | "DANGER - ALKALI (SODIUM HYDROXIDE) SOLUTION."  |
| Mixer:                 | [Constant][Variable] speed [____] rpm, maximum. |
| Dissolving basket:     | [____].   |
| Floating seal:         | [____].   |
| Containment:           | Double wall and secondary containment.          |

#### 2.2.8.4 Biocide Tank

Provide [copper sulfate][Tolcide(R)][Glutaraldehyde][\_\_\_\_] solution resistant tank and comply with the following:

|                        |   |
|------------------------|---|
| Number of tanks:       | [____].   |
| Minimum tank capacity: | [____] litersgal.                               |
| Sign to read:          | [____].   |
| Mixer:                 | [Constant][Variable] speed [____] rpm, maximum. |
| Dissolving basket:     | [____].   |
| Floating seal:         | [____].   |
| Containment:           | Double wall and secondary containment.          |

#### 2.2.8.5 Coagulant Aid Tank

\*\*\*\*\*  
**NOTE: Polyelectrolytes degrade with storage.**  
 \*\*\*\*\*

Provide [polyelectrolyte][\_\_\_\_] solution resistant tank and comply with the following:

|                        |  |
|------------------------|--|
| Number of tanks:       | [____].  |
| Minimum tank capacity: | [____] litersgal.  |
| Sign reading:          | "CAUTION - [POLYELECTROLYTE SOLUTION - SLIP HAZARD] [____]." |
| Mixer:                 | [Constant][Variable] speed [____] rpm, maximum.              |
| Dissolving basket:     | [____].  |

|                |  |
|----------------|--|
| Floating seal: | [____].                                |
| Containment:   | Double wall and secondary containment. |

#### 2.2.8.6 Disinfecting Agent Tank

Provide [ammonium sulfate][hypochlorite] solution resistant tank and comply with the following:

|                        |   |
|------------------------|---|
| Number of tanks:       | [____].   |
| Minimum tank capacity: | [____] litersgal.                               |
| Sign reading:          | [____].   |
| Mixer:                 | [Constant][Variable] speed [____] rpm, maximum. |
| Dissolving basket:     | [____].   |
| Floating seal:         | [____].   |
| Containment:           | Double wall and secondary containment.          |

#### 2.2.8.7 Miscellaneous Tanks

Provide [poly(diallyldimethylammonium chloride)][calcium chloride][sodium aluminate][sodium metabisulfite (sodium pyrosulfite)][sodium chlorite] [sodium silicate][monosodium phosphate][disodium phosphate] solution resistant tanks and comply with the following:

|                        |   |
|------------------------|---|
| Number of tanks:       | [____].   |
| Minimum tank capacity: | [____] litersgal.                               |
| Sign reading:          | [____].   |
| Mixer:                 | [Constant][Variable] speed [____] rpm, maximum. |
| Dissolving basket:     | [____].   |
| Floating seal:         | [____].   |
| Containment:           | Double wall and secondary containment.          |

#### 2.2.8.8 Oxidant Tank

Provide [hydrogen peroxide][potassium permanganate] solution resistant tank and comply with the following:

|                  |         |
|------------------|---------|
| Number of tanks: | [____]. |
|------------------|---------|

|                        |  |
|------------------------|--|
| Minimum tank capacity: | [_____] litersgal.                               |
| Sign reading:          | ["DANGER - STRONG OXIDIZER"] [_____] .           |
| Mixer:                 | [Constant][Variable] speed [_____] rpm, maximum. |
| Dissolving basket:     | [_____] .  |
| Floating seal:         | [_____] .  |
| Containment:           | Double wall and secondary containment.           |

#### 2.2.8.9 Precipitant Tank

Provide [\_\_\_\_\_] solution resistant tank and comply with the following:

|                        |  |
|------------------------|--|
| Number of tanks:       | [_____] .  |
| Minimum tank capacity: | [_____] litersgal.                               |
| Sign reading:          | [_____] .  |
| Mixer:                 | [Constant][Variable] speed [_____] rpm, maximum. |
| Dissolving basket:     | [_____] .  |
| Floating seal:         | [_____] .  |
| Containment:           | Double wall and secondary containment.           |

#### 2.2.8.10 Primary Coagulant Tank

Provide [aluminum sulfate][ferric chloride][ferric sulfate][ferrous sulfate] solution resistant tank and comply with the following:

|                        |  |
|------------------------|--|
| Number of tanks:       | [_____] .  |
| Minimum tank capacity: | [_____] litersgal.                               |
| Sign reading:          | [_____] .  |
| Mixer:                 | [Constant][Variable] speed [_____] rpm, maximum. |
| Dissolving basket:     | [_____] .  |
| Floating seal:         | [_____] .  |
| Containment:           | Double wall and secondary containment.           |

#### 2.2.8.11 Prophylaxis Tank

Provide [hydrofluosilicic acid][sodium fluoride][sodium silicofluoride] solution resistant tank and comply with the following:

|                        |   |
|------------------------|---|
| Number of tanks:       | [____].   |
| Minimum tank capacity: | [____] litersgal.                               |
| Sign reading:          | [____].   |
| Mixer:                 | [Constant][Variable] speed [____] rpm, maximum. |
| Dissolving basket:     | [____].   |
| Floating seal:         | [____].   |
| Containment:           | Double wall and secondary containment.          |

#### 2.2.8.12 Sequestrant Tank

\*\*\*\*\*  
**NOTE: Polyelectrolytes degrade with storage.**  
 \*\*\*\*\*

Provide [sodium polyphosphate, glassy (sodium hexametaphosphate)][sodium tripolyphosphate] solution resistant tank and comply with the following:

|                        |  |
|------------------------|--|
| Number of tanks:       | [____].  |
| Minimum tank capacity: | [____] litersgal.  |
| Sign reading:          | "CAUTION - [SODIUM HEXAMETAPHOSPHATE] [SODIUM TRIPOLYPHOSPHATE] SOLUTION - SLIP HAZARD." |
| Mixer:                 | [Constant][Variable] speed [____] rpm, maximum.  |
| Dissolving basket:     | [____].  |
| Floating seal:         | [____].  |
| Containment:           | Double wall and secondary containment.   |

#### 2.2.9 Pressure Gauges

Provide diaphragm type gauges with Bourdon tube and diaphragm compartments filled completely with oil, and made of materials suitable for the application. Install diaphragm seals at each gauge connection to isolate gauges from corrosion, sludge or other hazards of the process fluid. Provide seal material that is compatible with the oil in the gauge and the process fluid.

#### 2.2.10 Injectors

Introduce injectors for chemical solution into the pipeline mains by means of a [hard rubber] [or] [plastic] injection nozzle, or by means of a suitable diffuser tube inserted through a corporation cock. Construct the device for introducing the solution into a pressure main in such a way that accidental breakage of discharge hose or tubing does not cause water to escape from the pipeline, and allows disassembling of the unit without

leakage.

## 2.2.11 Piping

### 2.2.11.1 Backflow Preventor

Provide backflow prevention devices or air gaps on tank fill lines in accordance with NAPHCC NSPC.

### 2.2.11.2 Chemical Solution Piping

\*\*\*\*\*  
**NOTE: Select materials in accordance with EM  
1110-1-4008 Liquid Process Piping.**  
\*\*\*\*\*

Incorporate provisions to allow solution piping to be conveniently and safely bled of trapped air and minimize infiltration of air bubbles. Provide chemical solution piping in accordance with Section 40 05 13 PIPELINES, LIQUID PROCESS PIPING.

#### 2.2.11.2.1 Smaller than 40 mm1-1/2 inch Diameter

Chemical solution piping smaller than 40 mm1-1/2 inch diameter must be [PVC pipe conforming to ASTM D1785 or CPVC pipe conforming to ASTM F441/F441M ][[\_\_\_\_\_] tubing][ or ][rubber hose]. Provide plastic fittings for plastic pipe with [flanged][ or ][threaded] joints. Make joints for rubber hose using a clamp-type mechanical coupling.

#### 2.2.11.2.2 Piping 40 mm1-1/2 inch Diameter or Greater

Chemical solution piping of 40 mm1-1/2 inch diameter or larger must be [rubber-lined] [or] [plastic-lined] steel pipe. Steel pipe must have [threads] [or] [flanges integral with the pipe] [or] [forged-steel flanges screwed to the pipe barrel].

### 2.2.11.3 Pipe Lining

Linings for steel pipe smaller than 150 mm6 inches must be not less than 4.8 mm3/16 inch thick. Provide continuous linings free of holidays.

### 2.2.11.4 Pipe Fittings

For steel pipe provide [flanged conforming to ASME B16.1 or ASME B16.5][ or ][forged-steel threaded conforming to ASME B16.11] pipe fittings.

### 2.2.11.5 Plumbing

Provide water piping, drain, waste and vent piping in accordance with Section 22 00 00 PLUMBING, GENERAL PURPOSE.

## 2.2.12 Electrical Work

\*\*\*\*\*  
**NOTE: Coordinate hazard areas with Section 26 20 00  
INTERIOR DISTRIBUTION SYSTEM and the drawings.**  
\*\*\*\*\*

Provide electric motor-driven equipment complete with motor, motor starter,

and controls. Provide electrical equipment and wiring in accordance with Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM. Implement hazard classifications in accordance with NFPA 70.

#### 2.2.12.1 Motor Starters

Provide motor starters complete with thermal overload protection and other appurtenances necessary for the motor control specified.

#### 2.2.12.2 Control and Protective Devices

Provide manual or automatic control and protective or signal devices required for the operation and any control wiring required for controls and devices. Provide motor controls conforming to NEMA ICS 1 or NEMA ICS 2. Prewire equipment to the maximum practicable extent. Control cabinets must conform to the requirements of UL 50, NEMA 250, [Type 4,][Type 7,][ or ][Type 12].

#### 2.2.13 Equipment Appurtenances

Provide galvanized steel, cadmium plated or Type 316 stainless steel bolts, nuts, anchors, washers and all other types of supports necessary for the installation of the equipment.

#### 2.2.14 Factory Painting

Factory painting must conform to manufacturer's standard factory finish, provided it does not discolor in the presence of hydrogen sulfide fumes, high water vapor atmosphere, alkaline water vapor, and concentrated chlorine (oxidizing) conditions. Coating must be at least 0.05 mm1.75 mils thick.

#### 2.2.15 Factory Test Report

Factory examine fiberglass tanks in accordance with ASTM E1067/E1067M prior to shipping. Furnish a copy of the corresponding test report with each tank.

### 2.3 MATERIALS

Submit Safety Data Sheets in conformance with ANSI Z400.1/Z129.1 for each chemical. Provide a [30][90][\_\_\_\_\_] day supply at the maximum pumping rate for each feeder or pair of duplexed feeders. Submit [two][\_\_\_\_\_] copies of certification stating that each supplied chemical meets the following requirements.

#### 2.3.1 Acids

AWWA B300 Hydrochloric (muratic acid), AWWA B703 sulphuric (sulfuric acid).

#### 2.3.2 Adsorption Agents

AWWA B600 powdered activated carbon.

#### 2.3.3 Bases

AWWA B501 caustic soda, AWWA B511 potassium hydroxide, AWWA B201 soda ash (sodium carbonate).

#### 2.3.4 Biocides

Glutaraldehyde (10 to 50 percent solution); Tolcide(R) (50 percent solution); AWWA B602 copper sulfate.

#### 2.3.5 Coagulant Aids

NSF/ANSI 60 Anionic polyelectrolytes, NSF/ANSI 60 cationic polyelectrolytes.

#### 2.3.6 Disinfecting Agents

AWWA B302 ammonium sulfate, AWWA B300 hypochlorites.

#### 2.3.7 Miscellaneous

AWWA B451 poly(diallyldimethylammonium chloride), AWWA B452 EPI-DMA polyamines, AWWA B453 polyacrylamide, AWWA B550 calcium chloride, AWWA B405 sodium aluminate, AWWA B601 sodium metabisulfite (Sodium Pyrosulfite), AWWA B303 sodium chlorite, AWWA B404 liquid sodium silicate, AWWA B504 monosodium phosphate, anhydrous, AWWA B408 polyaluminum chloride, AWWA B505 disodium phosphate, anhydrous.

#### 2.3.8 Oxidants

[50][35][\_\_\_\_\_] percent NSF/ANSI 60 hydrogen peroxide solution, AWWA B603 potassium permanganate [potassium permanganate may be supplied in powder form for onsite preparation] at the discretion of the Contracting Officer.

#### 2.3.9 Precipitants

AWWA B501.

#### 2.3.10 Primary Coagulants

AWWA B403 aluminum sulfate, AWWA B407 liquid ferric chloride, AWWA B406 ferric sulfate, AWWA B402 ferrous sulfate.

#### 2.3.11 Prophylaxis

AWWA B703 hydrofluosilicic acid, AWWA B701 sodium fluoride, AWWA B702 sodium silicofluoride.

#### 2.3.12 Sequestrants

AWWA B502 sodium polyphosphate, glassy (sodium hexametaphosphate), AWWA B503 sodium tripolyphosphate.

### PART 3 EXECUTION

#### 3.1 EXAMINATION

After becoming familiar with details of the work, verify all dimensions in the field, and advise the Contracting Officer of any discrepancy before performing the work.

#### 3.2 INSTALLATION

Submit detail drawings containing complete piping, wiring, schematic, flow diagrams, and any other details required to demonstrate that the system has

been coordinated and properly functions as a unit. On the drawings show proposed layout and anchorage of equipment and appurtenances, and equipment relationship to other parts of the work including clearances for installation, maintenance and operation.

#### 3.2.1 Chemical Feeding Equipment

Install controlled volume pumps, equipment, and appurtenances to provide a complete and integrated system in accordance with the instruction of the manufacturer and under the direct supervision of the manufacturer's representative.

#### 3.2.2 Gasoline Engines

Install gasoline engines in accordance with NFPA 37.

#### 3.2.3 Pipe, Tubing, Hangers and Supports

Install pipes and tubes in accordance with Section 22 00 00 PLUMBING, GENERAL PURPOSE.

#### 3.2.4 Field Painting

Thoroughly clean, prime and top-coat factory painted items requiring touching up in the field with the manufacturer's standard factory finish provided it does not discolor in the presence of hydrogen sulfide fumes, high water vapor atmosphere, alkaline water vapor, and concentrated chlorine (oxidizing) conditions. Paint the equipment which did not receive a factory finish as specified in Section 09 90 00 PAINTS AND COATINGS. Coating must be at least 0.05 mm1.75 mils thick. Provide piping identification as specified in [ASME A13.1][Section 09 90 00 PAINTS AND COATINGS. Mark pipe carrying materials not listed in Section 09 90 00 PAINTS AND COATINGS in accordance with ASME A13.1.]

#### 3.2.5 Framed Instructions

Submit framed instructions for approval prior to postings. Final size must be easy to read by operators 5 feet from instructions. Limit frame size to 11" x 17" size provide multiple frames if needed. Post framed instructions, containing wiring and control diagrams, where directed. Post condensed operating instructions as outlined in paragraph 3.4.2 Operating Instructions. Post the framed instructions before acceptance testing of the systems.

### 3.3 FIELD QUALITY CONTROL

#### 3.3.1 Testing

After installation of each controlled volume pump, carry out operating tests as specified below to assure that the chemical metering installation operates properly. If any deficiencies are revealed during any tests, correct such deficiencies and reconduct the tests. Submit reports of all tests in booklet form prior to final acceptance of the installation. Show all field tests performed to adjust each component and all field tests performed to prove compliance with the specified performance criteria, upon completion and testing of the installed system. Indicate in each test report the final position of controls.



#### 3.3.1.1 Tank Testing

Clean tanks of loose debris and dry prior to testing. Field test tanks for leaks or damage in shipment. Hydrostatically test tanks to [\_\_\_\_\_] kPapsig or 1.5 times the system operating pressure, whichever is greater, to detect large leaks and then with the specified chemical to detect small leaks. Test each tank with its solution for a period of 24 hours at which time no visible leakage is evident. Supply all pipes, hoses, pumps, water, power and other equipment required to convey the test liquids and to carry out the tests. Repair damage or leaks in tanks or replace tanks. Replace damaged ceramic tanks.

#### 3.3.1.2 Controlled Volume Pumps - Operational Tests

Test pumps to demonstrate that the pumps are capable of operating without vibration or leakage. Perform testing at the pump's maximum flow rate and at half the flow rate. Demonstrate testing while controlled and operated in all feasible modes with the pumps operated singly and in unison. Plot the response of each pump on curves for the various operating pressures encountered and the results compare to the curves shown on the manufacturer's published pump data. If control characteristic curves are not available at the time of testing, the pump manufacturer's service engineer must generate such curves for each pump; graphically depicting the pump displacement at 25, 50, 75, and 100 percent of motor speed for SCR equipped pumps, and at 25, 50, 75, and 100 percent of maximum stroke position for all pumps. Generate curves only for the specified back pressure.

#### 3.3.1.3 Controlled Volume Pumps - Time, Volume and Pumping Pressure Tests

Test pumps by filling [the standpipe][a portable calibrated standpipe furnished by the Contractor] with chemical and measuring the outage, with all other equipment valved off. Record the time, volume and pumping pressures.

#### 3.3.1.4 System Pressure Tests

\*\*\*\*\*  
**NOTE: To establish that full service can be provided, fill in the blank with the numerical value of the pressures that can be expected during normal operation of the system.**  
\*\*\*\*\*

Carry out tests at [\_\_\_\_\_] and [\_\_\_\_\_] kPapsig. Manually control back pressure valves for this testing, and reset as necessary after testing. The time to deliver a given quantity of chemical at a given stroke and speed setting must be the same at all pressures.

#### 3.3.1.5 Flow Tests

Test pumps to demonstrate zero L/secondgpm flow at a zero stroke or speed setting. Failure to meet this test is cause for rejection. Test pumps through full range of performance: min. flow [\_\_\_\_\_]. Submit test results to prove pump functions within specified system parameters.

#### 3.3.1.6 Synchronization Tests

Operate the pumps for a period of 4 hours to demonstrate that the double

diaphragm systems do not lose their synchronization. Loss of synchronization is also cause for rejection; repair or replace the pump as necessary to achieve synchronization. Fully retest repaired or replaced equipment.

### 3.3.2 Chemical Waste

\*\*\*\*\*  
**NOTE: In selection of chemicals, consider the environmental consequences, including disposal of precipitated solids and other wastes. Select the most appropriate options and edit to fit the situation for drinking water or waste water treatment systems.**  
\*\*\*\*\*

Neutralize chemicals wasted during testing procedures to achieve a pH value between 6.5 and 9.5 and a chlorine concentration of not more than 1 percent (10,000 mg/L). Route all chemicals wasted during testing procedures [as directed by the Contracting Officer][to the sanitary sewer] [through the treatment process] at a rate that the process can assimilate without upset.

### 3.3.3 Manufacturer Field Service

Provide the services of a manufacturer's representative who is certified by manufacturer in the installation, adjustment, and operation of the equipment specified. The representative must supervise the installation, adjustment, and testing of the equipment. Submit certificates to Contracting Officer for approval.

## 3.4 CLOSEOUT ACTIVITIES

### 3.4.1 FIELD TRAINING

Conduct a field training course for designated operating, maintenance and supervisory staff members. Provide training for a total period of [\_\_\_\_\_] hours of normal working time and start after the system is functionally complete but prior to final acceptance tests. Cover all of the items contained in the Operating and Maintenance Instructions during field training.

### 3.4.2 Operating Instructions

Submit complete copies of operating instructions outlining the step-by-step procedures required for system startup, operation and shutdown. Include in the instructions the manufacturer's name, model number, service manual, parts list, and brief description of all equipment and their basic operating features. Also include in the instructions as-built drawings of the piping layout, equipment layout, simplified wiring and control diagrams of the system as installed, and flow diagrams.

### 3.4.3 Maintenance Instructions

Submit complete copies of maintenance instructions listing routine maintenance procedures, possible breakdowns and repairs, and trouble-shooting guides.

-- End of Section --