
USACE / NAVFAC / AFCEC / NASA UFGS-32 31 13.53 (February 2020)

Preparing Activity: USACE Superseding
UFGS-32 31 13.53 (April 2008)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2020

SECTION TABLE OF CONTENTS

DIVISION 32 - EXTERIOR IMPROVEMENTS

SECTION 32 31 13.53

HIGH-SECURITY FENCES (CHAIN LINK AND ORNAMENTAL) AND GATES

02/20

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 DELIVERY, STORAGE, AND HANDLING

PART 2 PRODUCTS

- 2.1 COMPONENTS
 - 2.1.1 Chain Link Fence Fabric
 - 2.1.1.1 General
 - 2.1.1.2 Approval Of Polyvinyl Chloride-Coated Fence Materials
 - 2.1.2 Ornamental Fence Systems
 - 2.1.3 Posts
 - 2.1.3.1 Metal Posts for Chain Link Fence
 - 2.1.3.2 Accessories
 - 2.1.4 Chain Link Braces and Rails
 - 2.1.5 Chain Link Gates
 - 2.1.5.1 Gate Assembly
 - 2.1.5.2 Gate Leaves
 - 2.1.5.3 Gate Hardware and Accessories
 - 2.1.6 Ornamental Fence Gates
 - 2.1.6.1 Swing Gates
 - 2.1.6.2 Slide Gates
 - 2.1.7 Turnstiles
 - 2.1.8 Padlocks
 - 2.1.9 Gate Operator
 - 2.1.10 Electro-Mechanical Locks
- 2.2 MATERIALS
 - 2.2.1 Wire
 - 2.2.1.1 Wire Ties
 - 2.2.1.2 Barbed Wire
 - 2.2.1.3 Tension Wire
 - 2.2.2 Barbed Tape
 - 2.2.3 Concrete
- 2.3 FENCE FABRIC REINFORCEMENT

- 2.3.1 Wire Rope Accessories
- 2.3.2 Turnbuckles
- 2.3.3 Rope Clamps
- 2.3.4 Threaded Rods, U-Bolts, and Bolts

PART 3 EXECUTION

- 3.1 PREPARATION
 - 3.1.1 Line and Grade
 - 3.1.2 Excavation
- 3.2 INSTALLATION
 - 3.2.1 Installation Drawings
 - 3.2.2 Security Fencing
 - 3.2.3 Posts
 - 3.2.3.1 Earth and Bedrock
 - 3.2.3.2 Concrete Slabs and Walls
 - 3.2.4 Rails
 - 3.2.5 Fabric
 - 3.2.6 Supporting Arms
 - 3.2.7 Barbed Tape Installation
 - 3.2.8 Gate Installation
 - 3.2.9 Grounding
 - 3.2.10 Cable Reinforcement Installation
- 3.3 CLOSEOUT ACTIVITIES
 - 3.3.1 Cleanup

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC / NASA UFGS-32 31 13.53 (February 2020)

Preparing Activity: USACE Superseding
 UFGS-32 31 13.53 (April 2008)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2020

SECTION 32 31 13.53

HIGH-SECURITY FENCES (CHAIN LINK AND ORNAMENTAL) AND GATES 02/20

NOTE: This guide specification covers the requirements for chain link and ornamental fencing for high security applications.. Please review the UFC 4-022-03 "New Document Summary Sheet" that discusses Purpose, Application and Use, and Need. Document provides guidance and in some cases minimum requirements with the appropriate references.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#)

PART 1 GENERAL

NOTE: Where special fencing requirements exist, such as wolf-proofing, antiburrowing provisions, crossing drainage ditches, provisions for electrical installations, or special security installations, modify specifications and appropriate details included on the drawings. Modifications and details must afford security equal to that of the fence.

Where special entrance security requirements exist such as electronic locks, motor operated gates, closed circuit video; add details and modify the

specification accordingly.

NOTE: Certain types of security fence must meet the requirements of an applicable OPNAVINST. Edit this specification as needed for the type of fencing required.

Standard drawings are incorporated into UFC 4-022-03 Security Fences and Gates, Appendix C Fence and Gate Design Details. The details in this appendix illustrate general layouts for each type of fence or gate. These illustrations are not intended to depict the importance or size of each element. Provide details and drawings meeting the minimum mandatory requirements and modify for the specific application, environmental conditions, and local/project constraints. See paragraph titled "Integration With Other Requirements" for additional directional direction. Sizes and dimensions indicated are the minimum requirement that must be modified perservice policy and for the specific application, environmental conditions, and local constraints.

Show layout of fence including types and locations of gates, and gate sizes. Indicate on drawings the extent of clearing required.

Require test reports where closer product control is essential or where difficulty might be encountered determining quality of supplied materials.

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM A116	(2011) Standard Specification for Metallic-Coated, Steel Woven Wire Fence Fabric
ASTM A121	(2013) Standard Specification for Metallic-Coated Carbon Steel Barbed Wire
ASTM A153/A153M	(2016a) Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware
ASTM A240/A240M	(2019) Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications
ASTM A307	(2014; E 2017) Standard Specification for Carbon Steel Bolts, Studs, and Threaded Rod 60 000 PSI Tensile Strength
ASTM A392	(2011a; R 2017) Standard Specification for Zinc-Coated Steel Chain-Link Fence Fabric
ASTM A478	(1997; R 2019) Standard Specification for Chromium-Nickel Stainless Steel Weaving and Knitting Wire
ASTM A491	(2011; R 2017) Standard Specification for Aluminum-Coated Steel Chain-Link Fence Fabric
ASTM A563	(2015) Standard Specification for Carbon and Alloy Steel Nuts
ASTM A666	(2015) Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate and Flat Bar
ASTM A702	(2013) Standard Specification for Steel Fence Posts and Assemblies, Hot Wrought
ASTM A780/A780M	(2009; R 2015) Standard Practice for Repair of Damaged and Uncoated Areas of Hot-Dip Galvanized Coatings
ASTM A824	(2011; R 2017) Standard Specification for Metallic-Coated Steel Marcellled Tension Wire for Use With Chain Link Fence
ASTM A1023/A1023M	(2019) Standard Specification for Stranded Carbon Steel Wire Ropes for General Purposes
ASTM B117	(2019) Standard Practice for Operating Salt Spray (Fog) Apparatus

ASTM C94/C94M	(2020) Standard Specification for Ready-Mixed Concrete
ASTM F567	(2014a) Standard Practice for Installation of Chain Link Fence
ASTM F626	(2014) Standard Specification for Fence Fittings
ASTM F668	(2017) Standard Specification for Poly(Vinyl Chloride) (PVC) and other Organic Polymer-Coated Steel Chain-Link Fence Fabric
ASTM F844	(2007a; R 2013) Washers, Steel, Plain (Flat), Unhardened for General Use
ASTM F883	(2013) Padlocks
ASTM F900	(2011; R 2017) Standard Specification for Industrial and Commercial Swing Gates
ASTM F1043	(2018) Standard Specification for Strength and Protective Coatings on Steel Industrial Fence Framework
ASTM F1083	(2018) Standard Specification for Pipe, Steel, Hot-Dipped Zinc Coated (Galvanized) Welded, for Fence Structures
ASTM F1145	(2017) Standard Specifications for Turnbuckles, Swaged, Welded, Forged
ASTM F1184	(2016) Industrial and Commercial Horizontal Slide Gates
ASTM F1910	(1998; R 2018) Standard Specification for Long Barbed Tape Obstacles
ASTM F1911	(2005; R 2019) Standard Practice for Installation of Barbed Tape
ASTM F2408	(2016) Standard Specification for Ornamental Fences Employing Galvanized Steel Tubular Pickets
ASTM F2589	(2016) Standard Specification for Ornamental Fences Employing Steel Tubular Pickets
ASTM F2814	(2009; R 2015) Standard Guide for Design and Construction of Ornamental Steel Picket Fence Systems for Security Purposes

1.2 SUBMITTALS

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit

the following list to reflect only the submittals required for the project.

The Guide Specification technical editors have designated those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

The "S" following a submittal item indicates that the submittal is required for the Sustainability eNotebook to fulfill federally mandated sustainable requirements in accordance with Section 01 33 29 SUSTAINABILITY REPORTING. Locate the "S" submittal under the SD number that best describes the submittal item.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.][information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submittals with an "S" are for inclusion in the Sustainability eNotebook, in conformance to Section 01 33 29 SUSTAINABILITY REPORTING. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Fence Installation Drawings; G[, [_____]]

SD-03 Product Data

Fabric

Posts

Post Caps

Chain Link Braces

Line Posts

Sleeves

Top Rail

Bottom Rail

Tension Wire

Barbed Wire

Barbed Wire Supporting Arms

Barbed Tape

Latches

Hinges

Stops

Keepers

Rollers

Turnstiles

Padlocks

Wire Ties

Ornamental Fence Systems

Swing Gates

Slide Gates

Fence Fabric Reinforcement

SD-07 Certificates

Chain Link Fence

Fabric

Barbed Wire

Gate Hardware and Accessories

Concrete

Gate Operator

SD-10 Operation and Maintenance Data

Electro-Mechanical Locks

Gate Operator

Operating and maintenance instructions

1.3 DELIVERY, STORAGE, AND HANDLING

Deliver materials to site in an undamaged condition. Store materials elevated off of the ground to protect against oxidation caused by ground contact.

PART 2 PRODUCTS

2.1 COMPONENTS

2.1.1 Chain Link Fence Fabric

NOTE: In salt-laden or corrosive industrial atmosphere, either Class 2 fabric with 610 grams 2.0 ounces of zinc coating per square meter foot or Type I, aluminum-coated fabric, will be specified. In other areas, Class 1 with 370 grams 1.2 ounces of zinc coating per square meter foot or Type I will be specified. Class 2b polyvinyl chloride-coated steel fabric may be specified for other than security purposes when esthetics is of prime importance and the additional cost is justified. Fabric height must be as shown on the contract drawings. Minimum fabric height must be 1.9 m 6 feet for controlled areas and 2.13 m 7 feet for restricted areas. Minimum fabric height requirement for security fences and gates is 2.13 m 7 feet per UFC 4-022-03, Paragraph 2-8 Fence Fabric Height - Unless otherwise directed all security and perimeter fencing must have a minimum fence fabric height of 2.13 m 7 feet, excluding the top guard. Fence height including outriggers must be a minimum of 2.44 m 8 feet. Modifications to existing fences are not required to meet this new UFC. Consult with current Service policies on specific requirements regarding fence height and assets that may require a higher level of protection. Certain security applications require fabric to be embedded into the ground or into a concrete curb.

2.1.1.1 General

Provide [ASTM A392, [Class 1] [Class 2], zinc-coated steel wire with minimum coating weight of [370][610] grams [1.2][2.0] ounces of zinc per square meter foot of coated surface.] [ASTM A491, Type I, aluminum-coated steel wire.] [Class 2b polyvinyl chloride-coated steel fabric with 92 grams 0.3 ounces of zinc coating per square meter foot in accordance with ASTM F668.] Fabricate fence fabric of 9 gauge wire woven in 50 mm 2 inch mesh conforming to ASTM A116. [Provide manufacturer's standard [_____] in color for polyvinyl chloride coating for fabric and all other fence components.] [Provide twisted and barbed fabric on the top selvage and knuckled on the bottom selvage.]

[2.1.1.2 Approval Of Polyvinyl Chloride-Coated Fence Materials

**NOTE: Delete this paragraph if PVC Coated fencing
is not within the project scope.**

Inspect polyvinyl chloride-coated fence materials for cracking, peeling, and conformance with the specifications prior to installation. Replace any fence materials rejected by the Contracting Officer with approved materials at no additional cost to the Government.

]2.1.2 Ornamental Fence Systems

Submit manufacturer's catalog data. Provide [ASTM F2814](#) structural components consisting of tubular steel ornamental pickets and rails.

Provide [[ASTM F2408](#)] [[ASTM F2589](#)] industrial class pickets with a minimum cross-sectional area of [2.5 sq cm 1 sq in](#) and a minimum wall thickness of [6 mm 14 gal](#). Provide pickets with spear-pointed tips extending a minimum of [15 cm 6 in](#) above the top rail of the fence. Mount pickets to a top and bottom rail spaced a maximum of [2 m 80 in](#) apart. Space pickets along rails with a maximum gap not to exceed [5.5 cm 2.25 in](#). Secure pickets to rails by [welding] [inaccessible, tamper-proof fasteners]. Provide all items and accessories finished by [painting] [powder-coating] [_____] in [black][dark bronze][white][_____].

[Add the following accessories to further harden the Ornamental Fence System: [barbed wire on top of fence] [barbed wire along bottom of fence] [barbed wire along side of fence] [spiked railing along the top rail] [chain-link security mesh welded to the pickets and rails]. Accessories are specified separately in this section.

]2.1.3 Posts

2.1.3.1 Metal Posts for Chain Link Fence

**NOTE: For high security fences that are to be
sensored, posts will be limited to Group IA or Group
IC steel pipe only. Certain security applications
using intrusion detection sensors, must use steel
pipe framework only.**

Provide posts conforming to [ASTM F1083](#), zinc-coated. Group IA, with external coating Type A steel pipe. Group IC steel pipe, zinc-coated with external coating Type A or Type B and Group II, roll-formed steel sections, meeting the strength and coating requirements of [ASTM F1043](#) and [ASTM A702](#). Group III, [ASTM F1043](#) steel H-section may be used for line posts in lieu of line post shapes specified for the other classes. [Provide either Group IA steel pipe posts, Group IC, Group II, roll-formed steel sections, or Group III steel H-sections and be zinc coated (Type A) and polyvinyl chloride coated conforming to the requirements of [ASTM F1043](#).] Provide sizes as shown on the drawings. Use line posts and terminal (corner, gate, and pull) posts of the same designation throughout the fence. Provide gate post for the gate type specified subject to the limitation specified in [ASTM F900](#) and/or [ASTM F1184](#).

2.1.1.3.2 Accessories

- a. Provide accessories conforming to **ASTM F626**. Coat ferrous accessories with [zinc or aluminum coating.] [polyvinyl chloride-coated, minimum thickness of **0.152 mm 0.006 inch**, maximum thickness of **0.381 mm 0.015 inch**. Match color coating of fittings to color coating of the fabric.]
- b. Provide truss rods (with turnbuckles or other means of adjustment)for each terminal post.
- c. Provide **barbed wire supporting arms** of the [single][45 degree outward angle 3-strand] [V 6 strand] arm type and of the design required for the post furnished. Secure arms by [top tension wire][top rail][bolting][riveting].
- d. Furnish **post caps** in accordance with manufacturer's standard accessories.
- e. Provide 9 gauge steel tie wire for attaching fabric to rails, braces, and posts and match the coating of the fence fabric. [Use tie wires for attaching fabric to **tension wire** on high security fences made from **1.6 mm 16 gage** stainless steel. Provide double loop tie wires **165 mm 6.5 inches** in length.] Provide miscellaneous hardware coatings which conform to **ASTM A153/A153M** unless modified.

2.1.1.4 Chain Link Braces and Rails

NOTE: Normally rails will not be specified except where appearance is important and the added cost is justified. When top rails are not specified, top tension wire will be used. Bottom tension wire will be specified unless a bottom rail is required for high security fence.

NOTE: Use a single diagonal truss rod for fences less than **3.7 m 12 feet** high. Use two diagonal truss rods on fences **3.7 m 12 feet** and higher.

ASTM F1083, zinc-coated, Group IA, steel pipe, size NPS 1-1/4. Provide Group IC steel pipe, zinc-coated, that meets the strength and coating requirements of **ASTM F1043**. [Use braces and rails that are [Group IA] [Group IC], steel pipe, size NPS 1-1/4 or Group II, formed steel sections, size **42 mm 1-21/32 inch** and be zinc coated (Type A) and polyvinyl chloride-coated conforming to the requirements of **ASTM F1043**.] Group II, formed steel sections, size **42 mm 1-21/32 inch**, conforming to **ASTM F1043**, may be used as braces and rails if Group II **line posts** are furnished.

Braces [, **top rail**][and **bottom rail**]; Class [1, steel pipe, Grade [A] [or] [B]] [2, aluminum pipe] or [3, formed steel sections], in [size [____]]. [Provide PVC color coating, minimum thickness, **2.5 mm 0.10 inch**.] [Provide steel pipe, Class 1, Grade B conforming to the following performance criteria when subjected to salt spray testing in accordance with **ASTM B117**: Exterior [____] 1,000 hours with maximum 5 percent red rust; Interior [____] 650 hours with maximum 5 percent red rust.]

2.1.5 Chain Link Gates

NOTE: Show type of gates on the drawings, including degree of swing required. In heavy use conditions overhead slide gates should be considered if clearances permit, because these gates require less maintenance and repair than cantilever gates. Ground level track and roller systems should be avoided in climates where snow and ice may accumulate. Recessed tracks should never be used in climates where the recess may fill with ice and snow. Where gates are to receive electric locks, the gate post foundations should be lowered to frost depth to help prevent misalignment of the lock components.

2.1.5.1 Gate Assembly

Provide gate assembly conforming to [ASTM F900](#) and/or [ASTM F1184](#) of the type and swing shown. Provide gate frames conforming to strength and coating requirements of [ASTM F1083](#) for Group IA, steel pipe, with external coating Type A, nominal pipe size (NPS) 1-1/2. Provide gate frames conforming to strength and coating requirements of [ASTM F1043](#), for Group IC, steel pipe with external coating Type A or Type B, nominal pipe size (NPS) 1-1/2. [Provide gate frames made of polyvinyl chloride-coated steel pipe (Group IA)(Group IC) with external coating Type A, a nominal pipe size (NPS) 1-1/2, conforming to [ASTM F1043](#).] Use gate fabric that matches the specified chain link fabric.

2.1.5.2 Gate Leaves

For gate leaves, more than [2.44 m 8 feet](#) wide, provide either intermediate members and diagonal truss rods or tubular members as necessary to provide rigid construction, free from sag or twist. For gate leaves less than [2.44 m 8 feet](#) wide, provide truss rods or intermediate braces. Provide intermediate braces on all gate frames with an electro-mechanical lock. Attach fabric to the gate frame by method standard with the manufacturer. Welding is not an acceptable method for attaching fabric to gate frames.

2.1.5.3 Gate Hardware and Accessories

Submit manufacturer's catalog data. Furnish and install [latches](#), [hinges](#), [stops](#), [keepers](#), [rollers](#), and other hardware items as required for the operation of the gate. All items are required to match the material characteristics of the fence system being installed. Arrange latches for padlocking so that the padlock will be accessible from both sides of the gate. Provide stops for holding the gates in the open position. For high security applications, extend each end member of gate frames sufficiently above the top member to carry three strands of barbed wire in horizontal alignment with barbed wire strands on the fence.

2.1.6 Ornamental Fence Gates

2.1.6.1 Swing Gates

Submit manufacturer's catalog data. Fabricate swing gates by welding [5 sq cm 2 sq in](#) tubular steel ends and rails. Use pickets that match the

adjacent fence construction. Reinforce gates to ensure assembly sags no more than 1% of the gate leaf width or 5 cm 2 in, whichever is less. Size gate posts to accommodate the weight and width of each gate leaf. Mount gates to posts with weldable steel plates or blocks, pressed steel, or malleable iron hinges. Hot-dip galvanize all hinges with a minimum zinc weight of 66 g/sq m 1.20 oz/sq ft. Secure all tamper points by welding or peening the threads. Use swing gate latches and drop bar guides manufactured of pressed steel, hot-dipped galvanized with a minimum zinc weight of 366 g/sq m 1.20 oz/sq ft. Finish all gate hardware in the same color/coating as the fence system.

2.1.6.2 Slide Gates

Submit manufacturer's catalog data. Fabricate slide gates by welding 5 sq cm 2 sq in tubular steel ends and rails. Use pickets that match the adjacent fence construction. Select the type and class of slide gate to comply with ASTM F1184. Size gate posts to accommodate the weight and width of each gate leaf in accordance with ASTM F1184, or per manufacturer's recommendations. [Specify Type II, Class 2, interior roller design for cantilever slide gates.]

2.1.7 Turnstiles

Provide [galvanized steel] [metal], three wing turnstile consisting of a rotor, cage, ceiling plate, and bottom bearing plate. [Provide electronic opening and closing [by card key] [_____].] Provide [continuous turn] [one way continuous turn] [one-third turn and stop] motion.

2.1.8 Padlocks

NOTE: Type P01 is key operated. Grade 6 is the top grade commercial lock; in Option A the key is captive in cylinder when padlock is unlocked; in Option B the cylinder is removable; Option 6 is environmentally resistant. For combination locks or other options and grades see ASTM F883.

Provide padlocks conforming to ASTM F883, Type [P01] [_____], Option[s] [A, B, and G] [_____] [and] [_____], Grade [6][_____]. Size 44 mm 1-3/4 inch. [Key all padlocks alike]. [Key all padlocks into master key system as specified in Section 08 71 00 DOOR HARDWARE].

2.1.9 Gate Operator

Provide electric gate operators for sliding gates as follows: Provide electric gate operators with a right angle gearhead instantly reversing motor with magnetic drum-type brake, friction disc clutch, reversing starter with thermal overload protection, and a chain-driven geared rotary-type automatic limit switch. Use only hardened steel machine cut worm and mating bronze gears that operate in a bath of oil. Gate operators with V-belt pulleys are not allowed. Equip gate operators with an emergency release to allow the gate to be operated manually that is also capable of being locked in the engaged or disengaged position. Provide positive stops on the gate tracks as a backup to the limit switches.

2.1.10 Electro-Mechanical Locks

Provide electro-mechanical locking devices for sliding gates and personnel gates that are solenoid actuated such that the deadbolt retracts when the solenoid is energized and remains electrically retracted until the gate is closed. Provide continuous duty type solenoid, rated for 120V ac, 60Hz operation. Ensure the locking device is unlockable by key and keyed on both sides. Monitor status of the electro-mechanical lock by two limit switches (integral to the locking device) wired in series. Ensure one switch monitors the deadlock lever and the other monitors the locking tongue.

2.2 MATERIALS

2.2.1 Wire

2.2.1.1 Wire Ties

Submit samples as specified. Provide wire ties constructed of the same material as the fencing fabric. [Provide accessories with polyvinyl (PVC) coatings similar to that specified for chain-link fabric or framework.]

2.2.1.2 Barbed Wire

Provide barbed wire conforming to [ASTM A121](#) zinc-coated, Type Z, Class 3, or aluminum-coated, Type A, with 12.5 gauge wire with 14 gauge, round, 4-point barbs spaced no more than [125 mm 5 inches](#) apart.

2.2.1.3 Tension Wire

Provide Type I or Type II tension wire, Class 4 coating, in accordance with [ASTM A824](#). [Provide 7 gauge coil spring wire for top wire.]

2.2.2 Barbed Tape

Provide reinforced barbed tape, [double coil] [single coil], for fence toppings fabricated from 430 series stainless steel with a hardness range of Rockwell (30N) 37-45 conforming to the requirements of [ASTM A240/A240M](#). Provide stainless steel strip [0.6 mm thick by 25 mm 0.025 inch thick by 1 inch](#) wide before fabrication. Provide barbs that are a minimum of [30.5 mm 1.2 inch](#) in length, in groups of 4, spaced on [102 mm 4 inch](#) centers. Use stainless steel core wire with a [2.5 mm 0.098 inch](#) diameter and a minimum tensile strength of [9.68 MPa 140 psi](#) and conforming to [ASTM A478](#). [The above requirements also apply to reinforced barbed tape, single coil, for ground application.] [Fabricate non-reinforced barbed tape, single coil, for ground applications from 301 series stainless steel, with a hardness range of Rockwell (30N) 50-55, in accordance with [ASTM A666](#). Provide stainless steel strips [0.6 mm thick by 31 mm 0.025 inch thick by 1.21 inches](#) wide before fabrication. Use barbs with a minimum of [30.5 mm 1.2 inch](#) in length, in groups of 4, spaced on [102 mm 4 inch](#) centers.] Use [1.3 mm No. 16 AWG](#) stainless steel twistable wire ties for attaching the barbed tape to the barbed wire [and to the fence for ground application].

Ensure long barbed tape obstacles conform to [ASTM F1910](#).

2.2.3 Concrete

[ASTM C94/C94M](#), using [19 mm 3/4 inch](#) maximum size aggregate, and having minimum compressive strength of [21 MPa 3000 psi](#) at 28 days. Use grout

consisting of one part portland cement to three parts clean, well-graded sand and the minimum amount of water to produce a workable mix.

[2.3 FENCE FABRIC REINFORCEMENT

NOTE: Reinforcement for chain link and ornamental fencing is typically constructed with wire rope and concrete deadman anchor. Refer to UFC 4-022-02, Security Engineering: Design and Selection of Vehicle Barriers and UFC 4-022-03 Security Fences and Gates for guidance and details.

Provide galvanized structural wire rope as indicated and in accordance with **ASTM A1023/A1023M**, **20mm3/4 inch** nominal diameter of strand, 19 wire strand, regular lay, extra improved plow steel (EIPS), independent wire rope core (IWRC) and with a minimum breaking strength of **9,175 Newtons 40,800 pound-force**. Galvanize cable, Class A, in accordance with **ASTM A1023/A1023M**.

2.3.1 Wire Rope Accessories

All structural steel members used in cable anchoring system shall be hot-dipped galvanized. Clamps, U-bolts, and associated hardware shall be hot-dipped galvanized in accordance with **ASTM A153/A153M**.

2.3.2 Turnbuckles

Turnbuckles shall be **30mm x 300mm x 300mm1-1/4 inches x 12 inches x inches** Type I, Grade 1 galvanized, in accordance with **ASTM F1145**.

2.3.3 Rope Clamps

Rope clamps shall be hot-dipped galvanized in accordance with **ASTM A153/A153M**.

2.3.4 Threaded Rods, U-Bolts, and Bolts

All threaded rods, U-bolts shall conform to **ASTM A307** and installed with **ASTM F844** and **ASTM A563** nuts. The entire bolt assembly shall be galvanized.

]PART 3 EXECUTION

3.1 PREPARATION

Perform complete installation conforming to **ASTM F567**.

3.1.1 Line and Grade

Install fence to the lines and grades indicated. Clear the area on either side of the fence line to the extent indicated. Space line posts equidistant at intervals not exceeding **3 m 10 feet**. Set terminal (corner, gate, and pull) posts whenever abrupt changes in vertical and horizontal alignment are encountered. Provide continuous fabric between terminal posts; however, ensure runs between terminal posts do not exceed **152.4 m 500 feet**. Repair any damage to galvanized surfaces, including welding,

with paint containing zinc dust in accordance with ASTM A780/A780M.

3.1.2 Excavation

Excavate holes to depths indicated. Clear all post holes of loose material and spread waste material where directed. Eliminate ground surface irregularities along the fence line to the extent necessary to maintain a [25][50] mm [1][2] inch clearance between the bottom of the fabric and finish grade.

3.2 INSTALLATION

3.2.1 Installation Drawings

Submit complete Fence Installation Drawings for review and approval by the Contracting Officer prior to shipment. Submit drawing details that include, but are not limited to the following information: Fence Installation Drawings, Location of gate, corner, end, and pull posts, Gate Assembly, Turnstiles, and Gate Hardware and Accessories. Install fence system per approved drawings.

3.2.2 Security Fencing

Install new security fencing, remove existing security fencing, and perform related work to provide continuous security for facility. Schedule and fully coordinate work with Contracting Officer.

3.2.3 Posts

NOTE: For fences over 1.83 m 6 feet tall in areas
of frequent high winds (113 kph (70 mph) or
greater), specify hole diameters of 406 mm 16 inches
for terminal posts and 305 mm 12 inches for line
posts.

3.2.3.1 Earth and Bedrock

- a. Set posts plumb and in alignment. Except where solid rock is encountered, set posts in concrete to the depth indicated on the drawings. Where solid rock is encountered with no overburden, set posts to a minimum depth of 457 mm 18 inches in rock. Where solid rock is covered with an overburden of soil or loose rock, set posts to the minimum depth indicated on the drawing unless a penetration of 457 mm 18 inches in solid rock is achieved before reaching the indicated depth, in which case terminate depth of penetration. Grout all portions of posts set in rock.
- b. Set portions of posts not set in rock in concrete from the rock to ground level. Set posts in holes not less than the diameter shown on the drawings. Make diameters of holes in solid rock at least 25 mm 1 inch greater than the largest cross section of the post. Thoroughly consolidate concrete and grout around each post, free of voids and finished to form a dome. Allow concrete and grout to cure for 72 hours prior to attachment of any item to the posts. Group II line posts may be mechanically driven, for temporary fence construction only, if rock is not encountered. Set driven posts to a minimum depth of 914 mm 3 feet and protect with drive caps when setting.

- c. Test fence post rigidity by applying a 222.4 newtons 50 pound force on the post, perpendicular to the fabric, at 1.52 m 5 feet above ground. Ensure post movement measured at the point where the force is applied is less than or equal to 19 mm 3/4 inch from the relaxed position. Test every tenth post for rigidity. When a post fails this test, make further tests on the next four posts on either side of the failed post. Remove, replace, and retest all failed parts at the Contractor's expense.

[3.2.3.2 Concrete Slabs and Walls

NOTE: Use the following paragraph where required by the design, otherwise delete. Sleeve joints for nonremovable fence sections are usually filled with lead or nonshrink grout. Removable fence sections may be useful as an economical means for providing access to equipment. Sleeve joints in removable fence sections may be a tight sliding type, or where moisture entry could be a problem, filled with pipe sulphur jointing compound.

When installed in concrete slabs or walls, set posts in zinc-coated sleeves, to a minimum depth of 300 mm 12 inches. Fill sleeve joint with lead, nonshrink grout, or other approved material. Set posts for support of removable fence sections in sleeves that provide a tight sliding joint and hold posts aligned and plumb without use of lead or setting material.

]3.2.4 Rails

NOTE: Top Rails are normally not applicable to High Security Installations

Bolt bottom rail to double rail ends and securely fasten double rail ends to the posts. Peen bolts to prevent easy removal. Install bottom rail before chain link fabric. [Provide 3/8" diameter eye hook anchored into concrete footing at midpoint.]

3.2.5 Fabric

NOTE: Normally the bottom of fence fabric will be installed no higher than 50 mm 2 inches from the ground. For Air Force projects, high security fence fabric will be installed no higher than 25 mm 1 inch from the ground. The height requirement for fence fabric will be verified with the user.

In areas where the soil along the fence line is prone to erosion, measures should be taken to maintain the level of security for which the fence is designed.

Tension requirements are for high security fence applications. Fabric fastening requirement of 300 mm

**12 inch spacing to top tension wire and bottom rail
is a high security fence requirement.**

- a. Set fabric height [at [1.8][2.1] m [6][7] feet] [_____] [as shown].
- b. Install chain link fabric on the side of the post indicated. Attach fabric to terminal posts with stretcher bars and tension bands. Space bands at approximately 381 mm 15 inch intervals. Install fabric and pull taut to provide a smooth and uniform appearance free from sag, without permanently distorting the fabric diamond or reducing the fabric height. Fasten fabric to line posts at approximately 381 mm 15 inch intervals and fastened to all rails and tension wires at approximately [610][305] mm [24][12] inch intervals.
- c. Cut fabric by untwisting and removing pickets. Accomplish splicing by weaving a single picket into the ends of the rolls to be joined. Install the bottom of the fabric [50][25] mm plus or minus 13 mm [2][1] plus or minus 1/2 inch above the ground.
- d. After the fabric installation is complete, exercise the fabric by applying a 222 newtons 50 pound push-pull force at the center of the fabric between posts; use a 133 newtons 30 pound pull at the center of the panel to ensure fabric deflection of not more than 63.5 mm 2.5 inches when pulling fabric from the post side of the fence. Every second fence panel is required to meet this requirement. Resecure and retest all failed panels at the Contractor's expense.

3.2.6 Supporting Arms

Install barbed wire supporting arms and barbed wire as indicated on the drawings and as recommended by the manufacturer. Anchor supporting arms [to the posts in a manner to prevent easy removal with hand tools] [with 9.5 mm 3/8 inch diameter plain pin rivets or, at the Contractor's option, with studs driven by low-velocity explosive-actuated tools for steel, wrought iron, ductile iron, or malleable iron. Do not use explosive-actuated tool to drive studs into gray iron or other material that can be fractured. Use a minimum of two studs per support arm.] Pull barbed wire taut and attach to the arms with clips or other means that will prevent easy removal.

[3.2.7 Barbed Tape Installation

**NOTE: Barbed tape is a high security fence option
when required.**

Install stainless steel reinforced barbed tape per ASTM F1911 and as detailed on the drawings. Stretch out barbed tape to its manufacturer's recommended length, set on top of the barbed wire and "V" shaped support arms, then secure it to the barbed wire. Secure the barbed tape to the barbed wire at the two points and at every spiral turn of both coils as shown on the drawings. Install stainless steel [reinforced][non-reinforced] barbed tape for ground applications [in accordance with manufacturer's recommendations][as shown on the drawings].

13.2.8 Gate Installation

- a. Install gates at the locations shown. Mount gates to swing as indicated. Install latches, stops, and keepers as required. Install [Slide] [Lift] gates as recommended by the manufacturer.
- b. Attach padlocks to gates or gate posts with chains. Weld or otherwise secure hinge pins, and hardware assembly to prevent removal.
- c. Submit [6][_____] copies of [operating and maintenance instructions](#). Outline the step-by-step procedures required for system startup, operation, and shutdown. Include the manufacturer's name, model number, service manual, parts list, and brief description of all equipment and their basic operating features. Include in the maintenance instructions routine maintenance procedures, possible breakdowns and repairs, and troubleshooting guide. Also include the general gate layout, equipment layout and simplified wiring and control diagrams of the system as installed.

3.2.9 Grounding

NOTE: Delete this paragraph if grounding is not required. If grounding is required and lightning protection is not part of project design, the requirements in the second set of brackets will be used in lieu of those in the first set of brackets. Provide fence grounding details when composite type posts are specified where grounding of the fence is required.

- a. Ground fencing as [indicated on drawings][and][specified].
- b. [Ground fences crossed by overhead powerlines in excess of 600 volts and ground all electrical equipment attached to the fence.]
- c. [Ground fences on each side of all gates, at each corner, at the closest approach to each building located within [15 m 50 feet](#) of the fence, and where the fence alignment changes more than 15 degrees. Ensure grounding locations are located no more than [198 m 650 feet](#) apart. Bond each gate panel with a flexible bond strap to its gate post. Ground fences crossed by powerlines of 600 volts or more at or near the point of crossing and at distances not exceeding [45 m 150 feet](#) on each side of crossing.]
- d. [Provide ground conductor consisting of [3.3 mmNo. 8 AWG](#) solid copper wire. Use grounding electrodes that measures [19 mm 3/4 inch](#) by [3.05 m 10 foot](#) long and are a copper-clad steel rod. Drive electrodes into the earth so that the top of the electrode is at least [152 mm 6 inches](#) below the grade. Where driving is impracticable, bury electrodes a minimum of [305 mm 12 inches](#) deep and radially from the fence. Install the top of the electrode to be less than [610 mm 2 feet](#) or more than [2.4 m 8 feet](#) from the fence. Clamp ground conductor to the fence and electrodes with bronze grounding clamps to create electrical continuity between fence posts, fence fabric, and ground rods. Measure total resistance of the fence to ground and ensure it is not greater than 25 ohms.]

[3.2.10 Cable Reinforcement Installation

Comply with the contract drawings. Install [1][2][___] strands of [1.9][2.5] cm [3/4][1] in steel aircraft cables mounted to the [chain link fence] [ornamental fence system] posts utilizing u-bolts and nuts. Peen the ends of the U-bolts to prevent removal. Tighten cables with galvanized steel turnbuckles with swaged fittings to the point there is no visible sag. Install [1 m x 1 m x .5 m][1.3 m x 1.3 m x 0.66 m][_____] [3 ft x 3 ft x 1.5 ft][4ft x 4 ft x 2ft][_____] concrete deadman anchors which are a minimum of [1][1.3][___] m [3][4][___] ft underground and installed in undisturbed surrounding soils. Space dead man anchors no more than 61 m 200 ft apart and on each side of gate openings. Connect steel aircraft cables to dead man anchors using swaged end fittings and turnbuckles attached to 3.2 cm 1.25 in galvanized threaded rod which is embedded into concrete anchor and held in place with two 10 cm x 10 cm x 0.66 cm 4 in x 4 in x ¼ in thick steel plates welded to the threaded rod. Place deadman anchors within 3 m 10 feet of last post and on each side of gate openings.

]3.3 CLOSEOUT ACTIVITIES

3.3.1 Cleanup

Remove waste fencing materials and other debris from the work site each workday.

-- End of Section --