

\*\*\*\*\*

USACE / NAVFAC / AFCEC

UFGS-33 52 40 (November 2018)

Change 2 - 11/20

-----

Preparing Activity: NAVFAC

Superseding

UFGS-33 52 43 (May 2011)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2024

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 33 - UTILITIES

#### SECTION 33 52 40

#### FUEL SYSTEMS PIPING (NON-HYDRANT)

11/18, CHG 2: 11/20

#### PART 1 GENERAL

- 1.1 SUMMARY
- 1.2 REFERENCES
- 1.3 ADMINISTRATIVE REQUIREMENTS
- 1.4 SUBMITTALS
- 1.5 QUALITY ASSURANCE
  - 1.5.1 Contractor Qualifications
  - 1.5.2 System Supplier
  - 1.5.3 Work Plan
  - 1.5.4 Pigging Plan
  - 1.5.5 Hydrotesting Plan
  - 1.5.6 Water for [Hydrotesting][Pigging]
  - 1.5.7 Design Data
    - 1.5.7.1 Pipeline Inventory
  - 1.5.8 Material and System Components Qualifications
  - 1.5.9 Nameplates
  - 1.5.10 Delivery, Storage, and Handling

#### PART 2 PRODUCTS

- 2.1 ELECTRICAL WORK
  - 2.1.1 General
  - 2.1.2 Grounding and Bonding
- 2.2 MATERIALS
  - 2.2.1 Types of Fuel
  - 2.2.2 Carbon Steel Piping
  - 2.2.3 Stainless Steel Piping
  - 2.2.4 Steel Reinforced Flexible Pipe
  - 2.2.5 External Protective Coatings for Aboveground Piping
  - 2.2.6 External Protective Coatings for Buried Steel Piping
    - 2.2.6.1 Carbon Steel Piping
    - 2.2.6.2 Stainless Steel Piping
    - 2.2.6.3 Rock Shield, Direct Buried Piping

- 2.2.7 Fittings
  - 2.2.7.1 General
  - 2.2.7.2 Carbon Steel Fittings
  - 2.2.7.3 Stainless Steel Fittings
  - 2.2.7.4 Steel Reinforced Flexible Pipe Fittings
- 2.2.8 Insulating Flange Kits (Electrically Isolating)
- 2.2.9 Bolts, Nuts and Washers
- 2.2.10 Flange Gaskets, Non-Metallic, Non-Electrically Isolating
  - 2.2.10.1 Nitrile Butadiene (Buna-N)
  - 2.2.10.2 Acrylonitrile Butadiene Rubber (NBR)
  - 2.2.10.3 Polytetrafluoroethylene (PTFE)
  - 2.2.10.4 Fluoro Rubber FKM
  - 2.2.10.5 Fluoroelastomer FPM
- 2.2.11 Flange Gaskets, Metallic
- 2.2.12 Flange Protectors
- 2.3 MANUAL VALVES
  - 2.3.1 Ball Valves
    - 2.3.1.1 Materials
    - 2.3.1.2 V-Port Ball Valve
    - 2.3.1.3 Full Port Ball (DBBV) Valves for Piggable Lines
    - 2.3.1.4 Electric Valve Actuator
  - 2.3.2 Plug (Double Block and Bleed) Valves
    - 2.3.2.1 General
    - 2.3.2.2 Valve Operation
    - 2.3.2.3 Relief Valves
    - 2.3.2.4 Bleed Valves
    - 2.3.2.5 Electric Valve Actuator
  - 2.3.3 Swing Check Valves
  - 2.3.4 Silent Check Valves
  - 2.3.5 Butterfly Valve with Fusible Link Operator
  - 2.3.6 Globe Valve
- 2.4 THERMAL RELIEF VALVE
  - 2.4.1 Valve Material
  - 2.4.2 Thermal Relief Valve (ASME Type)
  - 2.4.3 Thermal Relief Valve (Balanced Type)
- 2.5 PIPING ACCESSORIES
  - 2.5.1 Flexible Ball Joints
  - 2.5.2 Bellows Expansion Joints for Axial Movement
  - 2.5.3 Mechanically Adjustable Segmented Elastomeric Seal
  - 2.5.4 Pipe Sleeves
  - 2.5.5 Strainers
    - 2.5.5.1 Basket Type
    - 2.5.5.2 Cone Type
  - 2.5.6 Thermometer
  - 2.5.7 Pressure Gauge
  - 2.5.8 Pipe Supports
    - 2.5.8.1 General
    - 2.5.8.2 Adjustable Pipe Supports
    - 2.5.8.3 Low Friction Supports
    - 2.5.8.4 U-bolt Half Round Supports
    - 2.5.8.5 Concrete and Grout
  - 2.5.9 Sample Connections
  - 2.5.10 Sight Flow Indicators
- 2.6 PIGGING SYSTEM COMPONENTS
  - 2.6.1 Maintenance Pig Launchers and Receivers
  - 2.6.2 Smart Pig Launchers and Receivers
  - 2.6.3 Launcher and Receiver Closure Door
  - 2.6.4 Signaler
- 2.7 FLEXIBLE HOSE CONNECTORS

- 2.8 AUTOMATIC AIR VENT
- 2.9 SURGE SUPPRESSOR TANK AND VALVE
- 2.10 MISCELLANEOUS ACCESSORIES
  - 2.10.1 Concrete Anchor Bolts
  - 2.10.2 Coatings for Bolts, Studs, Nuts, and Washers
  - 2.10.3 Polytetrafluoroethylene (PTFE) Tape
  - 2.10.4 Pipe Sleeves
  - 2.10.5 Escutcheon
  - 2.10.6 Pipe Casings
  - 2.10.7 Buried Utility Tape
  - 2.10.8 Pipeline Markers
- 2.11 FINISHES
  - 2.11.1 Factory Coating
    - 2.11.1.1 Valves
    - 2.11.1.2 Equipment and Components
  - 2.11.2 Field Painting

### PART 3 EXECUTION

- 3.1 GENERAL
- 3.2 VERIFICATION OF DIMENSIONS
- 3.3 CLEANING OF PIPING
- 3.4 TRENCHING AND BACKFILLING
- 3.5 PIPING LAYOUT REQUIREMENTS
  - 3.5.1 Pipe Fabrication
  - 3.5.2 Interferences and Measurements
  - 3.5.3 Space and Access
  - 3.5.4 Location
  - 3.5.5 Pipe Supports
  - 3.5.6 Structural Support
  - 3.5.7 Grade
  - 3.5.8 Size Changes
  - 3.5.9 Direction Changes
  - 3.5.10 Threaded End Connections
  - 3.5.11 Existing Pipe Systems
  - 3.5.12 Bolted Connections
  - 3.5.13 Flanges and Unions
  - 3.5.14 Flange Protector
  - 3.5.15 Manual Valves
  - 3.5.16 Air Vents
  - 3.5.17 Drains
  - 3.5.18 Bellows Expansion Joints
  - 3.5.19 Thermometers
  - 3.5.20 Pipe Sleeves
  - 3.5.21 Escutcheons
- 3.6 SEISMIC REQUIREMENTS
- 3.7 STRUCTURAL ATTACHMENTS
- 3.8 WELDING
  - 3.8.1 General
- 3.9 INSTALLATION
  - 3.9.1 Precautions
  - 3.9.2 Protective Coatings for Buried Piping Including Stainless Steel Piping
    - 3.9.2.1 Application of Coating System
    - 3.9.2.2 Inspection and Testing
    - 3.9.2.3 Damage Repair
- 3.10 INTERIOR EPOXY COATING
- 3.11 INSTALLATION OF UNDERGROUND PIPE
  - 3.11.1 Pipe Assembly

3.11.2	Warning Tapes in Earth Trenches
3.11.3	Clearances
3.11.4	Protective Coating
3.11.5	Pipe Casing
3.11.6	Pipeline Markers
3.11.7	Steel Reinforced Flexible Pipe
3.12	SYSTEM COMMISSIONING
3.13	TESTING
3.13.1	Before Backfilling
3.13.1.1	Exterior Coating Holiday Test
3.13.2	Pneumatic Test
3.13.2.1	Pneumatic Test Procedure
3.13.3	Hydrostatic Test
3.13.4	Soak Testing
3.13.5	Performance Testing
3.14	PIPE PIGGING - CLEANING
3.14.1	General
3.14.2	Use of Fuel in Cleaning Pigging
3.14.3	Use of Water in Cleaning Pigging
3.14.4	Cleaning Pig Run
3.14.5	Wire Brush Pig Run
3.15	PIPE PIGGING VERIFICATION
3.15.1	Use of Water in Pipe Pigging Verification
3.15.2	Geometry/Ultrasonic Tool Reports
3.15.3	Pipeline Internal Inspection Operations
3.15.3.1	General
3.15.3.2	Preparatory Work
3.15.3.3	Pig Load And Launch
3.15.3.4	Pipeline Operation During Pigging
3.15.3.5	Brush and Gauging Survey
3.15.3.6	Geometry/Ultrasonic Survey
3.15.3.7	Pipe Wall Thickness Survey
3.15.3.8	Lost Pig
3.16	DEMONSTRATIONS
3.17	POSTED OPERATING INSTRUCTIONS

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC UFGS-33 52 40 (November 2018)  
Change 2 - 11/20  
-----  
Preparing Activity: NAVFAC Superseding  
UFGS-33 52 43 (May 2011)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2024

\*\*\*\*\*

### SECTION 33 52 40

#### FUEL SYSTEMS PIPING (NON-HYDRANT) 11/18, CHG 2: 11/20

\*\*\*\*\*

NOTE: This guide specification covers the requirements for piping, piping components, valving and miscellaneous accessories for general fueling systems, non-hydrant type and non-service station. Do not use this specification for designs related to pressurized hydrant fueling systems and super refueler fillstands. For such systems, refer to the requirements of the DOD Type III/IV/V, and Cut and cover Hydrant Refueling System Standards.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

\*\*\*\*\*

## PART 1 GENERAL

\*\*\*\*\*

NOTE: Use this UFGS in conjunction with UFC 3-460-01 "Design: Petroleum Fuel Facilities". Include in this specification any additional equipment/devices necessary to meet state and local regulations.

The specification is written around ASME's standard Class 150 rating. For applications requiring higher

pressure ratings (e.g., Class 300), the designer will have to modify this specification appropriately.

Cut and Cover systems must conform to Standard Design AW 078-24-33 UNDERGROUND VERTICAL STORAGE TANKS CUT AND COVER. Field fabricated ASTs must conform to AW 078-24-27 ABOVEGROUND VERTICAL STEEL TANKS WITH FIXED ROOFS. Standards can be found on the Whole Building Design Guide at the following location:

<http://www.wbdg.org/ffc/dod/non-cos-standards>.

\*\*\*\*\*

## 1.1 SUMMARY

This section defines the requirements for pipe, piping components, and valves as related to an non-hydrant, non-service station, fuel distribution system. Such systems include, but are not limited to: marine receipt, pipeline receipt, truck off-loading receipt, pump house, pump pad, truck loading, marine loading, transfer pipeline, product recovery, and other miscellaneous piping systems. Provide the entire fuel distribution system as a complete and fully operational system. Size, select, construct, and install equipment and system components to operate together as a complete system. Substitutions of functions specified herein will not be acceptable. Coordinate the work of the system manufacturer's service personnel during construction, testing, calibration, and acceptance of the system. System components and piping specified herein must be designed to handle a working pressure of [1900] [\_\_\_\_\_] kPa [275] [\_\_\_\_\_] psig at 38 deg C 100 deg F. Components specified herein must be compatible with the fuel to be handled. Components to be suitable for outside, unsheltered location, and to function normally in ambient temperatures between [\_\_\_\_\_] degrees C degrees F and [\_\_\_\_\_] degrees C degrees F.

## 1.2 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by

the basic designation only.

AMERICAN PETROLEUM INSTITUTE (API)

API 570	(2016; Addendum 1 2017; Addendum 2 2018; ERTA 1 2018) Piping Inspection Code: In-Service Inspection, Rating, Repair, and Alteration of Piping Systems
API RP 540	(1999; R 2004) Electrical Installations in Petroleum Processing Plants
API RP 1110	(2013; R 2018) Recommended Practice for the Pressure Testing of Steel Pipelines for the Transportation of Gas, Petroleum Gas, Hazardous Liquids, Highly Volatile Liquids, or Carbon Dioxide
API RP 1595	(2012; R 2019; 2nd Ed) Design, Construction, Operation, Maintenance, and Inspection of Aviation Pre-Airfield Storage Terminals
API RP 2003	(2015; 8th Ed) Protection Against Ignitions Arising out of Static, Lightning, and Stray Currents
API RP 2009	(2002; R 2007; 7th Ed) Safe Welding, Cutting, and Hot Work Practices in Refineries, Gasoline Plants, and Petrochemical Plants
API RP 2200	(1999; R 2004) Electrical Installations in Petroleum Processing Plants
API STD 600	(2015) Steel Gate Valves-Flanged and Butt-welding Ends, Bolted Bonnets
API STD 608	(2012) Metal Ball Valves - Flanged, Threaded, And Welding End
API Spec 5L	(2018; 46th Ed; ERTA 2018) Line Pipe
API Spec 6D	(June 2018, 4th Ed; Errata 1 July 2018; Errata 2 August 2018) Specification for Pipeline and Piping Valves
API Spec 6FA	(1999; R 2006; Errata 2006; Errata 2008; R 2011) Specification for Fire Test for Valves
API Spec 17J	(2016; Errata 2 2017; ADD 1 2017) Specification for Unbonded Flexible Pipe
API Std 594	(2017) Check Valves: Flanged, Lug, Wafer and Butt-Welding
API Std 607	(2016) Fire Test for Quarter-turn Valves and Valves Equipped with Non-metallic Seats

API Std 609

(2016; ERTA 2017) Butterfly Valves:  
Double Flanged, Lug-and-Wafer Type

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

ASME B1.1

(2024) Unified Inch Screw Threads (UN,  
UNR, and UNJ Thread Form)

ASME B16.5

(2020) Pipe Flanges and Flanged Fittings  
NPS 1/2 Through NPS 24 Metric/Inch Standard

ASME B16.9

(2018) Factory-Made Wrought Buttwelding  
Fittings

ASME B16.11

(2022) Forged Fittings, Socket-Welding and  
Threaded

ASME B16.20

(2023) Metallic Gaskets for Pipe Flanges

ASME B16.21

(2021) Nonmetallic Flat Gaskets for Pipe  
Flanges

ASME B16.34

(2021) Valves - Flanged, Threaded and  
Welding End

ASME B18.2.1

(2012; R 2021) Square, Hex, Heavy Hex, and  
Askew Head Bolts and Hex, Heavy Hex, Hex  
Flange, Lobed Head, and Lag Screws (Inch  
Series)

ASME B18.2.2

(2022) Nuts for General Applications:  
Machine Screw Nuts, and Hex, Square, Hex  
Flange, and Coupling Nuts (Inch Series)

ASME B31.3

(2022; Errata 2023) Process Piping

ASME BPVC SEC VIII D1

(2019) BPVC Section VIII-Rules for  
Construction of Pressure Vessels Division 1

AMERICAN WATER WORKS ASSOCIATION (AWWA)

AWWA C210

(2015) Standard for Liquid Epoxy Coating  
Systems for the Interior and Exterior of  
Steel Water Pipelines

ASTM INTERNATIONAL (ASTM)

ASTM A36/A36M

(2019) Standard Specification for Carbon  
Structural Steel

ASTM A53/A53M

(2024) Standard Specification for Pipe,  
Steel, Black and Hot-Dipped, Zinc-Coated,  
Welded and Seamless

ASTM A105/A105M

(2023) Standard Specification for Carbon  
Steel Forgings for Piping Applications

ASTM A123/A123M

(2017) Standard Specification for Zinc



	(Hot-Dip Galvanized) Coatings on Iron and Steel Products
ASTM A153/A153M	(2023) Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware
ASTM A182/A182M	(2024) Standard Specification for Forged or Rolled Alloy and Stainless Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service
ASTM A193/A193M	(2024) Standard Specification for Alloy-Steel and Stainless Steel Bolting Materials for High-Temperature Service and Other Special Purpose Applications
ASTM A194/A194M	(2024) Standard Specification for Carbon Steel, Alloy Steel, and Stainless Steel Nuts for Bolts for High-Pressure or High-Temperature Service, or Both
ASTM A234/A234M	(2024) Standard Specification for Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and High Temperature Service
ASTM A240/A240M	(2024) Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications
ASTM A269/A269M	(2024) Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service
ASTM A276/A276M	(2024) Standard Specification for Stainless Steel Bars and Shapes
ASTM A312/A312M	(2022a) Standard Specification for Seamless, Welded, and Heavily Cold Worked Austenitic Stainless Steel Pipes
ASTM A358/A358M	(2024) Standard Specification for Electric-Fusion-Welded Austenitic Chromium-Nickel Stainless Steel Pipe for High-Temperature Service and General Applications
ASTM A403/A403M	(2022b) Standard Specification for Wrought Austenitic Stainless Steel Piping Fittings
ASTM A564/A564M	(2019) Standard Specification for Hot-Rolled and Cold-Finished Age-Hardening Stainless Steel Bars and Shapes
ASTM A653/A653M	(2023) Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by

the Hot-Dip Process

ASTM A924/A924M	(2022a) Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process
ASTM A961/A961M	(2024) Standard Specification for Common Requirements for Steel Flanges, Forged Fittings, Valves, and Parts for Piping Applications
ASTM B117	(2019) Standard Practice for Operating Salt Spray (Fog) Apparatus
ASTM B696	(2000; R 2023) Standard Specification for Coatings of Cadmium Mechanically Deposited
ASTM B766	(2023) Standard Specification for Electrodeposited Coatings of Cadmium
ASTM D229	(2019) Standard Test Methods for Rigid Sheet and Plate Materials Used for Electrical Insulation
ASTM D1418	(2010; R 2016) Standard Practice for Rubber and Rubber Lattices - Nomenclature
ASTM D1655	(2018a) Standard Specification for Aviation Turbine Fuels
ASTM D3308	(2012; R 2017) Standard Specification for PTFE Resin Skived Tape
ASTM F336	(2002; R 2023) Standard Practice for Design and Construction of Nonmetallic Enveloped Gaskets for Corrosive Service
ASTM F436	(2011) Hardened Steel Washers

BRITISH STANDARDS INSTITUTION (BSI)

BS EN ISO 10497	(2022) Testing of Valves Fire Type-Testing Requirements
-----------------	---

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE 142	(2007; Errata 2014) Recommended Practice for Grounding of Industrial and Commercial Power Systems - IEEE Green Book
IEEE 1100	(2005) Emerald Book IEEE Recommended Practice for Powering and Grounding Electronic Equipment
IEEE C62.41.2	(2002) Recommended Practice on Characterization of Surges in Low-Voltage (1000 V and Less) AC Power Circuits

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION (ISO)

ISO 1629 (2013) Rubber and Latexes - Nomenclature

MANUFACTURERS STANDARDIZATION SOCIETY OF THE VALVE AND FITTINGS  
INDUSTRY (MSS)

MSS SP-58 (2018) Pipe Hangers and Supports -  
Materials, Design and Manufacture,  
Selection, Application, and Installation

NACE INTERNATIONAL (NACE)

NACE SP0188 (2024) Discontinuity (Holiday) Testing of  
New Protective Coatings on Conductive  
Substrates

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 30 (2024) Flammable and Combustible Liquids  
Code

NFPA 70 (2023) National Electrical Code

NFPA 77 (2024; ERTA 1 2023) Recommended Practice  
on Static Electricity

NFPA 407 (2022; TIA 21-1) Standard for Aircraft  
Fuel Servicing

NFPA 780 (2023) Standard for the Installation of  
Lightning Protection Systems

SOCIETY FOR PROTECTIVE COATINGS (SSPC)

SSPC SP 5/NACE No. 1 (2007) White Metal Blast Cleaning

SOCIETY OF AUTOMOTIVE ENGINEERS INTERNATIONAL (SAE)

SAE AMS3275 (2009; Rev C) Sheet, Acrylonitrile  
Butadiene (NBR) Rubber and Non-Asbestos  
Fiber Fuel and Oil Resistant

SAE J514 (2012) Hydraulic Tube Fittings

U.S. DEPARTMENT OF DEFENSE (DOD)

MIL-DTL-5624 (2024; Rev X) Turbine Fuel, Aviation,  
Grades JP-4 and JP-5

MIL-PRF-4556 (1998; Rev F; Am 1 1999; CANC Notice 1  
2011) Coating Kit, Epoxy, for Interior of  
Steel Fuel Tanks

MIL-PRF-13789 (1999; Rev E; Notice 1 2008; Notice 2  
1016; Notice 3 2021) Strainers, Sediment:  
Pipeline, Basket Type

MIL-STD-161 (2005; Rev G; Notice 1 2010)

Identification Methods for Bulk Petroleum  
Products Systems Including Hydrocarbon  
Missile Fuels

MIL-STD-3004-1

(2018) Quality Assurance for Bulk Fuels,  
Lubricants and Related Products

### 1.3 ADMINISTRATIVE REQUIREMENTS

Design conditions must be as specified in Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT). Refer to Section 01 78 23 OPERATION MAINTENANCE DATA.

### 1.4 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

#### SD-01 Preconstruction Submittals

Work Plan; G, [\_\_\_\_\_]

[ Pigging Plan; G, [\_\_\_\_\_] ]  
Hydrotesting Plan; G, [\_\_\_\_\_] ]  
Quality Assurance Plan; G, [\_\_\_\_\_] ]

#### SD-02 Shop Drawings

Grounding and Bonding  
Pipe Supports; G, [\_\_\_\_\_] ]  
Pigging System Components; G, [\_\_\_\_\_] ]

#### SD-03 Product Data

Carbon Steel Piping; G, [\_\_\_\_\_] ]  
[ Stainless Steel Piping; G, [\_\_\_\_\_] ]  
][ Steel Reinforced Flexible Pipe; G, [\_\_\_\_\_] ]  
[ External Protective Coatings For Aboveground Piping; G, [\_\_\_\_\_] ]  
[ External Protective Coatings For Buried Steel Piping; G, [\_\_\_\_\_] ]  
][ Rock Shield; G, [\_\_\_\_\_] ]  
[ Fittings; G, [\_\_\_\_\_] ]  
Carbon Steel Fittings; G, [\_\_\_\_\_] ]  
Insulating Flange Kits; G, [\_\_\_\_\_] ]  
Lightning Surge Arrester; G, [\_\_\_\_\_] ]  
Bolts, Nuts And Washers; G, [\_\_\_\_\_] ]  
Flange Protectors; G, [\_\_\_\_\_] ]  
Ball Valves; G, [\_\_\_\_\_] ]  
V Port Ball Valve; G, [\_\_\_\_\_] ]  
Full Port Ball (DBBV) Valves; G, [\_\_\_\_\_] ]  
Plug (Double Block and Bleed) Valves; G, [\_\_\_\_\_] ]  
Electric Valve Actuator  
Swing Check Valves  
Silent Check Valves  
Butterfly Valve with Fusible Link Operator  
Globe Valve; G, [\_\_\_\_\_] ]

Thermal Relief Valve; G, [\_\_\_\_]

Flexible Ball Joints; G, [\_\_\_\_]

Mechanically Adjustable Segmented Elastomeric Seal; G, [\_\_\_\_]

Pipe Sleeves; G, [\_\_\_\_]

Strainers; G, [\_\_\_\_]

Thermometer; G, [\_\_\_\_]

Sample Connections; G, [\_\_\_\_]

Sight Flow Indicators; G, [\_\_\_\_]

Flexible Hose Connectors; G, [\_\_\_\_]

Automatic Air Vent; G, [\_\_\_\_]

Surge Suppressor Tank And Valve; G, [\_\_\_\_]

Pipe Casings; G, [\_\_\_\_]

Buried Utility Tape; G, [\_\_\_\_]

Pipeline Markers; G, [\_\_\_\_]

Bellows Expansion Joints; G, [\_\_\_\_]

Flange Gaskets, Non-Metallic, Non-Electrically Isolating; G, [\_\_\_\_]

Flange Gaskets, Metallic; G, [\_\_\_\_]

#### SD-06 Test Reports

Exterior Coating Holiday Test

Pneumatic Test

Hydrostatic Test

Piping Dehydration Test

Performance Testing

Pipe Pigging Verification

#### SD-07 Certificates

[ Water for [Hydrotesting][Pigging]; G, [\_\_\_\_]

] Contractor Qualifications; G, [\_\_\_\_]

System Supplier; G, [\_\_\_\_]

Pipeline Inventory; G, [\_\_\_\_]

Qualifications of Owner's Inspector; G, [\_\_\_\_\_]

Survey Final Elevations; G, [\_\_\_\_\_]

Demonstrations

SD-08 Manufacturer's Instructions

Flexible Ball Joints; G, [\_\_\_\_\_]

Bellows Expansion Joints; G, [\_\_\_\_\_]

SD-10 Operation and Maintenance Data

Insulating Flange Kits; G, [\_\_\_\_\_]

Lightning Surge Arrester; G, [\_\_\_\_\_]

Ball Valves; G, [\_\_\_\_\_]

V Port Ball Valve; G, [\_\_\_\_\_]

Full Port Ball (DBBV) Valves; G, [\_\_\_\_\_]

Plug (Double Block and Bleed) Valves; G, [\_\_\_\_\_]

Electric Valve Actuator; G, [\_\_\_\_\_]

Swing Check Valves; G, [\_\_\_\_\_]

Butterfly Valve with Fusible Link Operator; G, [\_\_\_\_\_]

Globe Valve; G, [\_\_\_\_\_]

Thermal Relief Valve; G, [\_\_\_\_\_]

Flexible Ball Joints; G, [\_\_\_\_\_]

Mechanically Adjustable Segmented Elastomeric Seal; G, [\_\_\_\_\_]

Strainers; G, [\_\_\_\_\_]

Thermometer; G, [\_\_\_\_\_]

Sample Connections; G, [\_\_\_\_\_]

Sight Flow Indicators; G, [\_\_\_\_\_]

Automatic Air Vent; G, [\_\_\_\_\_]

Surge Suppressor Tank And Valve; G, [\_\_\_\_\_]

Bellows Expansion Joints; G, [\_\_\_\_\_]

1.5 QUALITY ASSURANCE

\*\*\*\*\*

**NOTE: Specify as directed by the Service  
Headquarters.**

\*\*\*\*\*

#### 1.5.1 Contractor Qualifications

Each installation Contractor must have successfully completed at least 3 projects of the similar scope and the same size or larger within the last 6 years. Each installation Contractor must demonstrate specific installation experience in regard to the specific system installation to be performed. Each installation Contractor must have taken, if applicable, manufacturer's training courses on the installation of piping and must meet the licensing requirements in the state. Experience must include the erection of piping systems in compliance with the requirements of ASME B31.3, and NFPA 30. Submit a letter listing prior projects, the date of construction, a point of contact for each prior project, the scope of work of each prior project, and a detailed list of work performed. Provide in the letter evidence of prior manufacturer's training and state licensing.

#### 1.5.2 System Supplier

As per requirements in Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT).

#### 1.5.3 Work Plan

Submit a comprehensive work plan that provides sufficient detail to demonstrate a thorough understanding of the project. Document that all components to be provided will function together and produce the result expected by the Government. Include any proposed dates for piping system shutdowns as well as the Contractor's ability to complete the work within the allotted shutdown periods. Show proposed dates and nature of piping system operations required of the Government. Include a list of manpower, spare piping and system component that will be on hand for each phase of the work. Describe, in detail, the means of:

- a. Coordinating work with Government and third parties.
- b. Preparing for safe piping repair work.
- c. Pneumatic pressure testing new piping sections.
- d. Hydrostatic pressure testing new piping sections.
- [ e. Drying lines after water was introduced for  
[hydrotesting][hydrotesting and pigging][pigging].
- ] [f. Interrupting or isolating an existing fuel service or system.
- ] g. Purging piping.
- h. Vapor monitoring.
- i. Preparations for containing and disposing of residual fuel.
- j. Cutting, sealing, and welding into existing piping systems.
- k. Welding tie-ins in place.
- l. Examining repair section tie-in welds.



m. Collecting, storing and disposing of waste fuel generated during work.

#### [1.5.4 Pigging Plan

\*\*\*\*\*  
**NOTE: Provide if piping is piggable.**  
\*\*\*\*\*

The Contractor must submit a detailed written plan covering all aspects of the pipeline pigging operation, including anticipated pig runs, types of pigs, sequence of work, and retrieval/repair procedures. The Contractor must identify for each pigging evolution, the characteristics of the pig (type/purpose) and method/medium for propulsion.

#### ]1.5.5 Hydrotesting Plan

The Contractor must submit a detailed written plan covering all aspects of the pipeline hydrostatic testing operations, including procedures and sequencing of testing, segments of piping to be tested, fluid to be used during testing, equipment removal and isolation, hydrostatic testing pressures, safety protocols, etc.

#### [1.5.6 Water for [Hydrotesting][Pigging]

Submit results of water testing and amount of water required.

#### ]1.5.7 Design Data

##### 1.5.7.1 Pipeline Inventory

Fuel system volume must be calculated using as constructed pipe lengths, internal diameters, fittings, and components. Totals must be provided for all items containing fuel with the exception of tanks which is covered by other specifications. A certified pipeline inventory - a detailed list with sizes, lengths, quantity, and volumes must be provided for the systems in this project. Such systems include, but are not limited to: marine receipt, pipeline receipt, truck off-loading receipt, pump house, pump pad, truck loading, marine loading, transfer pipeline, product recovery, and other miscellaneous piping systems.

#### 1.5.8 Material and System Components Qualifications

As per requirements in Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT).

#### 1.5.9 Nameplates

As per requirements in Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT).

#### 1.5.10 Delivery, Storage, and Handling

As per requirements in Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT). If fuel is used for [hydrotesting] [and] [or] [cleaning pigging], comply with all the requirements in Section 33 08 55 FUEL DISTRIBUTION SYSTEM START-UP (NON-HYDRANT).

## PART 2 PRODUCTS

### 2.1 ELECTRICAL WORK

\*\*\*\*\*

**NOTE:** Show electrical characteristics on the drawings.

Coordinate the ignition temperature of the fuel(s) to be handled with the electrical design. Ignition temperatures will be as defined in NFPA 497M. Fuel ignition temperatures will dictate the maximum allowable temperature rating of the electrical system components. Coordinate the area classification and the electrical design with UFC 3-460-01.

Coordinate piping, valve, system components and other systems bonding and grounding requirements with UFC 3-460-01. Include also in the design a bonding and grounding plan to relieve and control static electricity buildup as described in UFC 3-460-01.

\*\*\*\*\*

#### 2.1.1 General

Motors, manual or automatic motor control system components except where installed in motor control centers, and protective or signal devices required for the operation specified herein must be provided under this section in accordance with Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM. Any wiring required for the operation specified herein, but not shown on the electrical plans, must be provided under this section in accordance with Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM [, Section 33 71 01 OVERHEAD TRANSMISSION AND DISTRIBUTION] [, Section 33 71 02 UNDERGROUND ELECTRICAL DISTRIBUTION].

#### 2.1.2 Grounding and Bonding

Ground and bond as indicated on the drawings and in accordance with NFPA 70, NFPA 77, NFPA 407, NFPA 780, API RP 540, API RP 2003, IEEE 142, and IEEE 1100. Provide jumpers to overcome the insulating effects of gaskets, paints, or nonmetallic components.

### 2.2 MATERIALS

\*\*\*\*\*

**NOTE:** Contact Service Headquarters Cathodic Protection Expert for direction on pipeline cathodic protection.

\*\*\*\*\*

Pipe and fittings in contact with fuel must be stainless steel, interior epoxy coated carbon steel, or interior uncoated carbon steel as indicated on the drawings or as specified herein. No zinc coated metals, brass, bronze or other copper bearing alloys must be used in contact with the fuel. All carbon steel and stainless steel underground piping must have an exterior protective coating and must be cathodically protected in accordance with Section [26 42 13 GALVANIC (SACRIFICIAL) ANODE CATHODIC

PROTECTION (GACP) SYSTEM] [26 42 17 IMPRESSED CURRENT CATHODIC PROTECTION (ICCP) SYSTEM]. Cathodic protection for metal components that attach to a tank must be coordinated and compatible with the tank corrosion control system. Identification of piping must be in accordance with MIL-STD-161 unless specified otherwise. Material for manual valves must be as specified hereinafter. Do not use aluminum valves.

#### 2.2.1 Types of Fuel

\*\*\*\*\*  
**NOTE: Select type of fuel and insert expected temperature extremes.**  
\*\*\*\*\*

Components must be suitable for use with [F-24 turbine fuel (Jet A with additives FSII, CI/LE, and SDA); specific gravity 0.81 at 16 degrees C 60 degrees F; viscosity 1.62 CS at 16 degrees C 60 degrees F; Reid vapor pressure less than 0.35 kPa 0.05 psi, ASTM D1655] [JP-4 turbine fuel; specific gravity 0.76 at 16 degrees C 60 degrees F; viscosity 0.92 CS at 16 degrees C 60 degrees F; Reid vapor pressure 14 to 21 kPa 2 to 3 psi, MIL-DTL-5624] [JP-5 turbine fuel; specific gravity 0.82 at 16 degrees C 60 degrees F; viscosity 1.62 CS at 16 degrees C 60 degrees F; Reid Vapor pressure less than 0.35 kPa 0.05 psi, MIL-DTL-5624] [\_\_\_\_\_].

#### 2.2.2 Carbon Steel Piping

Subject each length of pipe to factory hydrostatic testing and ultrasonic testing in accordance with their respective pipe specification.

- a. Piping 300 mm 12-inches and Larger: API Spec 5L Product Specification Level (PSL) 1, Grade B, [seamless] [seamless or electric welded] [submerged-arc welded or gas metal-arc welded]; or ASTM A53/A53M Grade B, [seamless] [seamless or electric welded] [submerged-arc welded or gas metal-arc welded]; all having a wall thickness of 9 mm 0.375-inch.
- b. Piping 65 through 250 mm 2-1/2 through 10 inches: Schedule 40, API Spec 5L Product Specification Level (PSL) 1, Grade B, [seamless] [seamless or electric welded] [submerged-arc welded or gas metal-arc welded] Grade B; or Schedule 40, Seamless, ASTM A53/A53M Grade B.

\*\*\*\*\*  
**NOTE: Use schedule 80 for most piping 2 inches and smaller; except for extreme/high corrosion environments such as the tropics use Schedule 160 for aboveground and underground piping.**  
\*\*\*\*\*

- c. Piping 50 mm 2-inches and Smaller: Schedule [80][160], API Spec 5L Product Specification Level (PSL) 1, Grade B, [seamless] [seamless or electric welded] [submerged-arc welded or gas metal-arc welded] Grade B; or Seamless, Schedule [80] [160] ASTM A53/A53M Grade B.

\*\*\*\*\*  
**NOTE: Unless otherwise directed by the Service Headquarters, interior coat the piping as follows:**  
  
**Do not interior coat carbon steel piping for fuels other than aviation jet fuels.**

Do not interior coat carbon steel piping for jet fuel service in bulk fuel operations like Bulk Fuel Farms, Defense Fuel Support Points (DFSPs), Marine Pier Receipt/Issue, intraterminal transfer pipelines, and interterminal transfer pipelines.

Interior coat all carbon steel piping for jet fuel service in systems that directly load aircraft or that fill aircraft refueler trucks after receipt filtration. Do not interior coat carbon steel piping before receipt filtration.

\*\*\*\*\*

- d. Internal Pipe Coating (Epoxy Lining) for piping 90 mm 3.5 inches and larger must be internally coated with an epoxy coating in accordance with MIL-PRF-4556 and in accordance with Section 33 52 80 LIQUID FUELS PIPELINE COATING SYSTEMS. The ends of the pipe must be masked or wiped back a minimum of 25 mm one-inch but not more than 40 mm 1-1/2 inches.

### 2.2.3 Stainless Steel Piping

#### a. Piping:

- (1) ASTM A358/A358M, Grade 304L, Class 1 or Class 3 with supplementary requirements of S1, S2 and S3, or ASTM A312/A312M Type 304L, seamless (only). Any agreements between the purchaser and the manufacturer or supplier as referenced in the applicable ASTM must include the Contracting Officer as a party to the agreement. All longitudinal piping welds will receive 100 percent radiographic inspection, 100 percent liquid penetrant inspection, 100 percent visual inspection and all tests as required by the applicable ASTM Standard. All other welds must be inspected per Section 33 52 23.15 POL SERVICE PIPING WELDING. ASTM A312/A312M seamless piping must be provided with a minimum schedule 10S wall thickness for pipe 200 mm 8 inches and larger; minimum schedule 40S for pipe smaller than 200 mm 8 inches (except for threaded pipe which must be minimum Schedule 80S).
- (2) Pipe Ends: All Piping must be provided with beveled ends per Chapter V, ASME B31.3, and must be shipped with the ends capped.

\*\*\*\*\*

**NOTE: Do not require Factory Testing and Inspection Records be provided if calculations show that the maximum normal system operating pressure, pump deadhead pressure, or any thermal relief valve setpoint is 100 psig or less and the system surge pressure does not exceed 150 psig.**

\*\*\*\*\*

- (3) Factory Testing and Inspection Records: Per Table K341.3.2 of Chapter IX of ASME B31.3, visual, radiographic and liquid penetrant tests must be performed for each section of piping provided as all sections are subjected to cyclic conditions. All testing and inspections records must be submitted to the Contracting Officer and must indicate the pipe mark and installed location of each piping section on the project site. Observation by the Contracting Officer of the manufacturers and the fields

testing and inspection procedures must be allowed under this contract. Pipe certification along with pipe markings must be submitted before the pipe arrives on the job site.

(4) **Qualifications of Owner's Inspector**: Provide a qualified inspector in accordance with Chapter VI of **ASME B31.3**. to act as the owner's inspector (for the Government) at the pipe manufacturer's facility in addition to the manufacturer's inspector.

(5) **Quality Assurance Plan**: Submit Quality Assurance Plan for the welding, inspecting and testing of the welded seam pipe.

b. **Stainless Steel Control Tubing**: Seamless, fully annealed tubing conforming to **ASTM A269/A269M**, Grade TP316, Rockwell hardness B80 or less. Wall thickness for **13 mm 1/2-inch** tubing to be a minimum of **1.2 mm 0.049-inch**.

#### [2.2.4 **Steel Reinforced Flexible Pipe**

\*\*\*\*\*

**NOTE: Service Headquarters must approve use of HDPE steel reinforced flexible pipe. Do not use HDPE steel reinforced flexible pipe aboveground.**

The use of steel reinforced flexible pipe in lieu of traditional double-walled underground piping on projects in states that require double-walled underground piping needs to be coordinated between the system designer and the state agency that regulates underground piping. The test protocol to be used for testing the integrity of steel reinforced flexible pipe will need to be provided by the piping supplier and be accepted by the state regulatory agency as equivalent to the traditional double-walled underground piping test protocol required by that agency.

\*\*\*\*\*

Steel Reinforced High Density Polyethylene (HDPE) flexible piping must be manufactured in accordance with **API Spec 17J** and consist of an inner layer of HDPE material, a steel reinforcing layer and an outer HDPE protective layer.

#### ]2.2.5 **External Protective Coatings for Aboveground Piping**

Provide exterior coating of aboveground piping and fittings, piping in pits, pipe supports, filter separators, and miscellaneous metal and system components in accordance with Section **09 97 13.27** HIGH PERFORMANCE COATING FOR STEEL STRUCTURES. Color of finish coat must be [white][beige]. Do not coat aboveground stainless steel or aluminum surfaces.

#### [2.2.6 **External Protective Coatings for Buried Steel Piping**

##### 2.2.6.1 **Carbon Steel Piping**

a. New pipe and fittings must be factory coated in accordance with Section **33 52 80** LIQUID FUELS PIPELINE COATING SYSTEM.

b. Field joints and repairs must be in accordance with Section **33 52 80**

LIQUID FUELS PIPELINE COATING SYSTEMS.

- c. Field joints and repairs in tight spots (valve pits when heaters are too big) must be liquid epoxy in accordance with Section 33 52 80 LIQUID FUELS PIPELINE COATING SYSTEMS.
- d. Existing systems must match existing coating system and must be in accordance with Section 33 52 80 LIQUID FUELS PIPELINE COATING SYSTEMS.
- [ e. Abrasion-resistant topcoat. Following the initial FBE coating application, provide a 20 mil thick abrasion-resistant FBE topcoat. Abrasion-resistant topcoat must be specifically suited for directional boring piping installation.

]2.2.6.2 Stainless Steel Piping

\*\*\*\*\*  
NOTE: Use AWWA C210 liquid-epoxy coating system when piping is to be installed in non-fuel contaminated soil. For fuel contaminated soil, external coating system must be in accordance with 09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES, however, application of the polyurethane top coat is not required.  
\*\*\*\*\*

Provide exterior coating of piping with factory coated AWWA C210 Liquid-Epoxy Coating System.[ Provide exterior coating of piping with a zinc-rich epoxy/epoxy coating system in accordance with 09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES. For buried piping systems omit the polyurethane top coat.]

Damaged Areas of Pipe Coating: Provide exterior coating of piping with AWWA C210 Liquid-Epoxy Coating System.[ Provide exterior coating of piping with a zinc-rich epoxy/epoxy coating system in accordance with 09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES. For buried piping systems omit the polyurethane top coat.]

Fittings, Couplings, and Regular Surfaces: Provide exterior coating of piping with AWWA C210 Liquid-Epoxy Coating System.[ Provide exterior coating of piping with a zinc-rich epoxy/epoxy coating system in accordance with 09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES. For buried piping systems omit the polyurethane top coat.]

Testing of Protective Coatings: Perform tests with an approved silicone rubber electric wire brush or an approved electric spring coil flaw tester. Tester must be equipped with an operating bell, buzzer, or other audible signal which will sound when a holiday is detected at minimum testing voltage equal to 6,275 times the square root of the average coating thickness in mils. Tester must be a type so fixed that field adjustment cannot be made. Calibration by tester manufacturer must be required at six-month intervals or at such time as crest voltage is questionable. Certify in writing the calibration date and crest voltage setting. Maintain the battery at ample charge to produce the crest voltage during tests. Areas where arcing occurs must be repaired by using material identical to original coating or coating used for field joints. After installation, retest the exterior surfaces, including field joints, for holidays. Promptly repair holidays.

### [2.2.6.3 Rock Shield, Direct Buried Piping

\*\*\*\*\*  
NOTE: Specify rock shield where select fill is not  
available and possibility of damage from rock fill  
exists.  
\*\*\*\*\*

Provide a minimum 10 mm 3/8-inch-thick perforated rock shield around buried piping. Rock shield must consist of a polyethylene outer surface bonded to a closed cell foam substrate with uniform perforations intended for use with cathodic protection systems. Rock shield must overlap on itself no less than 152 mm 6 inches. Secure rock shield tightly to the pipe using either strapping tape or plastic ties. Air filled cell type rock shield is prohibited.

### ]2.2.7 Fittings

#### 2.2.7.1 General

Welding ells, caps, tees, reducers, must be of materials compatible for welding to the pipeline in which they are installed, and wall thickness, pressure and temperature ratings of the fittings must be not less than the adjoining pipeline. Unless otherwise specified herein or required by the conditions of installation, all elbows must be the 1.5 diameter (D) type. Miter joints are not acceptable. Make odd angle offsets with pipe bends or elbows cut to the proper angle. Butt weld fittings must be factory-made wrought fittings manufactured by forging or shaping. Fabricated fittings will not be permitted. Welding branch fittings must be insert type suitable for radiographic inspections specified herein.

Make branch connections with butt-welded tees except where the branch is at least two pipe sizes smaller than the run, in which case the branch connection can be made with a forged or seamless branch outlet fitting. The branch outlet fitting must be designed in such a way that the connection can be radiographed. The branch outlet fittings may be a non-radiographicable if: the piping it is connected to is aboveground, the branch outlet size is 2.5 inches or less in diameter, and the branch outlet is located in contained pumphouses, contained truck offloads, contained truck fill stands, and other visibly contained areas equipped with containment curb.

#### 2.2.7.2 Carbon Steel Fittings

\*\*\*\*\*  
NOTE: Select option for piggable fittings if line  
is piggable.  
\*\*\*\*\*

\*\*\*\*\*  
NOTE: Include the radiographicable examination of  
the fitting welds if calculations show that the  
maximum normal system operating pressure, pump  
deadhead pressure or any thermal relief setpoint is  
689 kPa 100 psig or more, or if the system surge  
pressure exceeds 1034 kPa 150 psig.  
\*\*\*\*\*

- a. Fittings 65 mm 2.5 inches and Larger: Butt weld, conforming to

ASTM A234/A234M, grade WPB and ASME B16.9 of the same wall thickness as the adjoining pipe.[ All welds must be radiographically examined throughout the entire length of each weld. Each fitting must be subjected to the Supplementary Requirements S3 and S4, Liquid Penetration examination and Magnetic-Particle Examination. Detectable flaws will not be accepted in the supplementary examinations. Fittings must be identified to relate them to their respective radiograph.]

- b. Fittings 50 mm 2 inches and Smaller: Forged, butt weld or socket welded (except flanges, see below). If specifically indicated on drawings, non-flange fittings may be threaded. Socket welded or threaded fittings must be Class 3000, conforming to ASTM A105/A105M, Grade 2 and ASME B16.11. Threaded fittings must only be used for above grade applications. Underground and in pits, low point drain pipe, and high point vent pipe must be butt welded.
- c. Flanges: Class 150 weld neck, butt weld, forged flanges conforming to ASTM A105/A105M, and ASME B16.5 except flanges that are to be connected to pumps must match the pump flanges rating. Threaded and slip-on flanges are not allowed. Flanges to be 2 mm 1/16-inch raised face with modified spiral serrated gasket surface finish, except where required otherwise to match system components furnished. Match flange face to valves or system components furnished. Flange face must be machined to match valves or system components furnished. Use of spacing rings or gaskets discs are not allowed. Flanges must be subjected to the Supplementary Requirements S56, Liquid Penetrant Examination as outlined in ASTM A961/A961M. Detectable flaws will not be accepted. For flanges 50 mm 2 inches and smaller located in contained pumphouses, contained truck offloads, contained truck fill stands, and other visibly contained areas the fitting may be forged (socket welded), Class 150, conforming to ASTM A105/A105M, Grade 2 and ASME B16.5. In pits, vaults, on thermal relief valve piping for pipeline routes, and other uncontained locations the flanges must be radiographicable, butt welded, weld neck type.

[ d. Piggable System

- (1) Provide barred tees on all branch outlets 50 mm 2-inch and larger when within 6.1 meters 20 feet of pig launcher or receiver barrel, including the barrels. Provide barred tees on all size outlets greater than 50 mm 2-inch in size with any part of the outlet on the bottom half of the pipe. Provide barred tees on all branch connections equal to or greater than 50 percent of piggable line size.
- (2) Use 1.5 D elbows, or 3 D sweeps between pig launchers and receivers. Do not place 1.5 D elbows back to back.

] e. Interior Epoxy Coating System must be applied to the fittings as specified in paragraph CARBON STEEL PIPING.

2.2.7.3 Stainless Steel Fittings

\*\*\*\*\*  
NOTE: Select option for piggable fitting if line is  
piggable.  
\*\*\*\*\*



- a. Fittings 65 mm 2.5 inches and Larger: Butt weld stainless steel conforming to ASTM A403/A403M, Class WP, Type 304L, seamless or welded, and ASME B16.9 of the same minimum wall thickness as the adjoining pipe. Welded fittings must be tested and inspected the same as the welded seam pipe and meet the same requirements as for the pipe.
- b. Fittings 50 mm 2 inches and Smaller: Forged Type 304 or 304L, butt weld, or socket welded (except flanges, see below). If specifically indicated on drawings, non-flange fittings may be threaded. Socket welded or threaded fittings must be Class 3000 conforming to ASTM A182/A182M and ASME B16.11. Threaded fittings must only be used for above grade applications. Underground and in pits, low point drain pipe, and high point vent pipe must be butt welded.
- c. Unions: Conforming to ASTM A182/A182M, Grade 304 or 316.

\*\*\*\*\*  
**NOTE: Type 304L stainless steel flanges are prohibited and must not be specified.**  
 \*\*\*\*\*

- d. Flanges. Class 150 weld neck, butt weld, forged Type 304 stainless steel flanges conforming to ASTM A182/A182M and ASME B16.5, except flange that are to be connected to pumps must match the pump flanges rating. Threaded and slip-on flanges are not allowed. Flanges to be 2mm 1/16-inch raised-face with modified spiral serrated gasket surface finish, except where required otherwise to match system components furnished. Flange face must be machined to match valves or system components furnished. Match flange face to valves or system components furnished. Flanges must be subjected to the Supplementary Requirements S56, Liquid Penetrant Examination as outlined in ASTM A961/A961M. Detectable flaws will not be acceptable. For flanges 50 mm 2 inches and smaller located in contained pumphouses, contained truck offloads, contained truck fill stands, and other visibly contained areas the fitting may be forged (socket welded), Class 150, conforming to ASTM A182/A182M and ASME B16.5. In pits, vaults, on thermal relief valve piping for pipeline routes, and other uncontained locations the flanges must be radiographable, butt welded, weld neck type.
- [ e. Piggable System:
  - (1) Provide barred tees on all branch outlets 50 mm 2-inch and larger when within 6 m 20 feet of pig launcher or receiver barrel, including the barrels. Provide barred tees on all size outlets greater than 50 mm 2-inch in size with any part of the outlet on the bottom half of the pipe. Provide barred tees on all branch connections equal to or greater than 50 percent of piggable line size.
  - (2) Use 1.5 D elbows, or 3 D sweeps between pig launchers and receivers. Do not place 1.5 D elbows back to back.
- ] f. Stainless Steel Tube Fittings. Flareless, 316 stainless steel fittings conforming to SAE J514.

#### [2.2.7.4 Steel Reinforced Flexible Pipe Fittings

End connections and mid-line connections for steel reinforced high density

polyethylene (HDPE) flexible pipe must be of stainless steel swaged onto the pipe ends.

End connections must terminate in either flanged or weld ends as indicated. Mid-line connections must terminate in flanged fittings if they are in a pit or double swage type if they are not.

#### ]2.2.8 Insulating Flange Kits (Electrically Isolating)

\*\*\*\*\*

NOTE: Use in the following locations to avoid affecting the underground piping cathodic protection system:

- a. Where piping transitions from aboveground to underground.
- b. Below drain and vent valves in underground pits and valve vaults.
- c. On both sides of motorized valves in underground valve vaults.

NOTE: Provide weatherproof lightning surge arrester around insulating flange kits where piping transitions from aboveground to underground.

NOTE: These gaskets are often installed to prevent corrosion between two flanges constructed of dissimilar metals such as carbon steel and stainless steel. Experience in even extremely corrosive marine environments shows them to be of little use in preventing flange to flange corrosion; the corrosion in those cases are usually the flange face and/or fasteners corroding to themselves. Before using to prevent flange to flange corrosion, contact Base Personnel and try and determine what kind of corrosion they have and how severe it is.

NOTE: Provide flange protectors where indicated and at cathodic protection isolating flanges.

\*\*\*\*\*

Provide **ASTM D229** electrical insulating material of 1,000 ohms minimum resistance or 500 Volts per mil (VPM) minimum dielectric strength; material must be resistant to the effects of aviation and non-aviation hydrocarbon fuels. Provide full face insulating gaskets between flanges. Provide full surface **0.75 mm 0.03-inch** thick wall thickness, spiral-wound mylar insulating sleeves between the bolts and the holes in flanges; bolts may have reduced shanks of a diameter not less than the diameter at the root of threads. Provide **3 mm 0.125-inch** thick high-strength phenolic insulating washers next to flanges and provide flat circular stainless steel washers over insulating washers and under bolt heads and nuts. Provide bolts **12 mm 0.5-inch** longer than standard length to compensate for the thicker insulating gaskets and the washers under bolt heads and nuts. Above grade flanges separated by electrically insulating flange kits must be provided with weatherproof **lightning surge arrester** devices. The surge arrester must bolt across flanges separated by insulating gasket kits per detail on contract drawings. Provide with flange protector as described

in this section. The arrestor must have the following features:

- a. Weatherproof NEMA 4 enclosure.
- b. Bidirectional and bipolar protection.
- c. Constructed of solid state components, no lights, fuses or relays and used without required maintenance or replacement.
- d. Withstand unlimited number of surges at 50,000 Amperes.
- e. Maximum clamping voltage of 700 Volts based on a [IEEE C62.41.2](#) 8x20 microsecond wave form at 50,000 Amperes peak measured at the device terminals (zero lead length).
- f. A UL listed arrestor for installation in Class 1, Division 1 and Division 2, Group D, hazardous areas.

Install the mounting bracket and leads on the flange side of the bolt insulating sleeve and washer, and size in accordance with this schedule:

Line Size	Bolt Size
50 mm 2 inch	16 mm 5/8 inch
65 mm 2.5 inch	16 mm 5/8 inch
80 mm 3 inch	16 mm 5/8 inch
100 mm 4 inch	16 mm 5/8 inch
150 mm 6 inch	19 mm 3/4 inch
200 mm 8 inch	19 mm 3/4 inch
250 mm 10 inch	22 mm 7/8 inch
300 mm 12 inch	22 mm 7/8 inch
350 mm 14 inch	25 mm 1 inch
400 mm 16 inch	25 mm 1 inch
Note: Make allowance for the 1 mm 1/32-inch thickness of the insulating sleeve around the bolts when sizing the mounting lugs.	

#### 2.2.9 Bolts, Nuts and Washers

- a. Bolts and nuts for pipe flanges, flanged fittings, valves and accessories must conform to [ASME B18.2.1](#) and [ASME B18.2.2](#), except as otherwise specified.
- b. Bolts must be of sufficient length to obtain full bearing on the nuts and must project no more than three full threads and no less than two full threads beyond the nuts with the bolts tightened to the required torque.
- c. Bolts must be regular hexagonal bolts conforming to [ASME B18.2.1](#) with material conforming to [ASTM A193/A193M](#), Class 2, Grade B8, stainless steel, when connections are made where a stainless steel flange is involved, and Grade B7, chromium molybdenum alloy, when only carbon

steel flanges are involved. Bolts and nuts chosen must have sufficient strength to seat gasket types chosen. Bolts must be threaded in accordance with ASME B1.1, Class 2A fit, Coarse Thread Series, for sizes 25 mm one-inch and smaller and Eight-Pitch Thread Series for sizes larger than 25 mm one-inch.

- d. Nuts must conform to ASME B18.2.2, hexagonal, heavy series with material conforming to ASTM A194/A194M, Grade 8, stainless steel for stainless steel bolts, and Grade 7, chromium molybdenum alloy for chromium molybdenum alloy bolts. Nuts must be threaded in accordance with ASME B1.1, Class 2B fit, Coarse Thread Series for sizes 25 mm one-inch and smaller and Eight-Pitch Thread Series for sizes larger than 25 mm one-inch.
- e. Provide washers under bolt heads and nuts. Use chromium molybdenum alloy washers dimensioned to ASTM F436 flat circular for chromium molybdenum bolts. Stainless steel washer dimensioned similar to ASTM F436 flat circular, use material the same as the bolt.
- f. Use torque wrenches to tighten all flange bolts to the torque recommended by the gasket manufacturer. Tight in the pattern recommended by the gasket manufacturer. Use anti-seize compound on stainless steel bolts.

#### 2.2.10 Flange Gaskets, Non-Metallic, Non-Electrically Isolating

ASME B16.21, composition ring, using a Nitrile Rubber such as Buna-N and NBR, polytetrafluoroethylene (PTFE), or a fluoro rubber such as FKM, FPM and Viton®. The gasket must be 3 mm 0.1250-inch thick. Gaskets must be resistant to the effects of aviation and non-aviation hydrocarbon fuels and manufactured of fire-resistant materials. Full-face gaskets must be used for flat-face flanged joints. Ring gaskets must be used for raised-face flanged joints. Gaskets must be of one piece factory cut. Select a gasket suitable for the working and test pressure of the fluid.

##### 2.2.10.1 Nitrile Butadiene (Buna-N)

Provide Buna-N material that conforms to SAE AMS3275.

##### 2.2.10.2 Acrylonitrile Butadiene Rubber (NBR)

Provide NBR material that conforms to SAE AMS3275.

##### 2.2.10.3 Polytetrafluoroethylene (PTFE)

Provide PTFE material that conforms to ASTM F336.

##### 2.2.10.4 Fluoro Rubber FKM

Provide FKM material that conforms to ASTM D1418.

##### 2.2.10.5 Fluoroelastomer FPM

Provide FPM material that conforms to ISO 1629.

#### 2.2.11 Flange Gaskets, Metallic

\*\*\*\*\*

**NOTE: Inner rings are mandatory for Class 900 and**

higher flanges.

\*\*\*\*\*

\*\*\*\*\*

**NOTE: Metallic Gaskets are not to be used where  
electrical isolation is required.**

\*\*\*\*\*

**ASME B16.20**, spiral-wound metal gaskets with [inner and] outer rings. Gaskets must be suitable for use on flat-face and raised-face flanges. The winding material is stainless steel 304 or 316L. The filler material is graphite or PTFE. The gasket must be in accordance with Military Specification MIL-G-24716. Select a gasket suitable for the working and test pressure of the fluid.

#### 2.2.12 Flange Protectors

\*\*\*\*\*

**NOTE: Provide at all cathodic protection isolation  
flanges from shorting out due to debris collecting  
in/on flange. Use the UV plastic type if possible  
as the stainless steel bands sometimes "ground out"  
the insulating flange.**

**Use in tropics and waterfront locations for all size  
flanges to minimize/prevent water migration between  
the flange faces and prevent corrosion.**

\*\*\*\*\*

Protectors must protect the bolts, studs, nuts, and gaskets of a flanged end connection from corrosion or damage due to exposure to the environment. Protectors must be weather and ultraviolet (UV) resistant. Protectors must allow for quick and easy removal and re-installation by maintenance personnel. Provide grease filled bolt caps. Corrosion Prevention grease must be non-expansive and designed for the service.[ Provide protectors that allow visual inspection of the flange gasket without requiring removal.][ For electrically insulating flange connections, provide protectors with grease fittings that allow the injection of grease into the flange cavity.]

#### 2.3 MANUAL VALVES

\*\*\*\*\*

**NOTE: Per Service Headquarters or officially  
designated alternate for marine environment, provide  
stainless steel valves on exterior (aboveground and  
in pits) piping.**

\*\*\*\*\*

\*\*\*\*\*

**NOTE: Select option for piggable valves if line is  
piggable.**

\*\*\*\*\*

All portions of a valve coming in contact with fuel in stainless steel pipelines or epoxy lined carbon steel pipelines must be of noncorrosive material. Valves in stainless steel pipelines or epoxy lined carbon steel pipelines must be Type 304 or Type 316 stainless steel or carbon steel internally plated with chromium or nickel or internally electroless nickel

plated. Valves in unlined carbon steel pipelines must have carbon steel body. Stem and trim must be stainless steel for all valves. Manually operated valves 150 mm 6 inches and larger must be worm-gear operated and valves smaller than 150 mm 6 inches must be lever operated or handwheel operated. Valves smaller than 50 mm 2 inches must have lever-type handles. Valves installed more than 2.4 m 8 feet above finished floor level. Sprocket wheel for chain operator must be aluminum.[ Valves in the piggable line flow path between the pig launchers and the pig receivers, including the valves in the isolation valve pits must be full bore, piggable, double block and bleed type. The full bore piggable valves at the launcher and the receiver must be ball type. Valves must be true full bore with no projections extending into the flow path of the pig train.]

### 2.3.1 Ball Valves

Ball valves must be fire tested and qualified in accordance with the requirements of API Std 607 and API STD 608. Seal material for the fire test must be graphite, seal material for the project must be as indicated below. Ball valves must be nonlubricated valves that operate from fully open to fully closed with 90-degree rotation of the ball. Valves 2 inches and larger must conform to applicable construction and dimension requirements of API Spec 6D, ANSI Class 150 and must have flanged ends. Valves 50 mm 2 inches and larger must conform to applicable construction and dimension requirements of API Spec 6D, ANSI Class 150 and must have flanged ends. The balls in valves 250 mm 10 inches and larger full port and 300 mm 12 inches and larger regular port and larger must have trunnion type support bearings. Except as otherwise specified or indicated, reduced port or full port valves may be provided at the Contractor's option. Balls must be solid, not hollow cavity.

#### 2.3.1.1 Materials

Ball must be stainless steel. Ball valves must have tetrafluoroethylene (TFE) or fluoroelastetomer (FKM), commonly referred to as Viton seats, body seals and stem seals. Valves 100 mm 4 inches and smaller must have a locking mechanism.

#### 2.3.1.2 V-Port Ball Valve

\*\*\*\*\*  
NOTE: Primarily used on Truck Offloading System to  
set minimum offload flow rate.  
\*\*\*\*\*

Valve must conform to requirements as specified for BALL VALVES paragraph in this section. Valve must be provided with characterized linear v-port for flow rate control, and with infinite position lever bracket with locking bolt for set position.

#### 2.3.1.3 Full Port Ball (DBBV) Valves for Piggable Lines

\*\*\*\*\*  
NOTE: Select option for piggable valves if line is  
piggable.  
\*\*\*\*\*

Required for piggable lines, and where indicated elsewhere. Ball valves

must be designed, manufactured, and tested to **API Spec 6D**, fire-safe and tested to **API Spec 6FA**, and **BS EN ISO 10497** (BS 6755, Part 2). Seal material for the fire test must be graphite, seal material for the project must be as indicated below. Valves must be trunnion-mounted with independent spring and hydraulically actuated, floating, single piston effect, self-relieving seat rings, with bi-directional sealing. Ball must be solid type with full through-conduit opening, suitable for passage of pipeline pigs. Stem must be anti-static, blow-out-proof design with o-ring seals and provided with an emergency sealant injection fitting. Valves must be 3-piece, bolted body design with raised-faced ANSI Class 150 flanged connections, equipped with body drain/bleed valve and vent fitting, and suitable for double block and bleed service in the closed and open positions. Valves must be all stainless steel construction, or carbon steel with stainless steel stem, and all wetted parts electroless nickel-plated. Valves must have nylon, devlon, or polytetrafluoroethylene (TFM) seat inserts, FKM B body, stem, and seat o-rings, with stainless steel and graphite body gaskets and graphite secondary stem seals. Valves located in vaults or pits must be equipped with actuator extensions.

#### 2.3.1.4 Electric Valve Actuator

Electric valve actuator must be as indicated for Plug (Double Block and Bleed) Valves, electric valve actuator.

#### 2.3.2 Plug (Double Block and Bleed) Valves

\*\*\*\*\*  
**NOTE: Select option for piggable valves if line is piggable.**  
\*\*\*\*\*

**API Spec 6D**, **API Spec 6FA**, ANSI Class 150, non-lubricated, resilient, double seated, trunnion mounted, tapered lift plug capable of two-way shutoff. Valve must have tapered plug of steel or ductile iron with chrome or nickel plating and plug supported on upper and lower trunnions. Sealing slips must be steel or ductile iron, with Viton seals which are held in place by dovetail connections. Valve design must permit sealing slips to be replaced from the bottom with the valve mounted in the piping. Valves must operate from fully open to fully closed by rotation of the handwheel to lift and turn the plug. Valves must have weatherproof operators with mechanical position indicators. Indicator shaft must be stainless steel. Minimum bore size must be not less than 65 percent of the internal cross sectional area of a pipe of the same nominal diameter unless bore height of plug equals the nominal pipe diameter and manufacturer can show equal or better flow characteristics of the reduced bore size design.[ Valves in the piggable line flow path between the pig launchers and the pig receivers, including the valves in the isolation valve pits, in fuel piping between the pig launchers and the pig receivers must be full bore, piggable. Valves must be true full bore with no projections extending into the flow path of the pig train. Full port plug valves in distribution piping must be provided with a **15 mm 1/2-inch** threaded body drain.]

##### 2.3.2.1 General

Valves in the operating tank suction and fill lines and the valves at the four valve manifold in the pump room in the tank fill lines must be provided with a factory-installed limit switch that is actuated by the valve closure. Tank fill line valve and four valve manifold limit

switches must be provided with one double pole double throw contacts or four single pole, double throw contracts, two for open, two for closed. Tank suction line valve limit switches must be provided with one double pole double throw contacts or four single pole, double throw contacts, for closed, and one single pole double throw contact or two single pole, double throw contacts for open. All components must be watertight and U.L. listed for Class I, Division 1, Group D hazardous areas.

#### 2.3.2.2 Valve Operation

Rotation of the handwheel toward open must lift the plug without wiping the seals and retract the sealing slips so that during rotation of the plug clearance is maintained between the sealing slips and the valve body. Rotation of the handwheel toward closed must lower the plug after the sealing slips are aligned with the valve body and force the sealing slips against the valve body for positive closure. When valve is closed, the slips must form a secondary fire-safe metal-to-metal seat on both sides of the resilient seal. Plug valves located in Isolation Valve Pits or vaults must be provided with handwheel extensions.

#### 2.3.2.3 Relief Valves

ANSI Class 150. Provide plug valves with automatic thermal relief valves to relieve the pressure build up in the internal body cavity when the plug valve is closed. Relief valves must open at 175 kPa 25 psi differential pressure and must discharge to the throat of, and to the upstream side, of the plug valve.

#### 2.3.2.4 Bleed Valves

ANSI Class 150, stainless steel body valve. Provide manually operated bleed valves that can be opened to verify that the plug valves are not leaking when in the closed position.

#### 2.3.2.5 Electric Valve Actuator

\*\*\*\*\*  
NOTE: Maximum available temperature ranges for a regular actuator is minus 30 degrees C to 70 degrees C minus 22 to 158 degrees F. A lower temperature rating than that will result in an actuator encapsulated in insulation making access top manual controls and the handwheel difficult.  
\*\*\*\*\*

The actuator, controls and accessories must be the responsibility of the valve-actuator supplier for sizing, assembly, certification, field-testing and any adjustments necessary to operate the valve as specified. The electric valve actuator must include as an integral unit the electric motor, actuator unit gearing, limit switch gearing, position limit switches, torque switches, drive bushing or stem nut, declutch lever, wiring terminals for power, remote control, indication connections and handwheel. The electrically actuated plug valve must be set to open and close completely in 30 to 60 seconds against a differential pressure of 2 MPa 275 psig. The actuator settings of torque and limit contacts must be adjustable. The valve actuator must be suitable for mounting in a vertical or horizontal position and be rated for 30 starts per hour. The valve actuator must be capable of functioning in an ambient environment temperature ranging from [\_\_\_\_\_] [minus 38 to 70 degrees C] [minus 22 to



158 degrees F].

- a. The electrical enclosure must be specifically approved by UL or Factory Mutual for installation in Class I, Division 1, Group D locations.
- b. The electric motor must be specifically designed for valve actuator service and must be totally enclosed, non-ventilated construction. The motor must be capable of complete operation at plus/minus 10 percent of specified voltage. Motor insulation must be a minimum NEMA Class F. The motor must be a removable subassembly to allow for motor or gear ratio changes as dictated by system operational requirements. The motor must be equipped with an embedded thermostat to protect against motor overload and also be equipped with space heaters. It must de-energize when encountering a jammed valve.
- c. The reversing starter, control transformer and local controls must be integral with the valve actuator and suitably housed to prevent breathing or condensation buildup. The electromechanical starter must be suitable for 30 starts per hour. The windings must have short circuit and overload protection. A transformer, if needed, must be provided to supply all internal circuits with 24 VDC or 110 VAC may be used for remote controls.
- d. The actuator gearing must be totally enclosed in an oil-filled or grease-filled gearcase. Standard gear oil or grease must be used to lubricate the gearcase.
- e. The actuator must integrally contain local controls for Open, Close and Stop and a local/remote three position selector switch: Local Control Only, Off, and Remote Control plus Local Stop Only. A metallic handwheel must be provided for emergency operation. The handwheel drive must be mechanically independent of the motor drive. The remote control capability must be to open and close. Rim pull to operate valve manually must not exceed 28 kg 80 pounds.
- f. Position limit switches must be functional regardless of main power failure or manual operation. Four contacts must be provided with each selectable as normally open or normally closed. The contacts must be rated at 5A, 120 VAC, 30 VDC.
- g. Each valve actuator must be connected to a PLC supplied by "others".
- h. The actuator must have a local display of position even when power has been lost.
- i. The actuator must be supplied with a start-up kit comprising installation instruction, electrical wiring diagram and spare cover screws and seals.
- j. The actuator must be performance tested and a test certificate must be supplied at no extra charge. The test should simulate a typical valve load with current, voltage, and speed measured.

### 2.3.3 Swing Check Valves

\*\*\*\*\*

**NOTE: Limited to 2-inch size and below. Used in underground PRT fill line.**

\*\*\*\*\*

Swing check valves must conform to **API STD 600**, regular type, ANSI Class 150 with flanged end connections. Discs and seating rings must be renewable without removing the valve from the line. The disc must be guided and controlled to contact the entire seating surface.

#### 2.3.4 Silent Check Valves

Spring assisted, wafer/tapped lug pattern, butterfly check with or globe type FKM or PTFE seat ring, designed to prevent flow reversal slamming of valve, dual plate, and must conform to **ASME B16.34**, **API Std 594**, except face to face dimensions may deviate from standard. Valves must be suitable for installation in any orientation. Valve body and trim material must be as previously indicated herein.

#### 2.3.5 Butterfly Valve with Fusible Link Operator

\*\*\*\*\*

**NOTE: Consult with Service Headquarters or officially designated alternate before using this valve. Not permitted on Air Force projects. There are specific locations this valve is to be used on Navy projects in accordance with UFC 3-460-01. The sole function of the valve is to provide a separate shutoff of the supply and return piping at each pantograph assembly in the event of a fire.**

\*\*\*\*\*

Valve must conform to **API Std 609**. Valve must meet the fire test requirements of **API Std 607**. Valve must be designed for bubble tight bidirectional shutoff service at operating conditions. Disc must be Type 304L or Type 316, stainless steel. Stem must be **ASTM A276/A276M** Type 416 or **ASTM A564/A564M** Type 630 stainless steel. Seal ring must be Teflon with metal backup. Stem seals must be capable of withstanding the rated pressure and temperature of the valve seat. Provide valves 6 inches and larger and valves at pump discharge with weatherproof gear operators with handwheel; other valves must have minimum 10 position throttling handles. Valve must have a fusible link type valve operator. The fusible link and spring assembly must close the valve automatically when the link material melts at **71 degrees C 165 degrees F** and lock the valve in the closed position. Spring assembly must be fully enclosed to ensure safety. Provide valve with flanged end connections independent of other flanged end connections provided on items such as system components, piping, piping components, or valves.

#### 2.3.6 Globe Valve

Valve must conform to **ASME B16.34**, Class 150.

### 2.4 THERMAL RELIEF VALVE

#### 2.4.1 Valve Material

Valves must have carbon steel bodies (stainless steel on stainless steel pipelines) and bonnets with stainless steel springs and trim. Valves must be Class 150 flanged end connections.

#### 2.4.2 Thermal Relief Valve (ASME Type)

Thermal relief valves must be the fully enclosed, spring loaded, angle pattern, single port, hydraulically operated type with plain caps, and must be labeled in accordance with ASME BPVC SEC VIII D1. Valve stems must be fully guided between the closed and fully opened positions. The valves must be factory-set to open at pressures indicated on the drawings. Operating pressure must be adjustable by means of an enclosed adjusting screw. The valves must have a minimum capacity of 20 GPM at 10 percent overpressure. Valves must have a replaceable seat. Relief valves that do not relieve to a zone of atmospheric pressure or tank must be a balanced type relief valve.

#### 2.4.3 Thermal Relief Valve (Balanced Type)

Thermal relief valves that do not relieve to a zone of atmospheric pressure or atmospheric tank must be a balanced type relief or regulator valve.

Thermal relief valves must be the fully enclosed, spring loaded, angle pattern, single port, fully balanced type (back pressure must not affect relief pressure) back pressure regulator/relief valve. Set valve at pressure indicated on drawings. Valve body must have 25 mm one-inch (minimum) raised face flange connections unless otherwise indicated. Orifice must have a minimum orifice size of 15 mm 0.500-inch in diameter. Valve must have bubble-tight piston and seat design with stainless steel piston and Viton seat. Valve must be selected for the nominal flow condition of: pass a minimum of [18] liters per minute [5] gallons per minute, at a differential pressure of [380] kilopascal [55] psig, with a nominal set pressure of [345] kilopascal [50] psig. Valve must be factory configured to open at required set pressure but must be field adjustable by means of an enclosed adjusting screw.

### 2.5 PIPING ACCESSORIES

#### 2.5.1 Flexible Ball Joints

\*\*\*\*\*  
NOTE: Indicate the location and details of each pipe expansion joint, amount of pipe movement, and pipe anchors on the drawings.  
\*\*\*\*\*

Flexible ball joints must be [stainless steel] [carbon steel with electroless nickel-plating to a minimum of 0.075 mm 3 mils thickness], capable of 360-degree rotation plus 15-degree angular flex movement, ASME B16.5, Class 150 flanged end connections. Provide pressure molded composition gaskets designed for continuous operation temperature of 135 degrees C 275 degrees F. Joints must be designed for minimum working pressure of ANSI Class 150. Injectable packing will not be allowed.

#### 2.5.2 Bellows Expansion Joints for Axial Movement

\*\*\*\*\*  
NOTE: Indicate the location and details of each pipe expansion joint, amount of pipe movement, and pipe anchors on the drawings.

Where joints are to be installed on piers or

anywhere in direct contact with salt water is a possibility, then require the bellows to be constructed of inconel.

\*\*\*\*\*

The expansion joints must be for axial compression and extension with capacity as per the design documents. Units must be of the externally pressurized design with internal and external integral guides and manufactured by an Expansion Joint Manufacturers Association certified manufacturer. They must incorporate multi-ply, Lo-corr bellows of [ASTM A240/A240M, 321/304 stainless steel] or [Inconel 625] if chlorides are present in the atmosphere. Unit must be equipped with travel limit stops, and internal guides vented to reduce the effects of sudden pressure changes. Flanges and housing must be stainless steel or carbon steel to match piping materials. Flanges must conform to ASME B16.5. Dual Expansion Joints must incorporate an intermediate anchor base. Housing must include lifting lug and drain port. Joints must be capable of 10,000 cycles over a period of 20 years.

Cold set joints to compensate for the temperature at the time of installation. Provide initial alignment guides on the connecting piping no more than 4 pipe diameters from the expansion joint. Provide additional alignment guides on the connecting piping no more than 14 pipe diameters from the first guide.

#### 2.5.3 Mechanically Adjustable Segmented Elastomeric Seal

Mechanically adjustable segmented elastomeric seals must be constructed of fuel resistant Buna-N elastomers and Type 316 stainless steel fasteners and hardware.

#### 2.5.4 Pipe Sleeves

Pipe sleeves must be installed where indicated and at all points where the piping passes through concrete construction. Such sleeves must be of sufficient inside diameter to provide a minimum clear distance between the pipe and the sleeve of 13 mm 1/2-inch. Sleeves through concrete pits or slabs must be standard weight carbon steel pipe with a protective coating. Each sleeve must extend through the respective pit wall or slab and must be provided with a wrap around Buna-N end seal (boot). (Viton when exposed to sunlight) and secured to the pipe sleeve and piping with adjustable stainless steel hose clamps. Sleeves where piping passes under roads or piping indicated to be double walled must be standard weight carbon steel pipe with a protective coating as previously specified. Alignment of the sleeve and piping must be such that the pipe is accurately centered within the sleeve by a nonconductive centering element. The sleeve must be securely anchored to prevent dislocation. Closure of space between the pipe and the pipe sleeve must be by means of a mechanically adjustable segmented elastomeric seal. The seal must be installed so as to be flush.

#### 2.5.5 Strainers

##### 2.5.5.1 Basket Type

\*\*\*\*\*

NOTE: Provide 4-basket type at receipt line when that line is receiving fuel: from a interterminal pipeline, from a installation pipeline from Bulk

Storage, from a marine receipt (barge or ship), and all other applications when receipt of fuel with large amounts of particulates is expected.

Provide single basket strainer when relatively clean fuel is expected.

Arrange two strainers in duplex fashion when relatively dirty fuel is expected.

\*\*\*\*\*

Strainer must be [single][ multi (four)] basket type arranged in a [simplex][duplex] configuration as indicated in compliance with MIL-PRF-13789, except as specified otherwise. Strainer end connections must be designed in accordance with ASME B16.5, Class 150. Strainer body material must be the same as the material specified for manual valves. Strainers must have removable baskets of [7][40][60][100][\_\_\_\_\_] mesh wire screen with larger wire mesh reinforcement; wire must be stainless steel, Type 316. Pressure drop for clean strainer must not exceed 21 kPa 3 psig at maximum design flow rate. The ratio of net effective strainer area to the area of the connecting pipe must be not less than three to one. Each strainer must be provided with a suitable drain at the bottom, equipped with a ball valve. The strainer must be equipped with a direct-reading, piston type differential pressure gauge that measures the differential pressure across the basket as perin accordance with Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT).

#### 2.5.5.2 Cone Type

Strainer must be stainless steel type 304 or 316, [7][40][60][100][\_\_\_\_\_] 100 mesh screen with the ratio of net open area of strainer to the area of the connecting pipe must be not less than three to one at the pump suction. Pump suction strainer must have a [7][40][60][100][\_\_\_\_\_]100 mesh screen with not less than 300 percent open area (ratio of the strainer open area to the cross section of pipe).

#### 2.5.6 Thermometer

\*\*\*\*\*

**NOTE: Used for Burner Fuels Oils and Lubricating Oils that require heating before pumping. Indicate the scale range for each thermometer on the drawings.**

\*\*\*\*\*

Analog, dial-type bimetallic actuated type that conforms to ASME B40.200. Thermometer must have a 125 mm 5 inches diameter dial, a hermetically sealed stainless steel case, a stainless steel stem, a safety glass face, a fixed threaded connection, and a scale range as indicated. Thermometer accuracy must be within one percent of the scale range.

#### 2.5.7 Pressure Gauge

See Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT).

#### 2.5.8 Pipe Supports

\*\*\*\*\*

**NOTE: Indicate installation details (including anchorage and spacing) of all supports on the**

drawings. Include applicable seismic zone design requirements.

For waterfront and projects in the tropics with condensing chloride environments, select galvanized options.

\*\*\*\*\*

#### 2.5.8.1 General

Pipe supports must conform to [MSS SP-58](#). Design pipe supports to meet the applicable requirements of ANSI/[ASME B31.3](#) or ANSI/ASME B31.4. Provide hot-dip galvanized finish on rods, nuts, bolts, washers, and supports.[ Provide Type 316 stainless steel nuts, bolts, washers, and screws when located at a pier.] Provide miscellaneous metal that conforms to [ASTM A36/A36M](#), standard mill finished structural steel shapes, hot-dipped galvanized.[ Provide galvanizing in accordance with [ASTM A123/A123M](#), [ASTM A153/A153M](#), [ASTM A653/A653M](#) or [ASTM A924/A924M](#), Z275 G90.]

#### 2.5.8.2 Adjustable Pipe Supports

Adjustable pipe supports must consist of a cast iron saddle and a threaded nipple connected to a carbon steel pipe by means of a special reducer conforming to [MSS SP-58](#). The supports must be provided with PTFE insulation strips.

#### 2.5.8.3 Low Friction Supports

Supports must have self-lubricating anti-friction bearing elements composed of 100 percent virgin tetrafluoroethylene polymer and reinforcing aggregates, prebonded to appropriate backing steel members. The coefficient of static friction between bearing elements must be 0.06 from initial installation for both vertical and horizontal loads and deformation must not exceed [51 micrometers 0.002-inch](#) under allowable static loads. Bonds between material and steel must be heat cured, high temperature epoxy. Design pipe support elements for the loads applied. Provide anti-friction material with a minimum of [2.3 mm 0.09-inch](#) thick. Provide hot-dipped galvanized steel supports. Provide supports that are factory designed and manufactured.

#### 2.5.8.4 U-bolt Half Round Supports

Supports must have anti-friction bearing half-round in contact with the bottom of the pipe. Provide Polytetrafluoroethylene or like hydrophobic, anti-corrosive material half-round with a compressive strength of at least [69 mPa 10 ksi](#) or greater as required. U-bolts must be installed in either a loose or limited guide configuration as indicated on the design drawings. Provide hot-dip galvanized u-bolts with seamless non-metallic low friction coating. U-bolt connection must be double nutted on the bottom and single bolted on top.

#### 2.5.8.5 Concrete and Grout

Concrete and grout for anchors and supports must comply with Section [03 30 00](#) CAST-IN-PLACE CONCRETE.

#### 2.5.9 Sample Connections

- a. Sample connections must be factory assembled units specifically

designed for obtaining representative samples from fuel pipelines. Each connection must include a 6 mm 1/4-inch sampling probe where the probe faces upstream, ball valve and 6 mm 1/4-inch quick disconnect coupling with dust plug, all assembled into a unit that is suitable for installation in a pipe nipple. The sampling probe must extend not less than 25 mm one-inch into the fuel pipe. All materials in the sample connections must be stainless steel or aluminum.

- b. Furnish two sampling hose assemblies to the Contracting Officer at the project site. Each assembly must consist of a 1.8 m 6-foot length of 6 mm 1/4-inch clear plastic tubing with internal bonding/grounding wire. One end of the tubing will contain a male connector that actuates flow when inserted into the quick disconnect coupler. Each end of the bonding/grounding wire must be equipped with clips for attaching to the pipe and metal sample container.

#### [2.5.10 Sight Flow Indicators

\*\*\*\*\*  
**NOTE: Sight flow indicators are seldom used as they tend to leak when subjected to cyclic pressure spikes. Do not use without permission of the Service Headquarters or officially designated alternate.**  
\*\*\*\*\*

Sight flow indicators must be ANSI Class 150 and must have flanged end connections. Sight flow indicators must consist of a housing containing a rotating propeller that is visible through a glass observation port. The housing must be stainless steel when installed in stainless steel lines and carbon steel when installed in carbon steel lines. The glass in the indicator must also meet the Class 150 rating.

#### ]2.6 PIGGING SYSTEM COMPONENTS

\*\*\*\*\*  
**NOTE: Select option for piggable system components if line is piggable.**  
\*\*\*\*\*

##### 2.6.1 Maintenance Pig Launchers and Receivers

Construct of the same materials as the pipe, valves and fittings for a Class 150 system. The length of the straight barrel and the line size section must be 1.5 meters 5 feet each. Provide associated launcher kicker piping and receipt bypass piping, not less than 80 mm 3-inch in size for 150 mm 6-inch lines and 100 mm 4-inch for up to 250 mm 10-inch and 150 mm 6-inch for up to 350 mm 14-inch pipelines.

##### 2.6.2 Smart Pig Launchers and Receivers

Construct of the same materials as the pipe, valves and fittings for a Class 150 system. The length of the straight barrel and the line size section must each be 4.5 meter 15-feet. Provide associated launcher kicker piping and receipt bypass piping, not less than 80 mm 3-inch in size for 150 mm 6-inch lines and 100 mm 4-inch for up to 250 mm 10-inch and 150 mm 6-inch for up to 350 mm 14-inch pipelines.

### 2.6.3 Launcher and Receiver Closure Door

The closure must be hinged, swing bolted closure of the same material as the pipe and for a Class 150 system. Gasket must be nitrile or viton. Eye bolts must be pinned to lugs on the hub.

### 2.6.4 Signaler

\*\*\*\*\*  
**NOTE: Units suitable for removal under pressure are expensive and are not needed if they are serviced after the pig is launched or received. Consider their use before specifying.**  
\*\*\*\*\*

The pig signaler must be mechanical flag type with manual reset, and be located on the pig launcher and the pig receiver. Material in contact with the fuel must be stainless steel. Units must be suitable for removal and installation under line pressure of 1.90 mPa 275 psig. Signaler must be capable of withstanding line pressure of a Class 150 system.

### 2.7 FLEXIBLE HOSE CONNECTORS

Flexible hoses connectors for fueling pumps must have ANSI Class 300 or 150 flanges to mate directly to the pump and Class 150 flanges to the system flanges. Flanges must be stainless steel and must conform to ASME B16.5. These units must have an inner stainless steel or Inconel, corrugated tube with external stainless steel braid, and all components must be rated for not less than 1.90 mPa 275 psig at 37 degrees C 100 degrees F. Face to Face dimension must be as recommended by the manufacturer. Use Inconel 625 inner bellows in coastal environments or where chlorides are present in the atmosphere.

For sizes larger than 150 mm 6 inches, connectors must incorporate the use of Lo-corr, multi-ply bellows, without external braid, with bellows rating of 300 psig and overall rating consistent with the flange ANSI class. Flanges must be plate type, Vanstone design, with axial movement control rods.

Fabricate piping to measurements established on the project site and position into place without springing or forcing. Make provisions for absorbing expansion and contraction without undue stress in any part of the system. The use of flexible connectors in permanently mounted pump suction and discharge lines as a method of compensating for piping misalignment is not acceptable.

### 2.8 AUTOMATIC AIR VENT

Unit must have 25 mm one-inch connections and automatically vent air under pressure, and prevent a vacuum when pressure drops below a positive pressure. As fuel fills the vent, a float must rise and form a drip-tight closure. The unit pressure rating must be a minimum of 2 MPa 275 psi. The float must be stainless steel. Body and cover be carbon steel or ductile iron and be internally epoxy coated.

### 2.9 SURGE SUPPRESSOR TANK AND VALVE

\*\*\*\*\*  
**NOTE: Seldom used device, typically on truck**  
\*\*\*\*\*



fillstands that are located a very long way from the pump house on a dead end line. Seek guidance from the Service Headquarters or officially designated alternate.

\*\*\*\*\*

The unit must be fabricated from carbon steel, internally coated pressure vessel with a rubber bladder or a stainless steel diaphragm separating the fuel from the gas charge. The epoxy coating must be in accordance with MIL-PRF-4556. The rubber bladder must be molded synthetic nitrile rubber (Buna-N). The unit must be constructed and labeled in accordance with ASME BPVC SEC VIII D1. The housing must be designed for a working pressure of 2 MPa 275 PSIG. The gas precharge must be dry nitrogen and must have a pressure gauge, gas valve, and an adapter for field charging. Bladder precharge pressure must be 550 KPa 80 PSIG [\_\_\_\_\_]. The connection to the piping system must be Class 150 ANSI flange, size as indicated on the drawings. The connection must have a check valve to provide unrestricted flow into the vessel and restricted flow from the vessel. The flange must have a 13 mm 1/2-inch NPT connection with a valve and adapter to relieve fluid pressure during gas recharging and to drain the vessel during removal. A charging assembly must be provided. The surge suppressor supplier must furnish a service person trained to provide installation check-out assistance and to supervise operation and testing necessary to place the surge control system into service and to provide training on charging, recharging, and checking the surge suppressor.

## 2.10 MISCELLANEOUS ACCESSORIES

### 2.10.1 Concrete Anchor Bolts

Concrete anchors must conform to ASTM A307, Grade C, hot-dipped galvanized.

### 2.10.2 Coatings for Bolts, Studs, Nuts, and Washers

Carbon steel bolts, studs, nuts, and washers must be provided with a factory applied [cadmium coating that conforms to ASTM B696 or ASTM B766] [hot-dipped zinc coating that conforms to ASTM F2329].

### 2.10.3 Polytetrafluoroethylene (PTFE) Tape

Tape must conform to ASTM D3308.

### 2.10.4 Pipe Sleeves

Provided sleeves constructed of [hot-dipped galvanized steel, ductile iron, or cast-iron pipe] [uncoated carbon steel pipe] conforming to ASTM A53/A53M, [Schedule 30] [Schedule 20] [Standard weight].

### 2.10.5 Escutcheon

Escutcheon must be the chrome plated, stamped steel, hinged, split ring type. Inside diameter must closely fit pipe outside diameter. Outside diameter must completely cover the corresponding floor, wall, or ceiling opening. Provided each escutcheon with necessary set screws.

### 2.10.6 Pipe Casings

\*\*\*\*\*

**NOTE: Cased pipe crossings must be specifically**

designed for the purpose, including depth of burial versus pipe wall thickness calculations using API criteria and pipe wall thickness required for installation method (such as jack and bore). Appropriate exterior coatings must be considered for the casing. Casings must be designed to be isolated from the piping cathodic protection system, and include a test station for confirmation testing of isolation between pipeline and casing. Project drawings must fully detail method of centering pipe in casing, use of casing segmented seals, and boot to protect the segmented seal from soil backfill.

\*\*\*\*\*

Provide carbon steel casings in accordance with paragraph MATERIALS. Provide coating in accordance with Section 33 52 80 LIQUID FUELS PIPELINE COATING SYSTEMS. Alignment of the casing and piping must be such that the pipe is accurately centered within the sleeve by a nonconductive centering device specifically manufactured for the purpose. Closure of space between the pipe and the casing must be by means of a mechanically adjustable segmented elastomeric seal. The casing must be provided with a wraparound Buna-N end seal (boot), (Viton when exposed to sunlight) and be secured to the piping with adjustable stainless steel hose clamps. Sleeves where piping passes under roads must be not less than standard weight carbon steel pipe with a protective coating. Provide cathodic test station, leads and bonding to the pipe and casing such that the isolation between the casing and piping CP system can be verified.

#### 2.10.7 Buried Utility Tape

Provide detectable aluminum foil plastic-backed tape or detectable magnetic plastic tape for warning and identification of buried piping. Tape must be detectable by an electronic detection instrument. Provide tape in minimum 75 mm 3 inches width rolls, color coded for the utility involved, with warning identification imprinted in bold black letters continuously and repeatedly over entire tape length. Warning identification must be at least 25 mm one-inch high and must state as a minimum "BURIED JET FUEL PIPING BELOW". Provide permanent code and letter coloring that is unaffected by moisture and other substances contained in trench backfill material.

#### 2.10.8 Pipeline Markers

Provide pipeline markers constructed of 150 mm 6 inches diameter, one-half inch thick bronze disk with a 75 mm 3-inch long bronze headed bolt welded to the back of the disk. Engrave the front of the disk with the words "UNDERGROUND FUEL LINE" in the case of one line and "UNDERGROUND FUEL LINES" in the case of multiple fuel lines.

### 2.11 FINISHES

#### 2.11.1 Factory Coating

##### 2.11.1.1 Valves

Valve surfaces must be blasted clean according to SSPC SP 5/NACE No. 1. Valve surfaces must be primed and coated in accordance with Section 09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES.

#### 2.11.1.2 Equipment and Components

\*\*\*\*\*

**NOTE:** For all Navy projects (regardless of location), the 500 hour salt spray test is required and must be specified.

For Army projects, a salt spray test is optional. The 125 hour test is suggested for mild or noncorrosive environments. The 500 hour test is suggested for extremely corrosive environments.

\*\*\*\*\*

Unless otherwise specified, provide equipment and components fabricated from ferrous metal with the manufacturer's standard factory finish. [ Each factory finish must withstand [125] [500] hours exposure to the salt spray test specified in [ASTM B117](#). For test acceptance, the test specimen must show no signs of blistering, wrinkling, cracking, or loss of adhesion and no sign of rust creepage beyond 3 mm 1/8-inch on either side of the scratch mark immediately after completion of the test.] For equipment and component surfaces subject to temperatures above 50 degrees C 120 degrees F, the factory coating must be appropriately designed for the temperature service.

#### 2.11.2 Field Painting

\*\*\*\*\*

**NOTE:** Specify exterior, aboveground coatings per Section [09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES](#) if SSPC QP 1 contractor certification is required for any other coatings on the project. If Section [09 90 00 PAINTS AND COATINGS](#) is specified, consider choosing the option for the contractor to be certified to SSPC QP 1, as certified contractors are likely to have more experience working around fuel facilities.

\*\*\*\*\*

Painting required for surfaces not otherwise specified must be field painted as specified in [Section [09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES](#)][Section [09 90 00 PAINTS AND COATINGS](#)]. Do not paint aboveground stainless steel and aluminum surfaces. Do not coat equipment or components provided with a complete factory coating. Hot dip galvanized pipe support steel must not receive the Zinc-Rich Epoxy Primer Coat only the Epoxy Intermediate Coat and Polyurethane Topcoat must be applied to these surfaces. Prior to any field painting, clean surfaces to remove dust, dirt, rust, oil, and grease.

### PART 3 EXECUTION

\*\*\*\*\*

**NOTE:** Specify as directed by the Service Headquarters or officially designated alternate.

\*\*\*\*\*

#### 3.1 GENERAL

Installation, workmanship, fabrication, assembly, erection, examination, inspection, and testing must be in accordance with [ASME B31.3](#) and [NFPA 30](#),

except as modified herein. Safety rules as specified in NFPA 30 and NFPA 407 must be strictly observed. Never direct bury threaded connections, socket welded connections, unions, flanges, valves, air vents, or drains. Install all work so that parts requiring periodic inspection, operation, maintenance, and repair are readily accessible.

### 3.2 VERIFICATION OF DIMENSIONS

After becoming familiar with details of the work, verify dimensions in the field, and advise the Contracting Officer of any discrepancy before performing any work.

### 3.3 CLEANING OF PIPING

Keep the interior and ends of all new piping, affected by construction operations, thoroughly cleaned of foreign matter and water before and after being installed. Piping systems must be kept clean during installation by means of plugs or other approved methods. When work is not in progress, open ends of piping and fittings must be closed so that no water or other foreign substance will enter the pipes or fittings. Piping must be inspected before placing into position. The interior of each length of pipe must be cleaned after welding ensuring that the interior of the piping is free of foreign matter when it is connected into the system.

### 3.4 TRENCHING AND BACKFILLING

Trenching and backfilling must conform to Section 31 00 00 EARTHWORK, and the following bedding and backfill requirements. The pipe must be laid in a bed of sand 150 mm 6 inches deep, compacted in accordance with Section 31 00 00 EARTHWORK, paragraph BACKFILLING AND COMPACTION. Sand must meet the requirements of Section 31 00 00 EARTHWORK, paragraph SELECT GRANULAR MATERIAL. The full length of each section of pipe without any protective covering must be excavated to permit installation of the protective covering. Pipe that has the grade or joint disturbed after laying, must be taken up and relaid. Pipe must not be laid in water or when the trench or weather conditions are unsuitable for such work. After testing and application of protective covering to joints, sand backfill must be placed and compacted around the pipe or protective coating to a depth of 300 mm one foot above top of pipe. The remainder of the backfill must be the same as for other types of pipe.

### 3.5 PIPING LAYOUT REQUIREMENTS

#### 3.5.1 Pipe Fabrication

Fabricate piping to measurements established on the project site and position into place without springing or forcing. Make provisions for absorbing expansion and contraction without undue stress in any part of the system. The use of flexible connectors in permanently mounted pump suction and discharge lines as a method of compensating for piping misalignment is not acceptable.

#### 3.5.2 Interferences and Measurements

Provide offsets, fittings, and accessories required to eliminate interferences and to match actual system components connection locations and arrangements. Verify measurements before commencing work. Submit discrepancies for clarification before proceeding with the installations

to the Contracting Officer.

### 3.5.3 Space and Access

Keep piping, control tubing, which is not detailed close to structures and columns so as to take up a minimum amount of space. Ensure that access is provided for maintenance of system components, valves and gauges.

### 3.5.4 Location

Do not place unions in locations that will be inaccessible after the completion of the work. Place unions on each side of equipment.

### 3.5.5 Pipe Supports

Where provided hot dip galvanized pipe support steel must be surface prepped to SSPC SP 16, Brush-Off Blast Cleaning of Coated and Uncoated Galvanized Steel, Stainless Steels, and Non-Ferrous Metals. Once the steel is prepped, apply only the Epoxy Intermediate Coat and Polyurethane Topcoat per manufacturer's instructions.

Provide pipe supports with the maximum spacing as defined in Table 1 below, unless otherwise indicated. At the indicated locations. Provide additional pipe supports at concentrated piping loads (valves).

Table 1. Maximum Support Spacing									
Nominal Pipe Size (mm) (Inches)	25 mm one-inch and under	40 mm 1.5-in	50 mm 2-in	80 mm 3-in	100 mm 4-in	150 mm 6-in	200 mm 8-in	250 mm 10-in	300 mm 12-in
Maximum Support Spacing (m) (ft)	2 m 7-ft	2.75 m 9-ft	3 m 10-ft	3.5 m 12-ft	4.25 m 14-ft	5 m 17-ft	5.75 m 19-ft	6.50 m 22-ft	7 m 23-ft

Provide anchors where required to absorb or transmit thrust or eliminate vibration or pulsation. Provide supports near each change of direction. Select support components which do not restrict the movement of the pipe due to thermal expansion. Space supports uniformly and arrange symmetrically.

### 3.5.6 Structural Support

Provide supplementary or intermediate steel or other structural members as required for transmission of loads to members forming part of the supporting structure. Piping must not be supported from other piping.

### 3.5.7 Grade

Where profiles of piping lines are shown on the drawings, grade the line uniformly between changes in slope or direction. Maintain gradient to within 6 mm 1/4-inch over the entire length of pipe. When backfilling has been completed to the top of the pipe, the pipe must be surveyed at each joint, and logged by station number. Submit to the Contracting Officer for approval the survey final elevations before backfilling can continue.

### 3.5.8 Size Changes

Make changes in pipe size with reducing fittings. Do not use bushings. Make branch connections with butt-welded tees except where the branch is at least two pipe sizes smaller than the run, in which case the branch connection can be made with a forged or seamless branch outlet fitting. The branch outlet fitting must be designed in such a way that the connection can be radiographed. The branch outlet fittings may be a non-radiographicable if: the piping it is connected to is aboveground, the branch outlet size is 65 mm 2.5 inches or less in diameter, and the branch outlet is located either in a pump house or on a system component pad equipped with containment curb.

### 3.5.9 Direction Changes

Make changes in direction of pipes with 1.5 D fittings. Where piping is to be piggable, make changes in direction with 1.5 D fittings [and][or] 3 D sweeps as indicated. For piggable pipelines, do not place 1.5 D fittings back to back. Provide special fittings when required. Make odd-angle offsets with pipe bends or elbows cut to the proper angle. Make changes in direction with fittings, except that bending of pipe 100 mm 4 inches and smaller will be permitted, provided a pipe bender is used and wide sweep bends are formed. Mitering or notching pipe or other similar construction to form elbows or tees will not be permitted. The centerline radius of bends must not be less than 6 diameters of the pipe if a pipe bender is used.

### 3.5.10 Threaded End Connections

\*\*\*\*\*  
NOTE: As stated previously, avoid threaded end connections if possible. Threaded end connections may be used in certain aboveground applications if specifically indicated on the drawings. As stated previously, never require a threaded end connection to be direct buried.  
\*\*\*\*\*

Provide threaded end connections only on piping 50 mm 2 inches in nominal size or smaller and only where indicated on the drawings. Provide threaded connections with PTFE tape or equivalent thread-joint compound applied to the male threads only. Not more than three threads must show after the joint is tightened.

### 3.5.11 Existing Pipe Systems

\*\*\*\*\*  
NOTE: Delete this paragraph if connections to existing piping systems are not required. Indicate on the drawings the approximate location of each connection point between new and existing piping systems.  
\*\*\*\*\*

No interruptions or isolation of an existing fuel handling service or system may be performed unless the actions are appropriately documented in the approved work plan. Perform initial cutting of existing fuel pipe with a multiwheel pipe cutter, using a nonflammable lubricant. After cut is made, seal interior of piping with a gas barrier plug. Refer to

API RP 2009 and API RP 2200. Purge interior of piping with carbon dioxide or nitrogen prior to performing any welding process.

#### 3.5.12 Bolted Connections

For each bolted connection of stainless steel components (e.g., pipes, piping components, valves, and system components) use stainless steel bolts or studs, nuts, and washers. For each bolted connection of carbon steel components, use carbon steel bolts or studs, nuts, and washers. Bolts project no more than three full threads and no less than two full threads beyond the nuts with the bolts tightened to the required torque. Prior to installing nuts, apply a compatible anti-seize compound to the male threads.

#### 3.5.13 Flanges and Unions

Except where threaded end connections [and][or] unions are indicated, provide flanged joints in each line immediately preceding the connection to system components or material requiring maintenance such as pumps, general valves, control valves, strainers, and other similar items and as indicated. Assemble flanged joints square and tight with matched flanges, gaskets, and bolts.

#### 3.5.14 Flange Protector

\*\*\*\*\*  
**NOTE: See Note on FLANGE PROTECTORS paragraph in this section.**  
\*\*\*\*\*

Provide flange protectors [on each electrically insulating flange connection][on each flanged end connection, including valves and system components][where indicated on the drawings]. [ Fill the flange cavity of electrically insulating flange connections with a corrosion inhibitor type grease.] Provide grease filled bolt caps.

#### 3.5.15 Manual Valves

\*\*\*\*\*  
**NOTE: Show on the drawings double block and bleed plug valves installed upstream of each pump strainer as well as downstream of each filter separator control valve.**  
\*\*\*\*\*

Install isolation plug or ball valves on each side of each system equipment, at the midpoint of looped mains, and at any other points indicated or required for draining, isolating, or sectionalizing purpose. Install valves with stems vertically up unless otherwise indicated. Provide individual supports and anchors for each valve.

#### 3.5.16 Air Vents

Provide [\_\_\_\_\_] [40 mm] [1-1/2 inches] air vents at all high points and where indicated to ensure adequate venting of the piping system.

#### 3.5.17 Drains

Provide [\_\_\_\_\_] [50 mm] [2 inches] drains at all low points and where

indicated to ensure complete drainage of the piping. Drains must be schedule 120.

#### 3.5.18 Bellows Expansion Joints

Cold set joints to compensate for the temperature at the time of installation. Provide initial alignment guides on the connecting piping no more than 4 pipe diameters from the expansion joint. Provide additional alignment guides on the connecting piping no more than 14 pipe diameters from the first guide.

#### 3.5.19 Thermometers

Provide thermometers with separable sockets. Install separable sockets in pipelines in such a manner to sense the temperature of flowing fluid and minimize obstruction to flow.

#### 3.5.20 Pipe Sleeves

Provide a pipe sleeve around any pipe that penetrates a wall, floor, or slab. Do not install sleeves in structural members except where indicated or approved. Install pipe sleeves in masonry structures at the time of the masonry construction. Sleeves must be of such size as to provide a minimum of 12 mm 1/2-inch all-around clearance between bare pipe and the sleeve. Align sleeve and piping such that the pipe is accurately centered within the sleeve by a nonconductive centering element. Securely anchor the sleeve to prevent dislocation. Closure of the space between the pipe and the pipe sleeve must be by means of a mechanically adjustable segmented elastomeric seal. The seal must be installed so as to be flush. For wall or floor penetrations, extend each sleeve through its respective wall or floor and cut flush with each surface. Seal around sleeves that penetrate through valve or fuel related pits with a Buna-N casing seal. Seal around sleeves that penetrate through non-fire-rated walls and floors in accordance with Section 07 92 00 JOINT SEALANTS. Seal around sleeves that penetrate through fire-rated walls and floors as specified in Section 07 84 00 FIRESTOPPING.

#### 3.5.21 Escutcheons

Except for utility or equipment rooms, provide finished surfaces where exposed piping pass through floors, walls, or ceilings with escutcheons. Secure escutcheon to pipe or pipe covering.

### 3.6 SEISMIC REQUIREMENTS

\*\*\*\*\*  
**NOTE: Include applicable seismic design requirements on the drawings. Delete this paragraph if there are no specific seismic design requirements.**  
\*\*\*\*\*

Support and brace piping and attach valves to resist seismic loads as specified under Sections 13 48 73 SEISMIC CONTROL FOR MISCELLANEOUS EQUIPMENT[, 22 05 48.00 20 MECHANICAL SOUND, VIBRATION, AND SEISMIC CONTROL] and as shown on the drawings. Structural steel required for reinforcement to properly support piping, headers, and system components but not shown must be provided under this section. Material used for support must be as specified under Section 05 12 00 STRUCTURAL STEEL.



### 3.7 STRUCTURAL ATTACHMENTS

Provide attachment to building structure concrete and masonry by cast-in concrete inserts, built-in anchors, or masonry anchor devices. Apply inserts and anchors with a safety factor not less than 5. Do not attach supports to metal decking. Construct masonry anchors for overhead applications of ferrous materials only. Structural steel brackets required to support piping, headers, and system components, but not shown, must be provided under this section. Material used for support must be as specified under Section 05 12 00 STRUCTURAL STEEL.

### 3.8 WELDING

#### 3.8.1 General

All joints, unless indicated otherwise, in carbon steel and stainless steel piping systems must be welded. Do not weld carbon steel to stainless steel. Welding of fuel pipe joints must comply with Section 33 52 23.15 POL SERVICE PIPING WELDING.

### 3.9 INSTALLATION

#### 3.9.1 Precautions

Take special care to ensure that the protective coating on buried pipe is not damaged during installation and that the completed system is free of rocks, sand, dirt, water, weld slag, and foreign objects including construction debris. Take the following steps to ensure these conditions.

- a. Coated pipe must be handled only with canvas or nylon slings or padded clamps. Any coating damaged by improper handling or storage must be repaired as specified.
- b. Pipe brought to the site must be stored on blocks or horses at least 450 mm 18 inches above the ground and adequately supported to prevent sagging. Padded blocks or horses must be used for coated pipe. The method and height of storing coated pipe must be in accordance with the coating manufacturer's instructions. Pipe ends must be protected and capped against weather at all times, except to accommodate immediate installation.
- c. Visual inspection must be made of the inside of each length of pipe to ensure that it is clear and clean prior to installation.
- d. The open ends of the pipe system must be closed at the end of each day's work or when work is not in progress by use of expansion plugs and must not be opened until the work is resumed.
- e. A swab, with a leather or canvas belt disc to fit the inside diameter of pipe, must be pulled through each length of pipe after welding in place.
- f. Obstruction remaining in the pipe after completion of the system must be removed at the expense of the Contractor.
- g. Plasma cutters and torches are not to be used to make penetrations in the pipe or to cut pipe.

\*\*\*\*\*

**NOTE: Select option for swab pig run if line is piggable.**

\*\*\*\*\*

- h. After installation and backfill of the piggable piping is complete and before fuel is put in the pipe, the pipe will be cleaned per the paragraph[s] [CLEANING PIG RUN][WIRE BRUSH RUN] [CLEANING PIG RUN and WIRE BRUSH RUN] in this Section.

### 3.9.2 Protective Coatings for Buried Piping Including Stainless Steel Piping

#### 3.9.2.1 Application of Coating System

Application of coating system must be in accordance with 33 52 80 LIQUID FUELS PIPELINE COATING SYSTEMS.[ Application of coating system must be in accordance with 09 97 13.27 HIGH PERFORMANCE COATING FOR STEEL STRUCTURES.]

#### 3.9.2.2 Inspection and Testing

The condition of factory field coated piping must be the responsibility of the Contractor and all damage to the protective covering during transit and handling must be repaired at no additional cost to the Government. All field coating must be subject to approval by the Contracting Officer. The entire pipe must be inspected as specified in sub-paragraph TESTING OF PROTECTIVE COATINGS under paragraph PROTECTIVE COATINGS FOR BURIED STEEL PIPING. The inspection for holidays must be performed just prior to lowering the pipe into the ditch and every precaution must be taken during lowering and backfilling to prevent damage to the protective covering.

#### 3.9.2.3 Damage Repair

Damaged areas of coating must be repaired as specified in the preceding paragraph for fittings.

### 3.10 INTERIOR EPOXY COATING

When internally epoxy lined pipe is cut, the lining must be ground back from the end a minimum of 25 mm one-inch but not more than 38 mm 1-1/2 inches.

### 3.11 INSTALLATION OF UNDERGROUND PIPE

Underground fuel pipelines must be pitched as shown on the drawings. Where not indicated they must be pitched a minimum of 50 mm 2 inches per 30.5 m 100 feet. 50 mm Two-inch pipe size valved drain connections must be provided at all low points and 38 mm 1-1/2-inch pipe size valved outlet vent connections must be provided at all high points. Vent and drain lines must terminate in male cam-type locking end connectors with matching female dust covers and installed in pits. The pipe must have cover as shown on the drawings. Drain lines must be installed at the slopes indicated.

#### 3.11.1 Pipe Assembly

Pipe must be strung parallel and adjacent to or above a trench. The pipe must be supported on padded skids during welding and inspection of joints. Protective coating must be inspected and repaired prior to lowering the pipe into the trench. The pipe must be lowered using only

canvas or nylon slings. The sling must be dug from underneath the pipe after placements and must not be pulled from underneath the pipe while in contact with it. Care must be taken to prevent damage to the pipe, welded joints or coating and any such damage must be repaired as directed by the Contracting Officer. Pressure testing of the pipe must be done after it has been placed in final position in the trench.

### 3.11.2 Warning Tapes in Earth Trenches

For the purpose of early warning and identification of buried pipes outside of building walls during future trenching or other excavation, continuous identification tapes must be provided in the trench. Provide metallic core or metallic-faced, acid- and alkali-resistant, polyethylene plastic warning tape manufactured for the purpose of early warning and identification of utilities buried below the tape. Tape must be at least **80 mm 3 inches** in width. Color of tape must be as standard with the manufacturer with respect to the type of utility buried below the tape. Tape must have lettering at least **25 mm one-inch** high with warning and identification imprinted in bold black letters continuously over the entire tape length with not less than the following identification on the tape: BURIED JET FUEL PIPING BELOW. Tape must be installed in accordance with the printed recommendations of the tape manufacturer, as modified herein. Tapes must be buried at a depth of **150 mm 6 inches** from the top of the subgrade or **300 mm 12 inches** below the top surface of earth. Provide permanent color and printing, unaffected by moisture or soil.

### 3.11.3 Clearances

Install pipe to be clear of contact with other pipes, pipe sleeves, casings, reinforcing steel, conduits, cables, or other metallic structures. Where pipes cross other pipes or structures with a separation of less than **150 mm 6 inches**, install an insulating separator. Protect the pipe from contact with a **300 mm 12-inch** square by **25 mm one-inch** thick bituminous-impregnated canefiber board.

### 3.11.4 Protective Coating

When the protective coating on pipe is damaged, the Contracting Officer must be notified and must inspect the pipe before the coating is patched. If the damage to the pipe is deeper than **1.2 mm 0.050-inch**, the damage must be repaired by welding in accordance with paragraph WELDING. If the pipe is dented, out of round or damaged to the point that welding will not make it good as new, the length of pipe must be rejected.

### 3.11.5 Pipe Casing

\*\*\*\*\*  
**NOTE: Design casing vents to prevent the influx of rain or groundwater into the casing.**

**The use of casings on underground pipelines is highly discouraged due to increase problems with pipe corrosion and inability to provide cathodic protection to the pipe in the sleeve. Use steel casing sleeves only for those crossings where sleeves are required by authorities having jurisdiction (i.e.: Airfield Managers), or where it is necessary to place stainless steel lines bore under the roadway or railroad tracks to while**

avoiding interference with traffic, or where boring is the most economical construction method. Consider installing carbon steel and stainless steel pipelines under roadways by the traditional trenching method, or use alternative trenchless pipe construction methods for carbon steel pipelines to avoid the need for a casing. Do not use directional drilling for stainless steel lines. When using alternative trenchless methods for carbon steel lines, provide supplemental abrasion resistant coatings applied in addition to the fusion bonded epoxy exterior pipe coating. When required to construct planning construction of open trench cased crossings, consider the economics of installing spare casing sleeves to eliminate excavating for future fuel lines.

Locate crossings at a minimum depth of 36 inches (900 mm) beneath the bottom of drainage ditches. If this depth cannot be obtained, install above, but not in contact with, the casing or pipe, a 6-inch (150 mm) thick reinforced concrete slab of adequate length and width to protect the casing or pipe from damage by equipment such as ditch graders and mowers.

In areas with high normal or seasonal groundwater tables consider the use of a water excluding casing fill material. Refer to API RP 1102 for additional information on the use of casings.

\*\*\*\*\*

Casing must be continuous for the entire crossing as well as extend a minimum of 150 mm 6 inches beyond both sides of the crossing. Casings must be of such size as to provide a minimum of 12 mm 1/2-inch all-around clearance between bare pipe and the casing. Alignment of the casing and piping must be such that the pipe is accurately centered within the casing by nonconductive centering spacers properly spaced in the casing, and within 300 mm 12 inches of casing ends. Provide seals at each end of the casing. Include a vent on the higher end of each casing and a low point drain on the lower end of the casing. Ensure that the casing design electrically isolates fuel-carrying pipes from contact with the casing pipes. Provide cathodic protection test leads to the pipe and casing to monitor for electrical isolation.[ Fill casing with water excluding casing fill material]

#### 3.11.6 Pipeline Markers

Provide above underground fuel piping spaced every 90 meters 300 feet, at tees, and at changes in direction. For sections of underground piping less than 90 meters 300 feet long, place at midpoint. Provide directly above pipe for single lines and between pipes where pipes run in pairs. Provide additional marker over each mid-line fitting connections for steel reinforced flexible pipe. Cast marker into 450 mm 18-inch diameter, 300 mm 12-inch thick concrete plug unless it is set in an area with concrete paving in which case it must be cast into the concrete paving.

#### 3.11.7 Steel Reinforced Flexible Pipe

\*\*\*\*\*

**NOTE: Steel reinforced flexible pipe comes in reels. To the extent possible, design piping system such that the entire length of underground piping can be accommodated with one reel.**

\*\*\*\*\*

Connections between steel pipe and steel reinforced flexible pipe and between separate lengths of steel reinforced flexible pipe must not be made aboveground but must be made either inside a pit or vault, or direct bury them. Where practicable, end-line and mid-line connections must be located inside pit type enclosures of an appropriate size. Where it is not practicable to locate mid-line connections inside pit type enclosures, mid-line connections may be wrapped with a suitable waterproof protective substance and direct buried underground. The location of direct buried mid-line connections must be indicated on the final drawings and provided with a pipeline marker and monitoring well. Record GPS coordinates of all installed direct buried joints on as-built drawings.

### 3.12 SYSTEM COMMISSIONING

Conform to Section 33 08 55 FUEL DISTRIBUTION SYSTEM START-UP (NON-HYDRANT).

### 3.13 TESTING

\*\*\*\*\*

**NOTE: Hydrostatic testing with water requires explicit, written Service Headquarters approval except in the case of fuel piping systems containing fuels with a flash point of less than 38 degrees C 100 degrees F (i.e. JP-4, Mogas, Avgas, etc.); without that approval, hydrotesting with water is forbidden. Pressure testing of new Mogas, Avgas, and JP-4 pipelines must be with water.**

\*\*\*\*\*

Piping must be tested by pneumatic and hydrostatic pressure. Testing must comply with applicable requirements of ASME B31.3, NFPA 30 and the requirements specified herein. Hydrostatic testing must be performed using [fuel] [water] as the liquid[ with Service Headquarters approval]. Pressure and hydrostatic testing must be performed only after welding inspection has been completed. Labor, materials, equipment, electricity, repairs, and retesting necessary for any of the tests required herein must be furnished by the Contractor. Provide provisions to prevent displacement of the piping during testing. Keep personnel clear of the piping during pneumatic testing. Only authorized personnel must be permitted in the area during pneumatic and hydrostatic testing. Isolate system components such as pumps, tanks, filter separators, and meters from the piping system during the testing. Do not exceed the pressure rating of any component in the piping system during the testing. Following satisfactory completion of each test, relieve the test pressure and seal the pipe immediately.[ When water is authorized for hydrostatic testing [and] [or] pigging of fuel piping, ensure that all water is removed from the piping by a combination of pigging the piping, followed by dehydrating the line either with dehumidified air or vacuum extraction. Verification of pipeline dehydrating must be confirmed by measuring dew point of exhausted air. Do not allow water to remain in piping for more than 48 hours after testing. Schedule hydrotesting such that the pipeline can be filled with fuel as soon as possible (no more than two weeks) after

testing is complete as it is nearly impossible to assuredly remove all water and corrosion can occur if the time to fuel introduction is extended. The Contractor must submit the [piping dehydration test](#) prior to filling pipelines with fuel.] Piping to be installed underground must not receive field applied exterior coatings at the joints or be covered by backfill until the piping has passed the final pneumatic tests described herein.

### 3.13.1 Before Backfilling

Fuel piping must not be backfilled without completing the coating, pneumatic, weld radiograph and other piping examinations and approvals. Fuel piping in trench must not have exposed welds for longer than 30 days.

#### 3.13.1.1 Exterior Coating Holiday Test

Following installation, test the exterior coating of direct buried piping for holidays using high-voltage spark testing in accordance with [NACE SP0188](#). Repair holidays and retest to confirm holiday-free coating. Text must include all existing underground piping exposed for this project.

### 3.13.2 Pneumatic Test

Piping to be installed underground must not receive field applied protective covering at the joints or be covered by backfill until the piping has passed the pneumatic test described herein. To facilitate the tests, isolate various sections of the piping system and test each one separately. Where such sections terminate at flanged valve points, the line must be closed by means of blind flanges in lieu of relying on the valve. Furnish tapped flanges that can be attached to the end of the section of line being tested, and that will permit a direct connection between the piping and the air compressor [and][or] pressurizing pump. No taps in the permanent line will be permitted. Furnish all necessary equipment for testing; all gauges must be subject to testing and approval of the Contracting Officer. The air used for pneumatic testing must have a dew point of no more than [5 degrees C](#) [41 degrees F](#). Provide dehumidifying equipment on the suction or discharge side of the air compressor used to provide air for testing. Pressurizing pump must not exceed [4.7 L/s](#) [10 cfm](#).

#### 3.13.2.1 Pneumatic Test Procedure

\*\*\*\*\*  
**NOTE: Use 50 psig final test pressure unless  
permission to go higher is secured from the Service  
Headquarters and the Contracting Officer.**  
\*\*\*\*\*

Special safety measures, including the wearing of face mask, must be taken during testing under pressure. Only authorized personnel must be permitted in the area during testing. The pneumatic test pressure must be applied in increments. A preliminary [167 kPa](#) [25 psig](#) test must be applied. Maintain the pressure while soapsuds or equivalent materials are applied to the exterior of the piping. While applying the soapsuds, visually inspect the entire run of piping, including the bottom surfaces, for leaks (bubble formations). If leaks are discovered, repair the leaks accordingly and retest. Repeat process until system is leak-free at 25 psig. The full test pressure must then be applied. Unless otherwise directed by the Contracting Officer, all piping must be tested at a

pressure of [667] [333] kPa [50] [100] psig for not less than 2-hours, during which time there must be no drop in pressure, only pressure rises with temperature. The pressure source must be disconnected during the final test period. Any leaks revealed by the test must be repaired and the test repeated.

### 3.13.3 Hydrostatic Test

\*\*\*\*\*

NOTE: Unless otherwise directed by the Service Headquarters, hydrostatically test aboveground piping systems to the maximum allowable working pressure of the ASME B16.5 piping system flanges at 38 degrees C 100 degrees F and hydrostatically test underground piping systems to 1.5 times the maximum allowable working pressure of the ASME B16.5 piping system flanges at 38 degrees C 100 degrees F. Refer to UFC 3-460-01 for more guidance.

Hydrostatically testing the system to 1.5 times the flange rating, will require the designer to write the commissioning hydrostatic testing procedures, which will consider the removal of system components (i.e.: ball valves, control valves, meters), and provide procedures of the hydrostatic test which should include what valves to close, where to install the hydrostatic test pump, blind flange placements, high point vents and low point drains, and other requirements.

NOTE: Hydrostatic testing with water requires explicit, written Service Headquarters approval except in the case of fuel piping systems containing fuels with a flash point of less than 38 degrees C 100 degrees F (i.e. JP-4, Mogas, Avgas, etc.); without that approval, hydrotesting with water is forbidden.

NOTE: If hydrostatic testing with water, perform soak test after initial introduction of fuel as described in Section 33 08 55 FUEL DISTRIBUTION SYSTEM START-UP (NON-HYDRANT).

\*\*\*\*\*

Upon completion of pneumatic testing and after backfilling, hydrostatically test each underground piping system with [fuel] [water] at [1.9] [2] [2.9] [3.1] [\_\_\_\_\_] MPa [275] [285] [425] [450] [\_\_\_\_\_] psig in accordance with ASME B31.3 and API RP 1110, with no leakage or reduction in gauge pressure for four hours. Upon completion of pneumatic testing, hydrostatically test each aboveground piping system with fuel at [1.9] [2] [2.9] [3.1] [\_\_\_\_\_] MPa [275] [285] [425] [450] [\_\_\_\_\_] psig in accordance with ASME B31.3 and API RP 1110, with no leakage or reduction in gauge pressure for four hours. Furnish electricity, instruments, connecting devices, and personnel for test.[ Fuel must be furnished by the Government.][ If fuel is used for testing, comply with all the requirements in Section 33 08 55 FUEL DISTRIBUTION SYSTEM START-UP (NON-HYDRANT).][ In cases where it is not specified, water must be potable and treated and must meet all the requirements of water used for

hydrostatic testing in API 570.][ Upon completion of hydrostatic testing, perform "Soak Testing" of the piping systems per API RP 1595. Duration of the test must be a minimum of 4 days and maximum of 7 days.] Defects in work must be corrected at the Contractor's expense, and the test repeated until the work is proven to be in compliance with the Contract requirements.

#### 3.13.4 Soak Testing

\*\*\*\*\*  
NOTE: Perform soak test after initial receipt of fuel as described in Section 33 08 55 FUEL DISTRIBUTION SYSTEM START-UP (NON-HYDRANT). The timing of the initial receipt of fuel will depend on where water is used for just hydrotesting, or hydrotesting and pigging.  
\*\*\*\*\*

[Upon completion of hydrostatic testing with fuel, perform "Soak Testing" of the piping systems per API RP 1595. Duration of the test must be a minimum of 4 days and maximum of 7 days.] [Upon completion of initial receipt of fuel, perform "Soak Testing" of the piping systems per API RP 1595. Duration of the test must be a minimum of 4 days and maximum of 7 days.]

#### 3.13.5 Performance Testing

After the fuel system testing is completed (including pneumatic and hydrostatic testing) the fuel system must be flushed, cleaned and performance tested as specified in Section 33 08 55 FUEL DISTRIBUTION SYSTEM START-UP (NON-HYDRANT). All control valves, both manual and automatic, must be checked for leaks (any area wetted with fuel) and proper operation and adjusted, repaired or replaced to correct any defects.

#### [3.14 PIPE PIGGING - CLEANING

\*\*\*\*\*  
NOTE: Select bracketed paragraph if system is designed to be piggable. Standard cleaning pig runs are recommended on all systems.  
\*\*\*\*\*

\*\*\*\*\*  
NOTE: Pigging with water requires explicit, written Service Headquarters approval and is not allowed in systems which contained fuel previously.

NOTE: The choice of the fluid used to propel cleaning pigs will vary greatly from project to project.

- a. Pneumatic propelled cleaning pigs will almost always be used before any other pigs are run.
- b. Water propelled pigs will be allowed only after securing explicit, written Service Headquarters approval.
- c. Fuel propelled pigs may always be used.

\*\*\*\*\*



### 3.14.1 General

\*\*\*\*\*  
**NOTE: Include bracketed text for non-stainless piping systems, or if excessive contamination is anticipated.**  
\*\*\*\*\*

Track all pigs, using transmitter and receivers, at no less than 805 m 1/2-mile increments, but no less than at four locations. The Contractor must prepare a contingency plan for retrieving a stuck pig and repairing any piping deformations. After pigging, plug valves must be flushed of all debris using the drain port at the bottom of the valve.

### [3.14.2 Use of Fuel in Cleaning Pigging

Cleaning pigging with fuel will take place after the initial receipt of fuel as per Section 33 08 55 FUEL DISTRIBUTION SYSTEM START-UP (NON-HYDRANT). Ensure that the fuel that is returned to the storage tanks during the pig runs is free of gross contamination and passes the color assessment method, and meets the requirements of MIL-STD-3004-1. Provide temporary storage tanks for the high particulate and dark color fuel that accumulates in front of and behind each pig. The contractor is responsible for [cleaning the off-spec fuel in order to meet the requirements of MIL-STD-3004-1] [,dispose of the off-spec fuel off-base][,obtain permission from the Contracting officer to downgrade the fuel and dispose of it in the appropriate tank].

### ]3.14.3 Use of Water in Cleaning Pigging

Ensure that the water, in cases where it is not specified, must be potable and treated and must meet all the requirements of water used for hydrostatic testing in API 570. Dispose of the water in accordance with applicable Installation, city, county, state, and federal regulations.

### ]3.14.4 Cleaning Pig Run

[Contractor-provided pig launching and receiving barrels must be installed. ]Initially, a proving pig run (foam density 32 kg/m<sup>3</sup> 2 lb/ft<sup>3</sup> should be performed to ensure the system is fully piggable. Upon completion of the successful proving pig run, the piping system must be cleaned with a standard cleaning pig. This will provide thorough cleaning of the interior of the piping system. Cleaning pig must be the bi-directional disk scraper style with steel body and replaceable polyurethane guiding and sealing disks, as well as gauge plates of 80 percent pipe diameter with 3 mm 1/8-inch segmented aluminum fins. The pig body should include bypass nozzles and transmitter cavity. Propellant must be pressurized [fuel][water] using [the main system delivery pumps][portable pumps]. The pig must be examined after the initial run for signs of possible pipe damage, interior slag or other adhered particles. Additional runs must be performed until the amount of collected sludge or debris is minimized, as determined by the [Contracting Officer][System Supplier].

### 3.14.5 Wire Brush Pig Run

\*\*\*\*\*  
**NOTE: Select wire brush cleaning pig option if excessive slag or other adhered particles are**

suspected on the pipe interior. Require stainless steel brushes on stainless steel piping systems.

Never perform wire brush cleaning pig on interior epoxy coated piping systems.

\*\*\*\*\*

After the cleaning pig runs, the piping system must be cleaned with a wire brush style pig. This will remove weld slag and adhered particles from the system. Wire brush pig must be the bi-directional disk style or directional cup style with two circular [stainless] steel wire brushes. The pig body should include bypass nozzles and transmitter cavity. Perform wire brush pig runs until the amount of collected weld slag or debris is minimized, as determined by the [Contracting Officer][System Supplier].

### ]3.15 PIPE PIGGING VERIFICATION

\*\*\*\*\*

**NOTE: Pigging with water requires explicit, written Service Headquarters approval and is not allowed in systems which contained fuel previously.**

\*\*\*\*\*

#### [3.15.1 Use of Water in Pipe Pigging Verification

Ensure that the water, in cases where it is not specified, must be potable and treated and must meet all the requirements of water used for hydrostatic testing in [API 570](#). Dispose of the water in accordance with applicable Installation, city, county, state, and federal regulations.

#### ]3.15.2 Geometry/Ultrasonic Tool Reports

After the system is installed and prior to performance testing, a field/preliminary report must be issued and a debrief given to Government personnel onsite on the condition of the piping system that was pigged. This must be comprised of raw data in the form of a PC download or equivalent which shows a continuous scan of each data unit output. Results of a preliminary interpretation of the data must be reported. These must include as a minimum all critical anomalies. A final report must include a description of the principle of operation, explanation of raw data, presentation of raw data, data to be clearly marked with distance traveled scale with classified anomaly location and all identifiable pipeline features, and all anomalies to be classified with locations in summary tabular form, pipe wall thickness survey, as well as the software necessary to read the data. Submittal must be in the form of digital media copied to a CD or DVD (flash drives are unacceptable).

#### 3.15.3 Pipeline Internal Inspection Operations

##### 3.15.3.1 General

The following pigs will be propelled through the pipeline with [fuel][water] in order to inspect the pipeline: 1.7 kg 5 pound density foam swab, combination poly scraper-magnetic, stainless steel wire brush (plastic brush for internally lined piping), aluminum plate gauge, and geometry/ultrasonic tool. Tracking devices must be used on all pigs. At a minimum, the sequence of pig runs must be as follows: 1) foam swab for proving and cleaning, 2) wire brush for cleaning, 3) scraper-magnetic for

cleaning, 4) aluminum plate gauge for gauging internal anomalies, 5) scraper-magnetic for cleaning, 6) wire brush for cleaning, 7) scraper-magnetic for cleaning, 8) foam swab for cleaning, (Note: the number of pig flights of each type of cleaning pigs must be determined by the amount and type of debris removed. The conclusion of the cleaning process must be when debris recovered is only that from the pigs themselves. This determination will be determined by the project's System Supplier and the Contracting Officer), 9) geometry/ultrasonic tool. The pipe wall must be continuously monitored on a real-time basis during the geometry/ultrasonic pig run. Anomalies such as patches, couplings, or flanges must also be identified, and the wall thickness given. The geometry/ultrasonic pig's technician will determine if additional runs are necessary. A permanent data set of internal inspection survey findings must be generated.

#### 3.15.3.2 Preparatory Work

The Government will bring to the attention of the Contractor all statutes, rules and regulations relevant to the performance of the work on the site (on Government property) and will also provide the Contractor with a copy of its own site regulations (if any). Provide the pigging vendors with all-available pipeline records and drawings.

#### 3.15.3.3 Pig Load And Launch

\*\*\*\*\*  
**NOTE: If pig a launcher and a receiver are not  
provided in the contract, portable ones will be by  
the Contractor during pigging operations.**  
\*\*\*\*\*

The pig must be loaded into the pig launcher by the Contractor. The method of loading and lodging the front pig cup into the launcher must not involve the use of uncontrolled mechanical force applied to the rear of the pig.

#### 3.15.3.4 Pipeline Operation During Pigging

All pig runs must be made with the line packed with product. The system pumps will be used to propel the pig. The new pig traps will be used for pig launch and retrieval.

#### 3.15.3.5 Brush and Gauging Survey

Run a brush pig at least as often as previously indicated. The brush pig must be designed and provided by the geometry/ultrasonic pig vendor. Additional runs may be required based upon the amount of debris found in the pipeline. The onsite geometry/ultrasonic pig vendor's personnel must determine if additional runs are required. Immediately following the brush pig run and immediately prior to the geometry/ultrasonic survey, run, as a minimum, a single batching pig fitted with a gauge plate equal to 90 percent of the pipeline normal inside diameter. The plate is to be a segmented aluminum disk of 3 mm 1/8-inch thickness. The plate gauge pig must also include a tracker and tracking equipment. Track the pig assembly above ground during the operation.

#### 3.15.3.6 Geometry/Ultrasonic Survey

After a satisfactory gauging pig run, the pipeline geometric defects must

be determined by a geometry/ultrasonic tool. The geometry/ultrasonic tool must provide accuracy geometric anomaly detection, and bend radius measuring capability. The data obtained must be presented in a PC software format to allow user friendly analysis and presentation. The geometry/ultrasonic tool assembly must be capable of:

- a. Operating in [hydrocarbon liquid environment, specifically [jet fuel][\_\_\_\_]][water], at a pressure of up to ANSI 300 rating.
- b. Traversing the pipeline with nominal wall thickness and possible bore restrictions down to 90 percent of nominal pipe inside diameter.
- c. Traversing the pipeline length at a speed of between 60 and 100 m/min 3 and 5 ft/sec when propelled by pumped [jet fuel][water]. Pressure differential across pig not to exceed 34 kPa 50 psi.
- d. Traversing through smooth pipe bends as small as 3D (3 pipe diameters) radius and single miter bends of up to 10 degrees change of direction.
- e. Include a tracker and tracking equipment. Track the pig assembly above ground during the operation. The battery life of the tracker must not be less than 72-hours.
- f. Manual loading into the new horizontal pig trap.

The geometry/ultrasonic tool assembly instrumentation performance must be capable of:

- a. Battery life to be minimum 18-hours at operating conditions.
- b. Principle of operation to be electronically stored geometry system.
- c. Geometry sensing to span full circumference and length of pipe, with associated distance measuring method.
- d. Geometry system must be capable of:
  - (1) positive location and identification of each geometric anomaly.
  - (2) positive location and identification of each bend.
  - (3) positive location and identification of distance marker reference points of either magnetic or electronic type placed on or above the pipe.
- e. Classification of geometric anomalies to be as minimum:
  - (1) discrimination between ovality and intrusion anomalies.
  - (2) mechanical damage such as mill defects, dents, internal gouges, and buckles.
  - (3) pipeline weld defects (such as excess weld penetration).
  - (4) geometric thickness anomalies. As a minimum, these must be reported in the following categories within the listed accuracy.
    - (a) magnitude of anomaly (plus/minus 25 mm one-inch)

- (b) span of anomaly (plus/minus 25 mm one-inch)
- (c) ovality (plus/minus 2.5 mm 0.1-inch)
- (d) span of ovality (plus/minus 25 mm one-inch)
- (e) anomaly station (plus/minus 1:2,000)

#### 3.15.3.7 Pipe Wall Thickness Survey

The geometry/ultrasonic tool must provide accuracy measurement of pipe wall thickness (plus/minus 0.25 mm 0.01-inch). The data obtained must be presented in a PC software format to allow user friendly analysis and presentation.

#### 3.15.3.8 Lost Pig

The Contractor is responsible for a lost pig, finding the pig, retrieval of the pig, and all repairs, radiographs to the pipeline system and the pig.

#### 3.16 DEMONSTRATIONS

As per requirements in Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT).

#### 3.17 POSTED OPERATING INSTRUCTIONS

As per requirements in Section 33 57 55 FUEL SYSTEM COMPONENTS (NON-HYDRANT).

-- End of Section --