

\*\*\*\*\*

USACE / NAVFAC / AFCEC

UFGS-26 27 13.10 30 (October 2007)

Change 2 - 08/18

-----

Preparing Activity: AFCEC

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2025

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 26 - ELECTRICAL

#### SECTION 26 27 13.10 30

#### ELECTRIC METERS

10/07, CHG 2: 08/18

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 DEFINITIONS
- 1.3 SUBMITTALS
- 1.4 QUALITY ASSURANCE
  - 1.4.1 Installation Drawings
  - 1.4.2 Standard Products
  - 1.4.3 Alternative Qualifications
  - 1.4.4 Material and Equipment Manufacturing Data
- 1.5 WARRANTY
- 1.6 SYSTEM DESCRIPTION
  - 1.6.1 System Requirements
  - 1.6.2 Selection Criteria

#### PART 2 PRODUCTS

- 2.1 POWER METERS
  - 2.1.1 Physical and Common Requirements
  - 2.1.2 Voltage Requirements
  - 2.1.3 Current Requirements
  - 2.1.4 Electrical Measurements
  - 2.1.5 Meter Accuracy
  - 2.1.6 An on the Meter Display, Output and Reading Capabilities
  - 2.1.7 Installation Methods
  - 2.1.8 Disconnecting Switches
  - 2.1.9 Meter Programming
- 2.2 COMMUNICATIONS
  - 2.2.1 Communications Methods
    - 2.2.1.1 Optical Port
    - 2.2.1.2 Serial Port
    - 2.2.1.3 Ethernet
  - 2.2.2 Communications Protocols and Methods
  - 2.2.3 Communications Channels Surge Protection

- 2.3 METER DATA PROTOCOL
  - 2.3.1 Open Protocol
- 2.4 SPARE PARTS
  - 2.4.1 Parts List
- 2.5 METERING SYSTEM SCHEDULE

PART 3 EXECUTION

- 3.1 INSTALLATION
  - 3.1.1 Existing Condition Survey
  - 3.1.2 Scheduling of Work and Outages
- 3.2 FIELD APPLIED PAINTING
- 3.3 FIELD QUALITY CONTROL
  - 3.3.1 Performance of Acceptance Checks and Tests
    - 3.3.1.1 Meter Assembly
    - 3.3.1.2 Current Transformers
    - 3.3.1.3 Potential Transformers
  - 3.3.2 Follow-Up System Function Verification
  - 3.3.3 Training

-- End of Section Table of Contents --

\*\*\*\*\*

USACE / NAVFAC / AFCEC

UFGS-26 27 13.10 30 (October 2007)

Change 2 - 08/18

-----

Preparing Activity: AFCEC

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2025

\*\*\*\*\*

### SECTION 26 27 13.10 30

#### ELECTRIC METERS

10/07, CHG 2: 08/18

\*\*\*\*\*

NOTE: This guide specification covers the requirements for the installation of poly-phase electricity meters suitable for billing, allocation of costs, and recording of data for energy management and control applications and is intended to comply with the metering requirements of EPACT05.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

\*\*\*\*\*

\*\*\*\*\*

NOTE: Since metering for energy management and costs allocation varies widely, it is expected that the designer will make significant adjustments and additions to this guide specification.

NOTE: Use the following related guide specifications for power distribution equipment:

- - Section [26 12 19](#) PAD-MOUNTED, LIQUID-FILLED, MEDIUM-VOLTAGE TRANSFORMERS

- - Section [26 11 14.00 10](#) MAIN ELECTRIC SUPPLY STATION AND SUBSTATION

- - Section 26 22 00.00 10 480-VOLT STATION SERVICE  
SWITCHBOARD AND TRANSFORMERS

- - Section 26 23 00 SWITCHBOARDS AND SWITCHGEAR

NOTE: This specification provides guidance for the  
facility energy manager or design engineer after  
determining what data will be gathered and what  
analysis procedures will be used.

\*\*\*\*\*

## PART 1 GENERAL

### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the  
publications cited in the text of the guide  
specification. The publications are referred to in  
the text by basic designation only and listed in  
this paragraph by organization, designation, date,  
and title.

Use the Reference Wizard's Check Reference feature  
when you add a Reference Identifier (RID) outside of  
the Section's Reference Article to automatically  
place the reference in the Reference Article. Also  
use the Reference Wizard's Check Reference feature  
to update the issue dates.

References not used in the text will automatically  
be deleted from this section of the project  
specification when you choose to reconcile  
references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the  
extent referenced. The publications are referred to within the text by  
the basic designation only.

#### INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE 100	(2000; Archived) The Authoritative Dictionary of IEEE Standards Terms
IEEE C2	(2023) National Electrical Safety Code
IEEE C37.90.1	(2023; ERTA) Standard for Surge Withstand Capability (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus
IEEE C57.13	(2016) Standard Requirements for Instrument Transformers

#### INTERNATIONAL ELECTROTECHNICAL COMMISSION (IEC)

IEC 61000-4-5	(2017) Electromagnetic Compatibility (EMC)
---------------	--

- Part 4-5: Testing and Measurement  
Techniques - Surge Immunity Test

IEC 62053-22

(2020) Electricity Metering Equipment  
(A.C.) - Particular Requirements - Part  
22: Static Meters for Active Energy  
(Classes 0,2 S and 0,5 S)

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

ANSI C12.18

(2006; R 2023) Protocol Specification for  
ANSI Type 2 Optical Port

ANSI C12.20

(2015; E 2018) Electricity Meters - 0.1,  
0.2, and 0.5 Accuracy Classes

ANSI C62.61

(1993) American National Standard for Gas  
Tube Surge Arresters on Wire Line  
Telephone Circuits

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70

(2023; ERTA 1 2024; TIA 24-1; TIA 25-2)  
National Electrical Code

1.2 DEFINITIONS

Unless otherwise specified or indicated, electrical and electronics terms  
used in this specification and on the drawings are as defined in IEEE 100.

1.3 SUBMITTALS

\*\*\*\*\*

NOTE: Review submittal description (SD) definitions  
in Section 01 33 00 SUBMITTAL PROCEDURES and edit  
the following list, and corresponding submittal  
items in the text, to reflect only the submittals  
required for the project. The Guide Specification  
technical editors have classified those items that  
require Government approval, due to their complexity  
or criticality, with a "G." Generally, other  
submittal items can be reviewed by the Contractor's  
Quality Control System. Only add a "G" to an item,  
if the submittal is sufficiently important or  
complex in context of the project.

For Army projects, fill in the empty brackets  
following the "G" classification, with a code of up  
to three characters to indicate the approving  
authority. Codes for Army projects using the  
Resident Management System (RMS) are: "AE" for  
Architect-Engineer; "DO" for District Office  
(Engineering Division or other organization in the  
District Office); "AO" for Area Office; "RO" for  
Resident Office; and "PO" for Project Office. Codes  
following the "G" typically are not used for Navy  
and Air Force projects.

The "S" classification indicates submittals required

as proof of compliance for sustainability Guiding  
Principles Validation or Third Party Certification  
and as described in Section 01 33 00 SUBMITTAL  
PROCEDURES.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

- a. Provide the following in the maintenance manual:
  1. Condensed description of how the equipment operates.
  2. Block diagram indicating major assemblies.
  3. Troubleshooting information
  4. Preventive maintenance.
  5. Spare parts information.
- b. Provide operation and maintenance manuals required by submittal item "SD-10 Operation and Maintenance Data."

SD-02 Shop Drawings

SD-03 Product Data

Power Meters; G, [\_\_\_\_\_]

Current Transformers; G, [\_\_\_\_\_]

Potential Transformer; G, [\_\_\_\_\_]

Communications Module; G, [\_\_\_\_\_]

Protocol Modules; G, [\_\_\_\_\_]

Data Recorder; G, [\_\_\_\_\_]

Modem; G, [\_\_\_\_\_]

Include manufacturer's information for each component, device, and accessory provided with the meter, protocol module or communications module.

SD-06 Test Reports

Acceptance Checks and Tests; G, [\_\_\_\_\_]

SD-10 Operation and Maintenance Data

Power Meters; G, [\_\_\_\_\_]

Communications Module; G, [\_\_\_\_\_]

Protocol Modules; G, [\_\_\_\_\_]

Data Recorder; G, [\_\_\_\_\_]

Modem; G, [\_\_\_\_\_]

#### SD-11 Closeout Submittals

System Function Verification; G, [\_\_\_\_\_]

### 1.4 QUALITY ASSURANCE

#### 1.4.1 Installation Drawings

Drawings indicate but are not limited to the following:

a. Elementary diagrams and wiring diagrams with terminals identified of[ kilowatt][ advanced] meter,[ current transformers,][ potential transformers,][ protocol modules,][ communications modules,][ Ethernet connections,][ telephone lines]. [For each meter installation, provide a diagram identified by the building number.]

b. One-line diagram, including meters,[ switch(es),][ current transformers,][ potential transformers,][ protocol modules,][ communications modules,][ Ethernet connections,][ telephone outlets,][ and fuses]. [For each meter installation, provide a diagram identified by the building number.]

#### 1.4.2 Standard Products

Provide materials and equipment that are products of manufacturers regularly engaged in the production of such products which are of equal material, design and workmanship. Provide products that have been in satisfactory commercial or industrial use for 2 years prior to bid opening. The 2-year period includes applications of equipment and materials under similar circumstances and of similar size. Provide product that has been on sale on the commercial market through advertisements, manufacturers' catalogs, or brochures during the 2-year period. Where two or more items of the same class of equipment are required, these items must be products of a single manufacturer; however, the component parts of the item need not be the products of the same manufacturer unless stated in this section.

#### 1.4.3 Alternative Qualifications

Products having less than a 2-year field service record will be acceptable if a certified record of satisfactory field operation for not less than 6000 hours, exclusive of the manufacturers' factory or laboratory tests, is furnished.

#### 1.4.4 Material and Equipment Manufacturing Data

Do not use products manufactured more than 2 years prior to date of delivery to site, unless specified otherwise.

### 1.5 WARRANTY

Provide equipment items supported by service organizations which are reasonably convenient to the equipment installation in order to render satisfactory service to the equipment on a regular and emergency basis during the warranty period of the contract.

## 1.6 SYSTEM DESCRIPTION

### 1.6.1 System Requirements

The metering and reading system, consisting of commercial, off-the-shelf meters, [protocol modules](#), communications modules, and communication channels, will be used to record the electricity consumption and other values as described in the sections that follow and as shown on the drawings.

### 1.6.2 Selection Criteria

\*\*\*\*\*  
NOTE: Coordinate with the Public Works Department -  
when an installation-wide energy and utility  
monitoring system exists, include the last sentence.  
\*\*\*\*\*

Metering components are part of a system that includes the physical meter, [data recorder](#) function and communications ([modem](#)) method. Include sufficient metering components to measure the electrical parameters identified and to store and communicate the values as required in the following sections for every building site identified. Verify that the metering system installed on any building site is compatible with the facility-wide communication and meter-reading protocol system.[ Contractor must connect the metering system to the facility-wide energy and utility monitoring and control system.]

## PART 2 PRODUCTS

### 2.1 [POWER METERS](#)

\*\*\*\*\*  
NOTE: This specification is designed for projects  
where multiple metering systems will be installed on  
the same project. It is expected that different  
buildings may have different metering systems  
depending on the metering system that can be  
installed economically for any specific building and  
that meets the needs of the facility analysis and  
billing system.  
  
Metering features that are unique to a building  
should be listed in a schedule either in this  
specification or on accompanying drawings.  
\*\*\*\*\*

#### 2.1.1 Physical and Common Requirements

\*\*\*\*\*  
NOTE: Meters will generally be installed outside  
the building in a readily accessible location. In  
that case, use the socket-mount design. In the  
situations where panel-mounting is required, add the  
panel-mounting section.  
\*\*\*\*\*

- a. Install metering system components according to the Metering System



Schedule shown[ in this specification][ on the drawings].

- [ b. Power meter must be socket-mount design.]
- [ c. Power meter must be panel-mounted design. Furnish meters that are semi-flush, back-connected, dustproof, draw-out switchboard type. Provide cases with window removable covers capable of being sealed against tampering. Meters must be of a type that can be withdrawn through approved sliding contacts from fronts of panels or doors without opening current-transformer secondary circuits, disturbing external circuits, or requiring disconnection of any meter leads. Incorporate necessary test devices within each meter and provide means for testing either from an external source of electric power or from associated instrument transformers or bus voltage.]
- d. If existing meter base is usable, the meter base determines meter form factor. If a new meter is being installed, use meter and base form factor of 9S.

\*\*\*\*\*  
NOTE: If the measured load is less than 220 amps,  
use Class 200 meters for direct current reading  
without current transformers.  
\*\*\*\*\*

- [ e. Use Class 200 meters for direct current reading without current transformers.]
- f. Provide meter consisting of a Class 20, transformer rated design.
- g. Provide meter that is rated for use at temperature from -40 [\_\_\_\_\_] degrees Centigrade to +70 [\_\_\_\_\_] degrees Centigrade.
- h. Meter must have NEMA 3R enclosure for surface mounting.

\*\*\*\*\*  
NOTE: Select if the recorded data will be in a  
module inside the meter or external in a data  
logger. The preferred method is to install the  
recording module inside the meter case. Some  
retrofit applications may require an external data  
logger.  
\*\*\*\*\*

- i. Surge withstand must conform to IEEE C37.90.1.
- j. Provide meter with a standard[ 4] [\_\_\_\_\_] -year warranty.
- k. Provide meter in compliance with IEC 62053-22 (Part 21: Static Meter for Active Energy, classes 0.2S and 0.5S), certified by a qualified third party test laboratory.

#### 2.1.2 Voltage Requirements

- a. Furnish meter that is capable of connection to the service voltage phases and magnitude being monitored. If the meter is not rated for the service voltage, provide suitable potential transformers to send an acceptable voltage to the meter.

- b. Provide meter that is capable of connection to the service voltage indicated in the Metering System Schedule:
- c. Provide meter that accepts independent voltage inputs from each phase and is auto-ranging over the full range of input voltages.
- d. Optically isolate voltage input to 2500 volts DC from signal and communications outputs. Use components meeting or exceeding **IEEE C37.90.1** (Surge Withstand Capability).
- e. The Contractor is responsible for determining the actual voltage ratio of each **potential transformer**. Provide transformer conforming to **IEEE C57.13** and the following requirements.
  - (1) . Type: Dry type, of two-winding construction.
  - (2) . Weather: Outdoor or Indoor rated for the application.
  - (3) . Frequency: Nominal 60Hz, 50Hz for those bases that operate on 50Hz.
  - (4) . Accuracy: Plus or minus 0.3% at 60Hz or 0.3% for those systems that operate at 50Hz.

#### 2.1.1.3 **Current** Requirements

- a. Accept independent current inputs from each phase. Install current transformer with a full load rating as shown in the schedule.
- b. Provide single ratio current transformer with an Accuracy Class of [ 0.3][ 0.6] [ 1.2] with a maximum error of +/- [ 0.3%][ 0.6%][ 1.2%] at 5.0 amps.
- c. Current transformer must have:
  - (1) . Insulation Class: Provide 600 volt and below current transformers rated at 10 KV BIL. Provide current transformers for 2400 and 4160 volt service rated at 25 KV BIL.
  - (2) . Frequency: Nominal 60Hz, 50Hz for bases that operate on 50Hz.
  - (3) . Burden: Select burden class for the load.
  - (4) . Phase Angle Range: 0 to 60 degrees.
- d. Provide meter that accepts current input from standard instrument transformers (5A secondary current transformers.)
- e. Current inputs must have a continuous rating in accordance with **IEEE C57.13**.

\*\*\*\*\*

**NOTE:** Since loads in building can vary over time, multi-ratio current transformers allow the flexibility to change the ratio of the current transformer to match the load. The accuracy of current transformer performance decreases when the actual current is in the lower band of its measuring range.

\*\*\*\*\*

- f. Provide multi-ratio current transformer where indicated with a top range equal to or greater than the actual load. The Contractor is responsible for determining the actual ratio of each transformer. Provide current transformer conforming to IEEE C57.13.

#### 2.1.4 Electrical Measurements

Measure and report the following quantities:

\*\*\*\*\*

NOTE: Select each of the following measuring capabilities that are required and include the abbreviation in the Metering System Schedule for each building. Since power meters have a service life greater than 10 years, include optional features that are expected to be used and analyzed over the life of the meter.

\*\*\*\*\*

- a. Kilowatt-hours ("kWh" in Metering Systems Schedule) of consumption. Cumulative.
- b. Kilowatts of demand ("kW" in Metering Systems Schedule). Peak average over a selectable demand interval between 5 and 60 minutes (typically 15 minutes).
- c. Reactive power ("kVAR" in Metering Systems Schedule). Measured over the same interval as the peak kW reading.
- d. Power factor ("PF" in Metering Systems Schedule). Measured over the same interval as the peak kW reading.

\*\*\*\*\*

NOTE: At locations where time of use (TOU) billing is required by the electric company, this specification provides that all TOD meters cover the same periods as defined in the next section.

\*\*\*\*\*

- e. Time of use consumption ("TOU" in Metering Systems Schedule). Kilowatt-hours recorded separately for each period set by programming into the meter. Time periods must be capable of being changed without removal from service. The meter must internally record and store Time of Use data.
  - (1) . [Four (4)] minimum [\_\_\_\_\_] TOU Rates (Registers)
  - (2) . [Twenty (20)][\_\_\_\_\_] Year Calendar
  - (3) . [Two (2)] minimum [\_\_\_\_\_] seasons per year

\*\*\*\*\*

NOTE: Interval recording is an important tool for analyzing energy consumption within a building. For billing purposes, real-time reporting is not required. For non EPACT05 meters, the meter can be read nominally once per month with all recorded

interval data captured at that time. Where real-time data is needed by an energy management control system (EMCS) or other system, the systems may have their own connection to the meter or its own current and potential transformers.

\*\*\*\*\*

- f. Interval recording ("IR" in Metering Systems Schedule). Record kilowatt-hours for each[ 15][\_\_\_\_\_] minute interval and accumulate for[ 30][\_\_\_\_\_] days. Memory for recording the interval readings must be internal to the meter and ANSI C12.19 compliant. Provide time-stamped readings for every measured parameter.

- g. Meter readings must be true RMS.

#### 2.1.5 Meter Accuracy

\*\*\*\*\*

**NOTE: Meters used for billing purposes should generally be held to the same metering accuracies as established standards by utility companies.**

\*\*\*\*\*

Provide the following accuracies. Measure accuracies as percent of reading at standard meter test points.

- a. Provide power meter meeting ANSI C12.20 for Class 0.2 and IEC 62053-22 accuracy requirements.

#### 2.1.6 An on the Meter Display, Output and Reading Capabilities

Include the following output signals.

- a. The meter will have a face display plate and will display every electrical parameter indicated to be recorded. Do not require meters to indicate interval data collected in a data logger with a communications output feature. Display peak values, instantaneous and cumulative values.
- [ b. Include optical output port capable of 9600 bps communication with a hand-held reading device. Provide optical device that is compatible with ANSI C12.18]

\*\*\*\*\*

**NOTE: The following optional features will usually be deleted. These features could be used for connection to an Energy Management and Control System.**

\*\*\*\*\*

- [ c. Include output options for analog milliamp signals.]
- [ d. Provide meter with two channels of analog output, 0-1mA or 4-20mA, for positive[ and negative] watt/hour readings.]
- [ e. Include output option for pulse output. KYZ pulse output related to kWatts/HR.]
- [ f. Provide meter with two form C, dry contact relay outputs for alarm or

control.]

#### 2.1.7 Installation Methods

\*\*\*\*\*  
NOTE: Pad-mounted transformers have proven to be very reliable over a long life span. Installing the meters on the outside of the secondary wiring compartment has become somewhat a standard installation for military facilities, resulting in minimal maintenance. However, meters may be installed on the sides of buildings or within buildings.  
\*\*\*\*\*

a. Transformer mounted (XFMR)

- (1) . Locate meter base outside on the secondary side of the pad-mounted transformer.

\*\*\*\*\*  
NOTE: Do not use the stand-mounted method unless the transformer pad is being poured and the instrumentation conduit can be installed before the pour. Provide a drawing to show details for mounting and routing conduit and wires.  
\*\*\*\*\*

b. Stand-mounted adjacent to transformer ("STAND" in Metering Systems Schedule)

- (1) . Mount meter base on a structural steel pole approximately 4 feet from the transformer pad. See detail on the drawings.

\*\*\*\*\*  
NOTE: Provide a drawing to show details for building mounting and routing conduit and wires.  
\*\*\*\*\*

c. Building mounted ("BLDG" in Metering Systems Schedule)

- (1) . Mount meter base on the side of the existing building near the service entrance. See detail on the drawings.

d. Panel mounted. ("PNL" in Metering Systems Schedule)

- (1) . Mount meter where directed. See detail on the drawings.

e. Common features.

- (1) . PTs (if required for proper voltage range) and physically connect CTs to the service entrance cables inside the service entrance disconnect enclosure.

#### 2.1.8 Disconnecting Switches

\*\*\*\*\*  
NOTE: Shorting-type wiring blocks are recommended to allow connections to be corrected and changed  
\*\*\*\*\*

without the necessity of disconnecting power to the transformer, resulting in another power outage to the building being served.

\*\*\*\*\*

- a. Provide disconnecting wiring blocks between the current transformer and the meter. Build a shorting mechanism into the wiring block to allow the current transformer wiring to be changed without removing power to the transformer. Locate the wiring blocks where they are accessible without the necessity of disconnecting power to the transformer. For multi-ratio current transformers, provide a shorting block from each tap to the common lead.
- b. Equip voltage-monitoring circuits with disconnect switches to isolate the meter base or socket from the voltage source.

\*\*\*\*\*

**NOTE: If programming capability is not required, omit the following section.**

\*\*\*\*\*

#### 2.1.9 Meter Programming

- a. Provide power meter that is programmable by software supplied by the meter manufacturer.
- b. Provide user-friendly software with Windows-compatible interface.
- c. Operate software on [Windows][\_\_\_\_\_] operating systems.
- d. Provide software that allows the user to configure the meter, troubleshoot meter, query and display meter parameters and configuration data and stored values.
- e. Provide meter firmware that is upgradeable through one of the communications ports without removing the unit from service.

### 2.2 COMMUNICATIONS

\*\*\*\*\*

**NOTE: Communications features may not be needed. Data logging of one month of data may be recorded inside the meter. Recorded data may be read simply by a handheld instrument, if read daily.**

\*\*\*\*\*

#### 2.2.1 Communications Methods

##### 2.2.1.1 Optical Port

Communicate with a hand-held reading device according to the following requirements.

- a. Communications standards
  - (1) . ANSI C12.18
  - (2) . MV90 protocol

(3) . ANSI C12.20

b. Read operations

(1) . Current kWh values

(2) . Demand (kW) values since last reset

(3) . Last reset value

(4) . Meter status

[ (5) . Load profile]

c. Write operations

(1) . Meter setup

2.2.1.2 Serial Port

Provide serial port for connection to modem module where required in this specification.

[ a. On-Board serial port types]

[ (1) . RS232]

[ (2) . \[RS485]]

2.2.1.3 Ethernet

For those meters using the Ethernet, send logged information using open standard Internet Protocols.

a. On-board Ethernet port support

(1) . HTTP

(2) . SMTP

(a) Modbus

b. Distribute stored data by

(1) . FTP

[ (2) . E-Mail]

[ (a) On-board web server]

2.2.2 Communications Protocols and Methods

Use communications protocols and methods that are native to the meter. Provide [communications module](#)(s) as required to accomplish the following.

a. Include an IR port ("IR" in Metering Systems Schedule) for communication to external devices such as handheld readers that support a minimum speed of 9600 baud.

- b. [Include[ one][ RS-232 ("RS232" in Metering Systems Schedule)] or[ one][ RS-485 ("RS485" in Metering Systems Schedule)] digital communication port. Provide user configurable port with regard to speed, protocol, address, and other communications parameters that support a minimum communication speed of 9600 baud for the RS232 port.]
- [ c. Provide meter with a port that can be configured as a[ 10/100 Base-T Ethernet port ("BaseT" in Metering Systems Schedule)]]
  - [ (1) . A communication module that converts serial RS232 or RS485 to Ethernet will be acceptable.]
- [ d. Auto Answer minimum 1200 baud internal modem ("A56K" in Metering Systems Schedule). Include automatic data buffering to provide faster, more reliable communications and the ability to automatically answer on a connected line.]
- [ e. Equip meter with one pulse output channel ("Pulse" in Metering Systems Schedule) that can be configured for operation as KYZ pulse output.]

### 2.2.3 Communications Channels Surge Protection

Protect communications equipment against surges induced on its communications channels. Protect communication interfaces to all field equipment to meet the requirements of IEEE C37.90.1 or the requirements of IEC 61000-4-5, test level 4, while the equipment is operating. Do not use fuses for surge protection. For metallic cables and conductors which serve as communications channels between buildings, install surge protection at equipment rated for the application at each end, within 3 feet 0.9 meters of the building cable entrance. Provide surge protectors meeting the requirements of the applicable extension of ANSI C62 (for example, ANSI C62.61).

\*\*\*\*\*  
**NOTE: Communication methods, modules and software can be used for automatic meter reading (AMR). AMR may not be needed. If automatic meter reading (AMR) is to be implemented, considerable coordination of the communications sending, receiving and protocols will be required.**  
 \*\*\*\*\*

## 2.3 METER DATA PROTOCOL

Provide power meters that have communicating data protocols native or provide in supplemental modules to communicate with the communications methods that follow.

### 2.3.1 Open Protocol

\*\*\*\*\*  
**NOTE: This section should be modified to be facility specific.**  
 \*\*\*\*\*

Support the following open protocols. Verify that the meter native protocol is consistent with the facility data recording and communication and data storage system. Provide additional converters and modules as required for a complete measurement, recording, communicating and data



storage system.

- a. Provide meter that is fully supported by MV-90 software system or existing AMR software that is MV-90 compatible.
- b. For systems that use proprietary software, an alternative, competitive software system must be available.

Systems capable of using more than one brand of commercially available meters are expected. In addition, if proprietary meter reading software is used, meters are to be capable of being read by more than one manufacturer's software.

## 2.4 SPARE PARTS

### 2.4.1 Parts List

Provide spare parts as follows:

- a. Power meter - two for each type used.
- b. Current transformer - three for each type used.
  - c. Potential transformer - three for each type used.
- c. Communications module - one for each type used.
- d. Protocol module - one for each type used.
- e. Other electronic and power components - one for each type used.

## 2.5 METERING SYSTEM SCHEDULE

\*\*\*\*\*  
NOTE: Each building should be listed on a separate row. Identify the characteristics for the specific meter and communications method for each building. The following completed data is an example only. Delete existing values.  
\*\*\*\*\*

Metering System Schedule is available at  
<http://www.wbdg.org/ffc/dod/unified-facilities-guide-specifications-ufgs/forms-graphic>

\*\*\*\*\*  
NOTE: Provide a drawing to show locations and details for mounting and routing conduit and wires. Identify CT ratio and multi-tap ratios if known.  
\*\*\*\*\*

## PART 3 EXECUTION

### 3.1 INSTALLATION

Perform electrical installations conforming to IEEE C2, NFPA 70, and to the requirements specified herein. Provide new equipment and materials unless indicated or specified otherwise.

### [3.1.1 Existing Condition Survey

\*\*\*\*\*  
**NOTE: Remove the following section if existing  
condition surveys are not required.**  
\*\*\*\*\*

Perform a field survey, including inspection of all existing equipment, resulting clearances, and new equipment locations intended to be incorporated into the system, and furnish an existing conditions report to the Government. Identify those items that are non-workable as defined in the contract documents. The Contractor is responsible for repairs of modifications necessary to make the system perform as required.

### ]3.1.2 Scheduling of Work and Outages

\*\*\*\*\*  
**NOTE: Installation of current transformers and  
potential transformers will require that power be  
disconnected from the transformer and/or building.  
Provide coordination steps for the work and require  
Contractor to perform the work after normal hours.**  
\*\*\*\*\*

The Contract Clauses govern regarding permission for power outages, scheduling of work, coordination with Government personnel, and special working conditions.

### [3.2 FIELD APPLIED PAINTING

Where field painting of enclosures is required to correct damage to the manufacturer's factory-applied coatings, provide manufacturer's recommended coatings and apply in accordance with manufacturer's instructions.

### ]3.3 FIELD QUALITY CONTROL

#### 3.3.1 Performance of [Acceptance Checks and Tests](#)

##### 3.3.1.1 Meter Assembly

###### a. Visual and mechanical inspection

- (1) . Compare equipment nameplate data with specification and approved shop drawings.
- (2) . Inspect physical and mechanical condition.
- (3) . Inspect all bolted electrical connections for high resistance using low-resistance ohmmeter, verifying tightness of accessible bolted electrical connections by calibrated torque-wrench method.
- (4) . Verify grounding of metering enclosure.
- (5) . Verify the presence of surge arresters.
- (6) . Verify that the CT ratio and the PT ratio are properly included in the meter multiplier or the programming of the meter.

b. Electrical tests

- [ (1) . Calibrate watthour meters according to manufacturer's published data.]
- (2) . Verify that correct multiplier has been placed on face or meter where applicable.
- (3) . Prior to system acceptance, the Contractor will demonstrate and confirm the meter is properly wired and is displaying correct and accurate electrical information.

3.3.1.2 Current Transformers

a. Visual and mechanical inspection

- (1) . Compare equipment nameplate data with specification and approved shop drawings.
- (2) . Inspect physical and mechanical condition.
- (3) . Verify correct connection.
- (4) . Inspect all bolted electrical connections for high resistance using low-resistance ohmmeter, verifying tightness of accessible bolted electrical connections by calibrated torque-wrench method.
- (5) . Verify that required grounding and shorting connections provide good contact.

b. Electrical tests

- (1) . Perform resistance measurements through all bolted connections with low-resistance ohmmeter, if applicable.
- (2) . Perform insulation-resistance test.
- (3) . Perform a polarity test.
- (4) . Perform a ratio-verification test.

3.3.1.3 Potential Transformers

a. Visual and mechanical inspection

- (1) . PT's are rigidly mounted.
- (2) . PT's are correct voltage.
- (3) . Verify that adequate clearances exist between primary and secondary circuit.

b. Electrical tests

- (1) . Perform a ratio-verification test.

3.3.2 Follow-Up [System Function Verification](#)

Upon completion of acceptance checks and tests, the show by demonstration

in service that circuits and devices are in good operating condition and properly performing the intended function. As an exception to requirements stated elsewhere in the contract, give the Contracting Officer 5 working days' advance notice of the dates and times of checking and testing.

### 3.3.3 Training

Conduct a training course for meter configuration, operation, and maintenance of the system as specified. Orient the training for all components and systems installed under this contract. Deliver training manuals for [\_\_\_\_\_] trainees with two additional copies delivered for archiving at the project site. Furnish all audiovisual equipment and all other training materials and supplies. A training day is defined as eight hours of classroom instruction, including two 15-minute breaks and excluding lunchtime, Monday through Friday, during the daytime shift in effect at the training facility. For guidance in planning the required instruction, assume that attendees have a high school education or equivalent, and are familiar with utility systems. Obtain approval of the planned training schedule from the Government at least 30 days prior to the training.

a. Training: Teach the course at the project site within thirty days after completion of the installation for a period of one [\_\_\_\_\_] day(s). A maximum of [6][\_\_\_\_\_] personnel will attend the course. The training includes:

- (1) . Physical layout of each piece of hardware.
- (2) . Meter configuration, troubleshooting and diagnostics procedures.
- (3) . Repair instructions.
- (4) . Preventive maintenance procedures and schedules.
- (5) . Testing and calibration procedures.

-- End of Section --