
USACE / NAVFAC / AFCEC UFGS-41 22 23.19 (May 2025)

Preparing Activity: NAVFAC

Superseding
UFGS-41 22 23.19 (May 2020)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2025

SECTION TABLE OF CONTENTS

DIVISION 41 - MATERIAL PROCESSING AND HANDLING EQUIPMENT

SECTION 41 22 23.19

MONORAIL HOISTS

05/25

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 DEFINITIONS
- 1.3 SYSTEM DESCRIPTION
 - 1.3.1 Crane Design Criteria
 - 1.3.1.1 General
 - 1.3.1.2 Classification
 - 1.3.1.3 Rated Speeds
- 1.4 VERIFICATION OF DIMENSIONS
- 1.5 SUBMITTALS
- 1.6 QUALITY ASSURANCE
 - 1.6.1 Manufacturer Qualification
 - 1.6.2 Pre-Delivery Inspections
 - 1.6.2.1 Inspection of Hook Assembly
 - 1.6.2.1.1 Hook Non-Destructive Test (NDT)
 - 1.6.3 Drawings: Monorail Crane System
 - 1.6.4 Design Data: Load and Sizing Calculations
 - 1.6.5 Certificates
 - 1.6.6 Welding Qualifications and Procedure
- 1.7 CRANE SAFETY
 - 1.7.1 Nuclear Safety Analysis

PART 2 PRODUCTS

- 2.1 MATERIALS
 - 2.1.1 General
 - 2.1.2 Nameplates
 - 2.1.3 Capacity Marking
 - 2.1.4 Safety Warnings
- 2.2 STRUCTURAL REQUIREMENTS
 - 2.2.1 Structural Connections
 - 2.2.2 Monorail Track System
 - 2.2.3 End Stops

- 2.2.4 Bumpers
- 2.2.5 Additional Provisions for Outside Service
- 2.3 MECHANICAL REQUIREMENTS
 - 2.3.1 Threaded Fasteners
 - 2.3.2 Hoist
 - 2.3.2.1 Hoist Brakes
 - 2.3.2.2 Load Block and Hook
 - 2.3.2.3 [Hoisting Rope][Hoisting Chain]
 - 2.3.2.4 Drum
 - 2.3.2.5 Sheaves
 - 2.3.3 Travel Drives
 - 2.3.3.1 Trolley Drives
 - 2.3.4 Travel Brakes
 - 2.3.5 Wheels
 - 2.3.6 Drip Pans
 - 2.3.7 Hoist Capacity Overload Protection
 - 2.3.8 Air Requirements
 - 2.3.8.1 Hoist Pneumatic Limit Switches
 - 2.3.8.2 Air Supply
 - 2.3.8.3 Operator Air Controls
 - 2.3.9 Wind Speed Indicating Device
- 2.4 ELECTRICAL REQUIREMENTS
 - 2.4.1 Motors
 - 2.4.2 Controls
 - 2.4.3 Electrical Overcurrent Protection
 - 2.4.3.1 Conductors
 - 2.4.4 Limit Switches
 - 2.4.5 Operator Controls
 - 2.4.5.1 Pendant Push-button Station
 - 2.4.5.2 Radio Control System
 - 2.4.6 Runway Conductor System
 - 2.4.7 Capacity Overload Protection
 - 2.4.8 Enclosures
 - 2.4.9 Warning Devices
 - 2.4.10 Pilot Devices
 - 2.4.11 Cybersecurity
- 2.5 PAINTING SYSTEM
- 2.6 IDENTIFICATION PLATES
 - 2.6.1 Markings on Crane, Trolley, and Hook
- 2.7 ELECTRICAL ASSEMBLY

PART 3 EXECUTION

- 3.1 EXAMINATION
- 3.2 SHOP ASSEMBLY AND TESTS
- 3.3 ERECTION AND INSTALLATION
 - 3.3.1 Electrical Adjustments
 - 3.3.2 Field Welding
 - 3.3.3 Field Painting
- 3.4 FIELD QUALITY CONTROL
 - 3.4.1 Post-Erection Inspection
 - 3.4.2 Operational Tests
 - 3.4.2.1 No-Load Test
 - 3.4.3 Test Data
 - 3.4.4 Hook Tram Measurement
 - 3.4.5 Load Tests
 - 3.4.5.1 Wire Rope Run-In
 - 3.4.5.2 Manual Chain Hoist Load Control
 - 3.4.5.3 Rated Load Test

- 3.4.5.3.1 Hoist
- 3.4.5.3.2 Trolley
- 3.4.5.3.3 Trolley Loss of Power Test
- 3.4.5.4 Overload Test
 - 3.4.5.4.1 Hoist
 - 3.4.5.4.2 Trolley
- 3.5 MANUFACTURER'S FIELD SERVICE REPRESENTATIVE
- 3.6 OPERATION AND MAINTENANCE MANUALS
- 3.7 FIELD TRAINING
- 3.8 FINAL ACCEPTANCE

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC UFGS-41 22 23.19 (May 2025)

Preparing Activity: NAVFAC

Superseding
UFGS-41 22 23.19 (May 2020)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2025

SECTION 41 22 23.19

MONORAIL HOISTS 05/25

NOTE: This guide specification covers requirements for monorail hoists with manual, electric, or air powered lifting chains or wire rope; with or without manual, electric or air powered trolleys, and other accessories; suitable for indoor or outdoor use in general purpose service, with crane capacities less than 9 metric tons 10 tons 9,000 kg 20,000 pounds. The SI units in this specification are direct (soft) conversion from the U.S. customary units.

Use this guide specification to specify cranes that are procured as part of a building construction contract for such applications as machine shops, warehouses, and other areas that do not require specialized weight handling equipment.

This guide specification incorporates the design criteria and requirements identified in NAVCRANECEN INSTRUCTION 11450.2A (December 2018). Contact Navy Crane Center for more information (Naval Facilities Engineering Command, Navy Crane Center, Building 491, Norfolk Naval Shipyard, Portsmouth, Va., 23709-5000).

NOTE: Forward all procurement of OET systems at Naval Shore based activities with rated capacities of 9000 kg 20,000 pounds or greater or for use in specialized applications (e.g., ordnance handling, molten metal handling, special purpose service as defined in NAVSEA Publication 0989-030-7000, hazardous/explosive area environments, or precision handling operations requiring complex or synchronized lifting capacity) to: Naval Facilities Engineering Command, Navy Crane Center, Building 491, Norfolk Naval Shipyard, Portsmouth, Va., 23709-5000. (See NAVCRANECEN INSTRUCTION 11450.1C of 11 July 2019).

NOTE: This guide specification includes tailoring options for NAVFAC, which includes technical requirements specific to the Navy and Marine Corps. Crane procurements for the Navy and Marine Corps must select the NAVFAC tailoring option.

Crane tailoring options are included for the Air Force and outdoor environments. "General Purpose Service" and indoor operation is the default crane condition unless an alternate specialized tailoring option is selected.

Selection or deselection of a tailoring option (select view-tailoring options) will include or exclude that option in the section. Specific project editing is still required for the resulting section.

NOTE: Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in the respective project, whether or not brackets are present. Of particular note, if procurement is to go on an existing monorail system, all references to installing and testing a new monorail and associated equipment, such as end stops, must be removed.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

NOTE: Control types and systems may be specified as follows:

1. Remote or Pendant Crane Controls or a combination of the two can be provided for electric powered cranes. Pneumatic cranes must be pendant controlled.
2. Alternating current (AC) control systems must be specified for electric powered cranes. The vast majority of new cranes are AC powered and AC controlled.

NOTE: The RFP must provide the relevant dimensions and load data for the crane. See "Crane Inquiry Data Sheet" in CMAA 74 section 6.1 or see "Crane Information Form" at the following Navy Crane Center link:

<https://ncc.navfac.navy.mil/Popular-Links/DOWNLOADS/>

Projects that are routed through Navy Crane Center should be accompanied by a completed Crane Information Form (CIF) per the above link.

NOTE: Indicate on the plan drawings a schematic line for the location of the centerline of monorail track beam, including curves and switches. Only indicate the dimensions that are critical to locating points such as the end of the travel range of the hoist operating hook at each end of the track beam. Indicate any critical clearance requirements for the area adjacent the monorail track beam.

Indicate on the elevation drawings a generic elevation for the monorail beam. Only indicate the dimensions that are critical to locating points such as the ends of the vertical travel range of the hoist operating hook. Indicate any clearance requirements for the area above the monorail track beam.

When there is one hoist on one monorail system, the capacity rating of the monorail track beam and beam hangers must be equal to or greater than the hoist capacity. When there is more than one hoist on the monorail track beam, design and construct the monorail track beam and beam hangers for the most stressful positioning of the hoists on the track beam.

Indicate on the plan drawings the electrical junction box location (including mounting height).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of

the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN INSTITUTE OF STEEL CONSTRUCTION (AISC)

AISC 360 (2016) Specification for Structural Steel Buildings

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

ASME B1.1 (2024) Unified Inch Screw Threads (UN, UNR, and UNJ Thread Form)

ASME B30.10 (2024) Hooks

ASME B30.16 (2022) Overhead Underhung and Stationary Hoists

ASME B30.17 (2020) Overhead and Gantry Cranes (Top Running Bridge, Single Girder, Underhung Hoists)

ASME B30.30 (2019) Ropes

ASME HST-1 (2023) Performance Standard for Electric Chain Hoists

ASME HST-2 (2023) Performance Standard for Hand Chain Manually Operated Chain Hoists

ASME HST-4 (2021) Performance Standard for Overhead Electric Wire Rope Hoists

ASME HST-5 (2024) Performance Standard for Air Chain Hoists

ASME HST-6 (2020) Performance Standard for Air Wire Rope Hoists

ASME NUM-1 (2023) Rules for Construction of Cranes, Monorails, and Hoists (With Bridge or Trolley or Hoist of the Underhung Type)

AMERICAN WELDING SOCIETY (AWS)

AWS D1.1/D1.1M (2025) Structural Welding Code - Steel

AWS D14.1/D14.1M	(2019) Specification for Welding of Industrial and Mill Cranes and Other Material Handling Equipment
ASTM INTERNATIONAL (ASTM)	
ASTM A275/A275M	(2023) Standard Practice for Magnetic Particle Examination of Steel Forgings
ASTM A1023/A1023M	(2021) Standard Specification for Stranded Carbon Steel Wire Ropes for General Purposes
ASTM E543	(2021) Standard Specification for Agencies Performing Non-Destructive Testing
ASTM F436/F436M	(2024) Standard Specification for Hardened Steel Washers Inch and Metric Dimensions
ASTM F3125/F3125M	(2019) Standard Specification for High Strength Structural Bolts and Assemblies, Steel and Alloy Steel, Heat Treated, Inch Dimensions 120 ksi and 150 ksi Minimum Tensile Strength, and Metric Dimensions 830 MPa and 1040 MPa Minimum Tensile Strength
BRITISH STANDARDS INSTITUTION (BSI)	
BS ISO 4309	(2017) Cranes - Wire Ropes - Care and Maintenance, Inspection and Discard
CRANE MANUFACTURERS ASSOCIATION OF AMERICA (CMAA)	
CMAA 74	(2020) Specifications for Single Girder Cranes
ELECTRIFICATION AND CONTROLS MANUFACTURERS ASSOCIATION (ECMA)	
ECMA 15	(2018) Cable-less Controls for Electric Overhead Traveling Cranes
MATERIAL HANDLING INDUSTRY OF AMERICA (MHI)	
MHI MH27.1	(2016) Specifications for Underhung Cranes and Monorail Systems
NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)	
NEMA 250	(2020) Enclosures for Electrical Equipment (1000 Volts Maximum)
NEMA ICS 2	(2000; R 2020) Industrial Control and Systems Controllers, Contactors, and Overload Relays Rated 600 V
NEMA ICS 3	(2005; R 2010) Medium-Voltage Controllers Rated 2001 to 7200 V AC

NEMA ICS 5	(2017) Industrial Control and Systems: Control Circuit and Pilot Devices
NEMA ICS 8	(2011) Crane and Hoist Controllers
NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)	
NFPA 70	(2023; ERTA 1 2024; TIA 24-1; TIA 25-2) National Electrical Code
RESEARCH COUNCIL ON STRUCTURAL CONNECTIONS (RCSC)	
RCSC A348	(2020) RCSC Specification for Structural Joints Using High-strength Bolts
SOCIETY FOR PROTECTIVE COATINGS (SSPC)	
SSPC SP 6/NACE No.3	(2007) Commercial Blast Cleaning
SOCIETY OF AUTOMOTIVE ENGINEERS INTERNATIONAL (SAE)	
SAE J429	(2014) Mechanical and Material Requirements for Externally Threaded Fasteners
SAE J995	(2017) Mechanical and Material Requirements for Steel Nuts
U.S. AIR FORCE (USAF)	
AFMAN 91-118	(2010) Safety Design and Evaluation Criteria for Nuclear Weapon Systems
U.S. GENERAL SERVICES ADMINISTRATION (GSA)	
FS RR-W-410	(2022; Rev J) Wire Rope and Strand
U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)	
29 CFR 1910	Occupational Safety and Health Standards
29 CFR 1910.306	Specific Purpose Equipment and Installations
U.S. NAVAL SEA SYSTEMS COMMAND (NAVSEA)	
NAVSEA T9074-AS-GIB-010/271	(2014; Revision 1) Requirements for Nondestructive Testing Methods

1.2 DEFINITIONS

- a. Dead Loads: The weight of the trolley unit including the hoist or other components that are part of the trolley unit.
- b. Lifted Load: The load consisting of the rated load and the weight of lifting devices attached to the crane such as the load block, bucket, or other supplemental devices.
- c. Monorail Track: The track system along which the crane operates

horizontally, including track hangar rods, track connection devices, and runway structural supports.

- d. Original Equipment Manufacturer (OEM): the Company that produced the part or original equipment.
- e. Packaged Hoist: A commercially designed and mass produced hoist characterized by the motor, gearing, brake(s), and drum contained in a single package often connected by the use of c, d, or p-face flanges.
- f. Patented Track: A generic term referring to track built in accordance with MHI MH27.1 utilizing a composite track section incorporating a proprietary bottom flange shape. For this crane system, it is provided for the monorail track.
- g. Pendant: A control for a hoist or a crane. The pendant hangs from the hoist by a cable at a height that is easy for the operator to reach.
- h. Rated Load: The maximum working load suspended under the load hook.
- i. Standard Commercial Cataloged Product: A product, which is currently being sold, or previously has been sold, in substantial quantities to the general public, industry or Government in the course of normal business operations. Models, samples, prototypes or experimental units do not meet this definition. The term "cataloged" as specified in this section is defined as "appearing on the manufacturer's published product data sheets. These data sheets must have been published or copyrighted prior to the issue date of this solicitation and have a document identification number or bulletin number.

1.3 SYSTEM DESCRIPTION

NOTE: Remove the following sentence if the track supporting structure is existing. If the track supporting structure is to be installed, ensure Section 05 12 00 STRUCTURAL STEEL is included in the Request for Proposal (RFP).

The monorail track is covered in STRUCTURAL REQUIREMENTS.

[The requirements for the structures supporting the monorail track are specified in Section 05 12 00 STRUCTURAL STEEL, and must conform to AISC 360.

1.3.1 Crane Design Criteria

NOTE: Cranes installed outside the United States are still required to meet the requirements of U.S. standards as well as the features and characteristics specified.

When necessary, the design may be able to use the host nation's consensus standards in lieu of U.S. standards, with prior approval (e.g., EN, ISO, or

JIS in lieu of ASME). Contact Navy Crane Center for approval of foreign design standards prior to issuing the RFP. An equivalency study will be required from the contractor to justify use of the international standard

NOTE: Clearly show the area of hook coverage, track dimensions, rail size, hook vertical travel, clear hook height, and lifting capacity on drawings.

Crane(s) will operate in the given spaces and match the travel path indicated. Hook coverage, hook lift, clearances, lifting capacity, and load test weight must not be less than that indicated. Provide loaded hook coverage to the maximum extent possible. Provide a crane that maintains minimum clearances of 50 mm 2 inch lateral and 76 mm 3 inch overhead between the crane and obstructions and as required in ASME B30.17 and CMAA 74 or MHI MH27.1, as appropriate.

1.3.1.1 General

NOTE: For NAVY, crane capacity is limited to less than 9,000 kg 20,000 pounds, since Navy Crane Center is required to be contacted for cranes with higher capacities.

NOTE: Add number of hoists, building name, bay, and hoist rated load capacity in metric tons tons.

NOTE: For NAVFAC projects, capacity markings MUST be expressed in pound units and may have additional markings in metric units if the crane is located in Europe or Asia.

Include the following: Number of hoists [____], located in building identified as [____],[bay [____],] with the capacity expressed in [____] metric tons tons, for each hoist. Also clearly locate and identify each hoist and system components.

1.3.1.2 Classification

NOTE: Hoists can be electric powered (electric motor driven), pneumatic (air motor driven), or manually operated via hand chain.

Trolleys can be powered (electric or air), plain (pull-type via rope), or hand chain-operated (geared).

Plain type trolleys are recommended where trolley

motion is infrequent or relatively short. Due to the force required to manually operate this type of trolley, plain pull-type trolleys have a maximum recommended load of 3000 kg 3 tons with a hook lift less than 6 meters 20 feet above the operator's floor level. Hand chain-operated (geared type) trolleys are recommended where plain type trolleys would be impractical due to either a high capacity or high hook lift height. Motor operated trolleys are recommended where the operating frequency, distance traveled, or the type of load being handled would cause unsatisfactory operation if the trolley were of the plain or hand chain-operated type.

NOTE: Minimize the lowest overall crane depth for the configuration.

Electric powered cranes may have wire connected controls (pendants) or wireless controls. Coordinate the selection of wire connected controls and wireless controls with the users. When wireless controls are provided, coordinate the frequency of wireless controls with the local frequency manager.

Provide a monorail system with a(n)[electric powered][manual][air powered] hoist and[powered][manual plain type (pull operated)][manual hand chain (gear operated)] trolley. The hoist(s) must be designed for operation in an[indoor][outdoor] environment, general purpose service, meeting the requirements of ASME B30.16 and ASME B30.17, with an ambient temperature range of [_____] to [_____] degrees Celsius Fahrenheit. The hoist must have a minimum vertical hook lift of [_____] meters feet and as specified herein.

The hoist must be[pendant controlled][radio controlled][manually controlled] and operate in the spaces and within the loading conditions indicated. Provide a hoist, including hooks and hoisting rope or load chain, that is able to clear permanent obstructions in all operating configurations. The hoist must operate on[manual][[_____] -volts AC, [60 Hz] [_____] , [three][single] phase][[6][[_____] bar [90][[_____] psig air] power source. Maximum trolley wheel loads (without impact) due to dead loads and lifted loads, with the trolley in any position, must not cause a more severe loading condition in the track support structure.

1.3.1.3 Rated Speeds

NOTE: Slow full-load operating speeds invariably provide improved load control and increased productivity.

NOTE: Manual plain type (pull operated) trolleys are recommended where trolley motion is infrequent or the distance is short, providing good load spotting ability and use for hoists of 3 metric tons

3 tons capacity and under. Plain type trolleys are not recommended for hoists of 3 metric tons 3 tons capacity and greater, or for tracks higher than 6 m 20 feet above the floor level. Motor operated trolleys are recommended where the operating frequency, travel distance, rated load, or beam elevation makes other types of trolleys impractical.

Unless otherwise specified, the nominal rated maximum speed of the hoists and trolley will be the manufacturer's standard within the limits of Table 2 of ASME HST-1, HST-4, HST-5, HST-6, as applicable. For higher tonnage ratings, consult with the manufacturer(s).

NOTE: Specify the maximum rated speed under full load for the main hoist and trolley.

1. Hoist speeds must conform to the recommendations of CMAA 74 or ASME tables.

2. Trolley travel speed must conform to the recommendations of CMAA 74. A table of suggested hoisting and travel speeds can be found at the end of section 6 in CMAA 74. Trolley travel speed must not exceed the maximum speed that the floor walking, crane pendent control operator can comfortably negotiate in a work area, approximately 750 mm/s 150 ft/min.

NOTE: Recommend "Medium" rated speeds, where appropriate. Another consideration for operating speeds is the distance traveled per minute (e.g., 20 ft hook lift height corresponds to hook lift speed of 20 fpm). Consider limiting trolley travel speeds when operation occurs over shorter distances (e.g., for a 50 ft long monorail track, a trolley travel speed of 50 fpm may be more appropriate than the 80 fpm "medium" speed).

Most projects with powered travel will have a minimum and maximum speed entered. The speeds can be the same whether using two speed motors with magnetic controls or variable frequency drive controls.

Single speed motors will be selected if electronic controls are specified in paragraph CONTROLS. For 1-speed motors, only enter a maximum operating speed.

Two speed motors will be selected if magnetic controls are specified in paragraph CONTROLS. For 2-speed motors, recommend selecting a minimum speed that is 1/4 to 1/3 the maximum speed.

For VFD controlled hoists, a common minimum speed selection is 1/10th of maximum speed. Cranes using variable frequency drive controls are more flexible regarding speed selection.

Common maximum speed ranges:

Wire Rope Hoists IAW ASME HST-4 (fpm): 15 - 40

Chain Hoists IAW ASME HST-1 (fpm): 8 - 30

Trolley (fpm): 30 - 125

Cranes using variable frequency drive controls are more flexible regarding speed selection than magnetic contactor controls.

Provide the crane with rated (maximum) speeds within plus or minus 10 percent (in meters/second feet/min) for the main hoist and trolley at the rated load as specified in the table below. The minimum speed must not exceed the values listed.

Rated Speeds meters/second feet/min		
Description	Minimum	Maximum
Main Hoist	[_____] [manual]	[_____] [manual]
Trolley	[_____] [manual]	[_____] [manual]

The hook lift and travel speeds must be the manufacturer's standard within the limits specified at rated capacity. The minimum speeds must be met using standard control settings without slow speed selection, if provided.

1.4 VERIFICATION OF DIMENSIONS

The Contractor is responsible for the coordination and proper relation of their work to the building structure and to the work of all trades. Coordinate with the crane support structure design, where applicable, to provide the desired crane operating envelope (i.e., hook envelope and hook height). Verify all dimensions of the building that relate to fabrication of the monorail system and notify the Contracting Officer of any discrepancy before finalizing the crane order.

1.5 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item if the submittal is sufficiently important or

complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Monorail Crane System; G, [_____]

[Complete Schematic Wiring Diagram; G, [_____]

][Complete Pneumatic Diagram; G, [_____]

] SD-03 Product Data

NOTE: Each catalog cut must be marked-up to fully identify the model or size/rating of the item and supplemental pages with data or information to demonstrate specification compliance.

Hoist Brakes; G, [_____]

Travel Brakes; G, [_____]

Hoist and Trolley Units; G, [_____]

[Hoisting Rope; G, [_____]

][Hoisting Chain; G, [_____]

] *****

NOTE: The capacity overload protection submittal is only applicable to manual and air hoists. Do not

```

    add for electrical powered hoists
*****

[      Capacity Overload Protection; G, [_____]
] *****
    NOTE:  The Operator Controls submittal is only
    applicable to air hoists.  Do not add for electrical
    powered hoists or manual hoists.
*****

[      Operator Air Controls; G, [_____]

[      End Stops; G, [_____]

    Bumpers; G, [_____]

[      Monorail Track System; G, [_____]

][     Painting System; G, [_____]

] *****
    NOTE:  Limit switches do not exist for manual
    hoists, but are required on all electrical and
    pneumatic hoists.  Some pneumatic chain hoists do
    not have hoist limit switches or overload
    protection, but instead utilize a slip clutch as
    allowed in HOIST CAPACITY OVERLOAD PROTECTION and
    OVERLOAD PROTECTION.
*****

[      Pneumatic Limit Switches; G, [_____]

] *****
    NOTE:  The below submittals are Electrical and are
    not applicable to manual and air hoists that do not
    have any electronics or electrical power supply.
*****

[      Motors; G, [_____]

    Enclosures; G, [_____]

    Circuit Breakers; G, [_____]

    Disconnect Switch; G, [_____]

    Fuses; G, [_____]

    Limit Switches; G, [_____]

[      Variable Frequency Drives; G, [_____]

][     Radio Control System; G, [_____]

][     Pendant Push-Button Station; G, [_____]

][     Control Parameter Settings; G, [_____]

```



```

][      Pilot Devices; G, [_____]
]
]      Warning Devices; G, [_____]
[
]      Runway Conductor System; G, [_____]
]
]      Overload Protection; G, [_____]
]      SD-05 Design Data
]
]      Load and Sizing Calculations; G, [_____]
]
]      SD-06 Test Reports
[
]      Hook Non-Destructive Test (NDT); G, [_____]
]
]      Post-Erection Inspection; G, [_____]
]
]      Operational Tests; G, [_____]
]
]      Hook Tram Measurement; G, [_____]
]
]      Load Tests; G, [_____]
]
]      SD-07 Certificates
[
]      Wire Rope; G, [_____]
][
][      Load Chain; G, [_____]
][
][      Monorail System; G, [_____]
]
]      Hazardous Material; G, [_____]
[
]      Loss of Power Test; G, [_____]
]
]      Overload Test; G, [_____]
]
]      Brake Adjustment Record; G, [_____]

```

NOTE: The cybersecurity supplement submittal is not necessary for cranes which do not have electronic systems, such as manual or pneumatic hoists and trolleys.

In addition, the cybersecurity submittal is not required for electric cranes which are pendant controlled (vice wireless/radio controllers) AND utilize magnetic contactors (vice microprocessors/VFDs), provided there are no other microprocessors on the equipment.

The Cybersecurity Supplement submittal is required for cranes with microprocessors (e.g., VFDs or computers) or wireless controllers.

```

[      Cybersecurity Supplement; G

```

] SD-10 Operation and Maintenance Data

Operation and Maintenance Manuals, Data Package 3; G, [_____]

1.6 QUALITY ASSURANCE

1.6.1 Manufacturer Qualification

Monorail System, including sub-system components manufactured by vendors, must be designed by, or directly supervised by, a registered professional engineer (PE). PE licensing must be by a board or agency authorized to license and register professional engineers. The PE may be a Contractor's regular employee or a consultant. The PE's review and attestation of specification compliance and professional responsibility must be signified by their PE original seal and dated signature on the final drawings. The professional engineers must only undertake and perform work under this contract in the branch(s) of engineering in which they are licensed.

1.6.2 Pre-Delivery Inspections

Contractor is responsible for performance of quality control inspections, testing, and documentation.

1.6.2.1 Inspection of Hook Assembly

NOTE: For NAVY, carbon steel hooks require magnetic-particle type inspections and non-ferrous hooks (typically anti-spark hooks for hazardous areas) require liquid penetrant type inspection.

NAVY acceptance criterion is no linear indications greater than 1.5 mm 1/16 inch. General recommendation is that linear indications greater than 1.5 mm 1/16 inch not be allowed.

Inspect hook by a magnetic-particle type inspection prior to delivery. Furnish documentation of hook inspection to Contracting Officer prior to field operational testing.

Acceptance standard is no defects. A defect is defined as a linear indication for which the largest dimension is greater than [1.5][3] mm [1/16][1/8] inch [_____] long. Welding repairs of hook are not permitted. A hook showing linear indications, damage, or deformation is not acceptable.

[1.6.2.1.1 Hook Non-Destructive Test (NDT)

NOTE: This section is required for NAVY cranes.

Remove this section if the selecting agency does not require hook non-destructive testing or the necessary non-destructive testing is not IAW NAVY requirements.

For NAVFAC, add tailored paragraphs with additional

requirements.

For hooks of ferromagnetic materials, magnetic-particle inspect the hook over the entire area in accordance with [NAVSEA T9074-AS-GIB-010/271](#) or [ASTM A275/A275M](#).

Inspect each hook and shank over the entire surface area. If NDT cannot be performed on surfaces inside small holes (e.g., hook/nut captivation roll pin holes), visually inspect those surfaces to the maximum extent practical.

- a. Procedure for magnetic particle inspection: Conduct magnetic particle inspection in accordance with [NAVSEA T9074-AS-GIB-010/271](#). [ASTM A275/A275M](#) may be used with the following restrictions: Do not use DC yokes (including switchable AC/DC yokes used in the DC mode) or permanent magnet yokes. Do not use automatic powder blowers or any other form of forced air other than from a hand-held bulb for the application or removal of dry magnetic particles. Remove arc strikes. Equipment ammeters must have an accuracy of plus or minus 5 percent of full scale (equipment ammeter accuracy other than that stated is acceptable provided the MT procedure states that a magnetic field indicator is used to establish and verify adequate field strength for all aspects of the inspection.)
- b. Acceptance Criteria: Defects found on the hook will result in rejection of defective items for use on furnished hoist.
- c. Test Report: Submit a test report of the inspection of each hook to the Contracting Officer for approval prior to final acceptance of hoist installation. Certify test reports by the testing organization. The performing organization must provide a written statement of certification to [ASTM E543](#), current within one year of the date the NDT was performed. The NDT procedures including technique sheets specific to the types, shapes, and size of the parts being examined must adequately describe the orientation of the hooks within the magnetizing equipment, as applicable. The performing organization must have the NDT procedures and its technique sheet used for testing of the hook reviewed and approved by a Level III examiner who is independent from the NDT vendor. Submit the (Level III examiner) approved procedures, technique sheets, and certification to the Contracting Officer with the test report.

]1.6.3 Drawings: [Monorail Crane System](#)

- a. Submit drawings showing the general arrangement of all components in plan, elevation, and end views to demonstrate proper interface with the facility and relation to other hoists on the same monorail system, if applicable. Show all major features of the crane including: hook end approach to all termination points of the monorail, hook height, clearances and principal dimensions, hoist and trolley drives, motor nameplate data, overcurrent protective device ratings, and electrical or pneumatic schematic drawings, as applicable. Include weights and centers of gravity of major components (e.g., trolley/hoist). [Indicate on the drawings the wind speed above which the crane must be placed in the stowed position.](#)
- b. Submit shop drawings of all fabricated components. Shop drawing quality must be equivalent to the contract drawings accompanying this

solicitation. Drawings must be reviewed, signed, and sealed by a licensed professional engineer.

- c. Provide Bill of Materials for crane components on each drawing. The schedule must provide a cross reference between manufacturer data and shop drawings. Components listed on the schedule of crane components must include total quantity, description, original manufacturer, and part number for purchased items and size, material, and grade for fabricated components. Distributing agents will not be acceptable in lieu of the original manufacturer.

1.6.4 Design Data: Load and Sizing Calculations

NOTE: Design data for Load and Sizing Calculations, and welding procedures, may not be available for commercially procured hoists and trolleys.

Submit complete list of equipment and materials, including manufacturer's descriptive data and technical literature, performance charts and curves, catalog cuts, and installation instructions. Provide a list of all codes and standards, design assumptions, equations, specified efficiencies, limits, factors of safety, component ratings, and sources of values used. Include free body diagrams or sketches of each load case. Ensure the crane is designed for the operating wind load case in accordance with CMAA 74 or MHI MH27.1, as appropriate. Determine the wind forces that will cause the outdoor crane to move in a parked condition with the brakes provided.

1.6.5 Certificates

All certifications must be dated, bear the original signature, and include the printed name of the authorized representative of the Contractor or the manufacturer of the items or equipment being certified. Submit certifications that clearly identify the crane, the drives, components, and location (as applicable) to which it applies:

NOTE: Choose one item below: Wire Rope or Load Chain

- [a. Wire Rope Certification for each hoist with either the wire rope manufacturer's certification that the rope meets the published breaking force, or certification of the actual breaking force of a sample taken from the reel and tested. Show the published breaking force on the wire rope certificate; the actual wire rope breaking force must meet or exceed the published value. Certification must be compliant with the requirements of ASME B30.30 and traceable to the hoist and reel.
-]b. Load Chain Certification for each hoist from either the load chain manufacturer or the hoist manufacturer that the chain samples taken and tested meet the chain manufacturer's designed minimum breaking force, and the load chain has been proof tested with a load at least equivalent to one and a half times the hoist rated load divided by the number of chain parts supporting the load. Certification must be traceable to the crane and hoist.

] *****
NOTE: Choose item below if required

- [c. **Monorail System** Certificate stating that the new crane will operate properly on the monorail track. For monorail tracks provided by the Contractor, include statement certifying monorails have been aligned in accordance with **CMAA 74** or **MHI MH27.1**, as applicable. If monorail(s) are existing and if the crane(s) cannot operate without restriction, the Contractor must indicate crane limitations.
-] d. **Hazardous Material** Certificate that the crane does not contain hazardous material including asbestos, lead, cadmium, chromium, Polychlorinated Biphenyls (PCBs), or elemental mercury. Products required for the designing and manufacturing of cranes must not contain the prohibited materials.

NOTE: A Loss of Power Test Certificate is not necessary if the hoist and trolley functions are manually operated; there would be no power to lose.

- [e. **Loss of Power Test** Certificate stating that a test may be performed in which power is removed during operation without any detrimental effects to the crane.

] *****
NOTE: NAVFAC requirement is for the crane to be periodically load tested to 125 percent (plus 0 minus 5 percent) of rated load..

- f. **Overload Test** Certificate stating that the crane can be periodically load tested to 125 percent (plus [0][_____] minus [5][_____] percent) of rated load.

NOTE: NOTE: See "Brake Adjustment Record Form (NCC Form 09-002)" at the following Navy Crane Center link:

<https://ncc.navfac.navy.mil/Popular-Links/DOWNLOADS/>

- g. Certificate of the **Brake Adjustment Record**. Provide a brake adjustment record and installation/maintenance manuals for each brake on the crane. Each brake measurement must have a tolerance traceable to the associated brake manual or documentation provided by the brake manufacturer, location of measurements, and the actual brake setting. Changes made to settings of the brake, at any time, will void the record. A suitable brake record form can be located under downloads on the NAVFAC Navy Crane Center website.

NOTE: The cybersecurity supplement submittal is not necessary for cranes which do not have electronic systems, such as manual or pneumatic hoists and

trolleys.

In addition, the cybersecurity submittal is not required for electric cranes which are pendant controlled (vice wireless/radio controllers) AND utilize magnetic contactors (vice microprocessors/VFDs), provided there are no other microprocessors on the equipment.

The Cybersecurity Supplement submittal is required for cranes with microprocessors (e.g., VFDs or computers) or wireless controllers.

NOTE: If purchasing a laptop for crane maintenance, see UFGS Division 25 05 11 for Cybersecurity of Facility-Related Control Systems.

- [h. Cybersecurity Supplement reporting cybersecurity information for each individual network capable device, including microprocessors (e.g., VFDs) or wireless devices (e.g., controllers or remote terminal units), using the Cybersecurity Supplement (NCC Form 24-003) available for download at the following Navy Crane Center link:

<https://ncc.navfac.navy.mil/Popular-Links/DOWNLOADS/>

1.6.6 Welding Qualifications and Procedure

Welding must be in accordance with qualified procedures using AWS D14.1/D14.1M as modified. Written welding procedures must specify the Contractor's standard dimensional tolerances for deviation from camber and sweep and not exceed those specified in AWS D14.1/D14.1M, MHI MH27.1, and CMAA 74, as applicable. Welders and welding operators must be qualified in accordance with AWS D1.1/D1.1M or AWS D14.1/D14.1M.

1.7 CRANE SAFETY

Comply with the mandatory and advisory safety requirements of ASME HST-1, ASME HST-2, ASME HST-4, ASME HST-5, or ASME HST-6, as applicable, ASME B30.10, ASME B30.16, ASME B30.17, 29 CFR 1910.306, and all applicable provisions of 29 CFR 1910 and NFPA 70.

1.7.1 Nuclear Safety Analysis

NOTE: Certification is required for cranes handling nuclear materials. Results from the Safety Analysis will be utilized by the Using Agency as a basis for crane certification. Delete this paragraph if the crane is not required to handle nuclear materials.

This section is not applicable to NAVFAC projects. The Navy Crane Center must be involved with the procurement and overhaul of all NAVY cranes that handle Nuclear material as identified in the forward notes section of this specification.

Nuclear certification, testing, and rules of construction must be in accordance with ASME NUM-1. Air Force Nuclear certified hoists must meet requirements of AFMAN 91-118. Submit analysis and test reports to Contracting Officer for approval.

]PART 2 PRODUCTS

2.1 MATERIALS

2.1.1 General

Provide materials and equipment which are standard products of manufacturers regularly engaged in the fabrication of complete and totally functional cranes including necessary ancillary equipment. Material will be free from defects and imperfections that might affect the serviceability and appearance of the finished product. All material must be new and unused.

2.1.2 Nameplates

Secure nameplates to each major component of equipment with the manufacturer's name, address, type or style, model or catalog number, and serial number. Provide two monorail identification plates, one for each side of the track beam. Provide noncorrosive metal identification plates with letters which are easily read from the floor, showing a separate number such as M-1, M-2, for each monorail hoist.

2.1.3 Capacity Marking

**NOTE: NAVFAC requires markings to be indicated in
pound units. The kilogram marking option is
provided for cranes installed in a foreign country.**

Mark the rated capacity in pound units [with kilogram units printed in a different color] on each side of the monorail track beam. Capacity marks must be large enough to be clearly visible from the floor. Individual hoist units must have their rated capacity clearly marked in pound units[, with kilogram units printed in a different color,] on both sides of the lower block (when present), and additionally labeled on the hoist body.

2.1.4 Safety Warnings

Affix labels in a readable position to each lift block or control station in accordance with ASME B30.16 and ASME B30.17. Submit safety warnings, diagrams and other instructions suitably framed and protected for display as indicated by the Contracting Officer as follows:

Design and locate the word "WARNING" or other legend to bring the label to the attention of the operator. Provide durable type warning labels and display the following information concerning safe-operating procedures: Cautionary language against lifting more than the rated load; operating the hoist when the hook is not centered under the hoist; operating hoist with twisted, kinked or damaged rope; operating damaged or malfunctioning hoist; operating a rope hoist with a rope that is not properly seated in its hoist drum groove; lifting people; lifting loads over people; and removing or obscuring the warning label.

2.2 STRUCTURAL REQUIREMENTS

Structural steel materials must conform to the standards permitted in [CMAA 74](#), [MHI MH27.1](#), and [AISC 360](#), as applicable.

2.2.1 Structural Connections

- a. High-strength bolted structural connections must be designed and installed in accordance with [RCSC A348](#). Bolts must be of [ASTM F3125/F3125M](#), ASTM A325/A325M or Grade ASTM A490/A490M material, if not otherwise prescribed by the monorail OEM.
- b. Welded connections for the crane must be performed in accordance with [AWS D14.1/D14.1M](#). Welded connections to the building must be performed in accordance with [AWS D1.1/D1.1M](#).

[2.2.2 Monorail Track System

NOTE: For Monorail Hoists, track and its support structure is usually supplied by crane contractor. Use Monorail Track System only if crane contractor is to provide a new track.

Monorail tracks may be of two types. "Patented track" as defined in the definitions section and built IAW MHI MH27.1 and "rolled steel shapes" which is defined in [CMAA 74](#).

The activity may decide the track type to be used or allow the provider to decide.

- a. Provide the complete track suspension system that is required to hang the monorail track at its indicated location from the facility structure indicated on the drawings. Provide monorail and support structure for underrunning monorail of[rolled steel shapes conforming to [CMAA 74](#) Section 3][patented track beams conforming to [MHI MH27.1](#)][rolled steel shapes conforming to [CMAA 74](#) Section 3 or patented track beams conforming to [MHI MH27.1](#)].
- b. For rolled steel shapes, locate splices under structural support members.
- c. For patented track beams, perform splices as necessary in accordance with the manufacturer's recommendations and requirements. Align ends of lower T-section to minimize the horizontal gap on the running surface to not greater than 1.5 mm 1/16 inch and not greater than a vertical difference of 1.0 mm 1/32 inch for the wheel running surface alignment for a smooth crossing by the wheels. Splice assemblies must be from the same manufacturer as the patented track and located under structural support members. Submit manufacturer's standard published tables that verify the monorail track is sized in compliance with all specification requirements. When standard published tables are not available, provide calculations for the strength design and deflection of the beams
- d. Monorail support structure must be designed, fabricated, and installed

such that monorail meet the alignment tolerances of CMAA 74 or MHI MH27.1, as applicable. Provide means to allow for vertical adjustment of the track both before and after the system has been put in operation so that track can be erected and maintained level. Brace track to restrain against damaging lateral and longitudinal movements. Where the track is suspended from hanger rods, provide means preventing the hanger rod nuts from backing off the rods. Allowable stress in hanger rods is 20 percent of the minimum specified ultimate strength of the material used.

2.2.3 End Stops

Fit monorail track system with end stops at all open end locations in accordance with MHI MH27.1 and ASME B30.17. Locate stops to contact the power-driven trolley bumper and permit maximum trolley travel. Provide a system in which the travel wheels do not contact the end stops. End stops must be designed to absorb the maximum kinetic energy and impact force developed by the bumper contact.

2.2.4 Bumpers

Fit power-operated trolley frames with shock-absorbing bumpers capable of decelerating and stopping the trolley within the limits stated by ASME B30.17. Ensure bumpers conform to ASME B30.17. Bumpers must fully engage end stops. Mount bumpers so that there is no direct shear on mounting bolts (if any) upon impact. Bumpers must provide adequate clearance between the crane and surrounding structure when compressed to preclude damaging equipment (clearance requirements are defined in ASME B30.17 and MHI MH27.1 if applicable). When more than one crane is located and operated on the same monorail track, bumpers must be provided on their adjacent ends or on one end of one crane. Fit the other end of the trolley with a structural steel stop to engage the bumpers of the adjacent crane.

2.2.5 Additional Provisions for Outside Service

NOTE: This paragraph is applicable for outdoor
cranes only. See also TRAVEL DRIVES and TRAVEL
BRAKES.

Design members to prevent the collection of water on the crane. Provide a means to secure the crane against a wind pressure of 1.44 kPa 30 psf in accordance with ASME B30.17.

2.3 MECHANICAL REQUIREMENTS

All "should" statements in CMAA 74, MHI MH27.1, and ASME B30 are considered to be mandatory requirements.

2.3.1 Threaded Fasteners

Fasten mechanical connections that are not part of a commercial packaged assembly with SAE J429 Grade 5 fasteners, ASTM F436/F436M washers, and SAE J995 Grade 5 nuts. Lubricate all mechanical fasteners unless otherwise specified by the original component manufacturer.

2.3.2 Hoist

NOTE: Available hoist duty classes are captured below. The NAVY requires a minimum H3 (if HST-1 or HST-4) or A4 (if HST-5 or HST-6). Selecting a lower duty class, if the option exists, is not acceptable for NAVY cranes:

ASME HST-1 Electric Chain Hoist: H2, H3, H4
ASME HST-2 Hand Chain Hoist: no hoist duty classes
ASME HST-4 Electric Wire Rope Hoist: H1, H2, H3, H4, H5
ASME HST-5 Air Chain Hoist: A4, A5
ASME HST-6 Air Wire Rope Hoist: A4, A5

NOTE: Selecting either chain hoists (ASME HST-1, HST-2, or HST-5) or wire rope hoists (ASME HST-4 or HST-6) is not straight forward or consistent across all scenarios. Generally recommend chain hoists for lower lift heights (less than 6 meters 20 feet or lower capacities 4500 kilograms 10,000 pounds).

Air powered (pneumatic) hoists require continuous and reliable facility air supply.

NOTE: Trolleys can be manual (plain-type with a pull rope or gear/sprocket-type with a manual hand chain) or powered (electrical or air motor driven). Travel drives are addressed in a later section.

Powered hoists (electric or air) can have manually operated trolleys, however you typically would not expect to see powered trolleys (electrical or air) on a manual hoist.

Provide hoist conforming to ASME B30.16, except as modified and supplemented in this section. Packaged hoist and trolley units (packaged hoists) must be[electric chain hoist conforming to ASME HST-1, Duty Class[H3][H4][H2]][hand chain hoist conforming to ASME HST-2 with hand chain that reaches down to 1.2 meters 4 feet above the finished floor][double reeved electric wire rope hoist conforming to ASME HST-4, Duty Class[H3][H4][H1][H2]][air chain hoist conforming to ASME HST-5, Duty Class[A4][A5]][air wire rope hoist conforming to ASME HST-6, Duty Class[A4][A5]] or better and be rated for the operating environment.

Configure trolley such that the trolley frame contacts the trolley stops (or bumpers of an adjacent trolley) and prevents the trolley from dropping more than one inch in the event of an axle or wheel failure.

2.3.2.1 Hoist Brakes

NOTE: Each hoist must have, at a minimum, two

brakes capable of stopping and holding 125 percent of the hoist's rated load with the exception of manual and air hoists which may have only one brake (typically a mechanical load brake). For electrical powered packaged hoists, the most common brake configuration is one electro-mechanical spring set brake and one mechanical load brake (or self-locking worm gear).

Consider the CONTROLS paragraph under ELECTRICAL REQUIREMENTS.

If a variable frequency drive (VFD) is selected for use, the brake configuration must reflect the type of VFD selected (open loop vs closed loop). For open loop controls, brake configuration must be one electro-mechanical brake and one mechanical load brake (or self-locking worm gear).

If not using a VFD, and electromatic controls are selected, the brake configuration must still be one electro-mechanical brake and one mechanical load brake (or self-locking worm gear).

Additional tailoring options are provided for NAVFAC cranes.

- a. Equip the hoist with two holding brakes, each with a minimum torque rating of 125 percent of the rated load hoisting torque. Manual and air hoists with one hoist brake are acceptable, unless otherwise specified.
- b. Provide a brake configuration with one spring set brake and one mechanical load brake, or self-locking worm gear, that meet the identified requirements
 - (1) Spring set brakes must have a means of manual release. The brakes must be equipped with a manual brake release mechanism; maintained manual release mechanisms must automatically reset when power (electric or air) is applied to the brake. Provide microprocessor controlled drive (i.e., VFD) with manual adjusting brakes; functions controlled via magnetic contactors may utilized manual or self-adjusting brakes.
 - (a) Powered chain hoists are not required to have a means of manual release.
 - (2) Mechanical load brakes must be capable of stopping and holding 125 percent of the hoist's rated load and cannot require the load to be raised before being lowered.
 - (3) Air (pneumatic) brakes must prevent the lowering of the load in the event of a loss of air supply and cannot require the load to be raised before being lowered

2.3.2.2 Load Block and Hook

NOTE: The following list contains OUTDOOR and NAVFAC tailoring options.

NOTE: Where space permits, the NAVY prefers forged carbon steel hooks due to NDT periodicity requirements, however that option is not mandated.

NOTE: In list item a., for chain hoists, select the ductile/malleable cast iron material allowance.

- a. Provide a load block constructed of steel. The load block must be designed to prevent metal-to-metal contact of moving parts. Provide drain holes in areas where water can collect.[Ductile or malleable cast iron load block housings are acceptable on chain hoists.]
- b. Provide an unpainted and unplated forged[carbon] steel single barbed hook. Hooks must conform to the requirements of ASME B30.10. The hook must be a standard commercial product with a published design factor compliant with the requirements of ASME B30.16 for powered or manual hoists, as applicable. Fit hook with a safety latch designed to preclude inadvertent displacement of slings from the hook saddle. The hook and hook nut must be removable without unreeving of the hoist. Provide hook nut secured to the hook with a commercial standard removable and reusable means. Do not weld hook nut. When provided, shank and nut threads must be Class 1 or 2 fit per ASME B1.1. Uniquely mark the hook in a permanent fashion that is traceable to the NDT certification. The nut must be marked to match the hook. Hook must be free to rotate through 360 degrees when supporting the test load up to 125 percent of the rated capacity.

2.3.2.3 [Hoisting Rope][Hoisting Chain]

NOTE: Items a. and b. apply to wire rope and are for wire rope hoists only. In the hoist section, the appropriate packaged hoist must be chosen (ASME HST-4 or HST-6). If a wire rope hoist is chosen, item c (hoisting chain) must be removed from the specification.

Item c. only applies to chain hoists. In the hoist section, the appropriate packaged hoist must be chosen (ASME HST-1, HST-2, or HST-5). If a chain hoist is chosen, items a and b must be removed from the specification.

NOTE: Recommend selecting the option for adding a load chain container.

- [a. Wire rope must comply with ASME B30.30 and FS RR-W-410, ASTM A1023/A1023M, or BS ISO 4309 and have a rope classification

appropriate for the usage. Wire ropes must be handled and seized in accordance with ASME B30.30. The wire rope must be in a double reeved configuration equalized with a sheave. Select wire rope minimum design factor in accordance with ASME B30.16. Provide proof of Wire Rope breaking force.

- b. Provide hoist wire ropes with improved, extra-improved, or extra-extra-improved plow steel (or appropriate ISO grades), pre-formed, regular lay, bright, and uncoated, with an independent wire rope, wire strand, or otherwise, steel core. Drawn galvanized wire rope is allowed in general purpose service; hot-dipped galvanized wire rope is not permitted.
-]c. Provide a welded link load chain suitable for the specified hoist service (powered or manual). The load chain design factor must be compliant with the requirements of ASME B30.16 for powered or manual hoists, as applicable, and based on the chain's minimum breaking force. Provide the chain with a chain stop or dead end connection to prevent the load chain from running out of the hoist at its fully extended position.[Provide chain hoists with 3 meter 10 foot lift or more with a load chain container.] Chain containers on outdoor cranes must be provided with a drain hole.

]2.3.2.4 Drum

NOTE: The DRUM and SHEAVE paragraphs apply to wire rope hoists (ASME HST-4 or HST-6). Remove DRUM and SHEAVE paragraphs for chain hoists (ASME HST-1, HST-2, or HST-5).

Provide grooved drum made of steel. Design drum in accordance with ASME B30.16. All hoisting rope is to be wound in a single layer and provided with no less than two full dead wraps of hoisting rope remaining at each anchorage when the hook is in its extreme low position.

2.3.2.5 Sheaves

Provide steel sheaves. Size sheaves in accordance with ASME B30.16 for the minimum pitch diameters of running and equalizer sheaves.

]2.3.3 Travel Drives

Provide under running travel assemblies.

2.3.3.1 Trolley Drives

NOTE: Trolleys can be manual (plain-type with a pull rope or gear/sprocket-type with a manual hand chain) or powered (electrical or air motor driven).

Powered hoists (electrical or air) can have manually operated trolleys, however you typically would not expect to see powered trolleys (electrical or air) on a manual hoist.

NOTE: Plain type trolleys are recommended where trolley motion is infrequent or relatively short. Due to the required force to manually operate this type of trolley, it is also recommended for hoists with a maximum capacity of 3 tons with the elevation of the beam not more than 6 meters 20 ft above the operator's floor level.

Hand chain-operated trolleys are recommended where trolley motion is relatively infrequent or short and for those loads and beam heights where a plain-type trolley would be impractical.

Motor-operated trolleys are recommended where the operating frequency, distance of travel, or the type of load being handled would cause unsatisfactory operation if the trolley were the plain or of the hand chain-operated type.

NOTE: Outdoor tailoring option for cranes to have half of the total wheels driven in order to provide adequate holding capability against non-operating wind loads without providing additional wind tie-downs. See also paragraph TRAVEL BRAKES

NOTE: Trolley limit switches are an optional safety device.

Trolley travel limit switches are used to prevent the crane trolley from contacting the travel end stops at high speed should the crane operator mistakenly forget to slow down. If selected, ensure the appropriate options are chosen in the ELECTRICAL REQUIREMENTS, Limit Switches section.

[Provide a manual travel drive arrangement, consisting of[plain with a pull rope][hand chain operated] that reaches down to 1.2 meters 4 feet above the finished floor.

] [Provide a motor-driven travel drive arrangement driving through self-contained gear reduction units located at each driven wheel assembly. Gear reducers must be fully enclosed in an oil-tight housing and provided with a convenient means of lubricant level indication and draining.

- a. Provide at least one quarter of all wheels driven. Outdoor cranes must have half of the total wheels driven.[Provide trolley travel limit switches.]

]2.3.4 Travel Brakes

NOTE: OUTDOOR tailoring option in the following

paragraph for parking brake requirements. Parking brakes are one of the methods that can technically be used to secure outdoor cranes against high winds, however the requirements of TRAVEL DRIVES pushes the crane manufacturer in this direction. Another option chosen by the crane manufacturer could be rail clamps/anchors.

Provide motor driven travel drives with an end-mounted spring set brake conforming to the requirements of ASME B30.17 or non-freecoasting mechanical drive capable of stopping the motion of the travel function within a distance in meters feet equal to 10 percent of the full load speed in meters feet per minute when traveling at full speed with a full load. Size brakes for underrunning trolleys/carriers in accordance with ASME B30.17. Outdoor cranes with powered motions must be provided with travel brakes sized to 100 percent of rated motor torque. Parking brakes used to secure outdoor cranes in accordance with ASME B30.17 must be sized to secure against a wind pressure of 1.44 kPa 30 psf.

NOTE: NAVFAC tailoring option in the following paragraph for additional travel brake requirements.

Spring set brakes must be provided with a means to manually release the brake. The brakes must be equipped with a manual brake release mechanism; maintained manual release mechanisms must automatically reset when power (electric or air) is applied to the brake. Provide microprocessor controlled drive (i.e., VFD) with manual adjusting brakes; functions controlled via magnetic contactors may utilized manual or self-adjusting brakes.

2.3.5 Wheels

Provide under running wheel sizing and flange-to-rail head clearances in accordance with MHI MH27.1 and CMAA 74 recommendations, as applicable. The wheels must be compatible with their respective runway profile. Wheel material is to be cast or forged steel, or ductile or malleable cast iron. Gray cast iron trolley wheels are acceptable if they are the manufacturer's standard offering. Hollow stamped wheels may not be used; the use of plate steel is prohibited. Minimum tread hardness for underhung wheels that run on patented track is 375 BHN. Minimum tread hardness for wheels running on structural shapes is 320 BHN.

[2.3.6 Drip Pans

NOTE: Drip pans may also be added for any type of crane service if there is an additional requirement to prevent lubrication from falling to the floor or lifted load. Any portion of this section may be used to support the request of the Activity. Not recommended for outdoor service.

List items a. and b. are generic drip pan requirements for inclusion beneath gearboxes. List item c is less likely to be needed.

- a. The crane must be designed to preclude leakage of lubricants onto the lifted loads or the floor. Equipment or components, which cannot be made leak-proof, must be fitted with unpainted corrosion resistant steel drip pans or must have the foundations seal welded to create a dam. Drip pans that utilize liquid sealant to prevent leakage of lubricants are not permitted.
- b. The drip pans must be[sized to hold the entire gear case fluid capacity,] installed under all drive machinery (hoist and travel), and designed to permit easy removal of collected lubricant. A trolley floor designed to contain any lubricant drips may be used as fluid containment for any equipment that is mounted on it.
- c. Provide drip pans fitted around the shank of the hook and extending outward to encompass all possible points of lubrication drips from the load block. The drip pans must be easily removable without disassembly of the hook or load block and cannot interfere with the crane structure during testing of the upper limits.

][2.3.7 Hoist Capacity Overload Protection

NOTE: This section is redundant for electric powered cranes. Remove this section for electrical hoists, which address overload protection in ELECTRICAL REQUIREMENTS.

This hoist capacity overload protection MUST be included for manual or air hoists (ASME HST-2, HST-5, or HST-6).

Provide capacity overload protection which prevents further hoisting of a load set at or less than the crane's test load. If a non-adjustable slip clutch is utilized, the OEM factory setting is acceptable and must be identified. If the device is adjustable, provide it adjusted to prevent hoisting in excess of the test load.

][2.3.8 Air Requirements

NOTE: This section MUST be included for air hoists (ASME HST-5 or HST-6). Remove this section for manual and electrical hoists. Electrical hoist limit switches are addressed in ELECTRICAL REQUIREMENTS.

Provide the final settings and configurations data on the [Complete Pneumatic Diagram](#).

2.3.8.1 Hoist Pneumatic Limit Switches

NOTE: This section MUST be included for air hoists (ASME HST-5 or HST-6). Remove this section for manual and electrical hoists.

NOTE: This section includes options for hoisting
rope or load chain, make the appropriate selection
for the hoist type selected.

Provide a hoist limit switch to limit hook over-travel in both the raising and lowering direction.[Set the lower limit switch such that there are no less than a minimum of two wraps of hoisting rope on the hoist drum upon limit switch actuation.][For chain hoists, chain stops and an overload clutch that meets the requirements of ASME B30.16 are acceptable as upper and lower limit switches.]

2.3.8.2 Air Supply

NOTE: This section MUST be included for air hoists
(ASME HST-5 or HST-6). Remove this section for
manual and electrical hoists.

NOTE: A reeled air supply may be preferable or
necessary given the layout of the monorail track
system.

If the provided shop air is not lubricated choose
the option to provide air lubricator.

NOTE: Use bracketed sentences as required by the
project.

The air supply hose must not hang below the high hook position. Provide a pressure regulator, as necessary, in the air supply line to keep elevated supply pressure at the hoist within the manufacturer's recommended operating pressure range.[Provide an air lubricator as close to the hoist as practical and downstream of any air filters.]

[Provide a reeled runway air supply system for the crane, including all necessary hardware to the crane from a wall or column mounted valve.

]2.3.8.3 Operator Air Controls

Provide a pendant control station suspended from the trolley, with a method of strain relief to protect pneumatic lines from damage. Locate the top of the pendant station[1200 mm 4 feet] [_____] above the finished floor. Provide pendant controls that spring return to the OFF position. Pendant station must have its elements legibly marked and arranged vertically.

]2.3.9 Wind Speed Indicating Device

NOTE: This subpart is tailored to OUTDOOR
requirements, as wind speed indicating devices are
required on outdoor cranes.

This indicating device is likely to be electrical in nature on electrically powered cranes, however it is intentionally added under MECHANICAL REQUIREMENTS due to the possibility of manually powered outdoor cranes in which the ELECTRICAL REQUIREMENTS section is completely removed.

Provide a wind speed indicating device in accordance with ASME B30.17, which provides a visible and audible alarm to the crane operator at a predetermined wind speed. The transmitter must be mounted on the highest unobstructed location. A single facility based wind speed indicating device may serve as an alarm for more than one crane.

[2.4 ELECTRICAL REQUIREMENTS

NOTE: The entire ELECTRICAL REQUIREMENTS Article MUST be included for electrical hoists (ASME HST-1 or HST-4). Remove this Article for manual or air hoists (ASME HST-2, HST-5, or HST-6).

- a. The design, selection, rating, and installation of the electrical portions of the crane and its accessories must conform to the requirements of NEMA ICS 3, NEMA ICS 8, the applicable ASME HST standard, and NFPA 70, and other requirements specified herein.
- b. Each motion of the crane must be provided with a separate control system or drive. The loss of any one function must not prevent the operation of other unaffected functions. Two independent relays, contactors, drive inputs, or other equivalent components/logic must be utilized for each function to provide directional control such that the failure of a single relay/contactor/component cannot result in motion in an unintended direction.
- c. Disconnecting means for cranes must be in accordance with NFPA 70 Article 610.32.
- d. Unless otherwise specified, interconnecting wiring must be of copper stranded construction complying with Table 310.104(A) of NFPA 70. Interconnecting wiring containing asbestos in the insulation or outer covering is prohibited. Aluminum conductors must not be used. Aluminum connectors are allowed if they are rated for use with copper conductors (marked "AL/CU"). All conductors connected to or routed above resistors must have insulation shown in NFPA 70 Table 610.14(a) for 125 degrees C 257 degrees F. For packaged hoists and hoist/trolleys, provide wiring sizes in accordance with NFPA 70 Table 610.14(a). Conductors must be selected and de-rated based on maximum ambient temperature. Continuous loads such as utility and heating must be multiplied by 2.25 to determine ampacity in order to permit application of NFPA 70 610.14 (A) for crane supply conductors.
- e. Excluding conduit directly connected to dynamic breaking resistors, raceways must maintain a 12-inch clearance between the raceway and dynamic braking resistors. A separate grounding wire, sized in accordance with Section 250.122 of NFPA 70, must be routed with all ungrounded conductors. All wiring must be numbered or tagged at all connection points. Power conductors which are shielded such that

their wire size cannot be easily determined must be labeled as to the conductor size. All unused conduit openings must be plugged.

- f. Power cables and low voltage signal cables may not be mixed in the same conduit.

2.4.1 Motors

NOTE: Inverter duty motors are required for open loop variable frequency drives (VFD).

Select two speed motors for trolley drives if magnetic controls are specified in paragraph CONTROLS; select single speed motors if electronic controls are specified in paragraph CONTROLS.

U.S. Navy recommends 60-minute duty rating motors for commercial packaged hoists. The motor duty rating may be selected to match what is required by the class of HST-1 or HST-4 hoist (such as H1, H2, H3) specified.

NOTE: Included bracketed items as required by the project.

[Provide[two][single]-speed AC squirrel cage induction type motors for the trolley drives.

] [Provide two speed, AC squirrel cage induction type motor for the hoist.

] [Provide inverter duty motors for Open Loop Variable Frequency Drives (VFD).

] Provide motors with a minimum of Class F insulation. Provide motor overload protection. Provide motors painted to manufacturer's standard for "wash-down" service.

2.4.2 Controls

NOTE: If one or two speed point controls are required, recommend magnetic controls. If three or more speed points or infinitely variable speed adjustment is needed, Variable Frequency Drive (VFD) controls are required.

NOTE: Use the first list item to select one or two speed control for the hoist or trolley. Selections can be made using a combination of electronic controls and one or two speed motor controls for the various functions.

Use the second, third, and fourth list items to select electronic variable frequency drive controls for either the hoist or trolley. With VFD controls the hoist must be configured as open loop. Open

loop is more cost effective and requires a mechanical load brake (or self-locking worm gear).

When the two-speed trolley motor is specified, the slow speed will be 1/3 to 1/4 of rated travel speed. Reduced voltage starting, acceleration, and deceleration, serve to reduce the acceleration rate that is normal for squirrel-cage motors. Squirrel-cage motors with two-speed magnetic controls provide satisfactory results with slow trolley speeds and should be specified when short travel distances are involved and where fine positioning is not required.

For faster trolley speeds or finer positioning requirements, specify electronic controls.

NOTE: The final list item for hoist brake bypass keyswitch is optional for hoists with one electro-mechanical spring set brake and one mechanical load brake. Choose this option if the Activity wants the functionality; the intent for this keyswitch is to allow for easier load testing of all hoist brakes while the crane is installed by bypassing the primary electro-mechanical brake for independent testing of the mechanical load brake.

- [a. Provide[one][two]-speed magnetic controls for the[trolley drive][and][hoist drive]. Controllers must meet the requirements of **NEMA ICS 8**. Ensure that an energized drive motor initially rotates only in the direction selected by the operator by activating the corresponding direction; i.e., is not overhauled. For AC squirrel cage motor controllers, the requirements of **NEMA ICS 2**, Part 2, for general-purpose controllers, must be met.
-]b. Provide static reversing, open loop variable frequency drives (VFD) for the[trolley][and][hoist] electric controls. VFD controllers must meet **NEMA ICS 8**, Part 8 and at a minimum, provide under-voltage protection, electronic instantaneous over current protection, DC bus over voltage protection, and be able to withstand output line to line shorts without component failure. Select trolley drive such that the continuous rating of the controller is not less than the motor full load current based on **NFPA 70** Table 430.250. Select hoist drives such that the continuous rating of the controller is not less than 125 percent of the motor full load current based on **NFPA 70** Table 430.250. All hoist drives must have a motor over-torque limit to lock out the hoist and prevent gross overload of the associated hoist. Provide dynamic braking for each electric drive that is sized per VFD manufacturer's requirements. Roll-up on hoist functions must be less than 3 mm 1/8 inch measured at the hook block. Submit VFD **Control Parameter Settings**.
- c. Provide speed control, which is infinitely variable for each function, controlled via[radio control system][and][pendant pushbutton station].

- d. The[hoist][and][trolley] electro-mechanical brakes must set without delay. The hoist and trolley controllers must be sized to provide sufficient starting torque to initiate motion of that crane drive mechanism from standstill with 0 to 125 percent of rated load on the hook. Motors must operate smoothly at all speeds without torque pulsations, and must only be energized within the frequency range of 50-60 Hz at rated speed.
-] e. Provide a main line contactor. Energization of the main line contactor must be controlled by the POWER-OFF/POWER-ON switch/pushbutton on all controllers. Upon actuation of the POWER-OFF pushbutton; power to all drive motors, brakes, and controls must be removed. The mainline contactor must not be able to be energize while the POWER-OFF pushbutton is actuated. The POWER-OFF pushbutton circuitry must be independent of all controls or any other electronic devices.
- [f. Provide a spring returned brake bypass keyswitch for each hoist. The switch allows for actuation of the electro-mechanical brake for independent testing of the mechanical load brake. The normal position allows both brakes to work in their normal operating configuration. Label the keyswitch positions as "NORMAL" and "LOAD BRAKE TEST".

]2.4.3 Electrical Overcurrent Protection

Protection must not be less than that required by NEMA ICS 3, NEMA ICS 8, CMAA 74, NFPA 70, and 29 CFR 1910.306. All protection must be by circuit breakers or fuses. Provide a disconnect switch or enclosed type circuit breaker readily accessible to the crane operator for crane disconnect. Motor branch circuits must be individually protected according to NFPA 70 Article 610.42(A); Circuit breakers used for this purpose must be capable of being locked in the open position. The means for locking must remain in place with or without the lock installed. Motor full load current from NFPA 70 Article 430, Part XIV (Tables) must be used to calculate the circuit breaker size.

Provide disconnecting means on the crane in accordance with NFPA 70 Article 610.32. Provide for lockout/tagout of all hazardous energy sources. Provide product data for all circuit breakers and fuses.

2.4.3.1 Conductors

The crane contractor is responsible for ensuring that the monorail supply conductors and main contact conductors have adequate overcurrent protection complying NFPA 70 Article 610.41.

2.4.4 Limit Switches

NOTE: For hoists with a primary upper limit switch and a secondary upper limit switch, a bypass keyswitch is recommended for easier testing of the secondary upper limit switch. Wiring requirements necessitate that the primary upper limit stops hoisting in the upward direction when activated, therefore a bypass switch that allows continued hoisting upward after primary switch activation would allow for easier verification of the secondary upper limit operation.

- a. Provide primary upper and lower geared limit switches. Geared limits must allow reversing direction to back out of the limit without resetting. For wire rope hoists, the lower limit switch must be set such that there are a minimum of two wraps of rope on the hoist drum.
 - (1) For chain hoists using magnetic controls, chain stops and an overload clutch that meets the requirements of **ASME B30.16** are acceptable substitutions for upper and lower limit switches.
- b. Provide a mechanical hook block activated secondary upper limit switch that removes power from the hoist motor, hoist brake, and hoist controls. The secondary upper limit switch must conform to **NEMA ICS 5** and be wired independent of the directional controllers and the primary upper limit switch. The secondary upper limit must require hoist resetting prior to operation of the hoist in any direction.[Provide a two-position spring-returned bypass switch that allows for testing of the secondary upper limit by bypassing the primary upper limit.]
 - (1) Chain hoists using chain stops and an overload clutch in lieu of primary limit switches do not require a secondary limit switch.
- c. For hoists using microprocessor drives, the hoist secondary upper limit switch must be wired to remove all power from the hoist drive motor and brake(s) independent of the microprocessor drive.
- [d. Travel limit switches must be provided for the trolley motion to stop with the switch located [10][_____] feet before the monorail end stops. Limit switches must be mounted rigidly in a manner so as to protect the switch from misalignment or damage. The target/trip arm must be large enough to provide interception given a misalignment were to occur.

]2.4.5 Operator Controls

NOTE: Use bracketed items as required by the project.

NOTE: Available operator controls are pendant and radio control. Cranes can also be set-up to be controlled by two separate systems. For cranes with one set of controls use list item a.

For cranes with two sets of controls use list item b. In such a case, some type of interlock must exist to prevent control from both systems simultaneously. This interlock can be a switch on the pendant controller OR can be any option, which could include a single barrel connection on the trolley. The switch on the pendant is easier to use, but potentially more expensive. The single barrel connection on the trolley may be cheaper, but more difficult to access.

When specifying a radio control system, the following requirements must be considered and if needed added to the specification. None are hard requirements of NAVCRANECENINST 11450.2:

1. What type of batteries? Rechargeable?
2. Are spare batteries needed? How many?
3. Are spare remote control units required? How many?
4. Is a battery charger required?
5. Type of transmitter unit.
6. Is a belt/harness required for the remote control?

- [a. Provide crane equipped with a[pendant pushbutton station][radio control system.]
-] [b. Provide crane equipped with both a pendant pushbutton station and a radio control system.[Provide a selector switch to allow the use of only one of the two available control stations on the pendant controller.][Provide a selector switch or other means to allow the use of only one of the two available control stations.]
-] c. If VFD controls are not provided, provide directional contactors with both mechanical and electrical interlocks.

[2.4.5.1 Pendant Push-button Station

The cranes must be controlled from a pendant pushbutton station suspended from the trolley. Provide a method of strain relief to protect the electrical conductors from damage. Locate the pendant pushbutton station [1200 mm] [4 feet] [_____] above the finished floor. Pushbutton pendant station must have its elements legibly marked and arranged vertically, in order, in accordance with CMAA 74.[Provide[one speed][two speed][3-step infinitely variable][2-step infinitely variable] pendant pushbuttons for control of the[hoist][and][trolley].] Provide pendant pushbuttons for control that spring return to the OFF position. Voltage in the pendant pushbutton station must not exceed 150 Volts AC.

] [2.4.5.2 Radio Control System

Provide each system with a[belly box][handheld] [_____] type portable transmitter unit[and an identical back-up transmitter unit].[Provide each transmitter with an adjustable belt or harness to support it when worn by the operator]. Only one transmitter at a time can control the crane and there must be no interference from one crane's controller affecting operation of the other cranes in the building. Each transmitter must include: individual[infinitely variable spring return joystick motion control levers][push button controls] for each hoist and trolley; a maintained contact, keyed switch, marked ON-OFF, for portable transmitter unit power; indication of Battery Power, and indication of Transmitting Status; a red emergency STOP mushroom pushbutton. The transmitters and all controls must each be clearly and permanently labeled with functionality and direction. The remote radio control system must be designed to meet the requirements of NEMA ICS 8, Part 9 and ECMA 15. Each radio remote control lever must be in the OFF position before the associated crane function can begin. The system frequency must be within the unlicensed FCC Part 15 range. Each control unit must maintain a

continuous status signal to the associated receiver during operation. There must be no significant loss in systems efficiency and function at the end of eight hours of continuous battery use.

The Contractor must submit the frequency allocation application to the National Telecommunications and Information Administration (NTIA) via the latest revision of EL-CID software found on NTIA.gov. Provide the temporary authorization, and the final approved application when available. The technical section of the application must be completed by the manufacturer of the radio control equipment being furnished under this contract. Verify frequency availability at this activity prior to design approval.

][2.4.6 Runway Conductor System

- [a. Provide a rigid runway Conductor Bar System for the runway conductor system, including all necessary cables and hardware to the crane from a wall or column mounted disconnect switch. Provide electrification system with three power conductors and an equipment grounding conductor. Provide a UV resistant electrification system. Steel (non-stainless) conductor bars are prohibited. The crane must be grounded through the runway electrification system. The grounded conductors must be a minimum of 70 square millimeters. Provide runway conductors sized for simultaneous motions of the hoist, trolley mechanisms, and any ancillary loads. If there is any way the hook block, wire rope, or load chain can swing into the runway electrification, provide a guard installed to prevent contact.
 - b. Provide two Collector Shoes (tandem design) for each conductor; each collector shoe must be rated for not less than the runway conductor sizing, so as to provide redundancy.
-][c. Provide a Festoon System for the runway conductor system utilizing cables suspended from carriers riding on an I-beam or C-track for the crane, including all necessary cables and hardware to the crane from a wall or column mounted disconnect switch. Provide electrification system with three power conductors and an equipment grounding conductor. Provide a UV resistant electrification system. Conductors must be fabricated from copper. The crane is required to be grounded through this conductor system. The grounded conductors must be a minimum of 2/0 AWG. Provide conductors sized for simultaneous motions of the hoist and trolley mechanisms and any ancillary loads. Festooned cable loops must not extend low enough to come into contact with any obstructions.
-][d. Provide a Cable Reel System for the runway conductor system, including all necessary cables and hardware to connect the cable reel to the floor level fused disconnect switch. The cable reel must have three power conductors and an equipment grounding conductor. Provide a UV resistant electrification system. The crane is required to be grounded through this conductor system. Conductors must be fabricated from copper, and sized for simultaneous motions of the hoist and trolley mechanisms and any ancillary loads. The grounded conductors must be a minimum of 2/0 AWG.

][2.4.7 Capacity Overload Protection

NOTE: Overload protection on a crane is required

and may be provided by two types of systems:
Capacity Overload Protection and Over-Torque Limit.

Capacity Overload Protection may be adjustable. If adjustable, it MUST BE set at less than the crane's minimum test load; recommend setting at 100 percent of rated capacity or less. This protection can take the form of one of the following devices:

1. Clutch - Not adjustable and is common on package chain hoists.
2. Load Limit Switch - Installed on the wire rope and measures deflection. Does not require a break in the wire rope and is simply clamped onto the wire. Typically used on smaller hoists that have magnetic controls. Can also be installed as part of the equalizer sheave.
3. VFD Drive Overload Protection - Similar to the Over-Torque Limit but is set at a lower setting. Adjusted via parameters within the drive.

The Over-Torque Limit (i.e., torque limiting feature) only applies to cranes with VFD controls. It is a parameter setting in the drive and is typically set at 150 percent of rated motor torque. Manual hoists, air hoists, and electric hoists with magnetic controls do not have this feature. Delete second item if VFD controls are not specified.

- a. Provide a capacity overload protection device for all hoist systems[using VFD drive capacity overload protection; the capacity overload protection must be separate from torque limiting feature, however both may be controlled from the same VFD]. Set hoist capacity overload protection at [100][_____] percent of rated capacity. Hoist capacity overload protection must be adjustable between 80 and 150 percent of hoist capacity. Provide a keyed override or other means to disable the hoist capacity overload protection when performing a load test. If a slip clutch is used as the overload limiting device, it must comply with all ASME B30.16 requirements. Provide adjustable slip clutches set at or less than the cranes maximum test load. If the slip clutch is non-adjustable, the OEM factory setting is acceptable and must be identified with the Product Data sheets and O&M manual.
- [b. Initially, set the torque limiting capability of the VFD (that is separate from the capacity overload protective device) to 150 percent of the motor torque (amperage) necessary to hoist 100 percent load. It may be adjusted up only to avoid nuisance trips and adjusted down if possible while still avoiding nuisance trips.

]2.4.8 Enclosures

NOTE: Select classification of control panels, controls, and brakes based on the environmental conditions in which the crane will be installed:

1. Choose one of the following for an indoor installation: 1, 2, or 12.
2. Choose one of the following for an outdoor

installation: 3 or 4X.

Other enclosure types exist that might be a better alternative for a particular installation. If necessary, refer to NEMA 250.

- a. Provide enclosures for control panels, controls, and brakes in accordance with NEMA 250, Classification Type[1 indoor, general purpose][12 indoor without knockouts, general purpose][2 indoor, drip-proof][3 outdoor, dust-tight, rain-tight, sleet-resistant][4X outdoor] [_____]. Provide enclosures with listed drains to prevent accumulation of water within the enclosure.
- [b. Provide a non-resettable hour meter, connected across the main line contactor, readable from the exterior of the main control panel, to indicate the elapsed number of hours the crane is energized.

]2.4.9 Warning Devices

NOTE: A warning horn or light is required for all radio controlled cranes and recommended for all others.

Provide warning devices in accordance with ASME B30.17.[Provide a warning horn that is operable from a push button at the[pendant pushbutton][radio control] station.][Provide a warning[strobe light][rotating beacon] that is illuminated at all times during movement of the hoist or trolley function[, but may be deactivated on the operator control station].]

]2.4.10 Pilot Devices

Provide Indicator Lights mounted in an enclosure on the bottom of the trolley with lights sized and positioned to be visible from the ground. The lights must be the dual-lamp type. Provide a white light to indicate that power is available to the crane and a blue light to indicate that the main contactor is energized. Light voltage must be 115 VAC. Provide nameplates that are legible from ground level. The nameplates must read, in their respective order, "POWER AVAILABLE" and "CRANE ENERGIZED". The POWER AVAILABLE light must be supplied by a separate, fused transformer for its energization.

]2.4.11 Cybersecurity

Provide cranes with components that are not connected to the internet. At a minimum, cranes containing microprocessors (e.g., VFDs, computers, or load indicating devices) or wireless devices (e.g., controllers or remote terminal units) that are network capable must document and report cybersecurity information for each individual device.

]2.5 PAINTING SYSTEM

NOTE: Only include optional/bracketed list items a., b., and c. if:

- 1) A new monorail system is being provided by the

crane contractor

2) The new monorail system is made of structural shape.

List items a., b., and c. need not be included if existing monorail track is being reused or if the replacement monorail track is made from patented track.

NOTE: Three-coat zinc primer/epoxy/polyurethane system is provided for mild to severe atmospheric, indoor and outdoor cranes. For cranes in abnormal environments including exposure to chemicals or in immersion service, a system designed for that environment should be used. Other systems may suffice for milder environments.

- [a. Remove all grease, oil, and surface debris by solvent wiping or detergent/water scrubbing, prior to blast cleaning. Prepare surfaces to be coated by abrasive blasting to SSPC SP 6/NACE No.3, Commercial Blast Cleaning, or in accordance with the coating manufacturer's requirements, whichever is more stringent.
- b. Use a painting system appropriate for the conditions provided in the Crane Design Criteria section of this specification. Paint exposed portions of the crane[and crane track system] using a[three] [____]-coat system as follows: [zinc-rich primer consisting of a minimum of 77 percent zinc by weight in the dry film, an anticorrosive epoxy intermediate coat, and an aliphatic polyurethane top coat] [____]. All paint products must be supplied by a single manufacturer and free of chromates, lead, and mercury. Apply each coat in accordance with manufacturer's instructions and requirements. Ensure each coat is smooth, even, and free of runs, sags, orange peel, and other defects. Desired color of finish coat is[brilliant yellow] [____]. Submit product data for painting system.
- c. Coat faying surfaces of bolted connections per RCSC A348, but do not apply finish paint.
-] d. Paint, coatings, or galvanizing on the following items or areas is not acceptable: hoist wire rope or load chain, hooks, hook nuts, sheave and drum grooves, sprockets, wheel treads, lubrication fittings, nameplates, flange mounting faces, corrosion resistant steel, bronze, or other items not normally painted.
- e. Factory paint electrical and mechanical equipment including hoist, trolley, and track in accordance with the manufacturer's best standard practice for the specified environment.

2.6 IDENTIFICATION PLATES

NOTE: NAVFAC P-307 requires the capacity be displayed in pound units. The kilogram marking option is provided for cranes installed in a foreign country.

Furnish and install identification plates. Provide identification plates with clearly legible permanent lettering giving the manufacturer's name, model number, serial number, capacity in pound units,[with kilogram units printed in a different color,] and other essential information or identification.

2.6.1 Markings on Crane, Trolley, and Hook

To avoid operation of the crane in the wrong direction, affix the appropriate directional markings with arrows on both sides of the trolley, as applicable. Markings must be visible by the operator and from the loading point. Labels on the controls must have corresponding directional markings. Markings must agree with the markings on controller. Do not indicate directional arrows on controller.

[2.7 ELECTRICAL ASSEMBLY

NOTE: Instructions for electrical assembly is not necessary for cranes which do not have electrical systems, such as manual or pneumatic hoists and trolleys.

Installation of all electrical wiring, conduit, and components must be performed in accordance with the requirements of NFPA 70. As a minimum, items a. through f. below must be followed:

- a. All electrical connections must be installed in accordance with NFPA 70 Articles 110.14 or 430.9, as applicable, or as recommended by the device manufacturer.
- b. Crimped terminal lugs, if used, must be properly sized for the wire and installed using the device(s) - e.g., crimping tool and indenter - recommended by the terminal lug manufacturer.
- c. All spare conductors must be identified as spare conductors, and must have their ends insulated to preclude accidental contact with energized equipment.
- d. Bonding straps and equipment grounding conductors must be connected to engineered ground points, have all paint removed from their termination points, or have tooth lockwashers (star lockwashers) installed, to insure proper grounding of the equipment.
- e. Festoon cable must be installed with suitable strain relief and protected from physical damage in accordance NFPA 70 Article 610.11(E)(1). This includes damage from chafing against the crane structure and any other type of damage that may be incurred.

]PART 3 EXECUTION

3.1 EXAMINATION

After becoming familiar with all details of the work, and before performing any work, verify all dimensions in the field. The Contractor is responsible for the coordination and proper relation of the contracted

work to the building structure and to the work of all trades. Verify all dimensions of the building that relate to fabrication of the crane and notify the Contracting Officer of any discrepancy before finalizing the crane order.

[3.2 SHOP ASSEMBLY AND TESTS

NOTE: Shop testing is not typically justified for cranes utilizing commercial packaged hoist/trolley units.

The Government reserves the right to inspect the crane for compliance with this specification and to witness the functionality tests. Notify the Contracting Officer [14][_____] days prior to starting testing operations.

]3.3 ERECTION AND INSTALLATION

Perform the entire monorail system erection in accordance with manufacturer's instructions under the full-time supervision of the manufacturer's representative.

[3.3.1 Electrical Adjustments

NOTE: Electrical adjustments section is not necessary for cranes which do not have electrical systems, such as manual or pneumatic hoists and trolleys.

Adjust control system in accordance with manufacturer's instructions. Provide a copy of all Control Parameter Settings (VFD). Provide the final settings and configurations data on the [Complete Schematic Wiring Diagram](#).

]3.3.2 Field Welding

Perform welding indoors, where possible. Surface of parts to be welded must be free from rust, scale, paint, grease, and other foreign matter. Minimum preheat and interpass temperatures must conform to the requirements of [AWS D14.1/D14.1M](#).

3.3.3 Field Painting

Perform painting indoors, where possible. Field painting (including touch-up) must conform to the requirements of the coating manufacturer and as specified in the paragraph PAINTING SYSTEM.

3.4 FIELD QUALITY CONTROL

3.4.1 [Post-Erection Inspection](#)

After erection, the Contractor[, the Activity Crane Inspector/Test Director,] and the Contracting Officer must jointly inspect the crane monorail track and hoist systems and components to verify compliance with specifications and approved submittals. Notify the Contracting Officer [14][_____] days before the inspection. Provide a report of the inspection indicating the crane is considered ready for operational tests.

Document the results of this inspection and submit the post-erection inspection report to the Contracting Officer for approval.

3.4.2 Operational Tests

NOTE: Determine if Government furnished certified test weights are available at the site (recommended). If not, they must be provided by the Contractor. These weights are for acceptance testing and will not be permanently retained by the Government.

Check the clearance envelope of the entire crane prior to picking or traversing any load to ensure there are no obstructions. Test the systems in service to determine that each component of the system operates as specified, is properly installed and adjusted, and is free from defects in material, manufacture, installation, and workmanship. Rectify all deficiencies disclosed by testing and retest the system or component to prove the crane is operational.[The Contractor must furnish test weights, operating personnel, instruments, and other apparatus necessary to conduct field tests on each crane. Solid weights must be measured using calibrated equipment traceable to National Institute of Standards and Technology (NIST) with a minimum accuracy of plus or minus two percent.]

3.4.2.1 No-Load Test

- a. Raise and lower each hook through the full range of normal travel at rated speed for three complete cycles. Raise and lower each hook, testing other speeds of the crane. Verify proper operation of hoist limit switches. Operate the trolley in each direction the full distance between end stops and bring bumpers into contact with the end stops. Operate through the entire speed range and verify proper brake operation. Verify correct operation of all indication and ancillary devices, including securing methods for outdoor cranes.
- b. Hoist Limit Switch: Slowly raise the hoist into the primary upper limit switch and verify that the hoist stops when the limit switch is tripped and the hook is only capable of lowering. Ensure that the full speed runout distance after primary limit switch activation is less than the travel distance required to activate the secondary upper limit.
 - (1) Test the primary upper limit again, gradually increasing speed to full speed and verify that the secondary limit is not tripped when the primary limit is engaged at full speed
 - (2) Raise the hook slowly through the upper limit switch by using the limit switch bypass (where applicable). Activate the secondary hoist upper limit switch.
 - (3) Slowly lower the hoist into the lower limit switch and verify that the hoist stops when the limit switch is tripped and the hook is only capable of raising.
 - (4) When travel-limiting clutches are used as limit devices, follow

the methods for testing the travel-limiting clutch in the hoist operations manual.

3.4.3 Test Data

Submit all crane test data recorded on appropriate test record forms suitable for retention for the life of the crane. In addition, note, investigate, and correct any high temperatures or abnormal operation of any equipment or machinery. Record hoist and trolley speeds during each test cycle.

3.4.4 Hook Tram Measurement

Establish a throat dimension base measurement by installing two tram points and measuring the distance between these tram points (plus or minus 0.4 mm 1/64 inch). Record this base dimension. Measure the distance between tram points before and after load test. An increase in the throat opening from the base measurement is cause for rejection.

3.4.5 Load Tests

NOTE: For NAVFAC, require a rated load test of 100 percent (plus 0 / minus 10) and an overload test of 125 percent (plus 0 / minus 5) of the rated load.

Wire rope run-in is applicable to wire rope hoists.

- a. Perform the following tests as specified below.
- b. Test loads used in this section are defined as the following:
 - (1) Wire rope run-in load (when applicable): 25 - 50 percent of rated load.
 - (2) Manual powered chain hoist load control: a minimum of 23 kg 50 pounds times the number of load-supporting parts.
 - (3) Rated load test: 100 percent (plus [0][____] minus [10][____]) of rated load.
 - (4) Overload test: 125 percent (plus [0][____] minus [5][____]) of rated load.
- c. Testing of cranes must be done with the use of test weights. The use of dynamometers in lieu of lifting test weights is not permitted. Each test weight for crane tests must be marked with a unique identification number and the weight in pounds. The weight marked must be the actual weight taken from the scale or other measuring device. Solid weights must be measured using calibrated equipment traceable to the National Institute of Standards and Technology (NIST), with a minimum accuracy of plus or minus two percent (i.e., indicated weight must be within plus or minus two percent of actual weight). A list of test weights, with identification numbers and weights, must be retained. The list must include the type and serial number (or other identifier) of the weighing device(s) used to weigh the test weights. Where a lifting attachment supports multiple test weights (e.g., stacked weights or multiple weights suspended from a

padeye), the total capacity must be marked on the attachment. All rigging gear must meet OSHA and ASME requirements.

[3.4.5.1 Wire Rope Run-In

NOTE: This section is not applicable for hoists with load chain.

The primary purpose of this procedure is to exercise the newly installed wire rope.

Place the load on the hook. Start at ground level and hoist up to one foot below upper limit at slow speed. Hoist down to lower limit at slow speed. Repeat hoisting and lowering of the load for approximately 10 hoisting cycles, increasing the speed for each cycle. During this test, the capacity overload lockout should not activate.

]3.4.5.2 Manual Chain Hoist Load Control

NOTE: This section is only applicable to manually powered chain hoists. This section is not applicable for hoists with wire rope or for powered chain hoists.

Place the load on the hook. Start at ground level and hoist up to one foot below upper limit. Hoist down to lower limit. Observe for smooth operation of the hoist.

]3.4.5.3 Rated Load Test

3.4.5.3.1 Hoist

- a. Static Load Test: With the trolley centered between hangar supports, raise the test load approximately 300 mm one foot. Hold the load for 10 minutes. Rotate the load and hook 360 degrees clockwise and counterclockwise to check bearing operation with no binding. Observe for lowering of the load, which may indicate a malfunction of hoisting components or brakes. For new monorail installations, measure and verify deflection for the longest monorail beam section do not exceed CMAA 74 and MHI MH27.1, as applicable.
- b. Dynamic Load Test: Raise and lower test load through the full lift range and visually observe smooth control and acceleration between points. Completely stop the machinery at least once in each direction to ensure proper brake operation.
- c. Hoist Mechanical Load Brake (or Self-locking Worm Gear): Raise test load approximately 1500 mm 5 feet. With the hoist controller in the neutral position, release the holding brake. Document the method used to release the holding brake. The load brake must hold the test load. Again, with the holding brake in the released position start the test load down at slow speed and return the controller to the "off" position as the test load lowers. The load brake must stop and hold the test load. Re-engage the holding brake.

- d. Hoist Loss of Power Test: Raise the test load to approximately 2400 mm 8 feet. While slowly lowering the test load, disconnect the crane's power source. Verify that the test load does not lower and that the brake is set.

3.4.5.3.2 Trolley

Operate the trolley (if space is available) the full distance of the monorail system including all curves and switches in each direction with a test load on the hook. Check proper functioning through the range of speeds. Verify proper brake action and stopping distance.

3.4.5.3.3 Trolley Loss of Power Test

Raise the test load approximately midway between the powered trolley and any permanent obstruction on the operating floor. Starting at a safe distance from walls or other obstructions, attain a slow speed of powered trolley travel. While maintaining a safe distance from obstructions, disconnect the main power source at the wall to simulate a power failure. Verify that the trolley stops and that the brake sets properly. Measure the distance required for the trolley to stop.

3.4.5.4 Overload Test

3.4.5.4.1 Hoist

Disconnect or adjust the overload limit device to allow the hoist to lift the test load. Verify proper operation of the overload limit device after it is reconnected.

- a. Static Load Test: With the trolley centered between vertical supports, raise the test load approximately 300 mm one foot. Hold the load for 10 minutes. Rotate the load and hook 360 degrees clockwise and counterclockwise to check bearing operation with no binding. Observe for lowering of the load, which may indicate a malfunction of hoisting components or brakes.
- b. Dynamic Load Test: Raise and lower test load and visually observe smooth control. Stop the load during raising and lowering to verify that the brakes hold the load.
- c. Hoist Mechanical Load Brake (or Self-locking Worm Gear): Raise test load approximately 1500 mm 5 feet. With the hoist controller in the neutral position, release the holding brake. Document the method used to release the holding brake. The load brake must hold the test load. Again, with the holding brake in the released position start the test load down at slow speed and return the controller to the "off" position as the test load lowers. The load brake must stop and hold the test load. Re-engage the holding brake.
- d. Hoist Loss of Power Test: Raise the test load to approximately 2400 mm 8 feet. While slowly lowering the test load, disconnect the crane's power source. Verify that the test load does not lower and that the brake is set.

3.4.5.4.2 Trolley

Operate the trolley the full distance of the monorail rail system including all curves and switches in each direction with a test load on

the hook (one cycle) through the range of speeds. Verify proper brake action.

[3.5 MANUFACTURER'S FIELD SERVICE REPRESENTATIVE

**NOTE: This section is only recommended for larger
and more involved projects. Provide consideration
for number of cranes, type (power source) of cranes,
and local command experience with cranes.**

Furnish a qualified experienced manufacturer's field service representative to supervise the crane installation, assist in the performance of the on-site testing, and instruct personnel in the operational and maintenance features of the equipment.

]3.6 OPERATION AND MAINTENANCE MANUALS

Provide [two][_____] hard copies of operation and [two][_____] hard copies of maintenance manuals for the equipment furnished along with an electronic copy (PDF) of each on a Compact Disc. Provide one complete set prior to performance testing and final copies upon acceptance. Provide operation manuals that detail the step-by-step procedures required for system startup, operation, and shutdown. Include the manufacturer's name, model number, parts list, and brief description of all equipment and basic operating features. List in the maintenance manuals routine maintenance procedures, including weekly, monthly, semi-annual, and annual required maintenance items, possible breakdowns and repairs, and troubleshooting guides. Also include as-built drawings, piping and equipment layout, design calculations, Control Parameter Settings and printouts of any software, and simplified wiring and control diagrams of the system as installed. Secure approval of operation and maintenance manuals prior to the field training course (as applicable).

[3.7 FIELD TRAINING

NOTE: Training is recommended, but not required.

**Additional items that could be included in the
blank: general review of the entire capabilities,
limitations, and safety features of the crane.**

**An optional variable frequency drive (VFD) training
is available, should the crane be provided with
VFD's and the command feel the additional training
is beneficial.**

Conduct a training course for [eight][_____] operating and maintenance staff[and provide a copy of the training material to each participant]. Provide a training period consisting of a total of [4][8][_____] hours of normal working time and starting after the system is functionally completed but prior to final acceptance. Cover all pertinent points involved in operating, starting, stopping, and servicing the equipment, including all major elements of the Operation and Maintenance Manuals. Demonstrate in course instructions all routine maintenance operations such as lubrication, general inspection, and basic troubleshooting[, and

[_____]]].

[Provide a minimum [4][_____] hour training session on the Variable Frequency Drives (VFDs) discussing maintenance, troubleshooting of fault codes, theory of operation, and adjustment of crane parameters. This training session will be for an audience of approximately [eight][_____] people.

]] [3.8 FINAL ACCEPTANCE

NOTE: Use this paragraph as written for projects where the crane is the principal construction element or represents a very significant portion of the Contract cost. However, if the crane is part of a new facility or renovation, delete the acceptance paragraph from this section. Warranty period and operating and maintenance processes must coincide with the actual beneficial occupancy of the entire facility.

Final acceptance of crane system will not be given until Contractor has successfully completed all testing operations, corrected all material and equipment defects, and made all proper operational adjustments.

] -- End of Section --