
USACE / NAVFAC / AFCEA UFGS-10605 (August 2004)

Preparing Activity: NAVFAC Superseding
UFGS-10605N (September 1999)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 25 June 2004

SECTION TABLE OF CONTENTS

DIVISION 10 - SPECIALTIES

SECTION 10605

WIRE MESH PARTITIONS

08/04

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 DELIVERY, STORAGE, AND HANDLING
- 1.4 DESCRIPTION OF WORK

PART 2 PRODUCTS

- 2.1 MATERIALS
 - 2.1.1 Steel Shapes, Plates, and Bars
 - 2.1.2 Cold-Formed Steel
 - 2.1.3 Wire Mesh
 - 2.1.4 Floor Sockets
- 2.2 NORMAL DUTY PARTITIONS
 - 2.2.1 Wire Mesh
 - 2.2.2 Vertical Frames
 - 2.2.3 Horizontal Frames
 - 2.2.4 Center Reinforcing Bar
 - 2.2.5 Capping Bar
 - 2.2.6 Corner Posts
 - 2.2.7 Line Posts
 - 2.2.8 Hinged Doors
 - 2.2.9 Sheet Metal Base
- 2.3 HEAVY DUTY PARTITIONS
 - 2.3.1 Wire Mesh
 - 2.3.2 Panel Frames
 - 2.3.3 Center Reinforcing Bar
 - 2.3.4 Capping Bar
 - 2.3.5 Corner Posts
 - 2.3.6 Line Posts
 - 2.3.7 Hinged Doors
- 2.4 SLIDING DOORS
- 2.5 DOOR OPENING FRAMES
- 2.6 LOCKS
- 2.7 SERVICE WINDOWS

2.8 FABRICATION

- 2.8.1 Standard Panels
- 2.8.2 Sheet Metal Base Panels
- 2.8.3 Doors [and Service Windows]
- 2.8.4 Finish

PART 3 EXECUTION

3.1 INSTALLATION

- 3.1.1 Wire Mesh Partitions
- 3.1.2 Doors [and Service Windows]
- 3.1.3 Bracing
- 3.1.4 Touch-Up

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA UFGS-10605 (August 2004)

Preparing Activity: NAVFAC Superseding
UFGS-10605N (September 1999)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 25 June 2004

SECTION 10605

WIRE MESH PARTITIONS

08/04

NOTE: This guide specification covers the requirements for wire mesh partitions for normal and for extra heavy industrial use.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

NOTE: The following information shall be indicated on the project drawings:

1. Location, extent, height, and configuration of wire mesh partitions.
2. All openings, direction of door swing.
3. If the project includes both normal duty and heavy duty partitions, indicate the extent of each type.

PART 1 GENERAL

1.1 REFERENCES

NOTE: Issue (date) of references included in project specifications need not be more current than

provided by the latest guide specification. Use of
SpecsIntact automated reference checking is
recommended for projects based on older guide
specifications.

The publications listed below form a part of this specification to the
extent referenced. The publications are referred to within the text by the
basic designation only.

AMERICAN IRON AND STEEL INSTITUTE (AISI)

AISI SG-973 (1996) Cold-Formed Steel Design Manual

ASTM INTERNATIONAL (ASTM)

ASTM A 36/A 36M (2003a) Carbon Structural Steel

1.2 SUBMITTALS

NOTE: Submittals must be limited to those necessary
for adequate quality control. The importance of an
item in the project should be one of the primary
factors in determining if a submittal for the item
should be required.

A "G" following a submittal item indicates that the
submittal requires Government approval. Some
submittals are already marked with a "G". Only
delete an existing "G" if the submittal item is not
complex and can be reviewed through the Contractor's
Quality Control system. Only add a "G" if the
submittal is sufficiently important or complex in
context of the project.

For submittals requiring Government approval on Army
projects, a code of up to three characters within
the submittal tags may be used following the "G"
designation to indicate the approving authority.
Codes for Army projects using the Resident
Management System (RMS) are: "AE" for
Architect-Engineer; "DO" for District Office
(Engineering Division or other organization in the
District Office); "AO" for Area Office; "RO" for
Resident Office; and "PO" for Project Office. Codes
following the "G" typically are not used for Navy
projects.

Submittal items not designated with a "G" are
considered as being for information only for Army
projects and for Contractor Quality Control approval
for Navy projects.

Government approval is required for submittals with a "G" designation;
submittals not having a "G" designation are [for Contractor Quality Control
approval.][for information only. When used, a designation following the
"G" designation identifies the office that will review the submittal for

the Government.] The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Wire mesh partitions

Show layout, details, materials, dimensions, finishes, and all information necessary for fabrication and installation.

SD-03 Product Data

Wire mesh partitions

Submit for each type of partition, door, and window.

1.3 DELIVERY, STORAGE, AND HANDLING

Deliver materials in manufacturer's original, unopened containers or packaging with labels intact and legible. Deliver, store, and handle materials so as to prevent damage. Replace damaged or defective materials with new.

1.4 DESCRIPTION OF WORK

Wire mesh partitions shall be [all wire type] [sheet metal base type], [normal duty for normal industrial use] [heavy duty for extra heavy industrial use], and shall be provided complete with fasteners, capping bars, adjustable floor sockets, bracing, doors, [service windows,] hardware, and other items necessary for a complete, useable, and rigid installation.

PART 2 PRODUCTS

2.1 MATERIALS

2.1.1 Steel Shapes, Plates, and Bars

ASTM A 36/A 36M.

2.1.2 Cold-Formed Steel

AISI SG-973.

2.1.3 Wire Mesh

Carbon steel wire, woven diamond mesh, intermediate crimped.

2.1.4 Floor Sockets

Cast or forged steel or ductile iron, adjustable, approximately 64 mm 2 1/2 inches high.

2.2 NORMAL DUTY PARTITIONS

2.2.1 Wire Mesh

10 gage wire, 38 mm 1 1/2 inch mesh.

2.2.2 Vertical Frames

32 by 16 mm 1 1/4 by 5/8 inch cold-rolled C section channels or 32 by 16 by 3 mm 1 1/4 by 5/8 by 1/8 inch channels. [Provide only C channels where frames are installed toe to toe without posts.]

2.2.3 Horizontal Frames

25 by 16 mm One by 5/8 inch channels.

2.2.4 Center Reinforcing Bar

One 25 by 13 by 3 mm one by 1/2 by 1/8 inch channel with all wires woven through, or two 25 by 10 by 3 mm one by 3/8 by 1/8 inch channels bolted together with mesh in between.

2.2.5 Capping Bar

56 by 25 by 3 mm 2 1/4 by one by 1/8 inch channel or 50 by 6 mm 2 by 1/4 inch flat bar.

2.2.6 Corner Posts

Structural steel angles, 32 by 32 by 3 mm 1 1/4 by 1 1/4 by 1/8 inch.

2.2.7 Line Posts

Unless otherwise indicated, provide partitions more than 3600 mm 12 feet high with flat bar line posts bolted between vertical frame channels. Sizes of posts shall be as follows:

| Partition Height | Size of Posts |
|------------------|----------------------------|
| 3600 to 4400 mm | 44 by 7.9 mm or 50 by 6 mm |
| 4400 to 5900 mm | 63 by 7.9 mm |
| 5900 to 7100 mm | 75 to 7.9 mm |

| Partition Height | Size of Posts |
|--------------------------------------|--|
| 12 feet to 14 feet 8 inches | 1 3/4 by 5/16 inch or 2 by 1/4 inch |
| 14 feet 8 inches to 19 feet 8 inches | 2 1/2 by 5/16 inch |
| 19 feet 8 inches to 23 feet 8 inches | 3 by 5/16 inch |

2.2.8 Hinged Doors

Frames shall be 32 by 13 by 3 mm 1 1/4 by 1/2 by 1/8 inch channels with 32 by 3 mm 1 1/4 by 1/8 inch flat bar cover on top and bottom rails and on hinge stile and a 35 by 20 by 3 mm 1 3/8 by 3/4 by 1/8 inch angle riveted to the lock stile. Provide 1 1/2 pairs of regular weight, wrought steel, non-removable pin, butt hinges riveted or welded to the door and the door opening frame for each door.

2.2.9 Sheet Metal Base

Hot- or cold-rolled sheet steel, not lighter than 16 gage.

2.3 HEAVY DUTY PARTITIONS

2.3.1 Wire Mesh

6 gage wire, 50 mm 2 inch mesh.

2.3.2 Panel Frames

38 by 20 by 3 mm 1 1/2 by 3/4 by 1/8 inch steel channels.

2.3.3 Center Reinforcing Bar

One 38 by 20 by 3 mm 1 1/2 by 3/4 by 1/8 inch channel with all wires woven through, or two 32 by 10 by 3 mm 1 1/4 by 3/8 by 1/8 inch channels bolted together with mesh in between.

2.3.4 Capping Bar

Structural steel channel, 75 mm by 1.9 kg 3 inch by 4.1 pounds.

2.3.5 Corner Posts

Structural steel angles, 45 by 45 by 3 mm 1 3/4 by 1 3/4 by 1/8 inch.

2.3.6 Line Posts

Unless otherwise indicated, provide partitions with flat bar line posts bolted between vertical frame channels. Sizes of posts shall be as follows:

| Partition Height | Size of Posts |
|--------------------|-------------------------------------|
| 2100 to 3600 mm | 62 by 7.9 mm |
| 3600 to 4800 mm | 75 by 7.9 mm or 62 by 10 mm |
| 4800 to 6000 mm | 87 by 7.9 mm |
| Partition Height | Size of Posts |
| 7 feet to 12 feet | 2 1/2 by 5/16 inch |
| 12 feet to 16 feet | 3 by 5/16 inch or 2 1/2 by 3/8 inch |
| 16 feet to 20 feet | 3 1/2 by 5/16 inch |

2.3.7 Hinged Doors

Frames shall be 38 by 20 by 3 mm 1 1/2 by 3/4 by 1/8 inch channels with 38 by 3 mm 1 1/2 by 1/8 inch flat bar cover on top and bottom rails and on hinge stile and a 41 by 22 by 3 mm 1 5/8 by 7/8 by 1/8 inch angle riveted to the lock stile. Provide 1 1/2 pairs of heavyweight, wrought steel, non-removable pin, butt hinges riveted or welded to the door and the door opening frame for each door.

2.4 SLIDING DOORS

Frames shall be 38 by 20 by 3 mm 1 1/2 by 3/4 by 1/8 inch channels with 38 by 3 mm 1 1/2 by 1/8 inch flat bar cover all around. Provide two four-wheel, roller bearing hangers and steel box track for each door.

2.5 DOOR OPENING FRAMES

Provide frames the same size and shape as the vertical frames for the mesh panels.

2.6 LOCKS

Provide each door with a mortise type lock with a six-pin tumbler lock cylinder on the outside and a recessed knob on the inside.

2.7 SERVICE WINDOWS

Slide up type, mounted in standard mesh panel reinforced with channel tracks. Opening shall be 600 mm wide by 450 mm high 24 inches wide by 15 inches high unless otherwise indicated. Provide two spring loaded latches, operable only from the inside, to lock window in open and closed positions. [Form shelf of 12 gage sheet steel, 300 mm deep by 625 mm wide 12 inches deep by 25 inches wide, unless otherwise indicated.]

2.8 FABRICATION

2.8.1 Standard Panels

Wire shall be woven into diamond mesh, intermediate crimped, and securely clinched to frames. Joints shall be mortised and tenoned. Wire shall be continuous at center reinforcing bars, either woven through a single channel or bolted between two channels. Panel vertical frames shall have [6 mm 1/4 inch bolt holes 300 mm 12 inches o.c. for normal duty partitions] [10 mm 3/8 inch bolt holes 450 mm 18 inches o.c. for heavy duty partitions].

2.8.2 Sheet Metal Base Panels

Upper portion shall be as specified for standard panels, except that the wire shall be clinched into the center reinforcing bar. Form sheet steel to fit between the panel frames and securely bolt to the frames.

2.8.3 Doors [and Service Windows]

Construction shall be similar to that specified for panels. Wire mesh shall be the same as that used in the adjacent partition panels.

2.8.4 Finish

Thoroughly clean ferrous metal, treat with phosphate, and paint with [green] [black] [gray] enamel in the shop.

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 Wire Mesh Partitions

Install plumb, level, and true to line, within a tolerance of 3 mm in 3 m

1/8 inch in 10 feet or the height or run of the partition, if less than 3 meters 10 feet. Anchor floor sockets to the floor with expansion bolts. Vertical frames and posts shall be bolted together with [6 mm bolts 300 mm o.c. 1/4 inch bolts 12 inches o.c. for normal duty partitions] [10 mm bolts 450 mm o.c. 3/8 inch bolts 18 inches o.c. for heavy duty partitions]. Secure top frames to a continuous capping bar with 6 mm 1/4 inch diameter U bolts not more than 650 mm 28 inches o.c.

3.1.2 Doors [and Service Windows]

Install in accordance with the manufacturers' recommendations. Adjust as required so that doors [, windows,] and hardware operate freely and properly.

3.1.3 Bracing

Brace free standing partitions more than 6 meters 20 feet in length, at intervals not greater than 6 meters 20 feet [with a steel channel brace connected to the capping bar and anchored to the building wall or framing member] [with a structural steel I section or tube post welded to a 225 by 225 mm 9 by 9 inch steel base plate anchored to the floor with 4 expansion bolts] [or as indicated].

3.1.4 Touch-Up

Clean and paint scratches, abrasions, and other damage to shop painted surfaces to match the shop-applied finish.

-- End of Section --