

\*\*\*\*\*  
USACE / NAVFAC / AFCEA UFGS-02810 (August 2004)  
-----  
Preparing Activity: USACE Superseding  
UFGS-02811A (February 2002)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 25 June 2004

Latest change indicated by CHG tags

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 02 - SITE CONSTRUCTION

#### SECTION 02810

#### UNDERGROUND SPRINKLER SYSTEMS

08/04

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 PERFORMANCE REQUIREMENTS
- 1.3 SUBMITTALS
- 1.4 DELIVERY AND STORAGE
- 1.5 FIELD MEASUREMENTS

#### PART 2 PRODUCTS

- 2.1 MATERIALS AND EQUIPMENT REQUIREMENTS
  - 2.1.1 Standard Products
  - 2.1.2 Nameplates
  - 2.1.3 Extra Stock
- 2.2 PIPING MATERIALS
  - 2.2.1 Copper Tubing and Associated Fittings
  - 2.2.2 Red Brass Pipe and Associated Fittings
  - 2.2.3 Galvanized Steel Pipe and Associated Fittings
  - 2.2.4 Polyvinyl Chloride (PVC) Pipe, Fittings and Solvent Cement
    - 2.2.4.1 PVC Pipe
    - 2.2.4.2 PVC Fittings
    - 2.2.4.3 Solvent Cement
  - 2.2.5 Polyethylene (PE) Plastic Piping
  - 2.2.6 Dielectric Fittings
  - 2.2.7 Emitter Hose and Distribution Tubing
- 2.3 SPRINKLER AND EMITTER HEADS
  - 2.3.1 Pop-Up Spray Heads
    - 2.3.1.1 General Requirements
    - 2.3.1.2 Shrubbery Sprinkler Heads
  - 2.3.2 Rotary Pop-Up Sprinklers
  - 2.3.3 Bubbler Sprinkler Heads
  - 2.3.4 Surface Connected Lawn Sprinkler Heads
  - 2.3.5 Emitter Heads
- 2.4 VALVES

- 2.4.1 Gate Valves, Less than 80 mm (3 Inches) 3 Inches
- 2.4.2 Gate Valves, 80 mm (3 Inches) 3 Inches and Larger
- 2.4.3 Angle Valves, Less Than 65 mm (2-1/2 Inches) 2-1/2 Inches
- 2.4.4 Angle Valves, 65 mm (2-1/2 Inches) 2-1/2 Inches and Larger
- 2.4.5 Quick Coupling Valves
- 2.4.6 Remote Control Valves, Electrical
- 2.4.7 Drain Valves
  - 2.4.7.1 Manual Valves
  - 2.4.7.2 Automatic Valves
- 2.4.8 Pressure Regulating Master Valve
- 2.4.9 Backflow Preventers
  - 2.4.9.1 Pressure Type Vacuum Breaker
  - 2.4.9.2 Reduced Pressure Type Backflow Preventers
- 2.5 ACCESSORIES AND APPURTENANCES
  - 2.5.1 Valve Keys for Manually Operated Valves
  - 2.5.2 Valve Boxes and Concrete Pads
    - 2.5.2.1 Valve Boxes
    - 2.5.2.2 Concrete Pads
  - 2.5.3 Pressure Gauges
  - 2.5.4 Service Clamps
  - 2.5.5 Water Hammer Arresters
  - 2.5.6 Emitter Head Accessories
    - 2.5.6.1 Strainer
    - 2.5.6.2 Pressure Regulator
    - 2.5.6.3 Riser Adapters
    - 2.5.6.4 Tubing Stakes
    - 2.5.6.5 Emitter Outlet Check Valve (Bug Cap)
    - 2.5.6.6 Access Sleeve
    - 2.5.6.7 Closure Caps
- 2.6 AUTOMATIC CONTROLLERS, ELECTRICAL
- 2.7 ELECTRICAL WORK
- 2.8 CONCRETE MATERIALS
- 2.9 WATER SUPPLY MAIN MATERIALS
- 2.10 INSULATING JOINTS

## PART 3 EXECUTION

- 3.1 INSTALLATION
  - 3.1.1 Trenching
  - 3.1.2 Piping System
    - 3.1.2.1 Cover
    - 3.1.2.2 Clearances
    - 3.1.2.3 Minimum Slope
  - 3.1.3 Piping Installation
    - 3.1.3.1 Polyvinyl Chloride (PVC) Pipe
    - 3.1.3.2 Soldered Copper Tubing
    - 3.1.3.3 Threaded Brass or Galvanized Steel Pipe
    - 3.1.3.4 Insulating Joints
    - 3.1.3.5 Grooved Mechanical Joints
  - 3.1.4 Installation of Valves
    - 3.1.4.1 Manual Valves
    - 3.1.4.2 Automatic Valves
    - 3.1.4.3 Drain Valves
  - 3.1.5 Sprinklers and Quick Coupling Valves
  - 3.1.6 Installation of Drip Irrigation System
    - 3.1.6.1 Emitter Hose
    - 3.1.6.2 Emitter Heads
    - 3.1.6.3 Tubing Stakes
  - 3.1.7 Backflow Preventers

- 3.1.7.1 Pressure Type Vacuum Breaker
- 3.1.7.2 Reduced Pressure Type
- 3.1.8 Control Wire and Conduit
  - 3.1.8.1 Wires
  - 3.1.8.2 Loops
  - 3.1.8.3 Expansion and Contraction
  - 3.1.8.4 Splices
- 3.1.9 Automatic Controller
- 3.1.10 Thrust Blocks
- 3.1.11 Backfill
  - 3.1.11.1 Minimum Cover
  - 3.1.11.2 Restoration
- 3.1.12 Adjustment
- 3.1.13 Disinfection
- 3.1.14 Cleaning of Piping
- 3.2 FIELD TESTS
  - 3.2.1 Hydrostatic Pressure Test
  - 3.2.2 Leakage Tests
  - 3.2.3 Operation Test
- 3.3 FRAMED INSTRUCTIONS
- 3.4 FIELD TRAINING
- 3.5 CLEANUP

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCESA UFGS-02810 (August 2004)  
-----  
Preparing Activity: USACE Superseding  
UFGS-02811A (February 2002)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 25 June 2004

Latest change indicated by CHG tags

\*\*\*\*\*

SECTION 02810

UNDERGROUND SPRINKLER SYSTEMS  
08/04

\*\*\*\*\*

NOTE: This guide specification covers the requirements for underground sprinkler irrigation systems.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

\*\*\*\*\*

PART 1 GENERAL

\*\*\*\*\*

NOTE: Irrigation system requirements depend upon rainfall factors for the project area, plant selections, the quality of growth desired, and budgetary constraints. The area factors will be determined by a registered landscape professional. Reference is made to TM 5-803-13. While the design of a system with pop-up heads may be justified in some geographic areas, bubbler type systems may be required in areas where water conservation methods are being practiced. If source of water supply is from base water main through a service line and water meter, determine amount of water available for irrigation system from static pressure at point of connection to water main. In many cases, water

supply is adequate for short durations only. The amount of water required is determined from the type of turf to be irrigated, climate, terrain, and soil conditions. System piping layout, pipe sizes, and selection and spacing of heads and emitters must provide the required amount of water and complete coverage of the irrigated areas. Provide valves to allow irrigation of each area separately.

\*\*\*\*\*

## 1.1 REFERENCES

\*\*\*\*\*

NOTE: Issue (date) of references included in project specifications need not be more current than provided by the latest guide specification. Use of SpecsIntact automated reference checking is recommended for projects based on older guide specifications.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

### AMERICAN SOCIETY OF SANITARY ENGINEERING (ASSE)

|           |  |
|-----------|--|
| ASSE 1012 | (2002) Backflow Preventer with Intermediate Atmospheric Vent   |
| ASSE 1013 | (1999) Reduced Pressure Principle Backflow Preventers and Reduced Pressure Fire Protection Principle Backflow Preventers |
| ASSE 1020 | (1998) Pressure Vacuum Breaker Assembly  |

### AMERICAN WATER WORKS ASSOCIATION (AWWA)

|           |  |
|-----------|--|
| AWWA C509 | (2001) Resilient-Seated Gate Valves for Water Supply Service   |
| AWWA C606 | (1997) Grooved and Shouldered Joints   |
| AWWA C901 | (2002) Polyethylene (PE) Pressure Pipe and Tubing, 1/2 In. (13mm) Through 3 In. (76 mm), for Water Service |

### ASME INTERNATIONAL (ASME)

|             |  |
|-------------|--|
| ASME B1.2   | (1983; R 2001) Gages and Gaging for Unified Inch Screw Threads   |
| ASME B16.15 | (1985; R 1994) Cast Bronze Threaded Fittings Classes 125 and 250 |
| ASME B16.18 | (2002) Cast Copper Alloy Solder Joint Pressure Fittings          |
| ASME B16.22 | (2002) Wrought Copper and Copper Alloy                           |

## Solder Joint Pressure Fittings

|            |  |
|------------|--|
| ASME B16.3 | (1998) Malleable Iron Threaded Fittings                            |
| ASME B40.1 | (1991) Gauges - Pressure Indicating Dial<br>Type - Elastic Element |

## ASTM INTERNATIONAL (ASTM)

|                   |  |
|-------------------|--|
| ASTM A 183        | (2003) Carbon Steel Track Bolts and Nuts   |
| ASTM A 53/A 53M   | (2002) Pipe, Steel, Black and Hot-Dipped,<br>Zinc-Coated, Welded and Seamless                                  |
| ASTM A 536        | (1984; R 1999e1) Ductile Iron Castings   |
| ASTM B 32         | (2003) Solder Metal  |
| ASTM B 43         | (1998) Seamless Red Brass Pipe, Standard<br>Sizes  |
| ASTM B 88         | (2002) Seamless Copper Water Tube  |
| ASTM B 88M        | (1999) Seamless Copper Water Tube (Metric)   |
| ASTM D 1785       | (1999) Poly(Vinyl Chloride) (PVC) Plastic<br>Pipe, Schedules 40, 80, and 120                                   |
| ASTM D 2000       | (2001) Rubber Products in Automotive<br>Applications   |
| ASTM D 2241       | (2000) Poly(Vinyl Chloride) (PVC)<br>Pressure-Rated Pipe (SDR Series)  |
| ASTM D 2287       | (1996; R 2001) Nonrigid Vinyl Chloride<br>Polymer and Copolymer Molding and<br>Extrusion Compounds             |
| ASTM D 2464       | (1999) Threaded Poly(Vinyl Chloride) (PVC)<br>Plastic Pipe Fittings, Schedule 80                               |
| ASTM D 2466       | (2002) Poly(Vinyl Chloride) (PVC) Plastic<br>Pipe Fittings, Schedule 40  |
| ASTM D 2564       | (2002) Solvent Cements for Poly(Vinyl<br>Chloride) (PVC) Plastic Piping Systems                                |
| ASTM D 2774       | (2001) Underground Installation of<br>Thermoplastic Pressure Piping  |
| ASTM D 2855       | (1996; R 2002) Making Solvent-Cemented<br>Joints with Poly(Vinyl Chloride) (PVC)<br>Pipe and Fittings          |
| ASTM D 3261       | (2003) Butt Heat Fusion Polyethylene (PE)<br>Plastic Fittings for Polyethylene (PE)<br>Plastic Pipe and Tubing |
| ASTM F 441/F 441M | (1999e1) Chlorinated Poly(Vinyl Chloride)  |

(CPVC) Plastic Pipe, Schedules 40 and 80

FOUNDATION FOR CROSS-CONNECTION CONTROL AND HYDRAULIC RESEARCH  
(FCCCHR)

FCCCHR Manual (9th Edition) Manual of Cross-Connection  
Control

MANUFACTURERS STANDARDIZATION SOCIETY OF THE VALVE AND FITTINGS  
INDUSTRY (MSS)

MSS SP-80 (2003) Bronze Gate, Globe, Angle and Check  
Valves

MSS SP-85 (2002) Cast Iron Globe & Angle Valves,  
Flanged and Threaded Ends

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA ICS 2 (2000) Industrial Controls and Systems:  
Controllers, Contactors, and Overload  
Relays Rated Not More than 2000 Volts AC  
or 750 Volts DC

NEMA ICS 6 (1993; R 2001) Industrial Control and  
Systems: Enclosures

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2002) National Electrical Code

PLUMBING AND DRAINAGE INSTITUTE (PDI)

PDI WH 201 (1992) Water Hammer Arresters

U.S. GENERAL SERVICES ADMINISTRATION (GSA)

CID A-A-51145 (Rev D) Flux, Soldering, Non-Electronic,  
Paste and Liquid

1.2 PERFORMANCE REQUIREMENTS

\*\*\*\*\*

NOTE: In the design of the sprinkler system  
reference will be made to TM 5-813-5. For a site  
where specific pipe or material is required or where  
certain material will not be acceptable, the  
requirements will be specified and any restricting  
locations will be shown on the drawings. The  
following information will be shown on the drawings:

a. An irrigation legend.

b. The extent, size, type, and location of  
underground sprinkler irrigation system and all  
appurtenances including all piping, sprinkler heads,  
emitters, control valves, and controllers. Indicate  
obstacles that might interfere with the layout or  
operation of the system. Indicate where pipe under

walks and drives must be bored.

c. All required slopes and elevations.

d. Detail of drain pockets.

e. Flow rates and diameter of coverage for individual sprinkler heads and emitters.

f. Minimum irrigation rates.

g. Size, variety, and assembly of backflow prevention units.

h. Number and extent of electrical or hydraulic controller circuits, if required.

i. Automatic valve schedule and timing, along with valve identification key or legend.

\*\*\*\*\*

System shall operate with a minimum water pressure of [\_\_\_\_\_] kPa psi at connection to [main] [meter] [building] [backflow prevention device] and [\_\_\_\_\_] kPa psi at the last head in each zone.

### 1.3 SUBMITTALS

\*\*\*\*\*

NOTE: Submittals must be limited to those necessary for adequate quality control. The importance of an item in the project should be one of the primary factors in determining if a submittal for the item should be required.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy projects.

Submittal items not designated with a "G" are considered as being for information only for Army projects and for Contractor Quality Control approval



**for Navy projects.**

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Sprinkler System

Detail drawings for valves, sprinkler heads, backflow preventers, automatic controllers, emitter heads, and water hammer arresters. Drawings shall include a complete list of equipment and materials, and manufacturer's descriptive and technical literature, performance charts and curves, catalog cuts, and installation instructions. Drawings shall also contain complete wiring and schematic diagrams and any other details required to demonstrate that the system has been coordinated and will function as a unit. Drawings shall show proposed system layout, type and number of heads and emitters, zone valves, drain pockets, backflow devices, controllers, and mounting details of controllers. As-built Drawings which provide current factual information showing locations of mains, heads, valves, and controllers including deviations from and amendments to the drawings and changes in the work shall be included.

SD-03 Product Data

Framed Instructions

Labels, signs, and templates of operating instructions that are required to be mounted or installed on or near the product for normal, safe operation.

Field Training

Information describing training to be provided, training aids to be used, samples of training materials to be provided, and schedules and notification of training.

Sprinkler System

Detailed procedures defining the Contractor's provisions for accident prevention, health protection, and other safety precautions for the work to be done.

Spare Parts

Spare parts data for each different item of material and equipment specified, after approval of the related submittals and not later than the start of the field tests. The data shall include a complete list of parts and supplies, with current unit prices and source of supply.

Design Analysis and Calculations

Design analyses and pressure calculations verifying that system will provide the irrigation requirements.

#### SD-06 Test Reports

##### Field Tests

Performance test reports, in booklet form, showing all field tests performed to adjust each component; and all field tests performed to prove compliance with the specified performance criteria, upon completion and testing of the installed system. Each test report shall indicate the final position of control valves.

#### SD-07 Certificates

##### Sprinkler System

The material supplier's or equipment manufacturer's statement that the supplied material or equipment meets specified requirements. Each certificate shall be signed by an official authorized to certify in behalf of material supplier or product manufacturer and shall identify quantity and date or dates of shipment or delivery to which the certificates apply.

#### SD-10 Operation and Maintenance Data

##### Sprinkler System

[Six] [\_\_\_\_\_] copies of operation and [six] [\_\_\_\_\_] copies of maintenance manuals for the equipment furnished. One complete set prior to field testing and the remainder upon acceptance. Manuals shall be approved prior to the field training course. Operating manuals shall detail the step-by-step procedures required for system startup, operation, and shutdown. Operating manuals shall include the manufacturer's name, model number, parts list, and brief description of all equipment and their basic operating features. Maintenance manuals shall list routine maintenance procedures, possible breakdowns and repairs, and troubleshooting guides. Maintenance manuals shall include piping and equipment layout, simplified wiring and control diagrams of the system as installed, and system programming schedule.

#### 1.4 DELIVERY AND STORAGE

All equipment delivered and placed in storage shall be protected from the weather; excessive humidity and temperature variation; direct sunlight (in the case of plastic or rubber materials); and dirt, dust, or other contaminants.

#### 1.5 FIELD MEASUREMENTS

The Contractor shall verify all dimensions in the field and shall advise the Contracting Officer of any discrepancy before performing the work.

## PART 2 PRODUCTS

### 2.1 MATERIALS AND EQUIPMENT REQUIREMENTS

#### 2.1.1 Standard Products

Materials and equipment shall be the standard products of a manufacturer who has produced similar systems which have performed well for a minimum period of 2 years prior to bid opening. Equipment shall be supported by a service organization that is, in the opinion of the Contracting Officer, reasonably convenient to the site.

#### 2.1.2 Nameplates

Each item of equipment shall have the manufacturer's name, address, type or style, model or serial number, and catalog number on a plate secured to the item of equipment.

#### 2.1.3 Extra Stock

The following extra stock shall be provided: Two sprinkler heads of each size and type, two valve keys for operating manual valves, two wrenches for removing and installing each type of head, two quick coupler keys and hose swivels, and four irrigation controller housing keys.

### 2.2 PIPING MATERIALS

\*\*\*\*\*  
**NOTE: Select piping materials according to project requirements. Verify soil and water conditions onsite, use proper materials where corrosion problems exist.**  
\*\*\*\*\*

#### 2.2.1 Copper Tubing and Associated Fittings

Tubing shall conform to requirements of ASTM B 88M ASTM B 88, Type K. Fittings shall conform to ASME B16.22 and ASME B16.18, solder joint. Solder shall conform to ASTM B 32 95-5 tin-antimony. Flux shall conform to CID A-A-51145, Type I. Grooved mechanical joints and fittings shall be designed for not less than 862 kPa 125 psig service and shall be the product of the same manufacturer. Grooved fitting and mechanical coupling housing shall be ductile iron conforming to ASTM A 536. Gaskets for use in grooved joints shall be molded synthetic polymer of pressure responsive design and shall conform to ASTM D 2000 for circulating medium up to 110 degrees C 230 degrees F. Grooved joints shall conform to AWWA C606. Coupling nuts and bolts for use in grooved joints shall be steel and shall conform to ASTM A 183.

#### 2.2.2 Red Brass Pipe and Associated Fittings

Pipe shall conform to requirements of ASTM B 43, regular. Fittings shall be Class 250, cast bronze threaded conforming to the requirements of ASME B16.15.

#### 2.2.3 Galvanized Steel Pipe and Associated Fittings

\*\*\*\*\*  
**NOTE: Use of pipe is limited to fixed shrub head**

risers and reduced pressure type backflow preventers.

\*\*\*\*\*

Pipe shall conform to requirements of ASTM A 53/A 53M, Schedule 40.  
Fittings shall be Class 150 conforming to requirements of ASME B16.3.

#### 2.2.4 Polyvinyl Chloride (PVC) Pipe, Fittings and Solvent Cement

\*\*\*\*\*

NOTE: PVC pipe may be used where frost line is less than 300 mm (12 inches) deep or in areas where piping system can be winterized. Use Schedule 40 PVC fittings with solvent weld; do not use threaded Schedule 40 pipe. For risers use brass pipe or Schedule 80 PVC pipe with Schedule 80 PVC threaded fittings. Locate all risers away from walks. Use solvent cement for unthreaded PVC pipe and fittings. ASTM D 1785, PVC 1120, Schedule 40 is Type I, Grade 1 and wall thickness of Schedule 40. ASTM D 1785, PVC 1120, Schedule 80 is Type I, Grade 2 and wall thickness of Schedule 80. ASTM D 2241, PVC 1120, SDR 21 is Type I, Grade 1 and standard dimension ratio of 21.

\*\*\*\*\*

##### 2.2.4.1 PVC Pipe

Pipe shall conform to the requirements of ASTM D 1785, PVC 1120 Schedule [40] [80]; or ASTM D 2241, PVC 1120 SDR 21, Class 200.

##### 2.2.4.2 PVC Fittings

Solvent welded socket type fittings shall conform to requirements of ASTM D 2466, Schedule 40. Threaded type fittings shall conform to requirements of ASTM D 2464, Schedule 80.

##### 2.2.4.3 Solvent Cement

Solvent cement shall conform to the requirements of ASTM D 2564.

#### 2.2.5 Polyethylene (PE) Plastic Piping

Pipe shall conform to AWWA C901, outside diameter base with dimension ratio (DR) of 9.3 to provide 1034 kPa (150 psi) 150 psi minimum pressure rating. Fittings shall conform to ASTM D 3261, DR of 9.3.

#### 2.2.6 Dielectric Fittings

\*\*\*\*\*

NOTE: Provide dielectric fittings between copper and ferrous metal piping materials.

\*\*\*\*\*

Dielectric fittings shall conform to ASTM F 441/F 441M, Schedule 80, CPVC threaded pipe nipples, 100 mm (4 inch) 4 inch minimum length.

#### 2.2.7 Emitter Hose and Distribution Tubing

Emitter hose and distribution tubing shall conform to ASTM D 2287, maximum

inside diameter of 13 mm (1/2 inch), 1/2 inch, minimum wall thickness of 2.286 mm (90 mils), 90 mils, vinyl plastic extruded from non-rigid chloride, integrally algae-resistant, homogeneous throughout, smooth inside and outside, free from foreign materials, cracks, serrations, blisters and other effects. Slip fittings shall be provided.

## 2.3 SPRINKLER AND EMITTER HEADS

### 2.3.1 Pop-Up Spray Heads

#### 2.3.1.1 General Requirements

Pop-up spray heads lay flush with housing, then pop up when water pressure 138 kPa 20 psi is activated in system. The rising member supporting the nozzle shall be identical on full, half, third or quarter pattern sprinklers so that nozzles will be interchangeable. The sprinkler head shall be designed to be adjustable for coverage and flow. The nozzle shall be removable so head does not have to be removed for flushing or cleaning. Nozzle rises a minimum of 100 mm (4 inches) 4 inches above the body. The body shall be constructed with a 13 mm 1/2 inch female thread for installation in a fixed underground pipe system.

#### 2.3.1.2 Shrubbery Sprinkler Heads

\*\*\*\*\*  
**NOTE: Shrubbery sprinkler heads are recommended for flower beds, shrubs, and ground covers.**  
\*\*\*\*\*

Sprinkler heads shall be conical spray with adjustable or non-adjustable coverage and designed for permanent aboveground mounting on riser or pop-ups at a height compatible with ground covers. Provide brass nozzles.

#### 2.3.2 Rotary Pop-Up Sprinklers

\*\*\*\*\*  
**NOTE: Rotary pop-up sprinklers lay flush with housing, then pop up when water pressure is activated in system. Head rotates to direct water spray over a pattern of 360 degrees or a prescribed arc. Primarily used for watering large turf area.**  
\*\*\*\*\*

Sprinklers shall be capable of covering [\_\_\_\_\_]m feet diameter at [\_\_\_\_\_] kPa psi with a distribution rate of [\_\_\_\_\_] L/second gpm, [\_\_\_\_\_] pop-up, trajectory of [\_\_\_\_\_] , and maximum height of spray of [\_\_\_\_\_] . Construction shall be high impact molded plastic with filter screen, reducible watering radius, and choice of [\_\_\_\_\_] nozzles and have adjustable radius capabilities.

#### 2.3.3 Bubbler Sprinkler Heads

\*\*\*\*\*  
**NOTE: A water outlet that does not spray water but permits water to bubble and flow to surrounding plants.**  
\*\*\*\*\*

Heads shall be multiple-spray bubbler with adjustable flow and designed for

permanent aboveground mounting on risers.

#### 2.3.4 Surface Connected Lawn Sprinkler Heads

Heads shall be an impulse type with or without sled, ring, or wheel base; multiple T Type; a rotary type with sled, spike or wheel base; or oscillating type with wheel or sled base.

#### 2.3.5 Emitter Heads

\*\*\*\*\*  
**NOTE: Emitter head is an outlet device that permits water to drip or trickle from small tubings. Drip irrigation is frequent, slow application of water to specific root zone area of plants. The goal is to provide a constant level of subsurface moisture to the root ball of plant for most favorable growth.**  
\*\*\*\*\*

Emitter heads shall be self-cleaning, pressure compensating diaphragm with one or six self-piercing barbed outlets; each capable of emitting from 1 to 8 L/hour (1/4 to 2 gallons per hour) 1/4 to 2 gallons per hour flow. Emitter body shall be ultraviolet stabilized, algae, and heat resistant plastic construction.

### 2.4 VALVES

#### 2.4.1 Gate Valves, Less than 80 mm (3 Inches) 3 Inches

Gate valves shall conform to the requirements of MSS SP-80, Type 1, Class 150, [threaded] [soldered] ends.

#### 2.4.2 Gate Valves, 80 mm (3 Inches) 3 Inches and Larger

Gate valves shall conform to the requirements of AWWA C509 and have encapsulated resilient wedge, parallel seats, non-rising stems, and open by counterclockwise turning. End connections shall be flanged. Interior construction of valves shall be bronze including stem containing a maximum 2 percent aluminum and maximum 16 percent zinc.

#### 2.4.3 Angle Valves, Less Than 65 mm (2-1/2 Inches) 2-1/2 Inches

Angle valves shall conform to the requirements of MSS SP-80, Type 3, Class 150 [threaded] [soldered] ends.

#### 2.4.4 Angle Valves, 65 mm (2-1/2 Inches) 2-1/2 Inches and Larger

Angle valves shall conform to the requirements of MSS SP-85, Type II, Class 250 [threaded] [flanged] ends.

#### 2.4.5 Quick Coupling Valves

\*\*\*\*\*  
**NOTE: A quick coupling device is an effective method of keeping sprinkler out of the way when not in use, eliminating the possibility of damage, injury or theft.**  
\*\*\*\*\*

Quick coupling valves shall have brass parts and shall be two-piece unit consisting of a coupler water seal valve assembly and a removable upper body to allow spring and key track to be serviced without shutdown of main. Lids shall be lockable vinyl with spring for positive closure on key removal.

#### 2.4.6 Remote Control Valves, Electrical

\*\*\*\*\*  
**NOTE: An activated open and shut-off device for  
controlling water flow to sprinkler branch line.**  
\*\*\*\*\*

Remote control valves shall be solenoid actuated globe valves of 20 to 80 mm (3/4 to 3 inch) 3/4 to 3 inch size, suitable for [24] [\_\_\_\_\_] volts, [60] [50] cycle, and designed to provide for shut-off in event of power failure. Valve shall be cast bronze or brass or plastic housing suitable for service at 1034 kPa (150 psi) 150 psi operating pressure with external flow control adjustment for shut-off capability, external plug at diaphragm chamber to enable manual operation, filter in control chamber to prevent valve body clogging with debris, durable diaphragm, and accessibility to internal parts without removing valve from system.

#### 2.4.7 Drain Valves

##### 2.4.7.1 Manual Valves

Manual valves shall conform to requirements of MSS SP-80, Type 3, Class 150 [threaded] [soldered] ends for sizes less than 65 mm (2-1/2 inches) 2-1/2 inches and MSS SP-85, Type II, Class 250 [threaded] [flanged] ends for sizes 65 mm (2-1/2 inches) 2-1/2 inches and larger.

##### 2.4.7.2 Automatic Valves

\*\*\*\*\*  
**NOTE: This saves water to prevent draining 50 to  
100 mm (2 to 4 inch) diameter lines during  
irrigation cycles and avoid continuously saturated  
soil at drain joints. Automatic drains are  
necessary for cold climate areas to prevent freeze  
damage to sprinklers and pipes. PVC or ABS drain  
valves may be used with PVC systems.**

**Delete automatic drains for warm climate areas.**

\*\*\*\*\*

Automatic valves shall be brass or plastic, spring loaded ball drip type, Class 150 150 pounds and threaded ends, designed to close at 18 kPa (6 foot) 6 foot pressure head with positive seal at 21 kPa (3 psi) 3 psi pressure or greater and be open to drain at less than 21 kPa (3 psi) 3 psi pressure.

#### 2.4.8 Pressure Regulating Master Valve

\*\*\*\*\*  
**NOTE: Master valve automatically reduces a higher  
inlet pressure to a constant lower pressure  
regardless of supply fluctuations.**

\*\*\*\*\*

Pressure regulating master valve shall be automatic mechanical self-cleaning, self-purging control system having an adjustable pressure setting operated by a solenoid on alternating current with [0.70] [\_\_\_\_\_] amperes at [18] [24] volts. Valve shall close slowly and be free of chatter in each diaphragm position, have manual flow stem to adjust closing speed and internal flushing, and [one] [two] inlet tapings capable of being installed as a straight pattern valve. Body shall be cast bronze or brass with removable brass seat serviceable from top without removing valve body from system. Valve shall operate at 1034 kPa (150 psi) 150 psi working pressure and pilot range from 70 to 875 kPa (10 to 125 psi).10 to 125 psi.

#### 2.4.9 Backflow Preventers

\*\*\*\*\*

NOTE: Backflow preventer is designed to keep contaminated water from flowing back into potable water distribution system when some temporary abnormality in system causes higher pressure in contaminated part of system than in potable water piping.

\*\*\*\*\*

Reduced pressure principle assemblies, double check valve assemblies, atmospheric (nonpressure) type vacuum breakers, and pressure type vacuum breakers shall be tested, approved, and listed in accordance with FCCCHR Manual. Backflow preventers with intermediate atmospheric vent shall be in accordance with ASSE 1012. Reduced pressure principle backflow preventers shall be in accordance with ASSE 1013.

##### 2.4.9.1 Pressure Type Vacuum Breaker

\*\*\*\*\*

NOTE: Vacuum breaker is designed to prevent back siphonage only, and is not effective against backflow due to back pressure. A vacuum breaker located above flood elevation is adequate when located aboveground and higher than highest sprinkler head.

\*\*\*\*\*

Vacuum breaker shall conform to the requirements of ASSE 1020 and shall be [bronze] [brass] construction, with one or two check valves, vacuum relief, inlet and discharge shut-offs valves, field test cocks, and vacuum relief opening of greater diameter than unit.

##### 2.4.9.2 Reduced Pressure Type Backflow Preventers

\*\*\*\*\*

NOTE: Reduced pressure type backflow preventer is designed to prevent either back siphonage or back pressure from causing a reverse flow and subsequent contamination of potable water piping. Delete this requirement when system is connected to non-potable water supply system, or when sewage is injected into sprinkler system. When effluent pumps are down, add a fresh water connection with a reduced pressure



## **backflow preventer.**

\*\*\*\*\*

Backflow preventers shall be [Class 150] [Class [\_\_\_\_]] [150] [\_\_\_\_] pound flanged [cast iron], [bronze] [brass] mounted gate valve [and strainer], [304] [\_\_\_\_] stainless steel or bronze, internal parts. Total pressure drop through complete assembly shall be a maximum of 70 kPa (10 psi) 10 psi at rated flow. Piping shall be [red brass pipe and fittings] [galvanized steel pipe and fittings]. Strainers shall be bronze or brass construction with gasket caps. Units shall have 200-mesh stainless steel screen elements.

### **2.5 ACCESSORIES AND APPURTENANCES**

#### **2.5.1 Valve Keys for Manually Operated Valves**

Valve keys shall be 15 mm (1/2 inch) 1/2 inch diameter by 1000 mm 3 feet long, tee handles and keyed to fit valves.

#### **2.5.2 Valve Boxes and Concrete Pads**

##### **2.5.2.1 Valve Boxes**

Valve boxes shall be cast iron, plastic lockable, or precast concrete for each gate valve, manual control valve and remote control valve. Box sizes shall be adjustable for valve used. Word "IRRIGATION" shall be cast on cover. Shaft diameter of box shall be minimum 130 mm (5-1/4 inches). 5-1/4 inches. Cast iron box shall have bituminous coating.

##### **2.5.2.2 Concrete Pads**

Concrete pads shall be precast or cast-in-place reinforced concrete construction for reduced pressure type backflow preventers.

#### **2.5.3 Pressure Gauges**

Pressure gauges shall conform to requirements of ASME B40.1, single style pressure gauge for water with 115 mm (4-1/2 inch) 4-1/2 inch dial brass or aluminum case, bronze tube, gauge cock, pressure snubber, and siphon. Scale range shall be suitable for irrigation sprinkler systems.

#### **2.5.4 Service Clamps**

Service clamps shall be bronze flat, double strap, with neoprene gasket or "O"-ring seal.

#### **2.5.5 Water Hammer Arresters**

Water hammer arrester shall conform to the requirements of PDI WH 201; stainless steel construction with an encased and sealed bellows compression chamber.

#### **2.5.6 Emitter Head Accessories**

##### **2.5.6.1 Strainer**

Strainer shall be provided at inlet to each drip line. Strainer shall have stainless steel screen having equivalent of 140-mesh filtration capacity and incorporate flush valves within strainer to clean screen without

disassembling unit.

#### 2.5.6.2 Pressure Regulator

Pressure regulator shall be provided at each drip system if supply pressure exceeds 350 kPa (50 psi).50 psi.

#### 2.5.6.3 Riser Adapters

Riser adapters shall be provided with a rigid piping system.

#### 2.5.6.4 Tubing Stakes

Tubing stakes shall be plastic coated steel, or other non-corrosive strong material to secure tubing.

#### 2.5.6.5 Emitter Outlet Check Valve (Bug Cap)

Check valves shall be provided at end of each emitter outlet distribution line. Valves shall permit free flow of water with minimum restriction; prevent back siphoning, entry of insects, and contamination into outlet ports.

#### 2.5.6.6 Access Sleeve

Access sleeve shall be provided at buried emitters placed in covered boxes. Lids of access sleeve shall be secured with removable lugs. Drip hose in both vertical and horizontal axis shall be secured.

#### 2.5.6.7 Closure Caps

Closure caps shall be in accordance with manufacturer's recommendations.

### 2.6 AUTOMATIC CONTROLLERS, ELECTRICAL

\*\*\*\*\*  
**NOTE: Automatic electrical controller is used to control timing and quantity of water to sprinkler or emitter heads. Use 3 to 60 minutes for sprinkler heads and 0 to 3 hours for emitter heads.**  
\*\*\*\*\*

Controller shall conform to the requirements of NEMA ICS 2 with [120] [220]-volt single phase service, operating with indicated stations, and grounded chassis. Enclosure shall conform to NEMA ICS 6 Type 3R, with locking hinged cover, [pedestal-mounted] [wall-mounted]. Controller shall be programmed for various schedules by setting switches and dials equipped with the following features: A switch for each day of week for [one] [two] [three] schedules, allowing each station to be scheduled individually as to days of watering; a minute switch for each station with a positive increment range of [3 to 60 minutes] [0 to 3 hours], set time within one percent; a switch allowing selected schedules to be repeated after each completion of initial watering schedule and allowing each operation to be scheduled throughout a 24-hour day; a circuit breaker for surge protection; and circuit for a 9-volt rechargeable NiCad battery.

### 2.7 ELECTRICAL WORK

Wiring and rigid conduit for electrical power shall be in accordance with

NFPA 70, and Section 16375A ELECTRICAL DISTRIBUTION SYSTEM, UNDERGROUND.

## 2.8 CONCRETE MATERIALS

Concrete shall have a compressive strength of [17] [\_\_\_\_\_] MPa [2500] [\_\_\_\_\_] psi at 28 days as specified in Section 03300A CAST-IN-PLACE STRUCTURAL CONCRETE.

## 2.9 WATER SUPPLY MAIN MATERIALS

Tapping sleeves, service cut off valves, and connections to water supply mains shall be in accordance with Section 02510A WATER DISTRIBUTION SYSTEM.

## 2.10 INSULATING JOINTS

Insulating joints and dielectric fittings shall be in accordance with Section 02510A WATER DISTRIBUTION SYSTEM.

# PART 3 EXECUTION

## 3.1 INSTALLATION

Sprinkler system shall be installed after site grading has been completed. Excavation, trenching, and backfilling for sprinkler system shall be in accordance with the applicable provisions of Section 02300 EARTHWORK, except as modified herein.

### 3.1.1 Trenching

Trench around roots shall be hand excavated to pipe grade when roots of 50 mm 2 inches diameter or greater are encountered. Trench width shall be 100 mm 4 inches minimum or 1-1/2 times diameter of pipe, whichever is wider. Backfill shall be hand tamped over excavation. When rock is encountered, trench shall be excavated 100 mm 4 inches deeper and backfilled with silty sand (SM) or well-graded sand (SW) to pipe grade. Trenches shall be kept free of obstructions and debris that would damage pipe. Subsoil shall not be mixed with topsoil. Existing concrete walks, drives and other obstacles shall be bored at a depth conforming to bottom of adjacent trenches. Pipe sleeves for bored pipe shall be two pipe diameters larger than sprinkler pipe.

### 3.1.2 Piping System

#### 3.1.2.1 Cover

Underground piping shall be installed to meet the minimum depth of backfill cover specified.

#### 3.1.2.2 Clearances

Minimum horizontal clearances between lines shall be 100 mm 4 inches for pipe 50 mm (2 inches) 2 inches and less; 300 mm 12 inches for 65 mm (2-1/2 inches) 2-1/2 inches and larger. Minimum vertical clearances between lines shall be 25 mm.1 inch.

#### 3.1.2.3 Minimum Slope

Minimum slope shall be 50 mm per 10 m 6 inches per 100 feet in direction of drain valves.

### 3.1.3 Piping Installation

#### 3.1.3.1 Polyvinyl Chloride (PVC) Pipe

a. Solvent-cemented joints shall conform to the requirements of ASTM D 2855.

b. Threaded joints shall be full cut with a maximum of three threads remaining exposed on pipe and nipples. Threaded joints shall be made tight without recourse to wicks or fillers, other than polytetrafluoroethylene thread tape.

c. Piping shall be joined to conform with requirements of ASTM D 2774 or ASTM D 2855, and pipe manufacturer's instructions. Pipe shall be installed in a serpentine (snaked) manner to allow for expansion and contraction in trench before backfilling. Pipes shall be installed at temperatures over 5 degrees C. 40 degrees F.

#### 3.1.3.2 Soldered Copper Tubing

Pipe shall be reamed and burrs removed. Contact surfaces of joint shall be cleaned and polished. Flux shall be applied to male and female ends. End of tube shall be inserted into fittings full depth of socket. After soldering, a solder bead shall show continuously around entire joint circumference. Excess acid flux shall be removed from tubings and fittings.

#### 3.1.3.3 Threaded Brass or Galvanized Steel Pipe

Prior to installation, pipe shall be reamed. Threads shall be cut in conformance with ASME B1.2. Pipe joint compound shall be applied to male end only.

#### 3.1.3.4 Insulating Joints

Insulating and dielectric fittings shall be provided where pipes of dissimilar metal are joined and at connections to water supply mains as shown. Installation shall be in accordance with Section 02510A WATER DISTRIBUTION SYSTEM.

#### 3.1.3.5 Grooved Mechanical Joints

Grooves shall be prepared according to the coupling manufacturer's instructions. Grooved fittings, couplings, and grooving tools shall be products of the same manufacturer. Pipe and groove dimensions shall comply with the tolerances specified by the coupling manufacturer. The diameter of grooves made in the field shall be measured using a "go/no-go" gauge, vernier or dial caliper, narrow-land micrometer, or other method specifically approved by the coupling manufacturer for the intended application. Groove width and dimension of groove from end of pipe shall be measured and recorded for each change in grooving tool setup to verify compliance with the coupling manufacturer's tolerances. Grooved joints shall not be used in concealed locations.

### 3.1.4 Installation of Valves

#### 3.1.4.1 Manual Valves

Valves shall be installed in a valve box extending from grade to below

valve body, with a minimum of 100 mm 4 inches cover measured from finish grade to top of valve stem.

#### 3.1.4.2 Automatic Valves

Valve shall be set plumb in a valve box extending from grade to below valve body, with minimum of 100 mm 4 inch cover measured from grade to top of valve. Automatic valves shall be installed beside sprinkler heads with a valve box.

#### 3.1.4.3 Drain Valves

Entire system shall be manually or automatically drainable. Low points of system shall be equipped with drain valve draining into an excavation containing 0.03 cubic meter 1 cubic foot gravel. Gravel shall be covered with building paper then backfilled with excavated material and 150 mm 6 inches of topsoil.

#### 3.1.5 Sprinklers and Quick Coupling Valves

Sprinklers and valves shall be installed plumb and level with terrain.

#### 3.1.6 Installation of Drip Irrigation System

##### 3.1.6.1 Emitter Hose

Emitter laterals shall be buried [150] [\_\_\_\_\_] mm [6] [\_\_\_\_\_] inches deep. Connections shall be solvent welded in accordance with manufacturer's recommendation to standard weight Schedule 40 PVC fittings and bushings. Hose shall be installed in a serpentine manner. When cutting hose, shearing tool such as a pipe cutter, knife, or shears shall be used. Manufacturer's recommended tool and procedures when punching hose for emitters shall be followed.

##### 3.1.6.2 Emitter Heads

\*\*\*\*\*  
**NOTE: Installation of water emission points of drip irrigation system above soil surface aids visual checking of system for proper operation and reduces system clogging caused by root intrusion.**  
\*\*\*\*\*

Emitters shall be installed in a plastic emitter box. Emitter on a rigid PVC nipple shall be connected to PVC drip lateral with a tee or elbow. Tubing shall be attached to barbed fitting and daylight distribution tubing at root ball secured with stake, with bug cap at end of secured distribution tubing. After installing emitters and before operating system, end of drip lateral shall be opened and flushed clean. The number of emitters on a line shall not exceed manufacturer's recommendations for that hose or distribution tubing size and length.

##### 3.1.6.3 Tubing Stakes

Main irrigation line shall be secured with stakes where line is aboveground. Stakes shall be spaced to ensure that hose does not shift location in presence of foot traffic, operations, gravity on slope installations, or environmental effects. Discharge of the emitter distribution tubing shall be staked to ensure that discharge point of

emitter will be maintained at specified position in relation to plant material to be irrigated.

#### 3.1.7 Backflow Preventers

Backflow preventer shall be installed in new connection to existing water distribution system, between connection and control valves. Backflow preventer shall be installed with concrete pads.

##### 3.1.7.1 Pressure Type Vacuum Breaker

\*\*\*\*\*  
NOTE: Install device in an accessible location to facilitate inspection and servicing. Device can be installed on main line to irrigation system upstream of shut-off valves (valves may be located downstream from device).  
\*\*\*\*\*

Pressure type vacuum breaker shall be installed 300 mm 12 inches above highest head.

##### 3.1.7.2 Reduced Pressure Type

\*\*\*\*\*  
NOTE: Install device in an accessible location to facilitate inspection and servicing. To prevent freezing locate device inside a building and pipe the relief valve port through an air gap to a drain. Install the device 300 mm (12 inches), minimum, above grade.  
\*\*\*\*\*

Pipe lines shall be flushed prior to installing reduced pressure device; device shall be protected by a strainer located upstream. Device shall not be installed in pits or where any part of device could become submerged in standing water.

#### 3.1.8 Control Wire and Conduit

##### 3.1.8.1 Wires

Low voltage wires may be buried beside pipe in same trench. Rigid conduit shall be provided where wires run under paving. Wires shall be number tagged at key locations along main to facilitate service. One control circuit shall be provided for each zone and a circuit to control sprinkler system.

##### 3.1.8.2 Loops

A 300 mm 12 inch loop of wire shall be provided at each valve where controls are connected.

##### 3.1.8.3 Expansion and Contraction

Multiple tubes or wires shall be bundled and taped together at [3] [6] m [10] [20] foot intervals with 300 mm 12 inch loop for expansion and contraction.

#### 3.1.8.4 Splices

Electrical splices shall be waterproof.

#### 3.1.9 Automatic Controller

Exact field location of controllers shall be determined before installation. Coordinate the electrical service to these locations. Install in accordance with manufacturer's recommendations and NFPA 70.

#### 3.1.10 Thrust Blocks

\*\*\*\*\*  
**NOTE: Install thrust blocks at bends, tee plugs,  
and valves of 80 mm (3 inch) minimum pipe size.**  
\*\*\*\*\*

Concrete shall be placed so that sides subject to thrust or load are against undisturbed earth, and valves and fittings are serviceable after concrete has set. Thrust blocks shall be as specified in Section 02510A WATER DISTRIBUTION SYSTEM.

#### 3.1.11 Backfill

##### 3.1.11.1 Minimum Cover

\*\*\*\*\*  
**NOTE: Depths of cover are 300 mm (12 inches) for  
laterals and 450 mm (18 inches) for mains in warm  
climate areas. Use 600 mm (24 inches) for mains and  
laterals where piping can be drained in cold climate  
areas to protect pipe from frost. Consult local  
conditions in cold climates to protect against  
freezing of supply mains.**  
\*\*\*\*\*

Depth of cover shall be [300] [600] [\_\_\_\_\_] mm [12] [24] [\_\_\_\_\_] inches for 32 mm (1-1/4 inch) 1-1/4 inch pipe or smaller; [300] [450] [600] [\_\_\_\_\_] mm [12] [18] [24] [\_\_\_\_\_] inches for 40 to 50 mm (1-1/2 to 2 inch) 1-1/2 to 2 inch pipe; [450] [600] [\_\_\_\_\_] mm [18] [24] [\_\_\_\_\_] inches for 65 mm (2-1/2 inch) 2-1/2 inch pipe or larger; [1000] [\_\_\_\_\_] mm [36] [\_\_\_\_\_] inches for pipes under traffic loads, farm operations, and freezing temperatures; and [300] [450] mm [12] [18] inches for low-voltage wires. Remainder of trench or pipe cover shall be filled to within 80 mm 3 inches of top with excavated soil, and compact soil with plate hand-held compactors to same density as undisturbed adjacent soil.

##### 3.1.11.2 Restoration

\*\*\*\*\*  
**NOTE: Insert the section number and title for the  
restoration of pavements.**  
\*\*\*\*\*

Top 80 mm 3 inches shall be filled with topsoil and compacted with same density as surrounding soil. Lawns and plants shall be restored in accordance with Sections 02921 SEEDING, 02922 SODDING, 02923 SPRIGGING, and Section 02930 EXTERIOR PLANTS. Pavements shall be restored in accordance with Section [\_\_\_\_\_].

### 3.1.12 Adjustment

After grading, seeding, and rolling of planted areas, sprinkler heads shall be adjusted flush with finished grade. Adjustments shall be made by providing new nipples of proper length or by use of heads having an approved device, integral with head, which will permit adjustment in height of head without changing piping.

### 3.1.13 Disinfection

Sprinkler system fed from a potable water system shall be disinfected upstream of backflow preventer in accordance with Section 02510A WATER DISTRIBUTION SYSTEM.

### 3.1.14 Cleaning of Piping

Prior to the hydrostatic and operation tests, the interior of the pipe shall be flushed with clean water until pipe is free of all foreign materials. Flushing and cleaning out of system pipe, valves, and components shall not be considered completed until witnessed and accepted by Contracting Officer.

## 3.2 FIELD TESTS

\*\*\*\*\*  
**NOTE: Delete leakage tests if water supply service  
main is not part of contract.**  
\*\*\*\*\*

All instruments, equipment, facilities, and labor required to conduct the tests shall be provided by Contractor.

### 3.2.1 Hydrostatic Pressure Test

Piping shall be tested hydrostatically before backfilling and proved tight at a hydrostatic pressure of 1034 kPa (150 psi) 150 psi without pumping for a period of one hour with an allowable pressure drop of 35 kPa (5 psi).5 psi. If hydrostatic pressure cannot be held for a minimum of 4 hours, Contractor shall make adjustments or replacements and the tests repeated until satisfactory results are achieved and accepted by the Contracting Officer.

### 3.2.2 Leakage Tests

Leakage tests for service main shall be in accordance with Section 02510A WATER DISTRIBUTION SYSTEM.

### 3.2.3 Operation Test

At conclusion of pressure test, sprinkler heads or emitter heads, quick coupling assemblies, and hose valves shall be installed and entire system tested for operation under normal operating pressure. Operation test consists of the system operating through at least one complete programmed cycle for all areas to be sprinkled.

## 3.3 FRAMED INSTRUCTIONS

Framed instructions containing wiring and control diagrams under glass or



in laminated plastic shall be posted where directed. Condensed operating instructions, prepared in typed form, shall be framed as specified above and posted beside the diagrams. The framed instructions shall be posted before acceptance testing of the system. After as-built drawings are approved by Contracting Officer, controller charts and programming schedule shall be prepared. One chart for each controller shall be supplied. Chart shall be a reduced drawing of actual as-built system that will fit the maximum dimensions inside controller housing. Black line print for chart and a different pastel or transparent color shall indicate each station area of coverage. After chart is completed and approved for final acceptance, chart shall be sealed between two 0.505 mm (20 mil) 20 mil pieces of clear plastic.

#### 3.4 FIELD TRAINING

A field training course shall be provided for designated operating and maintenance staff members. Training shall be provided for a total period of [\_\_\_\_\_] hours of normal working time and shall start after the system is functionally complete but prior to final acceptance tests. Field training shall cover all of the items contained in the operating and maintenance manuals.

#### 3.5 CLEANUP

Upon completion of installation of system, all debris and surplus materials resulting from the work shall be removed.

-- End of Section --