
USACE / NAVFAC / AFCEA / NASA UFGS-16721 (October 2002)

Preparing Activity: USACE MasterFormat™ 2004 - 33 82 01
Superseding
UFGS-16721A (May 1999)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 23 June 2005

SECTION TABLE OF CONTENTS

DIVISION 16 - ELECTRICAL

SECTION 16721

INTERCOMMUNICATION SYSTEM

10/02

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 SYSTEM DESCRIPTION
 - 1.3.1 Sound Reproduction
 - 1.3.2 System Operation and Service Features
 - 1.3.2.1 Control and Power Requirements
 - 1.3.2.2 Call-In Indication
 - 1.3.2.3 Identification Plates
 - 1.3.2.4 Speaker/Handset Stations
 - 1.3.2.5 Privacy Switch
- 1.4 DELIVERY AND STORAGE
- 1.5 VERIFICATION OF DIMENSIONS

PART 2 PRODUCTS

- 2.1 MATERIALS
 - 2.1.1 Standard Products
 - 2.1.2 Identical Items
 - 2.1.3 Nameplates
 - 2.1.4 Spare Parts
- 2.2 TYPE 1 SYSTEM
 - 2.2.1 Master Station
 - 2.2.2 Intercommunication Amplifier
 - 2.2.3 Remote Station
 - 2.2.4 All-Call Amplifier
 - 2.2.5 Power Line Surge Protection
 - 2.2.6 Signal Surge Protection
- 2.3 TYPE 2 SYSTEM
 - 2.3.1 Master Station
 - 2.3.2 Remote Station
 - 2.3.3 Amplifier
 - 2.3.3.1 Intercommunication Amplifier
 - 2.3.3.2 All-Call Amplifier

- 2.3.3.3 Paging Amplifier
- 2.3.3.4 Power Line Surge Protection
- 2.3.3.5 Signal Surge Protection
- 2.3.4 Horn-Type Loudspeakers
- 2.3.5 Cone-Type Loud speakers
- 2.4 TYPE 3 SYSTEM
 - 2.4.1 Master Station
 - 2.4.2 Remote Station
 - 2.4.3 Amplifier
 - 2.4.3.1 Intercommunication Amplifier
 - 2.4.3.2 All-Call Amplifier
 - 2.4.3.3 Paging Amplifier
 - 2.4.3.4 Power Line Surge Protection
 - 2.4.3.5 Signal Surge Protection
 - 2.4.4 Horn-Type Loudspeakers
 - 2.4.5 Cone-Type Loud speakers
- 2.5 SPEAKER ENCLOSURES
- 2.6 TERMINALS
- 2.7 COMMUNICATIONS WIRING
- 2.8 SURGE PROTECTION

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 Signal and Control Circuits Wiring
 - 3.1.2 Conduit, Cable Tray and Tubing Systems
- 3.2 GROUNDING
- 3.3 ACCEPTANCE TESTS
- 3.4 TRAINING
- 3.5 INTERCOMMUNICATION SYSTEM, DATA PACKAGE 3

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-16721 (October 2002)

Preparing Activity: USACE MasterFormat™ 2004 - 33 82 01
Superseding
UFGS-16721A (May 1999)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 23 June 2005

SECTION 16721

INTERCOMMUNICATION SYSTEM 10/02

NOTE: This guide specification covers the requirements for electronic intercommunication systems, including master and remote stations of the wired and wireless types.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

PART 1 GENERAL

NOTE: This guide specification covers intercommunication systems and lists desirable features of electronic systems; however, not all manufacturers produce products with all the listed features. Manufacturers' catalogs may be consulted as to the features wanted and those features specified. Additional features, requirements, etc., may be made to this specification. Where intercommunication systems are to be used with other communication devices, consideration must be given to the electromagnetic compatibility of the intercommunication system in accordance with AR 5-12. This intercommunication system guide specification does not include all features and

design parameters which are available. However, specifying exact equipment configuration or design parameters which are unnecessarily restrictive to competition should be avoided.

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ELECTRONIC INDUSTRIES ALLIANCE (EIA)

EIA-160	(1951) Sound Systems
EIA-310-D	(1992) Racks, Panels, and Associated Equipment
TIA/EIA SE-A-103	(1949; R 1981) Speakers for Sound Equipment

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE C62.41	(1991; R 1995) Recommended Practice for Surge Voltages in Low-Voltage AC Power Circuits
-------------	---

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70	(2005) National Electrical Code
---------	---------------------------------

UNDERWRITERS LABORATORIES (UL)

UL 1449	(1996; Rev thru Jul 2002) Transient Voltage Surge Suppressors
UL 50	(1995; Rev thru Sep 2003) Enclosures for Electrical Equipment

1.2 SUBMITTALS

NOTE: Review submittal description (SD) definitions in Section 01330 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.][for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Intercommunication System
Installation

NOTE: State precisely in the project specifications what is to be shown in detail drawings. State also the calculations that need to be a part of the submittal.

Detail drawings shall consist of illustrations, schedules, performance charts, instructions, brochures, diagrams, catalog cuts, manufacturer's data, materials and equipment lists, and

operational and general maintenance instructions. Detail drawings shall be submitted for the overall system and for each major component. Drawings shall illustrate how each item of equipment has been coordinated and will function properly in the system. Detail drawings shall include an overall system schematic indicating relationship of intercommunication units on one diagram and showing power source, system controls, impedance matches, plus number, size, and maximum lengths of interconnecting wires and indicate clearances required for maintenance and operation. Calculations for power requirements of equipment shall be provided to show that the proper power levels are provided for the specified equipment.

SD-03 Product Data

Spare Parts

Complete list of parts and supplies.

Acceptance Tests

Test plan and procedures for the acceptance test shall explain in detail step-by-step actions and expected results to demonstrate compliance with the requirements specified. The procedures shall also explain methods for simulating the necessary conditions of operation to demonstrate system performance.

SD-06 Test Reports

Acceptance Tests

Upon completion and testing of the installed system, test reports shall be submitted in booklet form showing all field tests performed to adjust each component and to prove compliance with the specified performance criteria. Each test report shall include the final position of controls and operating mode of the system. The manufacturer, model number, and serial number of test equipment used in each test shall also be included.

SD-10 Operation and Maintenance Data

Intercommunication System

[Six] [_____] complete copies of operation manuals outlining the step-by-step procedures required for system start-up, operation and shutdown. The manuals shall include equipment layout and schematics of simplified wiring and control diagrams of the system as installed. Instructions shall include the manufacturer's name, model number, and a brief description of equipment and components, and their basic operating features.

[Six] [_____] complete copies of maintenance manuals listing routine maintenance procedures, possible breakdowns and repairs, and troubleshooting guides.

Intercommunication System, Data Package 3

Submit data package in accordance with Section 01781 OPERATION AND MAINTENANCE DATA.

1.3 SYSTEM DESCRIPTION

NOTE: This guide specification covers the requirements for three different types of intercommunication systems, one of which shall be selected for the project. The various types are as follows:

Type 1, Direct Connected, Keyed System. This type of system is applicable for relatively small systems (maximum quantity of remote stations approximately 30) and generally when only a small number of master stations (usually 1 or 2) are required. However, if there is a requirement for annunciation at more than one location or a requirement for multiple conversation paths, the use of this system with more than 1 or 2 master stations, or with many more than 30 remote stations may be justified or required.

Type 2, Single Conversation Path, Central Control System. This type of system is applicable to relatively large systems (more than approximately 30 stations) where only one conversation path is required and usually only one master station. This type of system is applicable to BEQ's. This type of system includes public address and paging systems when the unique requirements are included.

Type 3, Multiple Conversation Paths, Central Control System. This type of system is applicable to various size systems where a large portion of the total quantity of stations are master stations. A limited quantity of conversation paths may be specified as required.

The Intercommunication System shall be solid state, modular in design, and shall be of the [wired] [and] [wireless] type as indicated. [Stations shall have capacity for later expansion to [[_____] master] [and] [[_____] remote] stations [with [_____] handset] [and] [or] [with hands free operation] without sacrificing any equipment or feature of performance.] [When both wired and wireless circuitry are used, such interface shall not present a reduction of function or quality.]

1.3.1 Sound Reproduction

The intercommunication system shall reproduce a signal at all receiving stations from a 40 dB minimum input signal referenced to a microphone sound pressure level (SPL) over the frequency range of [300] [_____] to [3300] [_____] Hz. The received signal shall have a dynamic range of 30 dB, adjustable at the receiving station. Unless otherwise specified SPL shall be 20 micro Paschal. The root-mean-square (rms) extraneous noise (e.g. hum) level introduced by the intercommunication system shall be at least [30] [_____] dB below the nominal signal level. Distortion, including envelope delay, intermodulation, cross talk, and other nonlinear sources, shall not exceed 5 percent.

1.3.2 System Operation and Service Features

1.3.2.1 Control and Power Requirements

The system shall have a power switch and an associated pilot light for ON and OFF operations. A volume control at each station shall be used to regulate listening volume. System shall operate on 110-125 Vac, single phase, 60 Hz.

1.3.2.2 Call-In Indication

Master stations shall have a "call-in" switch to provide an audible and/or visual indication of incoming calls from remote stations. Individual visual indication shall identify calling station and status, and remain actuated until a call is answered by a master station.

1.3.2.3 Identification Plates

In addition to the manufacturer's standard identification plates, engraved laminated phenolic identification plates shall be provided for each component connection and terminal. Identification labels shall be 3-layer black on white on black, engraved to show white letters on a black background. Any warning or caution labels shall be 3-layered red on white on red, engraved to show white letters on red background. Control switches and knobs shall be clearly marked with their function and status. Identification strips for station selector switches shall be located to clearly identify remote and master stations and shall be protected by transparent plastic inserts.

1.3.2.4 Speaker/Handset Stations

At speaker/handset stations, lifting the handset shall automatically cut out the loudspeaker in the station and all conversation shall be carried through the handset.

1.3.2.5 Privacy Switch

NOTE: Where noise does not exceed 55 dB, specify hands-free operation from distances up to 6 m (20 feet). In areas where the noise occasionally exceeds 55 dB, a talk-listen switch which overrides the hands-free operation should be specified. Where a high noise environment exists, delete hands-free operation and specify only a talk-listen switch.

A privacy switch shall be provided at each remote station. When in the ON position, the switch shall prevent any transmission of sound from the remote station. When in the OFF position, without further switch manipulation, the station shall respond to incoming calls upon voice activation from anywhere within a 6 m 20 foot radius of station.

1.4 DELIVERY AND STORAGE

All equipment delivered and placed in storage shall be stored with protection from the weather, humidity and temperature variation, dirt and dust, or other contaminants.

1.5 VERIFICATION OF DIMENSIONS

The Contractor shall become familiar with the details of the work and working conditions, shall verify dimensions in the field, and shall advise the Contracting Officer of any discrepancies before performing the work.

PART 2 PRODUCTS

2.1 MATERIALS

NOTE: Project drawings should clearly indicate the exact location of all stations, conduit, wiring, and junction boxes. If no drawings of the locations of master stations, remote stations, junction boxes, etc., are furnished with the specification, the number and type of stations and junction boxes and the distance between them must be included as a part of the project specification.

2.1.1 Standard Products

Material and equipment shall be the standard products of a manufacturer regularly engaged in the manufacture of such products. Items of equipment shall essentially duplicate equipment that have been in satisfactory use at least 2 years prior to bid opening. Equipment shall be supported by a service organization that is, in the opinion of the Contracting Officer, reasonably convenient to the site.

2.1.2 Identical Items

Items of the same classification shall be identical. This requirement includes equipment, modules, assemblies, parts, and components.

2.1.3 Nameplates

Each major component of equipment shall have the manufacturer's name, model number, and serial number on a plate screwed to the equipment.

2.1.4 Spare Parts

After approval of detail drawings and not later than [_____] months prior to the date of beneficial occupancy, the Contractor shall furnish spare parts data for each different item of equipment and component in the system. The data shall include a complete list of parts and supplies, with current unit prices and source of supply.

2.2 TYPE 1 SYSTEM

NOTE: Delete this section unless specifying a Type 1 System.

A manually switched direct connected keyed intercommunication system shall accommodate [_____] stations in any combination of master stations and remote stations. Master and remote stations shall be provided in the quantities indicated. Each master station shall selectively communicate

with any other master station and any remote station by actuation of an appropriate selector switch. [Each master station shall be designed to be capable of initiating a message to all other master stations and all remote stations simultaneously or in groups of not less than 10 stations per group.]

2.2.1 Master Station

[Desk] [Surface wall] [Recessed wall] [Rack]-mounted master stations shall have:

1. Station-selector switches and talk-listen switches that are heavy duty type gold plated contacts rated for five million operations.
2. Volume Control to regulate incoming call volume.
3. A light annunciation that identifies the calling stations and stations in use. The light shall remain on until the call is answered.
4. A tone annunciator with a momentary audible tone signal that announces incoming calls.
5. [A handset with hook switch, telephone type, arranged to disconnect the speaker when the handset is lifted. The cord shall be 450 mm 18 inches long and permanently coiled.]
6. A metallic central control cabinet that shall comply with EIA-310-D. The cabinet shall houses terminal strips, power supplies, amplifiers, system volume control, and auxiliary equipment. It shall be lockable and ventilated.
7. The master station shall accommodate [_____] stations and shall have a speaker sensitivity of 40 dB minimum.

2.2.2 Intercommunication Amplifier

The system intercommunication amplifier shall as a minimum conform to the following specifications:

Output Power:	2 watts rms minimum with adequate power for all functions and a 20% spare capacity
Total Harmonic Distortion:	Less than 5 percent at rated output power with a load equivalent to one station connected to output terminals
Signal-To-Noise Ratio:	60 dB or greater at rated output
Frequency Response:	Plus or minus 2 dB from 200 Hz to 10,000 Hz
Output Regulation:	Maintains output level within 2dB from full to no load
Input Sensitivity:	Matched to input circuit and providing full-rated output with sound-pressure level

of not more than 10 dynes/sq. cm 0.000145 psi
impinging on master stations, speaker
microphones, or handset transmitters.

2.2.3 Remote Station

[Desk] [Surface wall] [Recessed wall] [Rack]-mounted remote station shall have [stainless steel] [anodized aluminum] faceplate with tamper proof mounting screws and [galvanized steel] [aluminum] backbox . The remote station shall have:

A speaker with a minimum sensitivity of 40 dB for speakers less than 200 mm 8 inches in diameter and 45 dB for speakers 200 mm 8 inches or greater. Plus:

1. A call announcement monitor lamp that lights when there are incoming calls.
2. A recurring momentary tone that announces incoming calls.
3. Call Switch that permits a call to the master station.
4. Privacy Switch. When in the on position, the switch prevents the transmission of sound from the remote station to the system. When in the off position, without further switch manipulation, response can be made to incoming calls.
5. [A handset with hook switch, telephone type, arranged to disconnect the speaker when the handset is lifted. The cord shall be 450 mm 18 inches long and [permanently coiled] [metallic jacketed].]

2.2.4 All-Call Amplifier

All-call amplifier shall, as a minimum, conform to the following specifications:

Output Power:	Minimum of 0.5 watt rms for each station
Total Harmonic Distortion:	Less than 5 percent at rated output power with a load equivalent to the quantity of stations connected to it in all-call mode of operation
Signal-To-Noise Ratio:	60 dB or greater at rated output
Frequency Response:	Plus or minus 2 dB from 200 Hz to 10,000 Hz
Output Regulation:	Maintains output level within 2dB from full to no load.
Input Sensitivity:	Compatible with master stations and central equipment so amplifier delivers full-rated output with sound pressure level of less than 10 dynes/sq. cm 0.000145 psi

impinging on master
station, speaker microphone or hand set
transmitter.

Amplifier Protection: Prevent damage from shorted or open circuit.

2.2.5 Power Line Surge Protection

All amplifiers shall have a device, whether internal or external, which provides protection against voltage spikes and current surges originating from commercial power sources per IEEE C62.41 B3, combination wave form and NFPA 70. Fuses shall not be used for surge protection. The surge protector shall be rated for a maximum let thru voltage of 350 Volts ac (line to neutral) and 350 Volts ac (neutral to ground). Surge protection device shall be UL listed and labeled as having been tested in accordance with UL 1449.

2.2.6 Signal Surge Protection

All amplifiers shall have internal protection circuits which protects the component from mismatched loads, direct current and shorted output lines. Communication cables/conductors shall have surge protection installed at each point where it exits or enters a building.

2.3 TYPE 2 SYSTEM

**NOTE: Delete this section unless specifying a Type 2
System.**

A microprocessor switched single conversation path, central control intercommunication system shall include [an annunciator panel,] a master station, automatic switching equipment, remote stations and all amplifiers, control equipment and ancillary devices required to provide features specified. The master station shall selectively communicate with any remote station by actuating the [two] [three] digit number assigned to that remote station. [The master station shall be designed to communicate with all remote stations simultaneously or in groups of not less than 10 stations by actuating an assigned "all-call" number.] Only the selected remote station shall listen or talk to the master station. A nonselected remote station shall not be able to hear or interfere with any portion of conversation between a master station and the selected remote station. Hanging up the master station handset shall reset the system for next call. The quantity and location of remote stations shall be as indicated on the drawings. [A paging function shall also be part of the system.]

2.3.1 Master Station

[Desk-top] [Surface wall] [Recessed wall] [Rack-mounted] type master station equipped with:

1. A 12 digit keypad selector to transmit calls to other stations and initiate commands for programming operations.
2. Volume control to regulate incoming call volume.
3. Light annunciation to identify calling stations and stations in use. The light shall remain on until a call is answered.

4. Tone annunciation with a momentary audible tone signal that announces incoming calls.
5. Reset controls that cancels calls and resets system for the next call.
6. [A handset with hook switch, telephone type, arranged to disconnect the speaker when the handset is lifted. The cord shall be 450 mm 18 inches long and permanently coiled.]
7. A metallic central control cabinet that shall comply with EIA-310-D. The cabinet shall houses terminal strips, power supplies, amplifiers, system volume control, and auxiliary equipment. It shall be lockable and ventilated.
8. The master station shall accommodate [_____] stations and shall have a speaker sensitivity of 40 dB minimum.

2.3.2 Remote Station

[Desk-top] [Surface wall] [Recessed wall] [Rack-mounted] remote stations with [stainless steel] [anodized aluminum] face plates with tamperproof mounting screws and [galvanized steel] [aluminum] backbox shall be provided. The remote station shall have:

1. A speaker with a minimum sensitivity of 40 dB for speakers less than 200 mm 8 inches in diameter and 45 dB for speakers 200 mm 8 inches or greater.
2. A call announcement monitor lamp that lights when during incoming calls.
3. A recurring momentary tone that announces incoming calls.
4. Call Switch that permits a call to the master station.
5. Privacy Switch. When in the on position, the switch prevents the transmission of sound from the remote station to the system. When in the off position, without further switch manipulation, response can be made to incoming calls.
6. [A handset with hook switch, telephone type, arranged to disconnect the speaker when the handset is lifted. The cord shall be 450 mm 18 inches long and [permanently coiled] [metallic jacketed].]

2.3.3 Amplifier

2.3.3.1 Intercommunication Amplifier

Intercommunication amplifiers shall as a minimum conform to the following specifications:

Output Power:	2 watts rms minimum with adequate power for all functions and a 20% spare capacity
Total Harmonic Distortion:	Less than 5 percent at rated output power with a load equivalent to one station connected to output terminals
Signal-to-Noise	

Ratio:	60 dB or greater at rated output
Frequency Response:	Plus or minus 2 dB from 200 Hz to 10,000 Hz
Output Regulation:	Maintains output level within 2dB from full to no load
Input Sensitivity:	Matched to input circuit and providing full-rated output with sound-pressure level of not more than 10 dynes/sq. cm 0.000145 psi impinging on master stations, speaker microphones, or handset transmitters.

2.3.3.2 All-Call Amplifier

All-call amplifiers shall as a minimum conform to the following specifications:

Output Power:	Minimum of 0.5 watt rms for each station
Total Harmonic Distortion:	Less than 5 percent at rated output power with a load equivalent to quantity of stations connected to it in all-call mode of operation
Signal-to-Noise Ratio:	60 dB or greater at rated output
Frequency Response:	Plus or minus 2 dB from 50 Hz to 10,000 Hz
Output Regulation:	Maintains output level within 2dB from full to no load.
Input Sensitivity:	Compatible with master stations and central equipment so amplifier delivers full-rated output with sound pressure level of less than 10 dynes/sq. cm 0.000145 psi impinging on master station, speaker microphone or hand set transmitter.
Amplifier Protection:	Prevent damage from shorted or open circuit.

2.3.3.3 Paging Amplifier

NOTE: To specify proper power rating of amplifier, allow 1 watt for each cone type speaker and 1.5 watts for each horn type. Special circumstances may dictate greater power requirements.

The paging amplifiers as a minimum shall conform to the following specifications:

Input Voltage:	120 V ac, 60 Hz
Frequency Response:	Within plus or minus 3 dB from 60 to 10,000 Hz
Minimum Signal-to-	

Noise Ratio:	60 dB at rated output
Total Harmonic Distortion:	Less than 3 percent at rated power output from 70 to 12,000 Hz
Output Regulation:	Less than 2 dB from full to no load
Controls:	On/off, Input levels, and low cut filter
Input Sensitivity:	Matched to input circuit and providing full rated output with sound pressure level of less than 10 dynes/sq. cm 0.000145 psi impinging on speaker microphone or handset transmitter
Amplifier Protection:	Prevents damage from shorted or open output
Power Output:	[_____] watts or greater.

2.3.3.4 Power Line Surge Protection

All amplifiers shall have a device, whether internal or external, which provides protection against voltage spikes and current surges originating from commercial power sources per IEEE C62.41 B3, combination wave form and NFPA 70. Fuses shall not be used for surge protection. The surge protector shall be rated for a maximum let thru voltage of 350 Volts ac (line to neutral) and 350 Volts ac (neutral to ground). Surge protection device shall be UL listed and labeled as having been tested in accordance with UL 1449.

2.3.3.5 Signal Surge Protection

All amplifiers shall have internal protection circuits which protects the component from mismatched loads, direct current and shorted output lines. Communication cables/conductors shall have surge protection installed at each point where it exits or enters a building.

2.3.4 Horn-Type Loudspeakers

Horn-type loudspeakers shall be all metal [weather proof] construction complete with universal mounting brackets. [Shall be suitable for Class [1, Groups C and D] [1, Groups B,C, and D] [2, Groups E, F and G] hazardous locations and equipped with 13 mm 1/2 inch threaded conduit entry]. The horn type loudspeakers shall be provided with an internally mounted, factory installed line transformers. and shall as a minimum conform to the following specifications:

Power Rating:	25 [_____] watts
Horizontal Dispersion Angle:	[57] [70] [90] [115] [_____]
Vertical Dispersion Angle:	[57] [90] [115] [_____]
Axial Sensitivity:	Minimum of [60] [_____] dB
Line Transformers	

Power Rating: At least 4 watts with at least four taps and comply to EIA-160 with insertion rate of 0.5 dB.

2.3.5 Cone-Type Loud speakers

Cone-type loud speakers shall be enclosed in a [steel housing] [back boxes] and shall be acoustically dampened with a front face of at least 1.21 mm 0.0478 inches steel. The whole assembly shall be rust proofed and factory primed complete with mounting assembly and suitable for [surface ceiling] [flush ceiling] [pendant] [wall] mounting with a relief of back pressure. The cone-type loudspeakers shall comply with the following specifications:

Minimum Axial Sensitivity: A pressure rating of 45 dB in compliance with TIA/EIA SE-A-103

Frequency Response: Within plus or minus 3 dB from 70 to 15,000 Hz

Minimum Dispersion Angle: 100 degrees

Line Transformers

Power Rating: At least 4 watts with at least four taps with insertion rate of 0.5 dB.

Speaker Size: 200 mm 8 inches with 254 mm 1 inch voice coil and minimum 142 grams 5 oz ceramic magnet.

2.4 TYPE 3 SYSTEM

NOTE: Delete this section unless specifying a type 3 system.

A microprocessor switched multiple conversation path central control intercommunication system shall be provided. The system shall be capable of communicating with other master stations and remote stations selectively or in any combination thereof. Each master station shall selectively communicate with any other master station or any remote station by actuating number assigned to called station. [Each master station shall also be designed to initiate a message to all other master stations and all remote stations simultaneously or in groups of not less than 10 stations.] Station quantities shall be as indicated on drawings. [A paging functions shall also be part of the system.]

2.4.1 Master Station

[Desk-top] [Surface wall] [Recessed wall] [Rack-mounted] master stations equipped with:

1. A 12 digit keypad selector to transmit calls to other stations and initiate commands for programming operations.

2. Volume control to regulate incoming call volume.

3. Light annunciation to identify calling stations and stations in use. The light shall remain on until a call is answered.
4. Tone annunciation with a momentary audible tone signal that announces incoming calls.
5. Reset controls that cancels calls and resets system for the next call.
6. [A handset with hook switch, telephone type, arranged to disconnect the speaker when the handset is lifted. The cord shall be 450 mm 18 inch long and permanently coiled.]
7. A metallic central control cabinet that shall comply with EIA-310-D. The cabinet shall houses terminal strips, power supplies, amplifiers, system volume control, and auxiliary equipment. It shall be lockable and ventilated.
8. The master station shall accommodate [_____] stations and shall have a speaker sensitivity of 40 dB minimum.

2.4.2 Remote Station

[Desk-top] [Surface wall] [Recessed wall] [Rack-mounted] remote stations with [stainless steel] [anodized aluminum] face plates with tamperproof mounting screws and [galvanized steel] [aluminum] backbox shall be provided. The remote station shall have:

1. A speaker and with a minimum sensitivity of 40 dB for speakers less than 200 mm 8 inches in diameter and 45 dB for speakers 200 mm 8 inches or greater.
2. A call announcement monitor lamp that lights when during incoming calls.
3. A recurring momentary tone that announces incoming calls.
4. Call Switch that permits a call to the master station.
5. Privacy Switch. When in the on position, the switch prevents the transmission of sound from the remote station to system. When in the off position, without further switch manipulation, response can be made to incoming calls.
6. [A handset with hook switch, telephone type, arranged to disconnect the speaker when the handset is lifted. The cord shall be 450 mm 18 inches long and [permanently coiled] [metallic jacketed].]

2.4.3 Amplifier

2.4.3.1 Intercommunication Amplifier

Intercommunication amplifiers shall as a minimum conform to the following specifications:

Output Power:	2 watts rms minimum with adequate power for all functions and a 20% spare capacity
Total Harmonic Distortion:	Less than 5 percent at rated output power with a load equivalent to one station connected to

	output terminals
Signal-to-Noise Ratio:	60 dB or greater at rated output
Frequency Response:	Plus or minus 2 dB from 200 Hz to 10,000 Hz
Output Regulation:	Maintains output level within 2dB from full to no load
Input Sensitivity:	Matched to input circuit and providing full-rated output with sound-pressure level of not more than 10 dynes/sq. cm 0.000145 psi impinging on master stations, speaker microphones, or handset transmitters.

2.4.3.2 All-Call Amplifier

All-call amplifiers shall as a minimum conform to the following specifications:

Output Power:	Minimum of 0.5 watts rms per station
Total Harmonic Distortion:	Less than 5 percent at rated output power with a load equivalent to [_____] stations connected to output terminal
Signal-to-Noise Ratio:	60 dB or greater at rated output
Frequency Response:	Plus or minus 2 dB from 50 Hz to 10,000 Hz
Output Regulation:	Maintains output level within 2dB from full to no load.
Input Sensitivity:	Compatible with master stations and central equipment so amplifier delivers full-rated output with sound pressure level of less than 10 dynes/sq. cm 0.000145 psi impinging on master station, speaker microphone or handset transmitter.

Amplifier Protection: Prevent damage from shorted or open circuit.

2.4.3.3 Paging Amplifier

NOTE: To specify proper power rating of amplifier, allow 1 watt for each cone type speaker and 1.5 watts for each horn type. Special circumstances may dictate greater power requirements.

The paging amplifiers shall conform to the following specifications:

Input Voltage:	120 V ac, 60 Hz
Frequency Response:	Within plus or minus 3 dB from 60 to 10,000 Hz

Minimum Signal-to-Noise Ratio: 60 dB at rated output

Total Harmonic Distortion: Less than 3 percent at rated power output from 70 to 12,000 Hz

Output Regulation: Less than 2 dB from full to no load

Controls: On/off, Input levels, and low cut filter

Input Sensitivity: Matched to input circuit and providing full rated output with sound pressure level of less than 10 dynes/sq. cm 0.000145 psi mpinging on speaker microphone or handset transmitter

Amplifier Protection: Prevents damage from shorted or open output

Power Output: [_____] watts or greater.

2.4.3.4 Power Line Surge Protection

All amplifiers shall have a device, whether internal or external, which provides protection against voltage spikes and current surges originating from commercial power sources per IEEE C62.41 B3, combination wave form and NFPA 70. Fuses shall not be used for surge protection. The surge protector shall be rated for a maximum let thru voltage of 350 Volts ac (line to neutral) and 350 Volts ac (neutral to ground). Surge protection device shall be UL listed and labeled as having been tested in accordance with UL 1449.

2.4.3.5 Signal Surge Protection

All amplifiers shall have internal protection circuits which protects the component from mismatched loads, direct current and shorted output lines. Communication cables/conductors shall have surge protection installed at each point where it exits or enters a building.

2.4.4 Horn-Type Loudspeakers

Horn-type loudspeakers shall be all metal [weather proof] construction complete with universal mounting brackets. [Shall be suitable for Class 1, Groups C and D] [1, Groups B,C, and D] [2, Groups E, F and G] hazardous locations and equiped with 12.7 mm 1/2 inch threaded conduit entry]. The horn type loudspeakers shall be provided with an internally mounted, factory installed line transformers. and shall as a minimum conform to the following specifications:

Power Rating: 25 [_____] watts

Horizontal Dispersion Angle: [57] [70] [90] [115] [_____]

Verticle Dispersion Angle: [57] [90] [115] [_____]

Axial Sensitivity: Minimum of [60] [_____] dB

Line Transformers

Power Rating: At least 4 watts with at least four taps and with insertion rate of 0.5 dB.

2.4.5 Cone-Type Loud speakers

Cone-type loud speakers shall be enclosed in a [steel housing] [back boxes] and shall be acoustically dampened with a front face of at least 1.21 mm 0.0478 inches steel. The whole assembly shall be rust proofed and factory primed complete with mounting assembly and suitable for [surface ceiling] [flush ceiling] [pendant] [wall] mounting with a relief of back pressure. [Baffle for flush speakers shall be a minimum thickness of 0.8128 mm 0.032 inches aluminum [brushed to a satin sheen and lacquered] [with textured white finish] [_____]]. [Vandal-proof high strength baffles for flush mounted speakers shall be self-aging cast aluminum with tensile strength of 3,093 kg/sq. cm 44,000 psi and a minimum thickness of 0.635 mm 0.025 inch. The mounting screws shall be heat-treated alloy and textured white epoxy finish.] The cone-type loudspeakers shall comply with the following specifications:

Minimum Axial Sensitivity: A pressure rating of 45 dB.

Frequency Response: Within plus or minus 3 dB from 70 to 15,000 Hz

Minimum Dispersion Angle: 100 degrees

Line Transformers

Power Rating: At least 4 watts with at least four taps with insertion rate of 0.5 dB.

Speaker Size: 200 mm 8 inches with 25 mm 1 inch voice coil and minimum 142 grams 5 oz ceramic magnet

2.5 SPEAKER ENCLOSURES

Speaker enclosures shall be compatible with the speakers specified and comply with UL 50.

2.6 TERMINALS

Terminals shall be [solderless, tool-crimped pressure] [or] [_____] type.

2.7 COMMUNICATIONS WIRING

Type of signal and control circuit wire and number of conductors shall be provided as recommended by the intercommunication system manufacturer, and as necessary to provide a complete and operable system. Where required, cable shall be UL classified low smoke and low flame for use in air plenums in accordance with NFPA 70.

2.8 SURGE PROTECTION

Major components of the system such as Master Stations, Amplifiers, and Remote Stations, shall have a device, either internal or external, which

shall provide protection against voltage spikes and current surges.

PART 3 EXECUTION

3.1 INSTALLATION

All system components and appurtenances shall be installed in accordance with the manufacturer's instructions and as specified and shown. Units to be mounted outside or subject to inclement conditions shall be weatherproof or be mounted in weatherproof enclosures.

3.1.1 Signal and Control Circuits Wiring

Signal and control circuits shall be installed in accordance with NFPA 70 and as indicated. The conductors shall be separated as recommended by the equipment manufacturer.

3.1.2 Conduit, Cable Tray and Tubing Systems

Wiring shall be installed in rigid conduit, intermediate metal conduits, cable trays, or electric metallic tubing as specified in Section 16402 INTERIOR DISTRIBUTION SYSTEM.

3.2 GROUNDING

The connection of interfacing components shall be accomplished through the use of transformers and the tying of interconnecting lines to a unit ground bus at one end only. The ground and distribution ground buses shall be solid copper wire with insulating covering.

3.3 ACCEPTANCE TESTS

After installation has been completed, the Contractor shall conduct an acceptance test, using the approved test plan, to demonstrate that the equipment operates in accordance with specification requirements. The Contractor shall notify the Contracting Officer [_____] days prior to the performance of tests. In no case shall notice be given until after the Contractor has received written approval of the test plans. The acceptance tests shall include as a minimum the following test:

Operational Test: Test originating station-to-station, all call, and page messages at each intercommunication station. Verify proper routing and volume levels and that the system is free of noise and distortion. Test available message path from each station on system.

Frequency Response Test: Determine frequency response of two transmission paths, including all-call, and paging, by transmitting and recording audio tones. Minimum acceptable performance is within 3dB from 150 to 2500 Hz.

Signal-to-Noise Ratio Test: Measure signal-to-noise ratio of complete system at normal gain setting as follows:

a. Disconnect speaker microphone and replace it in the circuit with a signal generator using a 1000 Hz signal. Measure signal-to-noise ratio at paging speakers.

b. Repeat test for four speaker microphones and for each separately controlled zone of paging loudspeakers.

c. Minimum acceptable ratio is 35 dB.

Distortion Test: Measure distortion at normal gain settings and rated power. Feed signals at frequencies of 150, 200, 400, 1000, and 2500 Hz into each paging and all-call amplifier, and a minimum of 2 selected intercommunication amplifiers. For each frequency, measure distortion in the paging and all-call amplifier outputs. Maximum acceptable distortion at any frequency is 5 percent total harmonics.

Acoustic Coverage Test: Feed pink noise into system using octaves centered at 500 and 4000 Hz. Use sound level meter with octave band filters to measure level at three locations in each paging zone. Maximum permissible variation in level is plus or minus 3 dB; in levels between adjacent zones, plus or minus 5 dB.

Power output Test: Measure electrical power output of each paging amplifier at normal gain setting of 150, 1000 and 2500 Hz. Maximum variation in power output at these frequencies is plus or minus 3 dB.

3.4 TRAINING

The Contractor shall conduct a training course for [_____] members of the operating staff and for [_____] members of the maintenance staff as designated by the Contracting Officer. The training course will be given at the installation during normal working hours for a total of [_____] hours for the operating staff and [_____] hours for the maintenance staff, and shall start after the system is functionally complete but prior to final acceptance tests. The field instructions shall cover all of the items contained in the approved operating and maintenance instructions, as well as the demonstration of routine maintenance operations. The Contracting Officer shall be notified at least 14 days prior to the start of the training course.

3.5 INTERCOMMUNICATION SYSTEM, DATA PACKAGE 3

The Contractor shall submit data package in accordance with Section 01781 OPERATION AND MAINTENANCE DATA.

-- End of Section --