
USACE / NAVFAC / AFCEA / NASA UFGS-23 73 33.00 40 (June 2006)

Preparing Activity: NASA Superseding
 UFGS-23 73 33.00 40 (April 2006)
 NASA-15700S (December 2005)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 9 October 2006

Latest change indicated by CHG tags

SECTION TABLE OF CONTENTS

DIVISION 23 - HEATING, VENTILATING, AND AIR CONDITIONING

SECTION 23 73 33.00 40

INDOOR INDIRECT FUEL-FIRED HEATING AND VENTILATING UNITS

06/06

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 MECHANICAL SYSTEMS IDENTIFICATION
 - 1.3.1 Diagrams
 - 1.3.2 Metal Tags
 - 1.3.3 Service Labeling
- 1.4 STORAGE AND PROTECTION OF EQUIPMENT AND MATERIALS
- 1.5 AUTOMATIC CONTROL OF SYSTEMS
- 1.6 GENERAL REQUIREMENTS

PART 2 PRODUCTS

- 2.1 STANDARD PRODUCTS
- 2.2 MATERIAL AND EQUIPMENT
- 2.3 IDENTIFICATION PLATES
- 2.4 STEEL PIPING FOR STEAM, CONDENSATE, CHILLED AND HOT WATER
 - 2.4.1 Type BCS (1000-kPa150-psi Service)
 - 2.4.2 Type BCS (2500-kPa350-psi Service)
- 2.5 VALVES
 - 2.5.1 Gate Valves
 - 2.5.1.1 Type 2500 350
 - 2.5.1.2 Type 1000 150
 - 2.5.1.3 Type 850 125
 - 2.5.2 Globe and Angle Valves
 - 2.5.2.1 Type 2500 350
 - 2.5.2.2 Type 1000 150
 - 2.5.2.3 Type 850 125
 - 2.5.3 Check Valves
 - 2.5.3.1 Type 2500 350
 - 2.5.3.2 Type 850 125
 - 2.5.4 Manual Radiator Valves

- 2.5.5 Cone-Plug Balancing Valve (CPBV)
- 2.5.6 Eccentric Plug Valves (EPV)
- 2.5.7 Ball Valves (BAV)
 - 2.5.7.1 Metal
 - 2.5.7.2 Polyvinylchloride (PVC)
 - 2.5.7.3 Chlorinated Polyvinylchloride (CPVC)
- 2.5.8 Butterfly Valves (BUV)
- 2.5.9 Dial Cocks
- 2.5.10 Diaphragm Control and Instrument Valves (DCIV)
- 2.6 VIBRATION ISOLATORS
 - 2.6.1 Mountings
 - 2.6.2 Bases
 - 2.6.3 Pipe and Duct Vibration Isolation
 - 2.6.4 Floor-Mounted Piping
 - 2.6.5 Vertical Piping
- 2.7 INSULATION
 - 2.7.1 Adhesives
 - 2.7.2 Jacketing
 - 2.7.3 Coatings
- 2.8 BOILERS
 - 2.8.1 Factory Testing
 - 2.8.2 Firetube Boiler
 - 2.8.3 Watertube Boiler
 - 2.8.4 Gas-Burning Equipment
 - 2.8.5 Atmospheric Gas Burners
 - 2.8.6 Fuel Oil Burners
 - 2.8.7 Mechanical-Draft Gas Burner Unit
 - 2.8.7.1 Forced-Draft Fan Unit
 - 2.8.7.2 Induced-Draft Fan Unit
 - 2.8.8 Boiler Trim and Accessories
 - 2.8.8.1 Gas-Pressure Regulating Valve
 - 2.8.8.2 Gas-Control Valves
 - 2.8.8.3 Pressure Gage and Thermometer
 - 2.8.8.4 Pressure-Relief Valves
 - 2.8.9 Combustion Safety Controls
 - 2.8.9.1 Atmospheric Burners
 - 2.8.9.2 Mechanical-Draft Burners
- 2.9 REFRIGERATION PIPING AND SPECIALTIES
 - 2.9.1 Piping and Fittings
 - 2.9.2 Refrigerant Liquid Receiver
 - 2.9.3 Shutoff and Check Valves
 - 2.9.4 Solenoid Valves
 - 2.9.5 Expansion Valves
 - 2.9.6 Evaporator Pressure Regulators
 - 2.9.7 Filter/Dryers
 - 2.9.8 Liquid Sight Glasses
 - 2.9.9 Moisture Indicators
 - 2.9.10 Discharge-Line Oil Separator
 - 2.9.11 Liquid-Suction Interchangers
 - 2.9.12 Line Strainers
 - 2.9.13 Mufflers
- 2.10 RECIPROCATING REFRIGERANT COMPRESSOR UNITS
 - 2.10.1 Compressor
 - 2.10.2 Motors
 - 2.10.3 Accessories
- 2.11 RECIPROCATING COMPRESSOR-CONDENSER UNITS
 - 2.11.1 Compressor
 - 2.11.2 Accessories
 - 2.11.3 Air-Cooled Condenser

- 2.11.3.1 Fans and Drives
 - 2.11.3.2 Condensing Coil
 - 2.11.3.3 Condensing Pressure Control
- 2.11.4 Water-Cooled Condenser
 - 2.11.4.1 Construction
- 2.12 COILS
 - 2.12.1 Coil Pressure and Temperature Ratings
 - 2.12.2 Coil Casings
 - 2.12.3 Coil Headers
 - 2.12.4 Coil Tubing
 - 2.12.5 Coil Circuiting
 - 2.12.6 Drainable Coils
 - 2.12.7 Testing
- 2.13 UNIT HEATERS
 - 2.13.1 Casing
 - 2.13.2 Heat Exchangers
 - 2.13.3 Burners
 - 2.13.4 Fans
 - 2.13.5 Motors
 - 2.13.6 Controls
 - 2.13.7 Propeller Unit Heaters (PUH)
 - 2.13.7.1 Vertical Discharge Units
 - 2.13.7.2 Horizontal Discharge Units
 - 2.13.7.3 Heating Elements
 - 2.13.7.4 Casings
 - 2.13.7.5 Propellers and Motors
 - 2.13.7.6 Sound Rating
 - 2.13.7.7 Control
 - 2.13.8 Cabinet Unit Heaters (CUH)
 - 2.13.8.1 Heating Element (CUH)
 - 2.13.8.2 Fan and Drive Assembly (CUH)
 - 2.13.8.3 Filters (CUH)
 - 2.13.8.4 Enclosures (CUH)
 - 2.13.8.5 Insulation (CUH)
 - 2.13.8.6 Control Cycle (CUH)
 - 2.13.9 Unit Ventilators (UV)
 - 2.13.9.1 Heating Element (UV)
 - 2.13.9.2 Fan and Drive Assembly (UV)
 - 2.13.9.3 Filters (UV)
 - 2.13.9.4 Dampers (UV)
 - 2.13.9.5 Enclosure (UV)
 - 2.13.9.6 Wall Sleeve (UV)
- 2.14 FAN COIL UNITS
 - 2.14.1 Enclosure
 - 2.14.2 Casing
 - 2.14.3 Coils
- 2.15 AIR HANDLING UNITS (FACTORY ASSEMBLED)
 - 2.15.1 Air-Handling System Balancing Provisions
 - 2.15.2 Motor Requirements
 - 2.15.3 Unit Cabinet
 - 2.15.4 Multizone Units
- 2.16 AIR HANDLING UNITS (FIELD ASSEMBLED)
 - 2.16.1 Enclosure
 - 2.16.2 Coil Supports
 - 2.16.3 Access Doors and Panels
 - 2.16.4 Drain Pans
 - 2.16.5 Eliminators
- 2.17 PACKAGED AIR-CONDITIONING UNITS
 - 2.17.1 Window-Type, Packaged, Self-Contained

- 2.17.1.1 Construction
- 2.17.2 Console-Type, Packaged, Self-Contained
- 2.17.3 Remote-Split-Type, Packaged, Self-Contained
 - 2.17.3.1 Air-Cooled Condenser
 - 2.17.3.2 Water-Cooled Condenser
 - 2.17.3.3 Vibration Isolation
- 2.18 DUCTWORK
 - 2.18.1 Galvanized Steel Ductwork Materials
 - 2.18.1.1 Duct Hangers
 - 2.18.1.2 Mill-Rolled Reinforcing and Supporting Materials
 - 2.18.2 Rigid Fibrous-Glass Ductwork Materials
 - 2.18.3 Flexible Duct Materials
 - 2.18.4 Manual Volume Dampers
 - 2.18.4.1 Gravity Backdraft and Relief Dampers
 - 2.18.4.2 Power-Operated Dampers
 - 2.18.4.3 Flexible Connectors for Sheet Metal
 - 2.18.4.4 Fire Dampers
- 2.19 AIR DIFFUSERS
 - 2.19.1 Type Air-Diffusion Devices
 - 2.19.1.1 Type DRA
 - 2.19.1.2 Type DRB
 - 2.19.1.3 Type DRC
 - 2.19.1.4 Type DRE
 - 2.19.1.5 Type DRH
 - 2.19.1.6 Type DP Series
 - 2.19.1.7 Type DLB
 - 2.19.1.8 Type DLS
 - 2.19.1.9 Type DSA
 - 2.19.1.10 Type GS
 - 2.19.1.11 Type GR
 - 2.19.1.12 Type GCA
 - 2.19.1.13 Type GCB
 - 2.19.1.14 Type GCD
 - 2.19.1.15 Type GCE
 - 2.19.1.16 Type GCF
 - 2.19.1.17 Type RS
 - 2.19.1.18 Type RR
 - 2.19.1.19 Type RCA
 - 2.19.1.20 Type RCB
 - 2.19.1.21 Type RCC
 - 2.19.1.22 Type RCD
 - 2.19.1.23 Type RCE
 - 2.19.1.24 Type RCF
 - 2.19.1.25 Type TS
 - 2.19.1.26 Type TR
 - 2.19.1.27 Type TSR
 - 2.19.2 Rigid Fibrous-Glass Ductwork
- 2.20 MIXING BOXES
 - 2.20.1 Dual-Duct Mixing Boxes
 - 2.20.1.1 Construction
 - 2.20.2 Single Duct, Constant Volume, Terminal Reheat Units
 - 2.20.2.1 Casing
 - 2.20.2.2 Coils
 - 2.20.2.3 Controls
 - 2.20.3 Variable Constant-Volume Boxes
- 2.21 FILTERS
 - 2.21.1 Filter Gages and Manometers

PART 3 EXECUTION

- 3.1 INSTALLATION
- 3.2 CLEANING
- 3.3 INSULATION SYSTEMS
 - 3.3.1 Refrigerant and Cold Water Suction Piping
 - 3.3.2 Chilled Water, Hot-Water, and Condensate-Return Piping
 - 3.3.3 Chilled-Water and Dual-Temperature Pumps
- 3.4 BOILERS
- 3.5 AIR HANDLING UNITS
 - 3.5.1 Installation
 - 3.5.2 Enclosure Test
- 3.6 DUCTWORK
 - 3.6.1 Installation
 - 3.6.2 Openings in Roofs and Walls
 - 3.6.3 Ductwork Cleaning Provisions
 - 3.6.4 Fire Damper Tests
- 3.7 FILTERS
- 3.8 CONTROLS
 - 3.8.1 Installation
 - 3.8.2 Mechanical Refrigeration Air Dryer Installation
 - 3.8.3 Testing, Calibration, and Acceptance
 - 3.8.4 Operating Instructions and Operator Training
- 3.9 AIR-HANDLING SYSTEMS TESTING
 - 3.9.1 Low-Velocity Duct Systems
 - 3.9.2 High-Velocity Duct Systems
 - 3.9.3 Test Apparatus and Procedures
- 3.10 REFRIGERATION SYSTEMS TESTING
 - 3.10.1 Pressure Testing
 - 3.10.2 Vacuum Testing
 - 3.10.3 Operating Test
- 3.11 AIR AND HYDRONIC SYSTEMS TESTING, AND ADJUSTMENT
 - 3.11.1 Air-Handling Systems
 - 3.11.2 Hydronic Systems
 - 3.11.2.1 Balancing, Adjustment, and Acceptance
 - 3.11.2.2 Hydronic Systems Preparation
 - 3.11.3 Adjustment and Acceptance Criteria
 - 3.11.4 Test Report
- 3.12 STEAM AND CONDENSATE SYSTEMS TESTING
 - 3.12.1 Test Duration
 - 3.12.2 Test Gages
 - 3.12.3 Acceptance Pressure Testing
 - 3.12.4 Operational Testing
 - 3.12.5 Test Records
- 3.13 ROTATING MACHINERY
 - 3.13.1 Alignment
 - 3.13.2 Vibration Analyzer
 - 3.13.3 Acceptance Tests
 - 3.13.4 Test Records
- 3.14 OPERATION AND MAINTENANCE

-- End of Section Table of Contents --

when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AIR MOVEMENT AND CONTROL ASSOCIATION INTERNATIONAL (AMCA)

AMCA 300 (2005) Reverberant Room Method for Sound Testing of Fans

AMCA 301 (2005) Methods for Calculating Fan Sound Ratings from Laboratory Test Data

AIR-CONDITIONING AND REFRIGERATION INSTITUTE (ARI)

ARI 520 (2004) Standard for Positive Displacement Condensing Units

AMERICAN GAS ASSOCIATION (AGA)

IAS Directory (1999) Directory of AGA and CGA Certified Appliances and Accessories

AMERICAN IRON AND STEEL INSTITUTE (AISI)

AISC/AISI 121 (2004) Standard Definitions for Use in the Design of Steel Structures

AISI SG-03-2 (2002; R 2004) Cold-Formed Steel Design Manual

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

NSF/ANSI 14 (2004; R 2005, Addendum 1.0) Plastics Piping System Components and Related Materials

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS (ASHRAE)

ASHRAE 15 (2004) Safety Code for Refrigeration

ASHRAE 51 (1999; Errata, 2006) Laboratory Methods of Testing Fans for Aerodynamic Performance Rating

ASHRAE-04 (2005) Handbook, Fundamentals (SI Edition)

ASHRAE-05	(2003) Handbook, HVAC Applications (SI Edition)
ASHRAE-06	(2004) Handbook, HVAC Systems and Equipment (IP Edition)
ASHRAE-07	(2004) Handbook, HVAC Systems and Equipment (SI Edition)
ASHRAE-08	(2002) Handbook, Refrigeration (SI Edition)

AMERICAN WATER WORKS ASSOCIATION (AWWA)

AWWA C504	(2000; R 2001) Standard for Rubber-Sealed Butterfly Valves
-----------	--

ASME INTERNATIONAL (ASME)

ASME B1.20.1	(1983; R 2001) Pipe Threads, General Purpose (Inch)
ASME B1.21M	(1997; Addenda 1998) Standard for Metric Screw Threads - MJ Profile
ASME B16.21	(2005) Nonmetallic Flat Gaskets for Pipe Flanges
ASME B16.22	(2001) Standard for Wrought Copper and Copper Alloy Solder Joint Pressure Fittings
ASME B16.3	(1998) Standard for Malleable Iron Threaded Pipe Unions; Classes 150, 250, and 300
ASME B16.34	(2004) Valves - Flanged, Threaded and Welding End
ASME B16.5	(2003) Standard for Pipe Flanges and Flanged Fittings: NPS 1/2 Through NPS 24
ASME B16.9	(2003) Standard for Factory-Made Wrought Steel Buttwelding Fittings
ASME B31.5	(2001) Refrigeration Piping and Heat Transfer Components
ASME B36.10M	(2004) Standard for Welded and Seamless Wrought Steel Pipe
ASME B40.100	(2000) Pressure Gauges and Gauge Attachments
ASME BPVC SEC VI	(2004) Boiler and Pressure Vessel Code; Section VI, Recommended Rules for the Care and Operation of Heating Boilers
ASME BPVC SEC VIII D1	(2004) Boiler and Pressure Vessel Code; Section VIII, Pressure Vessels Division 1

ASME SI-01 (2001) Units, Boiler and Pressure Vessel
Codes, Section I - IX

ASSOCIATED AIR BALANCE COUNCIL (AABC)

AABC MN-1 (2002) National Standards for Total System
Balance

ASTM INTERNATIONAL (ASTM)

ASTM A 106/A 106M (2004) Standard Specification for Seamless
Carbon Steel Pipe for High-Temperature
Service

ASTM A 123/A 123M (2002) Standard Specification for Zinc
(Hot-Dip Galvanized) Coatings on Iron and
Steel Products

ASTM A 234/A 234M (2005) Standard Specification for Piping
Fittings of Wrought Carbon Steel and Alloy
Steel for Moderate and High Temperature
Service

ASTM A 307 (2004) Standard Specification for Carbon
Steel Bolts and Studs, 60 000 PSI Tensile
Strength

ASTM A 36/A 36M (2005) Standard Specification for Carbon
Structural Steel

ASTM A 436 (1984; R 2001) Standard Specification for
Austenitic Gray Iron Castings

ASTM A 53/A 53M (2004a) Standard Specification for Pipe,
Steel, Black and Hot-Dipped, Zinc-Coated,
Welded and Seamless

ASTM A 653/A 653M (2004a) Standard Specification for Steel
Sheet, Zinc-Coated (Galvanized) or
Zinc-Iron Alloy-Coated (Galvannealed) by
the Hot-Dip Process

ASTM A 694/A 694M (2003) Standard Specification for Carbon
and Alloy Steel Forgings for Pipe Flanges,
Fittings, Valves, and Parts for
High-Pressure Transmission Service

ASTM A 90/A 90M (2001) Standard Test Method for Weight
[Mass] of Coating on Iron and Steel
Articles with Zinc or Zinc-Alloy Coatings

ASTM B 280 (2003) Standard Specification for Seamless
Copper Tube for Air Conditioning and
Refrigeration Field Service

ASTM B 61 (2002) Standard Specification for Steam or
Valve Bronze Castings

ASTM B 62 (2002) Standard Specification for

Composition Bronze or Ounce Metal Castings

ASTM B 88	(2003) Standard Specification for Seamless Copper Water Tube
ASTM B 88M	(2003) Standard Specification for Seamless Copper Water Tube (Metric)
ASTM C 1139	(1990; R 2002) Standard Specification for Fibrous Glass Thermal Insulation and Sound Absorbing Blanket and Board for Military Applications
ASTM C 552	(2003) Standard Specification for Cellular Glass Thermal Insulation
ASTM C 553	(2002) Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications
ASTM C 612	(2004) Standard Specification for Mineral Fiber Block and Board Thermal Insulation
ASTM D 1784	(2003) Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds
ASTM F 568M	(2004) Standard Specification for Carbon and Alloy Steel Externally Threaded Metric Fasteners

CSA INTERNATIONAL (CSA)

ANSI Z21.13a/CSA 4.9a	(2005; Addenda 2004) Standard for Gas-Fired Low Pressure Steam and Hot Water Boilers
CSA DIR.015	(1996) List of Products and Components CSA Certified to US Standards

FM GLOBAL (FM)

FM P7825	(2003) Approval Guide
----------	-----------------------

HYDRONICS INSTITUTE DIVISION OF GAMA (HYI)

HYI RATINGS	(2004) 1=B=R Ratings for Boilers, Baseboard Radiation, and Finned Tube (Commercial)
-------------	---

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION (ISO)

ISO 1940-1	(2003) Mechanical Vibration - Balance Quality Requirements for Rotors in a Constant (Rigid) State - Part 1: Specification and Verification of Balance Tolerance - International Restrictions
------------	--

ISA - THE INSTRUMENTATION, SYSTEMS AND AUTOMATION SOCIETY (ISA)

ISA RP60.9 (1981) Piping Guide for Control Centers

MANUFACTURERS STANDARDIZATION SOCIETY OF THE VALVE AND FITTINGS
INDUSTRY (MSS)

MSS SP-104 (2003) Standard for Wrought Copper Solder
Joint Pressure Fittings

MSS SP-67 (2002a; R 2004) Standard for Butterfly
Valves

MSS SP-72 (1999) Standard for Ball Valves with
Flanged or Butt-Welding Ends for General
Service

MSS SP-80 (2003) Bronze Gate, Globe, Angle and Check
Valves

MSS SP-86 (2002) Guidelines for Metric Data in
Standards for Valves, Flanges, Fittings
and Actuators

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA MG 1 (2003) Standard for Motors and Generators

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 220 (2006) Standard on Types of Building
Construction

NFPA 70 (2005) National Electrical Code

NFPA 90A (2002) Standard for the Installation of
Air Conditioning and Ventilating Systems

SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION
(SMACNA)

SMACNA 1481 (1995e2) HVAC Duct Construction Standards
- Metal and Flexible

SMACNA 221 (2002) HVAC Systems - Testing, Adjusting
and Balancing

SOCIETY OF AUTOMOTIVE ENGINEERS INTERNATIONAL (SAE)

SAE J513 (1999) Refrigeration Tube Fittings -
General Specifications

U.S. DEPARTMENT OF DEFENSE (DOD)

MS DOD-G-24508 (1998d) Grease, High Performance,
Multipurpose (Metric)

MS MIL-B-18796 (1998f) Burners, Single: Oil, Gas, and
Gas-Oil Combination for Packaged Boilers

MS MIL-P-26915

(1992c) Primer Coating, Zinc Dust
Pigmented, for Steel Surfaces

U.S. DEPARTMENT OF ENERGY (DOE)

DOE CE-3

(2001) How to Buy an Energy-Efficient
Commercial Unitary Air Conditioner

DOE CE-5

(2000) How to Buy an Energy-Efficient
Commercial Boiler

DOE RA-1

(2000) How to Buy an Energy-Efficient Room
Air Conditioner

DOE RE-5

(2000) How to Buy an Energy-Efficient Gas
Water Heater

UNDERWRITERS LABORATORIES (UL)

UL 181

(2005) Standard for Factory-Made Air Ducts
and Air Connectors

UL 726

(2001; R 2005e7) Standard for Oil-Fired
Boiler Assemblies

UL 795

(1999; R 2005e5) Standard for
Commercial-Industrial Gas Heating Equipment

UL 834

(2004e5) Standard for Heating, Water
Supply and Power Boilers - Electric

1.2 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions
in Section 01 33 00 SUBMITTAL PROCEDURES and edit
the following list to reflect only the submittals
required for the project. Submittals should be kept
to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the
submittal requires Government approval. Some
submittals are already marked with a "G". Only
delete an existing "G" if the submittal item is not
complex and can be reviewed through the Contractor's
Quality Control system. Only add a "G" if the
submittal is sufficiently important or complex in
context of the project.

For submittals requiring Government approval on Army
projects, a code of up to three characters within
the submittal tags may be used following the "G"
designation to indicate the approving authority.
Codes for Army projects using the Resident
Management System (RMS) are: "AE" for
Architect-Engineer; "DO" for District Office
(Engineering Division or other organization in the
District Office); "AO" for Area Office; "RO" for

Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Connection Diagrams and Control Diagrams shall be submitted for the following systems in accordance with paragraph entitled, "Diagrams," of this section.

Air Systems
Hydronic Systems
Air-Hydronic Systems
Unitary Systems

Schematics shall be submitted for each HVAC duct system in accordance with paragraph entitled, "Diagrams," of this section.

Fabrication drawings shall be submitted for the following items:

Valves
Air Diffusers
Boilers
Chillers
Coils
Ductwork
Compressor
Heat Exchangers
Vibration Isolators
Condenser
Unit Heaters
Air Handling Units
Air-Conditioning Units
Mixing Boxes

Installation Drawings shall be submitted for the following systems in accordance with the paragraph entitled, "Installation," of this section.

Air Systems
Hydronic Systems
Air-Hydronic Systems
Unitary Systems

SD-03 Product Data

Equipment and performance data shall be submitted for the

following items including sound data for supply air-diffusion devices in terms of Noise Criteria (NC) index for the capacity range of the device. Data shall also include air and hydronic pressure differences, the direction of air and water flow, temperature differentials, power rating, operating temperatures and pressures, efficiencies and limit or safety temperatures and pressures.

Air Diffusers

Fans

Boilers

Chillers

Coils

Valves

Ductwork

Compressor

Heat Exchangers

Piping

Vibration Isolators

Insulation

Condenser

Unit Heaters

Air Handling Units

Air-Conditioning Units

Mixing Boxes

Filters

Manufacturer's catalog data shall be submitted for the following items in sufficient detail and scope to verify compliance with the requirements of the contract documents.

Air Diffusers

Fans

Boilers

Chillers

Coils

Ductwork

Compressor

Heat Exchangers

Piping

Vibration Isolators

Insulation

Condenser

Unit Heaters

Air Handling Units

Air-Conditioning Units

Mixing Boxes

Filters

Spare Parts

Accessories

Equipment foundation data for the following items shall include equipment weight and operating loads; horizontal and vertical loads; starting torques and their direction; rpm of equipment; size, location and projection of anchor bolts; horizontal and vertical clearances for installation, operation, and maintenance; plan dimensions of foundations and relative elevations; and installation requirements such as noise abatement, vibration isolation, and utility services.

Vibration Isolators
Boilers
Piping
Compressor
Condenser
Coils
Valves
Unit Heaters
Fans
Air Handling Units
Air-Conditioning Units
Ductwork
Air Diffusers
Mixing Boxes

SD-05 Design Data

Design analysis and calculations shall be submitted for HVAC Systems and shall include the following items when applicable.

Flow Rates
Air Distribution
Design Pressures and Losses
Fan and Pump Design Speeds
Sound and Comfort Design
Vibration Calculations
Insulation Requirements
Filter Requirements
Boiler and Chiller Design

SD-06 Test Reports

Test reports shall be submitted for the following items on each type of HVAC system.

Pressure Tests
Vacuum Testing
Operating Test

SD-08 Manufacturer's Instructions

Manufacturer's [Installation Instructions](#) shall be submitted in accordance with paragraph entitled, "Installation," of this section.

[Operating Instructions](#) shall be submitted for all proposed equipment.

SD-10 Operation and Maintenance Data

[Operation and Maintenance Manuals](#) shall be submitted for the following systems in accordance with paragraph entitled, "Operation and Maintenance," of this section.

Air Systems
Hydronic Systems
Air-Hydronic Systems
Unitary Systems

1.3 MECHANICAL SYSTEMS IDENTIFICATION

Contractor shall provide a coordinated system of piping identification which includes:

A framed and plastic-protected diagrammatic layout of piping systems, showing and identifying piping, ducting, automatic or manual control locations, equipment, and valve locations. Where existing systems are being modified, existing layouts shall be brought up to date to include such modifications.

Metal tag-identified major valves, piping systems components, and equipment

1.3.1 Diagrams

Connection, control and installation diagrams for [Air Systems](#), [Hydronic Systems](#), [Air-Hydronic Systems](#) and [Unitary Systems](#) shall be submitted meeting referenced standards within this section.

Design analysis and calculations shall be submitted for HVAC Systems and shall include the following items when applicable. Chart listing of equipment shall be by designation numbers and showing capacities to include [Flow Rates](#), [Air Distribution](#), [Design Pressures and Losses](#), [Fan and Pump Design Speeds](#), [Sound and Comfort Design](#), [Vibration Calculations](#), [Insulation Requirements](#), [Filter Requirements](#) and [Boiler and Chiller Design](#). They shall also include heating and cooling capacities, horsepower, pipe sizes, and voltage and current characteristics.

Diagrams shall be neat mechanical drawings provided with extruded aluminum frames and [4 millimeter 1/8-inch](#) acrylic plastic protection. Location shall be as directed by the Contracting Officer.

[Connection diagrams](#) shall be submitted for the following systems indicating the relations and connections of devices and apparatus by showing the physical layout of all controls, the interconnection of one system (or portion of system) to another, and internal tubing, wiring, and other devices.

[Control diagrams](#) shall be submitted for the following systems indicating the physical and functional relationship of equipment, electrical diagrams showing size, type and capacity of the systems, and pneumatic diagrams for air and gas systems.

[Schematics](#) shall be submitted for each HVAC duct system indicating dampers, regulating devices, terminal units, supply outlets, return and exhaust inlets, and the size, velocity and flow ([cubic meter per minute or liter per second](#)) ([cfm or gpm](#)) for main branch circuits or ducts. Drawings shall include air intakes and exhaust air and relief air louvers where applicable.

1.3.2 Metal Tags

Identification tags made of brass or aluminum indicating function of a control or similar component shall be installed on system devices. Tags shall be [50 millimeter 2 inches](#) in diameter; marking shall be stamped.

1.3.3 Service Labeling

Piping, including that concealed in accessible spaces, exposed, bare, painted, or insulated, shall be labeled to designate service. Each label shall include an arrow or arrows to indicate flow direction.

1.4 STORAGE AND PROTECTION OF EQUIPMENT AND MATERIALS

Equipment and materials stored at the site shall be fully protected from damage, dirt, debris, and weather.

1.5 AUTOMATIC CONTROL OF SYSTEMS

Automatic control systems shall be complete in all details and shall include accessories to maintain specified conditions.

Automatic temperature control systems may be equivalent pneumatic, electronic, electric/electronic, low-voltage electric, or pneumatic/electronic.

Sequence of operations to be controlled shall be as shown on drawings.

1.6 GENERAL REQUIREMENTS

NOTE: If Section 23 00 00.00 40 HEATING, VENTILATING, AND AIR-CONDITIONING is not included in the project specification, applicable requirements therefrom should be inserted and the following paragraph deleted. If Section 23 05 48.00 40 VIBRATION AND SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT is not included in the project specification, applicable requirements therefrom should be inserted and the second paragraph deleted. If Section 26 18 39.00 40 MEDIUM-VOLTAGE MOTOR CONTROLLERS is not included in the project specification, applicable requirements therefrom should be inserted and the third paragraph deleted.

[Section 23 00 00.00 40 HEATING, VENTILATING, AND AIR-CONDITIONING applies to work specified in this section.]

[Section 23 05 48.00 40 VIBRATION AND SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT applies to work specified in this section.]

[Section 26 18 39.00 40 MEDIUM-VOLTAGE MOTOR CONTROLLERS applies to this section.]

PART 2 PRODUCTS

NOTE: Pump, fan, compressor, and motor balance shall conform to ISO Std. 1940/1 - (1986) Balance Quality Requirements of Rigid Rotors - Determination of Permissible Residual Unbalance unless otherwise noted. Motor vibration levels shall conform to NEMA Specification MG-1, Motors and Generators, Part 7 unless otherwise noted.

2.1 STANDARD PRODUCTS

Mechanical materials and equipment, including chillers, spare parts and accessories, to be provided under this contract shall be current standard catalog products of manufacturers regularly engaged in the manufacture of the products.

2.2 MATERIAL AND EQUIPMENT

Mechanical material and equipment shall meet the specified requirements and shall be suitable for the installation shown. Components bearing the same part number shall be identical in form, fit, and function. Materials and equipment shall be new and free from defects.

2.3 IDENTIFICATION PLATES

Standard manufacturer's identification plates shall be provided for each individual piece of equipment.

2.4 STEEL PIPING FOR STEAM, CONDENSATE, CHILLED AND HOT WATER

Steam, condensate, and water piping for 1050-, 2500-kilopascal 150-, 350-pound per square inch (psi) service shall be black carbon steel (BCS).

2.4.1 Type BCS (1000-kPa150-psi Service)

Pipe or tube (DN6 through DN250) (1/8 through 10 inches): Schedule 40 for steam and water, Schedule 80 for condensate, seamless black carbon steel, conforming to ASTM A 53/A 53M, or ASTM A 106/A 106M, and ASME B36.10M

Fittings (DN6 through DN50) (1/8 through 2 inches): 2100-kilopascal 300-psi working steam pressure (wsp) banded malleable iron, screwed end, conforming to ASME B16.3 and ASTM A 234/A 234M

Fittings DN65 through DN250) (2-1/2 through 10 inches): Wall thickness to match pipe, long radius, butt weld, black carbon steel, conforming to ASTM A 234/A 234M, Grade WPB.

Unions (DN6 through DN50) (1/8 through 2 inches): 1800-kilopascal 250-psi wsp, malleable iron, screwed end, ground joint, with brass or bronze seat insert.

Flanges (DN65 through DN250) (2-1/2 through 10 inches): 1000-kilopascal 150-pound, forged carbon steel, welding neck, with raised face or flat face and concentric finish, conforming to ASME B16.5 and ASTM A 694/A 694M

Flange gaskets: Gaskets shall conform to MSS SP-86 and ASME B16.21.

Bolting: Hexhead bolts and nuts shall conform to ASTM F 568M ASTM A 307.

2.4.2 Type BCS (2500-kPa350-psi Service)

Pipe or tube (DN6 through DN250) (1/8 through 10 inches): Schedule 40 for water, Schedule 80 for steam and condensate; seamless black carbon steel, conforming to ASTM A 106/A 106M and ASME B36.10M

Fittings (DN65 through DN250) (2-1/2 through 10 inches): Schedule 40 for

water, Schedule 80 for steam and condensate long-radius, butt weld, black carbon steel, conforming to ASME B16.9 and ASTM A 234/A 234M

Flanges (2-1/2 through 10 inches) (DN65 through DN250): 300-pound 2100-kilopascal, forged carbon steel, weld neck, with raised face and concentric serrated finish, conforming to ASME B16.5 and ASTM A 694/A 694M

Gaskets: Spiral-wound, non-asbestos fiber material filled, carbon steel, with centering provisions, conforming to ASME B16.5, Group 1, and ASTM A 694/A 694M

Bolting: Heavy hexhead, carbon-steel bolts or bolt studs and semifinished heavy hex-nuts, conforming to ASTM F 568M ASTM A 307, Grade B

2.5 VALVES

2.5.1 Gate Valves

Body end connections shall be flanged for valves larger than DN50 2 inches,, unless butt weld ends are required. Screwed or socket weld shall be used for sizes DN50 2 inches and under.

For water usage, seat and seal material shall be of the manufacturer's standard Teflon, Viton, or nylon. For steam usage, the materials shall be as specified on the drawing depending on pressures and temperatures.

2.5.1.1 Type 2500 350

Valves shall be rated 2100 kilopascal 300 psi wsp and shall conform to ASME B16.34.

Body to bonnet connection shall be union or gasketed-bolted type for valves DN50 2 inches and under and gasketed-bolted type for valves larger than DN50 2 inches. Bonnet shall be OS&Y type, rising stem.

2.5.1.2 Type 1000 150

Valves shall be rated 1000-kilopascal 150-psi wsp and shall conform to ASME B16.34.

Body to bonnet connection shall be union or gasketed-bolted type for valves DN50 2 inches and under and gasketed-bolted type for valves larger than DN50 2 inches. Bonnet shall be OS&Y type, rising stem.

For condensate service, screwed-end gate valves shall be 1000-kilopascal 150-psi, wsp-rated, forged steel, conforming to ASME B16.34, as modified and supplemented herein, except that trim shall be manufacturer's standard corrosion-resistant steel.

2.5.1.3 Type 850 125

Valves shall be rated 850-kilopascal 125-psi wsp and shall conform to ASME B16.34.

Valves, in sizes DN50 2 inches and under, shall be union-bonnet type.

Stem shall be rising and backseating type.

2.5.2 Globe and Angle Valves

Body end connections shall be flanged for valves larger than DN50 2 inches, unless butt weld ends are required. Screwed or socket weld shall be used for sizes DN50 2 inches and under.

For water usage, seat and seal material shall be of the manufacturer's standard Teflon, Viton, or nylon. For steam usage, the materials shall be as specified on the drawing depending on pressures and temperatures.

2.5.2.1 Type 2500 350

Valves shall be rated 2100-kilopascal 350-psi wsp and shall conform to ASME B16.34.

2.5.2.2 Type 1000 150

Valves shall be rated 1000-kilopascal 150-psi wsp and shall conform to ASME B16.34.

Pressure-regulating station bypass valves shall be Type 150.

2.5.2.3 Type 850 125

Valves shall be rated 850-kilopascal 125-psi wsp and shall conform to MSS SP-86 and MSS SP-80, globe or angle.

Valves DN50 2 inches and under in size shall be union bonnet type.

Stem shall be rising and backseating type.

2.5.3 Check Valves

2.5.3.1 Type 2500 350

Valves shall be rated 2100-kilopascal 300-psi wsp and shall conform to applicable portions of ASME B16.34.

Valves shall be horizontal swing-check type.

Body end connections shall be flanged for valves larger than DN50 2 inches unless butt weld ends are required. Screwed or socket weld shall be used for sizes DN50 2 inches and under.

Body-to-cover connection shall be union or gasketed-bolted type.

Trim materials, including hinge pin, shall be manufacturer's standard corrosion-resistant alloys for the specified service.

2.5.3.2 Type 850 125

Valves shall be rated 850-kilopascal 125-psi wsp and standard horizontal swing type.

Body end connections shall be flanged for valves larger than DN50 2 inches and screwed in sizes DN50 2 inches and under.

Body-to-cover connection in sizes larger than DN50 2 inches shall be gasketed-bolted type.

Swing-check pin shall be corrosion-resistant steel, bronze, or brass. Swing check angle of closure shall be manufacturer's standard, unless a specific angle is required.

Valve disk shall be regrindable metal or renewable composition type.

2.5.4 Manual Radiator Valves

Valves to control heating medium to heating element shall be packless type. Valve end connection shall be the same size as the supply line.

2.5.5 Cone-Plug Balancing Valve (CPBV)

Cone-plug balancing valves in sizes through DN32 1-1/4 inches shall be thread end, conforming to ASME B1.20.1 and ASME B1.21M, and shall be rated for service at not less than 1200 kilopascal at 121 degrees C 175 psi at 250 degrees F. Valve body and components shall be ASTM B 61 bronze or manufacturer's equal-strength brass materials. Valve plug shall be swivel-type contoured cone and shall not rattle or make any noise in service at any balancing position. Valve shall have high temperature, service-rated packing, with bushing in bottom of gland and gland adjustment. Valves shall be fitted with a memory device which shall permit a valve set at a balance point to be opened or closed but not opened beyond the balance point. Valve shall be nonrising stem type.

2.5.6 Eccentric Plug Valves (EPV)

Eccentric plug valves in sizes DN50 2 inches and smaller shall be constructed of manufacturer's standard brass or bronze materials conforming to ASTM B 61 or ASTM B 62. Valves shall be rated for service at 1200-kilopascal 175-psi maximum nonshock pressure at 121 degrees C 250 degrees F. Valve body shall have screwed ends. Eccentric plug surfaces in contact with flow shall be coated with a 60 to 70 Shore A durometer hardness elastomer, resistant to treated water.

Reopening, limited to eccentric plug valves in sizes DN65 2-1/2 inches and larger, shall be constructed of Type 2 nickel-alloy iron conforming to ASTM A 436. Valves shall be rated for service at 1200-kilopascal 175-psi maximum nonshock pressure at 121 degrees C 250 degrees F. Valve body shall have screwed ends. Eccentric plug surfaces shall be coated with a 60 to 70 Shore A durometer hardness elastomer, resistant to treated water.

2.5.7 Ball Valves (BAV)

2.5.7.1 Metal

Valves shall conform to MSS SP-72.

Valves shall be rated for service at not less than 1200 kilopascal at 93 degrees C 175 psi at 200 degrees F.

Valve bodies in sizes DN50 2-inch iron pipe size (ips) and smaller shall be screwed-end-connection type, constructed of Class A copper alloy.

Valve bodies in sizes DN65 2-1/2-inch ips and larger shall be flanged-end connection type, constructed of Class D, E, or F material.

Balls and stems of valves DN50 2-inch ips and smaller shall be

manufacturer's standard Class A copper alloy with 900 Brinell hard-chrome plate finish or Class C corrosion-resistant steel alloy with hard-chrome plate.

Ball and stems of valves DN65 2-1/2-inch ips and larger shall be manufacturer's standard Class C, corrosion-resistant steel alloy with hard-chrome plate. In valves DN150 6-inch ips and larger, balls shall be Class D with 900 Brinell hard-chrome plate.

Valves shall be suitable for flow from either direction and shall seal equally tight in either direction.

Valves shall have full-pipe-size flow areas.

Valves with ball seals kept in place by spring washers are not acceptable. Valves shall have adjustable packing glands. Seats and seals shall be tetrafluoroethylene.

2.5.7.2 Polyvinylchloride (PVC)

Ball valves shall be manufactured from a PVC compound that meets the requirements of Class 12454-B PVC as outlined in ASTM D 1784. Valves shall also conform to NSF/ANSI 14.

Valves shall have Teflon ball seals and Viton stem and body seals. Ball valves shall carry a pressure rating of 1000-kilopascal 150-psicirculating water pressure (cwp) at 24 degrees C 75 degrees F.

2.5.7.3 Chlorinated Polyvinylchloride (CPVC)

Ball valves shall be manufactured from a compound that meets or exceeds the requirements for Class 23447-B CPVC in ASTM D 1784. Valves shall also conform to NSF/ANSI 14.

Valves shall have Teflon ball seals and Viton stem and body seals. Ball valves shall carry a pressure rating of 1000-kilopascal 150-psi cwp at 24 degrees C 75 degrees F.

2.5.8 Butterfly Valves (BUV)

Butterfly valves shall conform to MSS SP-67, except as modified and supplemented herein.

Butterfly valves shall be wafer type for mounting between specified flanges and shall be rated for 1000 kilopascal (150 psig) 150-pounds per square inch, gage (psig) shutoff and nonshock working pressure.

Valves installed in insulated piping systems shall be provided with extended bonnets placing the operator beyond the specified insulation.

Disk shall be free of external ribs and shall be streamlined.

Use of taper pins to secure the valve disk to the shaft is prohibited.

Shafts shall be a standard manufacturer's component for the valve provided.

Seats and seals shall be resilient-elastomer type designed for field removal and replacement. Elastomers shall be Buna-N, ethylene propylene terpolymer, chloroprene, or approved equivalent, formulated for continuous

immersion service at 121 degrees C 250 degrees F, minimum, and shall be applied at least 10 percent below maximum continuous service temperature. Bonding adhesives, if used, shall comply with elastomer temperature requirements and shall have an effective life equal to or greater than the elastomer.

Seals on DN500 20-inch and smaller valves shall be designed to use standard split-V packing, dual O-rings, and quad rings or they shall be of the adjustable pull-down type.

Seats may be installed in the valve body or on the disk except that circular cross-section O-ring construction is not acceptable.

Seat or disk matting surfaces shall be corrosion-resistant material such as austenitic gray cast iron and bronzes specified for the disk or the materials specified for stems. These materials shall be welded to substrate and ground or shall be mechanically retained. Plated or similarly applied surfacing materials are not acceptable.

Bearings shall be permanently lubricated sleeve type of manufacturer's standard corrosion-resistant steel, bronze, nickel-copper alloy, nylon, or filled tetrafluoroethylene. Bearings shall be designed for a pressure not exceeding the published design load for the bearing material or one-fifth of the compressive strength of the bearing or shaft material. The operating end of the shaft shall be provided with dual inboard bearings or a single inboard and an outboard bearing in or beyond the operator.

Padlocking feature shall be provided to make valve tamperproof.

For balancing service, valve operators shall have provision for infinite position locking.

Manual nonchain-operated valves through DN150 6 inches shall be provided with not less than nine-position, lever-lock handles not exceeding 450 millimeter 18 inches in length.

Manual valves DN200 8 inches and larger, or smaller if the application torque exceeds a pull of 110 newton meter 80 foot-pounds shall be provided with gear operators.

Where valves are indicated to be chain operated, all sizes shall be equipped with gear operators, and chain length shall be suitable for proper storage and operation.

Gear operators shall be worm-gear type. Operator shall be totally enclosed in a cast-iron housing, suitable for grease or oil lubrication. Gears shall be hobcut. Cast-iron-housed traveling-nut operators conforming to AWWA C504 and MSS SP-86 are acceptable. Maximum manual pull on the handwheel or chain wheel shall be 110 newton-meter 80 foot-pounds.

Modulating or remotely actuated two-position service valves shall be provided with pneumatic operators, pilot positioners, valve position indicators, boosters, and relays where necessary. Operating air supply pressure shall be as indicated in the contract documents.

Pneumatic operator and adjustable stroke crosslink system shall be provided for bypass operation.

Maximum load on a pneumatic operator shall not exceed 85 percent of rated

operator capacity.

2.5.9 Dial Cocks

Dial cocks in sizes DN65 2-1/2-inch ips and smaller with pointer and etched position dial shall be rated 1000-kilopascal 150-psi wsp and shall be of manufacturer's standard all-brass construction.

2.5.10 Diaphragm Control and Instrument Valves (DCIV)

Diaphragm control and instrument valves in sizes DN8 and DN10 1/4 and 3/8 inch shall have a forged-brass body with reinforced tetrafluoroethylene diaphragm, and an AISI 300 series corrosion-resistant steel spring with round phenolic handle. Handle shall be fitted with disks color-coded in accordance with MSS SP-86 and ISA RP60.9.

2.6 VIBRATION ISOLATORS

Rubber shall be natural rubber. Elastomer shall be chloroprene. Shore A durometer measurement of both materials shall range between 40 and 60.

Weather-exposed metal vibration-isolator parts shall be corrosion protected. Springs shall be chloroprene coated.

Exact mounting sizes and number of vibration isolators shall be determined by the isolator manufacturer based on equipment that will be installed. Equipment rpm and spring deflections shall be checked to verify that resonance cannot occur.

NOTE: Refer to Section 23 05 48.00 40 VIBRATION AND
SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT if
design may induce vibration considerations.

2.6.1 Mountings

Type A: Composite pad, with 6 millimeter 1/4-inch thick elastomer top and bottom layers, molded to contain a pattern with nonslip characteristics in all horizontal directions. Elastomer loading shall not exceed 275 kilopascal 40 psi. Minimum overall thickness shall be 25 millimeter 1 inch. Deflections shall be limited to 6.4 millimeter 0.25 inch or less.

Type B: Double rubber-in-shear or elastomer-in-shear with molded-in steel reinforcement in top and bottom. Deflections shall be limited to 13 millimeter 1/2 inch or less.

Type C: Free-standing laterally stable open-spring type for deflections over 13 millimeter 1/2 inch, with built-in bearing and leveling provisions, millimeter 1/4-inch thick Type A base elastomer pads, and necessary accessories. Outside diameter of each spring shall be equal to or greater than 0.9 times the operating height of the spring under rated load.

Type D: Partially housed type, containing one or more vertically restrained springs with at least 13 millimeter 1/2-inch clearance maintained around springs, with adjustable limit stops, 6 millimeter 1/4-inch thick Type A base elastomer pads, and necessary accessories.

Type E: Pendulum-suspension configuration with free-standing stable spring

with resilient horizontal and vertical restraints to allow movements of not more than 6 millimeter 1/4 inch in each direction, 6 millimeter 1/4-inch thick Type A base elastomer pads.

Type F: Combination spring and rubber-in-shear or elastomer-in-shear steel framed for hanger-rod mounting. Minimum total static deflection shall be 1 inch 25 millimeter.

2.6.2 Bases

Type U: Unit isolators without rails, structural-steel bases, or inertia blocks

Type S: Structural-steel bases common to a supported assembly, made from welded-joint mill-rolled structural steel with closed-perimeter configuration, isolators attached to outrigger supports

Height of steel members shall be sufficient to provide stiffness required to maintain equipment manufacturer's recommended alignment and duty efficiency of power-transmission components.

2.6.3 Pipe and Duct Vibration Isolation

Type G: Isolators shall be devices with in-series contained steel springs and preformed fibrous-glass or chloroprene-elastomer elements for connecting to building-structure attachments. Devices shall be loaded by supported system during operating conditions to produce a minimum spring and elastomer static deflection of 25 millimeter 1 inch and 10 millimeter 3/8 inch, respectively.

Type H: Isolators shall be devices with contained chloroprene-elastomer elements for connecting to building-structure attachments. Devices shall be loaded by supported system during operating conditions to produce a minimum elastomer static deflection of 10 millimeter 3/8 inch.

Type J: Isolators shall be devices with elastomers mounted on floor-supported columns or directly on the floor. Devices shall be loaded by supported system during operating conditions to produce a minimum elastomer static deflection of 10 millimeter 3/8 inch.

2.6.4 Floor-Mounted Piping

Type K: Isolators shall be devices with springs mounted on floor-supported columns or directly on the floor. Devices shall be loaded by supported system during operating conditions to produce a minimum spring static deflection of 25 millimeter 1 inch.

2.6.5 Vertical Piping

Type L: Isolators shall be pipe base-support devices with one or more contained steel springs. Devices shall be loaded by supported system during operating conditions to produce a minimum static deflection of 25 millimeter 1 inch. Devices shall be equipped with precompression and vertical-limit features, as well as a minimum 6 millimeter 1/4-inch thick elastomer sound pad and isolation washers, for mounting to floor.

Type M: Isolators shall be elastomer mounted baseplate and riser pipe-guide devices. Elastomer elements shall be contained double acting, and elastomers under rated load shall have a minimum static deflection of

10 millimeter 3/8 inch. Isolator shall be sized to accommodate thermal insulation within the stationary guide ring.

2.7 INSULATION

Thermal-insulation system materials shall be noncombustible, as defined by NFPA 220.

Surfaces to be insulated, extent of insulation, and thickness of insulation shall be as indicated on the contract drawings.

Insulation thickness and duct sizes are in millimeter inches. Nominal duct thickness sizes are internal dimensions. Internal insulation is [not] permitted. Pipe callouts are nominal pipe sizes in millimeter inches.

Insulation shall not impede access to duct covers/door used for duct cleaning and/or maintenance.

Mineral fiber blanket and felt insulation shall have a thermal conductivity less than 0.037 watt per square meter per degrees K 0.26 BTU inch/HR/square foot/degree F at operating temperatures, a density greater than 64 kilogram per cubic meter 4 pounds per cubic foot.. Insulation shall conform to ASTM C 553.

Mineral fiber rigid board and block insulation shall have a thermal conductivity less than 0.063 watt per square meter per degrees K 0.44 BTU inch/HR/square foot/degree F at operating temperature, a density greater than 48 kilogram per cubic meter 3 pounds per cubic foot. Insulation shall conform to ASTM C 612.

Fibrous glass blanket and board insulation shall have a thermal conductivity less than 0.039 watt per square meter per degrees K 0.27 BTU inch/HR/square foot/degree F at operating temperature, a density greater than 16 kilogram per cubic meter 1 pound per cubic foot. Insulation shall conform to ASTM C 1139.

Cellular glass shall have a minimum thermal conductivity less than 0.048 watt per square meter per degrees K 0.33 BTU inch/HR/square foot/degree F a density of 120 to 136 kilogram per cubic meter 7.5 to 8.5 pounds per cubic foot.

Cellular elastomer shall have a minimum thermal conductivity less than 0.039 watt per square meter per degrees K 0.27 BTU inch/HR/square foot/degree F/inch.

Cellular glass shall conform to ASTM C 552, Type II (pipe covering).

2.7.1 Adhesives

Adhesives shall be as recommended by the insulation manufacturer.

2.7.2 Jacketing

Jacketing shall be as recommended by the insulation manufacturer.

2.7.3 Coatings

Coatings shall be as recommended by the insulation manufacturer.

Coating color shall be as selected by the Contracting Officer.

Finish coating for cellular elastomer insulation shall be a polyvinylchloride lacquer approved by the manufacturer of the cellular elastomer.

2.8 BOILERS

Boilers shall have efficiencies in accordance with the recommended levels specified in DOE CE-5

Certificates shall be submitted for boilers showing efficiencies in accordance with the certification program specified in HYI RATINGS.

2.8.1 Factory Testing

Boilers, completely factory-assembled, shall be tested at the manufacturer's plant, and a certificate by an independent testing agency shall be submitted to the Contracting Officer for approval.

2.8.2 Firetube Boiler

Boiler shall be of the self-contained, multipass, package type, complete with accessories, mounted on a structural-steel base. A unit shall include the boiler, gas-burning equipment, boiler fittings, automatic controls, forced- or induced-draft fan, insulation, electric wiring, integral piping, and protective housing. Boiler shall be a horizontal, tubular, three-pass, Scotch marine type, constructed in accordance with ASHRAE-07, Chapter 28, UL 834, and ASME BPVC SEC VI. Boiler shall have a minimum of 1/2 square meter 5 square feet of effective fireside heating surface per boiler wattage horsepower.

2.8.3 Watertube Boiler

Boiler shall be of the self-contained, package-type, complete with accessories, mounted on a structural-steel base. A unit shall include the boiler, gas-burning equipment, boiler fittings, automatic controls, forced-or induced-draft fan, insulation, electric wiring, integral piping, and protective housing. Boiler shall be constructed in accordance with ASHRAE-07, Chapter 28, UL 834, and ASME BPVC SEC VI. Heating surface shall be based on a heat transfer of not more than 80 kilowatt per square meter 25,000 Btu per square foot per hour.

2.8.4 Gas-Burning Equipment

Automatic gas-fired units with input capacities of less than 87.9 kilowatt 300,000 Btu per hour shall be rated per DOE RE-5 [_____]. Automatic gas-fired units with input capacities of 87.9 kilowatt 300,000 Btu per hour and greater shall be rated GAMA [IAS Directory] [UL] and comply with ANSI Z21.13a/CSA 4.9a [UL 795]. Gas-fired burners shall be CSA DIR.015 listed.

2.8.5 Atmospheric Gas Burners

Gas burners shall conform to ANSI Z21.13a/CSA 4.9a . Gas burners shall be of the Bunsen type, the venturi type with raised, drilled ports, or the ribbon type of corrosion-resisting metal in cast-iron body, designed to operate without backfiring.

2.8.6 Fuel Oil Burners

Fuel oil burners shall be Factory Mutual (FM) and IRI (FIA) approved. Fuel oil burners shall have low fire start and may be of high-low, low-medium-high, or full modulation design for operation with No. 2 fuel oil.

2.8.7 Mechanical-Draft Gas Burner Unit

Burner shall be designed for horizontal installation and firing and shall conform to [UL 726](#), [ASME SI-01](#) and [MS MIL-B-18796](#). A burner unit shall consist of a complete fuel system, flame safeguard controls, boiler limit and fuel safety interlocks, combustion controls, fan units, and other accessories and components necessary for safe and efficient operation.

2.8.7.1 Forced-Draft Fan Unit

Forced-draft [fans](#) shall be an electric motor direct-driven, damper-controlled, centrifugal or axial-flow type unit. Unit shall have sufficient air capacity for complete combustion of the maximum fuel quantity to be burned at maximum firing ratio plus 15 percent excess volume against a 32-percent static pressure overload. Unit shall be constructed and rated in accordance with [ASHRAE-07, Chapter 18](#), and [ASHRAE 51](#). Adequate adjustments shall be included in the fan selection or design for maximum burner and boiler pressure drop, combustion air, and plant elevation above sea level.

2.8.7.2 Induced-Draft Fan Unit

[Fans](#) shall be designed especially for induced-draft service. Specified capacity shall be increased to compensate for the elevation above sea level at the point of installation, and shall be based on a flue-gas temperature of [288 degrees C](#) [550 degrees F](#). Parts of the fan in contact with the flue gases shall be designed to withstand the corrosive effects of the smoke, gases, and fly ash as well as flue-gas temperature up to [316 degrees C](#) [600 degrees F](#). Fan bearing shall have approved means to prevent overheating; provision shall be made for lubrication. Water-cooled bearings or air-cooled factory-sealed bearings shall be furnished if recommended by the fan manufacturer. Cleanout and inspection doors shall be provided in each fan housing. Unit shall be constructed and rated in accordance with [ASHRAE-07, Chapter 18](#), and [ASHRAE 51](#).

2.8.8 Boiler Trim and Accessories

2.8.8.1 Gas-Pressure Regulating Valve

Valve shall be of the automatic type and of the proper capacity, shall be adjusted for an outlet pressure of [1000 kilopascal](#) [4 inches](#) of water for natural gas or [625 pascal](#) [2-1/2 inches](#) of water for manufactured gas, and shall be installed in the connection to the gas boiler. Valve shall be selected from those listed in [ASHRAE-07, Chapter 28](#), [UL 834](#), and [IAS Directory](#).

2.8.8.2 Gas-Control Valves

Gas burner shall be supplied with an electric gas-control valve. Gas-control valve shall be positive in action, shall operate with a minimum of noise, and shall render satisfactory service with a 10-percent voltage fluctuation. Valve shall be designed to close immediately upon current

failure and to remain closed until the current is restored. Manual control valves shall also be provided in the main line to the burner and in the pilot line. Automatic valves shall be selected from those listed in [ASHRAE-07, Chapter 28, UL 834, and IAS Directory](#).

2.8.8.3 Pressure Gage and Thermometer

Combination pressure gage and thermometer with suitable pressure and temperature ranges shall be installed on each boiler.

2.8.8.4 Pressure-Relief Valves

Each boiler shall be provided with one or more relief valves constructed and installed in strict accordance with [ASHRAE-07, Chapter 28, UL 834, and ASME BPVC SEC VI](#). Aggregate relieving capacity of the relief valves shall be not less than that required by the above referenced publication. Relief valves shall be ASME rated and stamped.

2.8.9 Combustion Safety Controls

Combustion-control system shall be automatic and shall be installed in strict accordance with the manufacturer's recommendations and under the direct supervision of a representative of the manufacturer. Combustion controls shall conform to applicable requirements of [UL 726, ASME SI-01 and MS MIL-B-18796](#), except as revised herein. Upon completion of the installation, the Contracting Officer shall be furnished with a written statement from the manufacturer's representative certifying that the combustion-control equipment has been properly installed and is in perfect operating condition.

2.8.9.1 Atmospheric Burners

A flame-failure, safety-control system of the electronic type incorporating a flame rod shall be provided. Ignition of electronically supervised pilots shall be accomplished with a suitable start-stop station so that manual depression of the start button will energize only the pilot valve and ignition transformer. On proof of pilot flame, the main gas valve shall cycle on demand of the controller. Upon failure of main and pilot flame, all fuel valves shall be deenergized and an alarm shall sound within 2 to 4 seconds. System shall require manual restart. Pilot shall be supervised during the off-cycle of the main burner and the pilot valve shall close and sound an alarm if any electronically supervised pilot is extinguished.

Components of the system shall consist of, but shall not be limited to, a flame sensing device, electronic relay, pilots, disconnect switch, wiring, pressure regulators, interlocks, gas control valves, and pilot gas control valve.

2.8.9.2 Mechanical-Draft Burners

A complete, fully automatic flame-failure, safety-control system of the electronic type, including a prewired and factory-tested programming assembly, shall be provided. Controls shall conform to the requirements of [UL 726, ASME SI-01 and MS MIL-B-18796](#). Control shall be of the fail-safe design where component failure within the control or the presence of actual or simulated flame prior to startup will prevent burner operation. Flame-failure control shall be readily removable from the chassis for servicing without disconnecting any wiring. Necessary devices for

automatic starting and programming of the pilot and main-burner equipment shall be furnished. Flame-failure sensing device shall be of the flame-frequency, ultraviolet-detector, or flame-rectification type operating in conjunction with an electronic relay. Relay shall open the circuit to the fuel valves in not more than 4 seconds if main-burner flame is not properly established or upon flame failure and shall also actuate an alarm.

Controls shall create a safety shutdown prior to energization of the main fuel valve if the pilot flame is not ignited and detected by the sensing device.

This pilot-proving period shall be limited to 10 to 15 seconds. Trial for main fuel ignition shall be limited to 15 seconds, and repurging the boiler of combustion gases by at least four air changes shall be mandatory if ignition does not occur during the 15-second period. Control shall recycle automatically after a limit or operating control opens or after an electrical failure. A safety shutdown due to flame failure shall require manual reset of safeguard controls before operation can be resumed and shall prevent recycling of the burner equipment. A low-fire start shall be provided on high-low-type burner controls.

Components of the system shall include a motor starter, disconnect switch, electronic flame relay, alarm relays, indicating lights, flame-sensing device, wiring, control cabinet, damper for draft control, gas-shutoff safety valve, fan interlocks, airflow switches, and gas-pressure controls.

2.9 REFRIGERATION PIPING AND SPECIALTIES

2.9.1 Piping and Fittings

Tubing (to 22 millimeter 7/8-inch outside diameter (od)): Annealed Type K, conforming to ASTM B 88, where bending or flare connection is required

Tubing (over 22 millimeter 7/8-inch od): Hard-drawn, seamless-copper tubing conforming to ASTM B 280, No. C12200

Fittings (to 22 millimeter 7/8-inch od): Flared-type, conforming to SAE J513

Fittings (over 22 millimeter 7/8-inch od): 1050 kilopascal 150-psig, wrought-copper socket-joint, conforming to MSS SP-104 and ASME B16.22

Flexible connectors (all sizes): Flexible connections for reciprocating equipment shall be of the seamless, corrugated, all nonferrous-metal type with external nonferrous metal reinforcing braid.

2.9.2 Refrigerant Liquid Receiver

Receiver shall conform to ASHRAE-07, ASHRAE-05 and ASHRAE-06, and ASME BPVC SEC VIII D1 with stamp, and to requirements indicated and specified herein.

Refrigerant liquid receiver shall have all necessary openings, accessories, and support provisions.

Pumpdown capacity of receiver shall be 80 percent of the internal volume of the receiver.

Receiver shall be equipped with inlet-outlet drop pipe, drain plug, purging valve, relief valves of capacity and setting required by ASHRAE 15, and two bull's-eye liquid-level sight glasses. Sight glasses shall be in the same vertical plane, 90 degrees apart, perpendicular to the axis of the receiver, and not over 75 millimeter 3 inches horizontally from the drop pipe, measured along the axis of the receiver. In lieu of bull's-eye sight glass, external gage glass with metal glass guard and automatic-closing stop valves may be provided.

2.9.3 Shutoff and Check Valves

Shutoff valves shall be packless diaphragm (in sizes commercially available), with packed, ground-finish stem, key operated, back seating, sealed-cap type; otherwise, angle pattern valves shall be used whenever possible. Check valves shall be lift type for gases and vapors and swing-check type for liquids.

2.9.4 Solenoid Valves

Valves shall be brass or steel body, packless type, with corrosion-resistant steel trim, rated for continuous-duty service, direct-or pilot-operated, provided with manual lift stems, and designed for use with type of refrigerant used. Valve capacities shall be sufficient for the requirements of the installation at a pressure drop not in excess of 14 kilopascal 2 psi. Valves in suction lines shall be sized in accordance with temperature rise and superheat normal to the system.

2.9.5 Expansion Valves

Valves shall be thermal-expansion type to suit specific system refrigerant, designed to fit coil distributors, and capable of operating from 40 to 100 percent of full load at system head pressure without hunting or liquid hammer. Valves shall have external equalizer connections and external superheat adjustments with seal caps. Joint connections shall be mechanical threaded or flanged type. Valves shall require not over 15 degrees C 4 degrees F superheat change to move from fully open to fully closed position. Superheat setting shall be minus 12 degrees C 10 degrees F at full load.

Expansion valves shall be balanced double seated or pilot operated, capable of stable operation at 15 percent design load.

Each valve shall be provided with external strainer.

2.9.6 Evaporator Pressure Regulators

Evaporator pressure regulators shall have a maximum pressure drop at design conditions of 21 kilopascal 3 psi with refrigerants R-22 or R-502. Regulators shall be installed with valved gages upstream and downstream and shall be fully adjustable, both for setting and for throttling range from open to closed.

2.9.7 Filter/Dryers

Filter/dryers in sizes 13 millimeter 1/2 inch and larger shall be the full-flow, replaceable-core type. Sizes smaller than 13 millimeter 1/2 inch shall be the sealed type. Cores shall be of a suitable desiccant that will not plug, cake, dust, channel, or break down but shall remove water, acid,

and foreign material from the refrigerant. Dryer shall be constructed so that no desiccant will pass into the refrigerant lines. A filter/dryer shall be provided in the liquid line to each evaporator and shall be piped with a three-valve bypass. Pressure drop through the dryer shall not exceed 14 kilopascal2 psi when operating at full connected evaporator capacity.

2.9.8 Liquid Sight Glasses

Sight glasses shall be double glass, see-through type, with cover cap on each side. Sight glass shall be provided in liquid line immediately preceding each expansion valve. Glass shall be furnished with a color-change-type moisture indicator.

2.9.9 Moisture Indicators

Color-change moisture indicators shall be provided downstream from each filter/dryer and bypass or shall be combined as a single unit in the liquid sight glasses.

2.9.10 Discharge-Line Oil Separator

Discharge-line oil separator of rated capacity equal to or greater than the compressor capacity shall be provided in the discharge line from each compressor when recommended by the compressor manufacturer for the specific installation. Separator shall be provided with an oil float-valve assembly or needle valve and orifice assembly, drain-line shutoff valve, and sight glass. Oil-return line shall be connected to the compressor as recommended by the compressor manufacturer.

2.9.11 Liquid-Suction Interchangers

Liquid-suction interchangers shall be provided to increase system efficiency to subcool liquid refrigerant or to prevent liquid refrigerant from entering the compressor.

2.9.12 Line Strainers

Strainers shall be Y-type with removable basket. Strainers in sizes DN50 2-inch ips and smaller shall have solder ends; in sizes DN65 2-1/2-inch ips and larger, strainers shall have flanged ends. Minimum body working-pressure rating shall be 1800 kilopascal 250 psig. Body shall have cast-in arrows to indicate direction of flow. Strainer bodies fitted with screwed screen retainers shall have straight threads and shall be gasketed with nonferrous metal. Strainer bodies fitted with bolted-on screen retainers shall have offset blowdown holes. Body material shall be cast bronze in sizes DN50 2 inchesips and smaller, and cast bronze or cast iron in sizes DN65 2-1/2 inches ips and larger.

Minimum free-hole area of strainer element shall be equal to not less than 5 times the internal area of connecting piping. Strainer screens for liquid service shall have perforations not to exceed 0.25 millimeter 0.010 inch or equivalent wire mesh. Strainer screens for vapor or gas service shall have perforations not to exceed 0.50 millimeter 0.02 inch or equivalent wire mesh. Strainer screens shall have finished ends fitted to machined screen chamber surfaces to preclude bypass flow. Strainer element material shall be AISI Type 304 or 316 corrosion-resistant steel.

2.9.13 Mufflers

A muffler shall be provided in a hot-gas discharge line.

2.10 RECIPROCATING REFRIGERANT COMPRESSOR UNITS

Reciprocating refrigerant compressor unit shall consist of a multicylinder compressor, prime mover, drive, and specified accessories for remote location. Unit shall be mounted on a vibration-isolated, welded, rolled structural steel or cast-iron base.

2.10.1 Compressor

Compressor shall conform to performance criteria as shown on the [drawings] [equipment schedule].

2.10.2 Motors

Hermetically sealed motors shall conform to requirements of ARI 520 for motors specified herein, except that two manually resettable thermal overload protective devices shall be located within motor windings.

2.10.3 Accessories

Crankcase oil heaters shall be provided and shall be controlled as recommended by the manufacturer.

An external oil filter (in addition to oil pump suction strainer) and magnetic plugs in crankcase shall be provided.

2.11 RECIPROCATING COMPRESSOR-CONDENSER UNITS

Reciprocating compressor-condenser unit shall include a multicylinder compressor, prime mover, drive, condenser, receiver, intercomponent piping and wiring, control panel, and specified accessories for remote location. Unit shall be mounted on a vibration-isolated, welded structural-steel base ready for terminal field connections.

2.11.1 Compressor

Compressor shall conform to performance criteria as shown on the [drawings] [equipment schedule].

2.11.2 Accessories

Crankcase oil heaters shall be provided and shall be controlled as recommended by the manufacturer.

An external oil filter (in addition to oil pump suction strainer) and magnetic plugs in crankcase shall be provided.

2.11.3 Air-Cooled Condenser

Unit shall conform to performance criteria as shown on the [drawings] [equipment schedule].

2.11.3.1 Fans and Drives

Fans shall be propeller type, of corrosion-resistant construction, and

shall be statically and dynamically balanced to ISO 1940-1-1986, [G6.3] [G2,5] [G1,0] [_____]. Fan discharge shall be vertical. Maximum fan tip speed shall be 50 meter per second 10,000 feet per minute (fpm).

Fan drive shall be direct.

Fan drive shall be V-belt, with corrosion-protected shaft and antifriction type bearings. [Bearings shall be sealed against moisture and dirt, prelubricated, and suitable for not less than 10,000 operating hours without need of relubrication] [Bearings shall be permanently lubricated sealed bearings].

Condenser fan motors shall be totally enclosed type.

Condenser fan motors shall be resiliently mounted.

2.11.3.2 Condensing Coil

Condensing coils shall be designed and sized specifically for air-cooled condenser service. Coil construction shall be seamless copper tube, with copper or aluminum extended surface integral with or mechanically attached to the tube.

Where a condenser is being used as a combination receiver, the pumpdown capacity shall be 80 percent of the available condenser volume. Coil shall be protected from physical damage.

2.11.3.3 Condensing Pressure Control

Condensing pressure control shall be accomplished by an electronic solid-state control system that will modulate speed of the motor, from 0 to 100 percent by fan cycling or by a combination of methods.

2.11.4 Water-Cooled Condenser

Water-cooled condenser shall include all necessary water and refrigerant connections, purge valve, relief devices and refrigerant valves.

Condenser shall conform to performance criteria as shown on [drawings] [equipment schedule].

Where a condenser is being used as a combination receiver, the pumpdown capacity shall be 80 percent of the available condenser volume.

Unit shall be selected for water velocities not in excess of 2 meter per second 7 fps and a fouling factor of 0.0010.

2.11.4.1 Construction

Condensing surface between halogen refrigerant and cooling water shall be copper; tube sheets shall be nonferrous metal.

Compressor suction and discharge valves shall be flange connected, wrench operated, rising stem type, and with cap. Other valves shall be packless type, wherever possible.

Refrigerant circuit shall be factory cleaned and factory charged with dry nitrogen or refrigerant.

2.12 COILS

2.12.1 Coil Pressure and Temperature Ratings

Coils shall be designed for the following fluid operating pressures and temperatures:

<u>SERVICE</u>	<u>PRESSURE (kPa)</u>	<u>TEMPERATURE (DEGREES C)</u>
Steam - low pressure	170	131
Steam - high pressure	1050	178
Steam - superheated	2400	260
Hot water	1400	121
Chilled water	1400	121
Volatile refrigerant	1400	149

<u>SERVICE</u>	<u>PRESSURE (PSI)</u>	<u>TEMPERATURE (DEGREES F)</u>
Steam - low pressure	25	267
Steam - high pressure	150	366
Steam - superheated	350	500
Hot water	200	250
Chilled water	200	250
Volatile refrigerant	200	300

Coils shall be air-pressure tested under water at following minimum pressures:

<u>SERVICE</u>	<u>PRESSURE (kPa)</u>
Steam (low and high pressure)	1700
Water (hot and chilled)	1700
Volatile refrigerant	2800

<u>SERVICE</u>	<u>PRESSURE (PSI)</u>
Steam (low and high pressure)	250
Water (hot and chilled)	250
Volatile refrigerant	400

2.12.2 Coil Casings

Coil casing shall be mill-galvanized sheet metal with not less than 0.38 kilogram of zinc per square meter 1.25 ounces of zinc per square foot of two-sided metal surface conforming to ASTM A 653/A 653M. Minimum shall be 1.6 millimeter 16-gage, and casing shall be flanged on four sides for bolted assembly.

2.12.3 Coil Headers

Coil headers shall be cast iron, brass, copper, or aluminum casting.

Direct expansion, volatile refrigerant coils shall have copper or brass headers with necessary control connections.

Steam and water coil headers shall be fitted with DN8 1/4-inch ips spring-loaded plug drains and vent petcocks. Automatic vents shall be provided where needed.

2.12.4 Coil Tubing

Coils shall be constructed of copper tubing with aluminum or copper fins. Helical coil fins shall be wound tight to the tubes and solder-coated. Plate fins shall have spacer collars in metallic contact with the adjacent fin, and fins shall be mechanically bonded to the tube. No bare tube surface shall be visible within the finned portion of the coil.

Cooling coils of helical wound copper design shall be solder-coated.

Coil tubes in water and volatile refrigerant service shall be parallel and shall have sufficient intermediate full coil depth supports to prevent sagging of unsupported span due to working fluid pressures and temperatures and summer and winter coil-ambient conditions. Sagging shall be unacceptable if tube centerline is displaced by more than 5 millimeter 3/16 inch from centerline of tube connection at outlet header when coils are more than two rows deep and when installed in accordance with the manufacturer's instructions. Provisions for expansion and contraction shall be adequate to preclude sagging and distortion under thermal loads applied in indicated or specified service. Tubes shall be sloped to be free draining.

Heating-coil face tube spacing shall be a maximum of 75 millimeter 3 inches on center for DN25 1-inch tubes, 50 millimeter 2 inches for 3/4-inch DN20 tubes, and 38 millimeter 1-1/2 inches for DN18 5/8-inch tubes.

Coil face tube spacing for cooling coils and for helically wound heating coils immediately followed by water-cooling coils shall not exceed 38 millimeter 1-1/2 inches on center.

Tubes shall be straight, turns shall be made through headers or return U-bends, and connections and joints shall be brazed.

Coil tube material shall be seamless deoxidized copper.

Coil tube material for superheated-steam service to 2400 kilopascal 350 psi at 260 degrees C 500 degrees F shall be seamless 90-10 copper-nickel with 0.89 millimeter 0.035-inch wall thickness.

Raw coil tube stock wall minimum thickness shall be 0.89 millimeter 0.035

inch.

Where mechanical insert devices are used to increase liquid turbulence within tubes, the wall thickness of these tubes shall be increased by 0.25 millimeter 0.010 inch over the minimum raw coil tube stock specified for the service.

Tube minimum outside diameter shall be 18 millimeter 5/8 inch.

2.12.5 Coil Circuiting

Standard or full-circuited water coils shall have as many full-length tubes in each circuit as the number of tubes in the depth of the coil face; double-circuit water coils shall have twice as many as standard coils; and half-circuit water coils shall have half as many as standard coils and to the next larger whole number where odd numbers are involved.

Coils more than two rows deep shall be counterflow type; however double- or half-circuit coils, with a reasonable deviation from counterflow arrangement may be used, provided the pressure drop and capacity requirements are met.

2.12.6 Drainable Coils

Drainable coils shall be capable of being purged free of water with compressed air.

Self-draining coils shall have a drain point at the end of every tube and shall be pitched to that point. Drain provisions shall include: drained headers; U-bends with integral plugs; or nonferrous plugs in cast-iron headers. Each tube shall drain substantially dry by gravity alone when drains and vents are open.

Coil pitch and leveling shall be field checked for drainability in the presence of the Contract Administrator.

2.12.7 Testing

Coils shall be factory pressure tested, dehydrated, vacuum tested, purged with inert gas, and sealed, prior to shipment to job site.

2.13 UNIT HEATERS

Unit heaters shall be suspended type and arranged for discharge of air as indicated on the construction drawings. Unit shall comply with applicable American Gas Association standards.

2.13.1 Casing

Casing shall be manufactured of not less than 1 millimeter 20-gage steel. Casing inside and outside shall be given a phosphate pretreatment, primer, and baked enamel finish. Horizontal louvers shall be provided and shall be completely recessed inside of the casing frame.

2.13.2 Heat Exchangers

Heat exchangers shall be welded construction, heavy aluminized steel. Each exchanger shall be formed in a clam-shell design to completely surround the burner. Individual combustion chambers shall be provided for each burner.

2.13.3 Burners

Burners shall be die-formed, aluminum-painted, heavy thickness mild steel with long slot ports for even supply of gas. Burner assembly shall be of unitized construction with integral crossover for positive burner ignition. A draft diverter shall be an integral part of each heat exchanger section to allow backdrafts to bypass burner assembly without affecting normal operation.

2.13.4 Fans

Fans shall be propeller type, designed and manufactured for unit heater application. Fans shall have a minimum of three aluminum blades.

2.13.5 Motors

Motors shall conform to NEMA MG 1, be totally enclosed, with sleeve bearings and built-in overload protection. Motors shall be mounted to back panel by a fan guard motor mount constructed of spring steel wire.

2.13.6 Controls

Controls shall include high limit switch, fan controls, a 24-volt automatic gas valve with 100 percent safety pilot shutoff, a pressure regulator with leak limiting device, and manual main and pilot valves. An integral junction box for power and control connections shall be provided.

2.13.7 Propeller Unit Heaters (PUH)

2.13.7.1 Vertical Discharge Units

Vertical discharge units shall operate at speeds not in excess of 1,200 revolutions per minute (rpm), except that units with 15 kilowatt 50,000 Btu per hour output and less shall operate at speeds up to 1,800 rpm. Discharge opening shall be covered with a fanguard.

Louver cone diffusers shall be provided.

2.13.7.2 Horizontal Discharge Units

Maximum volume and face velocity for horizontal discharge units shall be:

<u>CUBIC METER PER SECOND</u>	<u>METER PER SECOND</u>
Up to 0.47	4.1
0.48 to 1.42	4.6
1.43 and over	5.1
<u>CFM</u>	<u>FPM</u>
Up to 1,000	800
1,001 to 3,000	900
3,001 and over	1,000

CFM

FPM

Adjustable double deflection louvers shall be provided.

2.13.7.3 Heating Elements

Heating elements shall be manufacturer's standard construction, rated for service at not less than 150 degrees C at 520 kilopascal 300 degrees F at 75 psi.

2.13.7.4 Casings

Casings with smoothly contoured propeller orifice rings shall be constructed of 1 millimeter 20-gage or thicker cold-rolled carbon steel. Casing surface finish shall include phosphate pretreatment, prime coating, and baked enamel finish.

2.13.7.5 Propellers and Motors

Propellers shall have not less than four aluminum blades and shall be dynamically balanced to ISO 1940-1-1986, [G6.3] [G2.5] [G1.0] [_____].

Horizontal-discharge units shall be provided with fan inlet safety guard.

Motors shall be mounted on elastomer vibration isolators.

2.13.7.6 Sound Rating

Unit heater shall be tested and sound rated in accordance with AMCA 300 and AMCA 301.

2.13.7.7 Control

Unit heaters shall be controlled by line-voltage thermostats.

2.13.8 Cabinet Unit Heaters (CUH)

Cabinet unit heaters shall be quiet-operating type, complete with heating elements, fans and drives, filters, baffles and division walls, control provisions, and enclosures with access panels as necessary.

Cabinet shall be sized not larger than indicated in the detail drawings.

Unit pressure components shall be rated for service at not less than 1050 kilopascal 150 psi at system working temperature.

2.13.8.1 Heating Element (CUH)

Heating element shall be manufacturer's standard aluminum fin or serpentine copper-type tube and shall be drainable and ventable.

Cataloged capacity of the heating element shall be constant and permanent.

Tube material shall be seamless deoxidized copper.

Fins shall be mechanically connected to the tubes. Loose fins at operating temperatures will be regarded as causing a reduction in capacity, and the Contractor shall replace such material at no additional cost to the

Government. Elements with bent fins are not acceptable.

Expansion provisions and supports shall be such that element movement is strainfree and noiseless.

Face area of the coil shall be not less than that indicated in the detail drawings.

2.13.8.2 Fan and Drive Assembly (CUH)

Fan shall be centrifugal, forward-curved, double-width, double-inlet type, and shall be statically and dynamically balanced to ISO 1940-1-1986, [G6.3] [G2.5] [G1.0] [_____].

Fan drives shall be direct.

Fan drives shall be direct, except where belt drives are indicated in detail drawings. Belt-drive motors shall be fitted with adjustable rails and an adjustable sheave to permit 20 percent adjustment to fan speed. Independent fan shafts shall be elastomer mounted in self-aligning antifriction or sleeve-type bearings, with essentially lifetime lubrication.

Drives shall be two-, three-, or four-speed and switch positions shall include an off position.

Rotating elements shall be statically and dynamically balance to ISO 1940-1-1986, [G6.3] [G2.5] [G1.0] [_____]d, and fan and drive assembly shall be vibration isolated.

Direct-drive motors shall not exceed 1,200 rpm.

2.13.8.3 Filters (CUH)

Filters shall be installed in a bypass-proof frame to ensure filtering of all moving air before entry into heating element and shall be removable without tools.

2.13.8.4 Enclosures (CUH)

Enclosure configuration shall be as indicated in the detail drawings.

Enclosure surface finish shall include manufacturer's standard phosphate pretreatment, prime coat, and baked enamel finish in color as selected by the Contracting Officer.

2.13.8.5 Insulation (CUH)

Backs of recessed units shall be insulated with not less than 13 millimeter 1/2 inch of 48 kilogram per cubic meter 3-pound per cubic foot density fibrous-glass insulation conforming to NFPA 90A.

2.13.8.6 Control Cycle (CUH)

Sequence of operation shall be as indicated in the Control Diagrams.

Control components shall conform to requirements specified under paragraph entitled, "Controls."

2.13.9 Unit Ventilators (UV)

Unit ventilators shall be quiet-operating modular type, complete with heating elements, fans and drives, filters, baffles and division walls, dampers, control provisions, and enclosures with access panels as necessary.

Unit pressure components shall be rated for service at not less than 1050 kilopascal 150 psi at system working temperature.

Intercomponent wiring shall conform to NFPA 70, and components of unit assembly shall be UL listed and approved.

Heating, fan, and control modules shall have polarized, color-coded, plug-in connections.

2.13.9.1 Heating Element (UV)

Heating element shall be the manufacturer's standard aluminum fin or serpentine copper-tube type and shall be drainable and ventable.

Cataloged capacity of the heating element shall be constant and permanent.

Tube material shall be seamless deoxidized copper.

Fins shall be mechanically connected to the tubes. Loose fins at operating temperatures will be regarded as causing a reduction in capacity, and the Contractor shall replace such material at no additional cost to the Government. Elements with bent fins are not acceptable.

Expansion provisions and supports shall be such that element movement is strainfree and noiseless.

Face area of the coil shall be not less than that indicated in the detail drawings.

2.13.9.2 Fan and Drive Assembly (UV)

Fan shall be centrifugal, forward-curved, double-width, double-inlet type, and shall be statically and dynamically balanced.

Fans shall be belt driven, mounted on a common shaft. Shaft shall be supported by independent, elastomer-mounted, self-aligning, antifriction or sleeve-type bearings with lifetime lubrication. Motor sheave shall be adjustable to provide not less than 20 percent speed variation either way from capacity point. Belt tension shall be adjustable.

Motor shall be manually controlled by two-position on/off switch.

Motor shall be manually controlled by three-position, high/low/off switch.

Motors shall be elastomer vibration-isolation mounted, permanent split-capacitor type with adjustable rail mounting.

2.13.9.3 Filters (UV)

Filters shall be installed in a bypass-proof frame to ensure filtering of all moving air before entry into the heating element and shall be removable without tools.

2.13.9.4 Dampers (UV)

Dampers shall be opposed-blade type constructed to resist salt air. Blades shall be galvanized steel with mechanically attached or secure sealing provisions not dependent upon adhesives. Bearings shall be high-grade commercial quality flanged-type with extended race and corrosion-resistant steel balls and plated races with factory-applied grease conforming to MS DOD-G-24508.

Face and bypass damper shall be provided with external bypass duct if required by the Unit Ventilator.

Mixing dampers shall be provided as an assembly within a mixing box. Dampers shall be capable of varying the proportion of mixed air from 100 percent room air to 100 percent outside air.

2.13.9.5 Enclosure (UV)

Enclosure surface finish shall include manufacturer's standard phosphate pretreatment, prime coat, and baked enamel finish, except as otherwise provided. Color shall be as selected by the Contracting Officer.

2.13.9.6 Wall Sleeve (UV)

Wall sleeve shall be constructed of not less than 1.3 millimeter 18-gage galvanized carbon steel. Finish shall consist of manufacturer's standard galvanized surface preparation and not less than two finish coats of baked enamel or one finish coat of high-build epoxy. Color shall be as selected by the Contracting Officer.

2.14 FAN COIL UNITS

Units shall include an enclosure for cabinet models and casing for concealed models.

Unit color shall be [____], or approved by the Contracting Officer.

2.14.1 Enclosure

Enclosure shall be constructed of not lighter than 1.3 millimeter 18-gage steel, properly reinforced and braced. Discharge louvers shall be four-way adjustable and shall be designed for proper air distribution throughout the conditioned space. Ferrous-metal surfaces shall be galvanized or treated with a rust-inhibiting finish. Exposed-to-view enclosure corners and edges shall be rounded. Access doors shall be hinged and shall be provided for piping and control compartments.

2.14.2 Casing

Casing shall be acoustically and thermally insulated internally with not less than 13 millimeter 1/2-inch thick insulation.

2.14.3 Coils

Water coils shall be constructed of not less than DN15 1/2-inch od seamless copper tubing with copper or aluminum plate fins mechanically bonded or soldered to the tubes and shall be provided with not less than 18 millimeter 5/8-inch od control valve.

2.15 AIR HANDLING UNITS (FACTORY ASSEMBLED)

Air handling unit shall be central-station type, factory fabricated, and sectionally or fully assembled. Performance shall be in accordance with values on [equipment schedule] [drawings].

Fan wheels shall be statically and dynamically balanced to ISO 1940-1-1986, [G6.3] [G2.5] [G1.0] [_____].

Dynamic balancing shall be in two planes.

2.15.1 Air-Handling System Balancing Provisions

Facilities shall be provided for the adjustment of fan speed for each air-handling system during air-quantity balancing operations, when required. Facilities provided shall be one of the following:

A variable-pitch drive with variable range to produce the fan speed necessary for proper air balance

A continuously variable drive or power unit to produce the fan speed necessary for proper air balance

Fixed-pitch pulleys providing the proper fan speed.

2.15.2 Motor Requirements

Hermetically sealed compressor motors shall conform to requirements for motors specified herein and to NEMA MG 1, and ARI 520, except that two manually resettable thermal overload protective devices shall be located within motor windings.

2.15.3 Unit Cabinet

Exterior surfaces of cabinets constructed of mill-galvanized steel shall be prepared by a phosphatizing treatment, and painted with two coats of manufacturer's standard enamel finish in color selected by the Contracting Officer.

2.15.4 Multizone Units

Multizone unit delivery dampers shall be part of the manufacturer's standard unit construction.

Face and bypass dampers and multizone unit delivery dampers shall be part of the manufacturer's standard unit construction.

A balancing plate shall be added to the heating coil when required to equalize resistance in airstreams of multizone units.

2.16 AIR HANDLING UNITS (FIELD ASSEMBLED)

Air handling unit shall be central station type of indicated configuration and shall include enclosure, centrifugal fans, guarded V-belt drives, motors, heating and cooling coils, filters, dampers, vibration isolation provisions, and indicated and specified accessories.

In addition to scheduled maximum system operating pressure and system testing pressure, the ceiling shall be capable of sustaining 1675 pascal 35

pounds per square foot load without permanent deformation or damage. Material shall be hot-dip galvanized.

2.16.1 Enclosure

Enclosure surfaces shall consist of self-supporting ceiling and wall panels mounted on, and fastened to, a concrete curbing. Self-supporting shall be defined as free of building construction, except building floor.

2.16.2 Coil Supports

Coil supports shall be fabricated structural steel not less than 6 millimeter 1/4 inch thick, hot-dip galvanized after fabrication. Hot-dip galvanizing shall conform to ASTM A 123/A 123M except that the amount of deposited zinc shall be not less than 700 gram per square meter 2.3 ounces per square foot of single-side surface when tested in accordance with ASTM A 90/A 90M.

2.16.3 Access Doors and Panels

Access doors shall be not less than 6000 by 1525 millimeter 24 by 60 inches and shall be constructed of 1.6 millimeter 16-gage galvanized metal. Doors shall be provided with two heavy-duty hinges with removable pins and a like number of heavy-duty latch sets operable from either side. Latch sets shall be of cast iron or wrought steel construction with provisions for wear adjustment. Doors shall seal against mechanically retained expanded chloroprene elastomer gaskets.

2.16.4 Drain Pans

Intermediate-coil, 75 millimeter 3-inch deep drip pans shall be provided for each tiered coil bank. Bottom pans shall be provided below the lowest coil. For tiered cooling coils, top pan shall extend 300 millimeter 12 inches beyond face of coil, and bottom pan shall extend not less than 600 millimeter 24 inches beyond base of coil. Where more than two pans are used, pan extension shall be proportional. Adequate supports shall be provided, made from the same type material as pans or hot-dip galvanized angle iron with isolation at interface. Pan material shall be 0.85 millimeter 22-gage, Type 304 corrosion-resistant steel with silver-soldered joints. To preclude standing water, drain pan shall be piped and sloped to drain. Drain shall be located at the lowest point. Exterior of pan shall be insulated to prevent condensation.

2.16.5 Eliminators

Eliminators shall be SMACNA three-break, hooked-edge design, constructed of reinforced 1.6 millimeter 16-gage galvanized steel with assembled brazed joints. Eliminator sections shall be easily removable for cleaning.

2.17 PACKAGED AIR-CONDITIONING UNITS

Air-cooled single package and split system units shall have efficiencies in accordance with the recommended levels specified in DOE CE-3.

2.17.1 Window-Type, Packaged, Self-Contained

Unit shall be a packaged self-contained assemblage that includes hermetic compressor, fan(s), motor drives, coils and controls for fully automatic operation, intercomponent piping and wiring, totally enclosed weatherproof

casing, and frame mounting ready for power connection.

Refrigerant shall be R-22 or R-134a. Units shall be shipped with a refrigerant holding charge.

2.17.1.1 Construction

Controls shall be located on front face of unit or with remote thermostat with on/off/fan selector, or at a remote panel. Conditioned-air circulating fan control shall be two- or three-speed, gradually adjustable, or solid-state.

Unit shall have provisions for admitting controlled amounts of outside air as makeup and for exhausting internal air.

Unit shall meet or exceed an Energy Efficiency Ratio (EER) rating as specified in DOE RA-1.

2.17.2 Console-Type, Packaged, Self-Contained

Unit shall be packaged, self-contained, floor-mounted assemblage which includes compressors, fans, motor(s), drives, coils, water-cooled condenser, controls for fully automatic operation, intercomponent piping and wiring, and a single casing suitable for exposed-to-view office locations ready for field terminal connections. Unit shall meet or exceed a 7.5 EER.

Units over 70 Megajoule 65,000 Btu shall meet or exceed 8.2 EER.

2.17.3 Remote-Split-Type, Packaged, Self-Contained

Air-conditioner shall consist of matched assemblies. Each unit shall be provided complete with frame and enclosure, interconnecting piping and wiring, necessary controls and safety devices, and operating charge of oil. Unit shall be ready for full-capacity operation after removal of shipping protection, connection to remote compressor/condenser or condenser, charging, and connection to utilities. Units shall be shipped with a refrigerant holding charge. Performance shall be in accordance with values shown on the [drawings] [equipment schedule].

Unit shall exceed a rating of 8.2 EER.

2.17.3.1 Air-Cooled Condenser

Air-cooled condenser with vertical/horizontal discharge, in a weather-protected casing, shall be suitable for installation remote from air-conditioning unit. Air inlet and discharge grilles shall be provided with galvanized wire-mesh birdscreens.

2.17.3.2 Water-Cooled Condenser

Water-cooled condensers shall include openings, water and refrigerant connections, purge valves, relief devices, refrigerant valves, liquid-level indicating device, and support provisions.

2.17.3.3 Vibration Isolation

Vibration isolation provisions shall conform to requirements specified in paragraph entitled, "Vibration Isolators."

2.18 DUCTWORK

2.18.1 Galvanized Steel Ductwork Materials

Galvanized steel ductwork sheet metal shall be carbon steel, of lock-forming quality, hot-dip galvanized, with regular spangle-type zinc coating, conforming to [ASTM A 653/A 653M](#), G90. Duct surfaces to be painted shall be treated by phosphatizing.

Sheet metal thickness and reinforcement thickness shall conform to [ASHRAE-05](#), [ASHRAE-07](#) and [SMACNA 1481](#).

2.18.1.1 Duct Hangers

Duct hangers in contact with galvanized duct surfaces shall be galvanized steel.

2.18.1.2 Mill-Rolled Reinforcing and Supporting Materials

Mill-rolled structural steel shall conform to [ASTM A 36/A 36M](#) and, whenever in contact with sheet metal ducting, shall be galvanized to commercial weight of zinc.

2.18.2 Rigid Fibrous-Glass Ductwork Materials

Rigid fibrous-glass duct system, including tapes, adhesives, vapor barriers, and joint sealers, shall conform to requirements of [NFPA 90A](#) and shall have [FM P7825](#) approval and [UL 181](#), Class 1 airduct listing, and be so labeled. Duct system shall have a thermal-conductivity K-value of [0.45 watt per meter degrees K](#) [0.26 Btu foot per hour per square foot per degrees F](#) for flat and [0.40 watt per meter degrees K](#) [0.23 Btu foot per hour per square foot per degrees F](#) for round duct at [24 degrees C](#) [75 degrees F](#) mean temperature. Duct system shall have a noise-reduction coefficient of 0.070 and a vapor-transmission rate of less than [0.011 nanogram per pascal second square meter](#) [0.02 perm](#) for flat board and [0.06 nanogram per pascal second square meter](#) [0.10 perm](#) for round duct. Minimum density shall be [80 kilogram per cubic meter](#) [5 pounds per cubic foot](#) for flat board and [52 kilogram per cubic meter](#) [3.25 pounds per cubic foot](#) for round duct. Vapor barrier shall be factory applied. Materials shall be odorless and nonallergenic when in service.

2.18.3 Flexible Duct Materials

Flexible duct connectors shall be in accordance with [UL 181](#), Class 1 material and shall comply with [NFPA 90A](#).

Metal duct shall be bendable through 180 degrees without damage, with an inside bend radius not greater than one-half the diameter of duct. Metal shall be aluminum or carbon steel protectively zinc-coated with materials conforming of [ASTM A 123/A 123M](#) or [MS MIL-P-26915](#).

Wire-reinforced cloth duct shall consist of a chloroprene or vinyl-impregnated and coated fibrous-glass cloth bonded to and supported by a corrosion-protected spring steel helix. Fabric may be a laminate of metallic film and fibrous glass. Working pressure rating of ducting shall not be less than three times maximum system pressure, and temperature range shall be within [minus 27 to 75 degrees C](#) [minus 20 to plus 175 degrees F](#).

Wire-reinforced fibrous-glass duct shall consist of a minimum 16 kilogram per cubic meter 1-pound per cubic foot density fibrous glass bonded to and supported by corrosion-protected spring helix. Vapor barrier shall be a 0.102 millimeter 4-mil minimum, pigmented polyvinylchloride film. Duct shall be bendable without damage through 180 degrees with an inside bend radius not greater than two duct diameters. Minimum wall thickness shall be 25 millimeter 1 inch. Thermal conductivity shall be not greater than 0.40 watt per meter degrees K 0.23 Btu foot per hour per square foot per degrees F at 24 degrees C 75 degrees F mean. Permeance shall be not greater than 0.06 nanogram per pascal second square meter 0.10 perm. Working pressure range shall be from minus 125 pascal 1/2-inch water gage (wg) to plus 375 pascal 1-1/2 inches wg; working temperature shall range from minus 29 to 121 degrees C minus 20 to plus 250 degrees F. Minimum sustained velocity without delamination shall be 12.2 meter per second 2,400 fpm. Materials shall conform to NFPA 90A. Acoustic properties shall be submitted for approval.

2.18.4 Manual Volume Dampers

Volume damper construction shall conform to ASHRAE-05, ASHRAE-07 and SMACNA 1481.

Dampers shall be equipped with an indicating quadrant regulator having a locking feature externally located and easily accessible for adjustment. Where damper rod lengths exceed 760 millimeter 30 inches, a regulator shall be provided at each end of damper shaft.

Damper shafts shall have two-end bearings.

Splitter damper shall be 0.85 millimeter 22-gage sheet metal, or 0.8 millimeter (2 gages) 2 gages heavier than duct in which installed; i.e., 1.0 millimeter 20-gage splitter in 0.85 millimeter 22-gage duct, up to 1.6 millimeter 16-gage maximum. Hinges shall be full length piano-type or 3 millimeter 1/8-inch thick door type.

Damper shaft shall be full length and shall extend beyond damper blade. A 10 millimeter 3/8-inch square shaft shall be used for damper lengths up to 500 millimeter 20 inches and a 13 millimeter 1/2-inch square shaft shall be used for damper lengths 500 millimeter 20 inches and larger. Where necessary to prevent damper vibration or slippage, adjustable support rods with locking provisions external to duct shall be provided at damper blade end.

Dampers in ducts having a width perpendicular to the axis of the damper that is greater than 300 millimeter 12 inches shall be multiblade type having a substantial frame with blades fabricated of 1.6 millimeter 16-gage metal. Blades shall not exceed 250 millimeter 10 inches in width and 1200 millimeter 48 inches in length and shall be pinned or welded to 13 millimeter 1/2-inch diameter shafts. Dampers greater than 1200 millimeter 48 inches in width shall be made in two or more sections with intermediate mullions, each section being mechanically interlocked with the adjoining section or sections. Blades shall have graphite-impregnated nylon or oil-impregnated sintered bronze bearings and shall be connected so that adjoining blades rotate in opposite directions.

2.18.4.1 Gravity Backdraft and Relief Dampers

Frame shall be constructed of not less than 40 by 100 millimeter 1-1/2- by 4-inch, adequately reinforced, 1.6 millimeter 16-gage galvanized carbon

steel. Frames and mullions shall be solidly secured in place and sealed with elastomer calking against air bypass.

Maximum blade width shall be 225 millimeter 9 inches; maximum blade length shall be 900 millimeter 36 inches. Blade material shall be 1.6 millimeter 16-gage galvanized steel, 2.0 millimeter 14-gage 6063 or 5052 alloy aluminum, or 1.3 millimeter 18-gage AISI 18-8 corrosion-resistant steel. Blades shall be provided with mechanically retained seals and 90-degree limit stops.

Dampers used for relief service shall have blades linked together to open not less than 30 degrees on 12.5 pascal 0.05-inch wg differential pressure.

Shaft bearings shall be graphite-impregnated nylon or oil-impregnated bronze.

2.18.4.2 Power-Operated Dampers

Dampers shall conform to applicable requirements specified under paragraph entitled, "Controls and Instrumentation."

2.18.4.3 Flexible Connectors for Sheet Metal

Connectors shall be UL-listed, 6 kilogram per square meter 20-ounce per square foot, fire-retardant, airtight, woven fibrous-glass cloth impregnated with chloroprene. Clear width, not including clamping section, shall be within 75 to 125 millimeter 3 to 5 inches.

2.18.4.4 Fire Dampers

Fire dampers in ductwork shall be provided at firewall barriers.

Fire dampers shall be constructed and labeled in accordance with UL.

2.19 AIR DIFFUSERS

Supply diffusers shall be provided with combination damper and equalizing grid; damper shall be extracting-splitter type, except where otherwise specified.

Gaskets shall be provided for supply-terminal air devices mounted in finished surfaces.

Color selection shall be from manufacturer's standard color chips and approved by the Contracting Officer.

Low-velocity systems shall encompass ductwork and plenums where maximum air velocity is 13 meter per second 2,500 fpm and maximum static pressure is 500 pascal 2 inches wg, positive or negative.

2.19.1 Type Air-Diffusion Devices

Construction of air-diffusion devices shall be aluminum.

2.19.1.1 Type DRA

Type DRA supply diffuser shall be round with five or more expanding cones with beaded edges to provide hemispherically diffused discharge air. Cones shall be arranged to provide a minimum of four air paths that

simultaneously diffuse air at 0.10 to 0.25 meter per second 20 to 50 fpm and aspirate room air at 25 to 35 percent of discharge volume.

Antismudge ring shall be provided.

Extended cones shall be provided.

2.19.1.2 Type DRB

Type DRB supply diffuser shall be round with four or more expanding cones to provide hemispherically diffused discharge air. Cones shall be arranged to provide a minimum of three air paths that simultaneously diffuse air at 0.10 to 0.25 meter per second 20 to 50 fpm. Pattern adjustment shall range from horizontal to downward projection, and any intermediate point, when mounted on exposed ductwork.

Integral or separate antismudge ring shall be provided.

Extended ceiling cone shall be provided.

2.19.1.3 Type DRC

Type DRC combination supply and return diffuser shall be round with four expanding cones; cones shall be arranged to provide one return air path and two supply air paths. A butterfly supply-air damper and an annular return-air damper shall be provided.

Antismudge ring shall be provided.

2.19.1.4 Type DRE

Type DRE supply diffuser shall be round with three or more expanding cones to provide discharge air paths that shall be, minimally, two-position adjustable for horizontal or vertical discharge.

Antismudge ring shall be provided.

2.19.1.5 Type DRH

Type DRH supply diffuser shall be half-round with four or more semiconical expanding members to discharge diffused air in a 180-degree pattern. Cones shall be arranged to provide a minimum of three air paths that shall simultaneously diffuse air at 0.10 to 0.25 meter per second 20 to 50 fpm. Opposed-blade volume control damper shall be provided.

2.19.1.6 Type DP Series

Type DP series supply diffuser shall have a square or rectangular, perforated face plate with opposed blade or splitter-damper volume control, white baked enamel exterior finish, and black matte finish on exposed-to-view interior surface. (Type DP series diffusers fit a hung ceiling grid system.)

Type DPA shall provide [one-way deflection.] [two-way opposed deflection.] [two-way diagonal deflection.] [three-way deflection.] [four-way deflection.]

2.19.1.7 Type DLB

Type DLB supply diffuser shall be linear bar type, frame mounted, with extruded-aluminum bar and frame.

Bars shall be 6 millimeter thick by 20 millimeter high, 13 millimeter 1/4-inch thick by 3/4-inch high, 1/2 inch on center. Bar spacing shall be pencil-proof. Bar deflection angle shall be zero degrees.

Floor- and sill-mounted diffusers shall be heavy-duty reinforced construction to carry loads of not less than 4800 pascal 100 pounds per square foot.

Diffusers shall be continuous length with hairline butt joints.

Mitered end caps shall be provided where diffuser run terminates.

Dampers shall be opposed-blade type.

An integral, pivoted, bar-type access door shall be provided.

Straightening grids shall be provided.

2.19.1.8 Type DLS

Type DLS supply diffuser shall be linear slot type, extruded aluminum construction, with fully adjustable integral air pattern and volume control vanes that deflect air pattern from horizontal along ceiling to straight down, or any intermediate setting. Pattern control element shall permit complete blanking-off of slot.

Slot width shall be 20 millimeter 3/4 inch.

Number of slots per unit run shall be as indicated in the manufacturer's catalog data.

Butts in continuous runs shall be aligned for hairline joints.

Ends of diffuser shall butt against walls without mitered end caps. End caps shall be provided where slot terminates.

Exposed-to-view part of frame shall be anodized aluminum; interior exposed-to-view components shall have a black matte finish.

2.19.1.9 Type DSA

Type DSA supply diffuser shall be square with four or more expanding flared members to provide radially diffused discharge air. Flared members shall be arranged to provide a minimum of four air paths that simultaneously diffuse air at 0.10 to 0.25 meter per second 20 to 50 fpm. Pattern adjustments shall include horizontal, vertical projection, and an intermediate position or range.

Integral extended surface to fit into module of lay-in ceiling shall be provided.

2.19.1.10 Type GS

Type GS supply grille shall be double deflection type with adjustable face

bars parallel to short dimension and adjustable rear bars parallel to long dimension.

Integral extended surface to fit into module of lay-in ceiling shall be provided.

2.19.1.11 Type GR

Type GR return grilles shall be single deflection type with fixed face bars.

Grilles installed in vertical surfaces shall have horizontal face bars set downward at approximately 35 degrees from vertical.

Grilles installed in horizontal surfaces shall have face bars straight and parallel to short dimension.

Integral extended surface to fit into module of lay-in ceiling shall be provided.

2.19.1.12 Type GCA

Type GCA shall have an individually adjustable, horizontal, curved-blade grille and a one-way pattern.

2.19.1.13 Type GCB

Type GCB shall have an individually adjustable, vertical, curved-blade grille and a one-way pattern.

2.19.1.14 Type GCD

Type GCD shall have an individually adjustable, vertical, curved-blade grille and a two-way pattern.

2.19.1.15 Type GCE

Type GCE shall have an individually adjustable, vertical and horizontal, curved-blade grille and a three-way pattern.

2.19.1.16 Type GCF

Type GCF shall have an individually adjustable, vertical and horizontal, curved-blade grille and a four-way pattern.

2.19.1.17 Type RS

Type RS shall be supply register, double-deflection type, with adjustable face bars parallel to short dimension and adjustable rear bars parallel to long dimension. Dampers shall be opposed-blade type.

Integral extended surface to fit into module of lay-in ceiling shall be provided.

2.19.1.18 Type RR

Type RR shall be return register, single-deflection type, and shall have fixed face bars with opposed-blade dampers.

Registers installed in vertical surfaces shall have horizontal face bars

set downward at approximately 35 degrees from vertical.

Registers installed in horizontal surfaces shall have face bars set straight and parallel to short dimension.

2.19.1.19 Type RCA

Type RCA shall have an individually adjustable, horizontal, curved-blade register and a one-way pattern with opposed-blade damper.

2.19.1.20 Type RCB

Type RCB shall have individually adjustable, vertical, curved-blade register and a one-way pattern with opposed blade damper.

2.19.1.21 Type RCC

Type RCC shall have an individually adjustable, horizontal, curved-blade register and a two-way pattern with opposed blade damper.

2.19.1.22 Type RCD

Type RCD shall have an individually adjustable, vertical, curved-blade register and a two-way pattern with opposed blade damper.

2.19.1.23 Type RCE

Type RCE shall have an individually adjustable, vertical and horizontal, curved-blade register and a three-way pattern with opposed-blade damper.

2.19.1.24 Type RCF

Type RCF shall have an individually adjustable, vertical and horizontal, curved-blade register and a four-way pattern with opposed-blade damper.

2.19.1.25 Type TS

Type TS supply troffer complete assembly shall be provided as indicated in the manufacturer's catalog data. Air handling section of unit shall be installed under this section.

2.19.1.26 Type TR

Type TR return troffer shall conform to requirements for Type TS supply troffer.

2.19.1.27 Type TSR

Type TSR combination supply and return troffer assembly shall be provided as indicated in the manufacturer's catalog data.

2.19.2 Rigid Fibrous-Glass Ductwork

[Rigid fibrous-glass ductwork is not allowed.]

2.20 MIXING BOXES

2.20.1 Dual-Duct Mixing Boxes

Units shall be mechanical constant-volume control type with a mechanical controller that is operated by the entering mixed-airstream and maintains a constant airflow through the unit.

Units shall be manual-damper volume control type. A calibration chart shall be provided with each unit. Each unit shall be labeled with capacity minimum/maximum range to facilitate field adjustment.

2.20.1.1 Construction

Unit shall be factory assembled, complete with casing, air mixing valve assembly, single air mixing valve operator, and mechanical constant-volume control, ready for field mounting and connection to control.

Components subject to friction shall have oil-impregnated bronze bearings, graphite-impregnated or lubricant-impregnated nylon bearings; and lubricant-impregnated elastomers, corrosion-resistant steel, and [____] .

Casing shall be fitted with rigid, airtight access panels, easily removable and of sufficient size to give free access to interior parts. Closure shall be achieved by spring-retained, quarter-turn, slotted-cam captive devices, or similar operating devices that permits unobstructed closure.

2.20.2 Single Duct, Constant Volume, Terminal Reheat Units

Units shall include a casing, volume regulators, sound attenuating thermal insulation, and heating coils.

2.20.2.1 Casing

Unit casings shall be constructed of 1 millimeter aluminum or mill galvanized steel 0.040-inch aluminum or 20-gage mill-galvanized steel and shall contain removable panels for access to interior parts. Units shall be insulated internally with 13 millimeter 1/2-inch thick mineral-fiber thermal and acoustic insulation, conforming to NFPA 90A.

2.20.2.2 Coils

Water coils shall be constructed of not less than 10 millimeter 3/8-inch outside diameter seamless copper tubing with or aluminum-plate fins mechanically bonded or soldered to the tubes, and with not less than 16 millimeter 5/8-inch outside diameter female solder connectors and manual air vent on return. Coils shall be tested at 150 percent of the working pressure.

2.20.2.3 Controls

Reheat output shall be controlled by a room thermostat designed to modulate the water flow in the coil by positioning a three-way valve.

2.20.3 Variable Constant-Volume Boxes

Casing shall be fabricated from galvanized steel and shall have internal thermal and acoustic insulation. Insulation shall be coated to prevent erosion and shall conform to NFPA 90A.

Casing internal leakage shall be limited to 2 percent of nominal box capacity when the internal pressure is 250 pascal 1 inch wg.

Casing shall be fitted with rigid, airtight access panels, easily removable, and of sufficient size to give unobstructed access to interior parts.

2.21 FILTERS

NOTE: Filters shall be in accordance with Section
23 41 13.00 40 PANEL FILTERS.

2.21.1 Filter Gages and Manometers

Air filter gages or manometers shall be provided for each type filter assembly. Gages shall be the dial-indicator type, graduated to read 0 to 500 pascal 0 to 2 inches wg, except that gages for HEPA filters shall read 0 to 750 pascal 0 to 3 inches wg. Manometers shall measure from minus 125 to 750 pascal 0.5 to 3 inches wg and be equipped with a built-in indicator bubble. Connect gage or manometer to static-pressure ports and install in a location so that resistance to airflow will be correctly indicated.

Static-submit pressure ports prior to installation and fabrication.

PART 3 EXECUTION

3.1 INSTALLATION

Install materials and equipment in accordance with the requirements of the contract drawings and recommendations of the manufacturer. Installation shall be accomplished by workers skilled in this type of work. Installation shall be so made that there is no degradation of the designed fire ratings of walls, partitions, ceilings, and floors. Emergency switches and alarms shall be installed in conspicuous locations.

Manufacturer's Installation Instructions shall be submitted indicating the manufacturer's recommended method and sequence of installation for HVAC systems.

Installation drawings shall be installed in accordance with referenced standards in this section. Drawings shall show details of equipment room layout and design.

Pipe valves and specialties shall be installed in accordance with manufacturer's recommendations and in accordance with paragraphs entitled, "Steel Pipe," "Valves," and "Refrigeration Specialties."

3.2 CLEANING

Exposed surfaces of piping and equipment that have become covered with dirt, plaster, or other material during handling and construction shall be thoroughly cleaned before such surfaces are prepared for final finish painting or are enclosed within the building structure.

Before final acceptance, mechanical equipment, including piping, ducting, and fixtures, shall be clean and free from dirt, grease, and fingermarks.

3.3 INSULATION SYSTEMS

Insulation and system components shall be installed per the manufacture's instructions.

Workmanship shall reflect the best current practices in the trade.
Contours on exposed work shall be smooth and continuous.

3.3.1 Refrigerant and Cold Water Suction Piping

Insulation shall be cellular-elastomer (Type T-3). Thickness shall be nominal 19 millimeter 3/4 inch. Surfaces, including valve, fittings, unions, and flanges, shall be insulated.

3.3.2 Chilled Water, Hot-Water, and Condensate-Return Piping

Insulation shall be cellular glass with PVC jacket. Thickness shall be not less than that given in the following list. Aboveground pipes, valve bodies, fittings, unions, flanges, and miscellaneous surfaces shall be insulated.

<u>PIPE SIZES (DN)</u> <u>DIAMETER NOMINAL</u>	<u>INSULATION THICKNESS</u> <u>MILLIMETER</u>
Up to 100	40
100 to 200	50
200 and over	65

<u>PIPE SIZES</u> <u>(INCHES)</u>	<u>INSULATION THICKNESS</u> <u>(INCHES)</u>
Up to 4	1-1/2
4 to 8	2
8 and over	2-1/2

3.3.3 Chilled-Water and Dual-Temperature Pumps

Insulation shall be cellular elastomer Type T-9. Thickness shall be 25 millimeter 1 inch. Surfaces subject to condensation shall be covered, and a vapor-barrier coating shall be supplied.

3.4 BOILERS

Boilers shall be installed and tested in accordance with manufacturer's recommendations.

3.5 AIR HANDLING UNITS

3.5.1 Installation

Coils shall be installed in accordance with the manufacturer's recommendations. Dampers shall be set in a fixed position to provide the outside air quantity scheduled.

Floor drains shall be provided where indicated in the equipment room layout drawings. Drain line shall be not less than **DN50 2 inches**.

3.5.2 Enclosure Test

Services of a competent, factory-trained manufacturer's representative shall be provided to supervise assembly, inspection, and testing of the enclosure.

Enclosure rigidity shall be tested by starting and stopping fans. No audible enclosure popping noise, deflection, or deformation in excess of specified limits shall result.

3.6 DUCTWORK

3.6.1 Installation

Sheetmetal construction shall be provided in accordance with the recommendations for best practices in **ASHRAE-05**, **ASHRAE-07**, **SMACNA 1481** and **NFPA 90A**.

Where construction methods for certain items are not indicated or described in the referenced standards or herein, the work shall be performed in accordance with **ASHRAE-04**.

Supplementary steel shall be designed and fabricated in accordance with **AISI SG-03-2** and **AISC/AISI 121**.

3.6.2 Openings in Roofs and Walls

Building openings are fixed as indicated in the equipment room layout drawings and equipment shall be provided to suit. Contractor may propose to alter these openings upon prior approval by the Contracting Officer and at his expense.

Openings indicated in outside walls and roof are approximate. Within [_____] calendar days after the award of contract, detail drawings showing exact opening dimensions and location of the equipment shall be submitted to the Contracting Officer for approval.

3.6.3 Ductwork Cleaning Provisions

Open ducting shall be protected from construction dust and debris in a manner approved by the Contracting Officer. Dirty assembled ducting shall be cleaned by subjecting main and branch interior surfaces to air streams moving at velocities two times the specified working velocities, at static pressures within maximum ratings. This may be done with filter-equipped, wheel mounted, portable blowers; compressed-air operated perimeter lances that direct the compressed air and which are pulled in the direction of normal air flow; or other means approved by the Contracting Officer. Compressed air used for cleaning ducting shall be water- and oil-free. Prior to acceptance, dust and debris shall be removed from exterior surfaces.

3.6.4 Fire Damper Tests

Operation tests shall be performed on each fire damper in the presence of the Contracting Officer by activating fusible link with localized heat. New links shall be provided and installed after successful testing.

3.7 FILTERS

Filter supports and retention elements shall be coordinated to provide a substantial, structurally sound, leakproof installation. Filter arrangements shall be as indicated in the manufacturer's catalog data.

Holding frames shall be gasketed on perimeter, or calked to each other, to supplementary steel, or to closures with elastomeric compounds recommended by the filter manufacturer. Substrate shall be prepared in accordance with the elastomer manufacturer's instructions, including the priming of surfaces in areas where the elastomer is not confined.

3.8 CONTROLS

3.8.1 Installation

Installation of control components shall be done by Contractor-certified control and instrumentation specialists or factory representatives.

Installation shall conform to the published or written instructions of the manufacturer.

Tubing shall be concealed, except in mechanical rooms or areas where other piping is exposed.

Multiple tube runs shall be neatly nested.

3.8.2 Mechanical Refrigeration Air Dryer Installation

Wall mounting shall be through rubber-in-shear mounts. Dryer shall be connected to air compressor outlet with pressure regulator installed downstream of dryer.

To prevent vibration, controllers shall be isolated by location or by mounting devices.

3.8.3 Testing, Calibration, and Acceptance

After completion of control and instrument piping, control equipment shall be tested and adjusted in terms of design, function, systems balance, and performance, and shall otherwise be made ready for air handling systems acceptance tests. Data showing set points and final adjustments of controls shall be provided.

3.8.4 Operating Instructions and Operator Training

NOTE: Insert required number of hours.

Six copies of written operating maintenance instructions and not less than [_____] hours of operator training shall be provided.

3.9 AIR-HANDLING SYSTEMS TESTING

**NOTE: The Systems Engineer/Condition Monitoring
Office/Predictive Testing Group should inspect the**

installation during acceptance testing using advanced monitoring technologies such as Infrared Imaging or Ultrasonic Listening. These technologies can identify insulation voids, insulation settling, and system/pressure/vacuum leaks.

Pressure tests shall be performed prior to insulation of surfaces, painting, and concealment of work.

3.9.1 Low-Velocity Duct Systems

Portions of systems as selected shall be inspected by the Contracting Officer and tested to positive or negative pressures, or both, whichever is normal to the portion of system under test, to verify the following:

There are no visible mechanical defects.

There is no audible leakage at any point when area ambient noise is at normal-occupancy level.

No leakage is perceptible to the hand, when placed within 150 millimeter 6 inches of a joint.

3.9.2 High-Velocity Duct Systems

High-velocity, high, and medium pressure systems shall be structurally tested at static pressures 50 percent in excess of total fan pressure. Leakage testing shall be at a pressure 25 percent higher than normal operating pressure, and in dual duct systems at maximum pressure at mixing box, when inlet valve is shut off. System will be acceptable provided:

There are no visible mechanical defects.

Measured total system leakage does not exceed 0.5 percent of total system cubic meter per second cfm capacity.

There is no audible leakage at any point when area ambient noise is at normal-occupancy level.

3.9.3 Test Apparatus and Procedures

Test apparatus and procedures shall be similar in all respects to that defined in ASHRAE-05, ASHRAE-07 and SMACNA 221. Filtered blower inlet and automatic safety relief device shall be provided to protect system. Accuracy of measurement of leakage flow rate shall be certified to be within 2 percent of total leakage flow.

3.10 REFRIGERATION SYSTEMS TESTING

NOTE: The Systems Engineer/Condition Monitoring Office/Predictive Testing Group should inspect the installation during acceptance testing using advanced monitoring technologies such as Infrared Imaging or Ultrasonic Listening. These technologies can identify insulation voids, insulation settling, and system/pressure/vacuum leaks.

Pressure, vacuum, structural-integrity, and leakage tests shall be applied to all systems and shall be conducted in accordance with the provisions of Paragraph 537 of ASHRAE-04, Chapter 35, ASHRAE-08 and ASME B31.5 except Subparagraphs 537.5, and as modified and supplemented herein.

Systems shall be tested in the presence of the Contracting Officer.

Tests shall be performed prior to insulation of surfaces, painting, and concealment of work.

Factory-sealed refrigeration equipment assemblies shall be kept isolated from field-installed piping until final acceptance of high-vacuum test.

Brazed and mechanical joints that fail structural or leakage tests shall be disassembled, cleaned, and remade.

After repairs have been made, tests shall be repeated until satisfactory results are obtained.

3.10.1 Pressure Testing

Pressure tests shall be conducted with a composite gas consisting of dry nitrogen and the refrigerant that will be used in the system being tested.

0.6 kilogram per wattOne-quarter pound per ton of refrigerant shall be used for R-22 systems.

Final test pressure shall be held for not less than 12 hours. There shall be no readable drop in pressure at the end of the test period. Correction of 2.1 kilopascal0.3 psi will be allowed for each degree of change between initial and final temperature, plus for an increase in temperature and minus for a decrease.

3.10.2 Vacuum Testing

After a successful pressure test, each system shall be connected to a high-vacuum pump capable of reducing absolute pressure in the system to a point where any water present will vaporize at a temperature appreciably below ambient temperature, and will be withdrawn from the system. The system shall be evacuated twice to a vacuum of 2.5 millimeters of mercury (mm Hg), absolute. First vacuum shall be held for not less than 1 hour and then broken with dry nitrogen. Second vacuum shall be held for not less than 6 hours at an ambient temperature of 4 degrees C 40 degrees F or more. With the system isolated at 2.5 mm Hg vacuum, the pressure shall not increase noticeably.

3.10.3 Operating Test

After repairs have been made and tests completed, sealed equipment valves shall be opened, and system shall be charged with refrigerant and lubricant, if necessary. Compressor may then be operated per manufacturers instructions.

For the first 8 hours of operation under load, each system shall be operated with the refrigerant dryers in the circuit. If the sight glass or moisture indicator reveals moisture in the system, dryer cartridges shall be replaced and the operation shall be repeated. This procedure shall be followed until there is no indication of moisture in the system. Dryer cartridges shall be replaced and the dryers shall be bypassed. Oil levels

shall be checked frequently and oil added only from sealed cans furnished by the compressor manufacturer.

If there is excessive hot-gas pulsation during operation, mufflers with not more than 7 kilopascal 1 psi drop at design conditions shall be provided. After installation of mufflers, steps necessary to bring system to specified operating condition shall be repeated.

3.11 AIR AND HYDRONIC SYSTEMS TESTING, AND ADJUSTMENT

NOTE: The Systems Engineer/Condition Monitoring Office/Predictive Testing Group should inspect the installation during acceptance testing using advanced monitoring technologies such as Infrared Imaging or Ultrasonic Listening. These technologies can identify insulation voids, insulation settling, and system/pressure/vacuum leaks.

NOTE: Variable pitch sheaves should only be used for system balance and adjustment purposes. After balance is determined they should be replaced with fixed sheaves.

[Operational balancing and adjustment of air-handling and hydronic systems shall be performed under the direction of an independent balancing agency whose field representative is a registered professional engineer. Work shall be done in accordance with ASHRAE-07, ASHRAE-05, Chapter 12 and Chapter 50 ASHRAE-06, Chapter 1, AABC MN-1 or SMACNA 221, where applicable, the requirements of the contract documents, and in the presence of the Contracting Officer.]

[Operational balancing and adjustment of air-handling and hydronic systems shall be done in accordance with ASHRAE-05, ASHRAE-07 and SMACNA 221, the requirements of the contract documents, and in the presence of the Contracting Officer.]

3.11.1 Air-Handling Systems

Final volume conditions for all systems shall be within plus or minus 5 percent of the conditions indicated on contract drawings.

Balancing and adjustment apparatus, procedures and test report shall be in accordance with Section II of ASHRAE-07, ASHRAE-05, Chapter 12 and Chapter 50 ASHRAE-06, Chapter 1, AABC MN-1 or SMACNA 221.

3.11.2 Hydronic Systems

3.11.2.1 Balancing, Adjustment, and Acceptance

Systems final flow conditions shall be within plus or minus 5 percent of conditions indicated on contract drawings.

Complete air balance shall have been accomplished before water balance begins.

3.11.2.2 Hydronic Systems Preparation

Hydronic systems shall be tested at 125 percent of rated pressure.

All valves shall be opened to full-open position, including coil-stop valves, bypass valves, and return-line balancing cocks.

Check rotation of pumps after obtaining approval by the Contracting Officer.

Expansion tanks shall be checked to determine that they are not air-bound and that system is full of water.

3.11.3 Adjustment and Acceptance Criteria

After balance and adjustment operations have been completed, the system shall be tested as a whole to verify that all items perform as an integral part of the system and that temperature and conditions are evenly controlled. Corrections and adjustment shall be made as necessary to produce the required specifications.

3.11.4 Test Report

Operational test reports shall be provided on systems tested. Test report format shall be approved by the Contracting Officer.

3.12 STEAM AND CONDENSATE SYSTEMS TESTING

NOTE: The Systems Engineer/Condition Monitoring Office/Predictive Testing Group should inspect the installation during acceptance testing using advanced monitoring technologies such as Infrared Imaging or Ultrasonic Listening. These technologies can identify insulation voids, insulation settling, and system/pressure/vacuum leaks.

Prior to acceptance of the work, completed systems shall be tested in the presence of the Contracting Officer.

System shall be subjected to pressure tests to determine structural integrity, and to operational and cyclic tests, as necessary, to determine that system functions and operates as required.

After pressure tests and cleaning operations have been satisfactorily completed, system components shall be adjusted for proper operation within the design and operating characteristics published by the component manufacturer. In addition to requiring the services of an authorized representative of the manufacturer, the Government reserves the right to require the services of an authorized representative of a component manufacturer if the Contractor is unable to adjust a component. The Contractor shall arrange for such services at no additional cost to the Government.

3.12.1 Test Duration

Duration of a test will be determined by the Contracting Officer.

A pressure test shall be held for a minimum of 2 hours and a maximum of 24 hours.

Test may be terminated by the Contracting Officer at any time after it has been determined that the system meets specified requirements.

3.12.2 Test Gages

Contractor's test gages shall conform to ASME B40.100 and shall have a current calibration certification.

3.12.3 Acceptance Pressure Testing

Testing shall take place during steady-state ambient temperature conditions.

Tests shall be hydrostatic unless otherwise specified or approved by the Contracting Officer.

Systems shall be tested at 1-1/2 times primary wsp rating of system components, and the applied pressure shall be maintained. System shall be monitored for a minimum of 1 hour in the presence of the Contracting Officer to detect any leakage.

Components that could be damaged by shock or test pressure shall be removed from piping systems prior to hydrostatic testing.

Movement limiting provisions shall be used to protect expansion joints against overextension from system pressures.

Piping system components, such as valves, shall be checked for functional operation under system test pressure.

3.12.4 Operational Testing

System shall be cycled three times, from start to operating thermal conditions, to verify adequacy of construction, system controls, and component performance.

3.12.5 Test Records

Contractor shall prepare and maintain test records of systems tests. Records shall show test-personnel responsibilities, dates, test gage identification numbers, ambient and test temperatures, pressure ranges, rates of pressure drop, leakage rates, and other system Characteristics.

3.13 ROTATING MACHINERY

3.13.1 Alignment

Before attempting alignment, the contractor will demonstrate that the pump/compressor/fan does not have any load/force imposed by the piping/duct system. Minimum alignment values (below) are for pump and driver at normal running temperatures. Values must be compensated for thermal growth. Limited movement of the pump compressor/fan or driver (commonly known as bolt-bound) must be corrected to ensure alignment capability. Hold down bolts shall not be undercut in order to perform adjustment.

Shims shall be commercially die-cut, without seams or folds, and be made of corrosion resistant stainless steel. No more than four shims shall be

used at any single point.

Units with drive motor over [7.5] [10] [15] [20] [25] ph shall have alignment jack bolts installed.

Direct drive pumps/compressors may have an intermediate shaft, spacer, or spool piece (sometimes called a jackshaft) Based on the motor nominal operating speed, the Pump/compressor and driver shall be aligned to the following minimum specifications:

Speed (RPM)	close-coupled offset (mils)	close-coupled angle(mils/in.)	spool piece angle (mils/in. @ coupling apt.)
600	6.0	2.0	3.0
900	5.0	1.5	2.0
1200	4.0	1.0	1.5
1800	3.0	0.5	1.0
3600	1.5	0.4	0.5
7200	1.0	0.3	0.4

[Pump alignment shall be performed under the direction of the manufacturer's representative.]

Final alignment settings shall be provided as part of the final test data.

3.13.2 Vibration Analyzer

Contractor shall use an Fast Fourier Transformer (FFT) analyzer to measure vibration levels. It shall have the following characteristics: A dynamic range greater than 70 dB; a minimum of 400 line resolution; a frequency response range of 5 Hz-10 KHz(300-600000 cpm); the capacity to perform ensemble averaging, the capability to use a Hanning window; auto-ranging frequency amplitude; a minimum amplitude accuracy over the selected frequency range of plus or minus 20 percent or plus or minus 1.5 dB.

An accelerometer, either stud-mounted or mounted using a rare earth, low mass magnet and sound disk(or finished surface) shall be used with the Fast Fourier Transformer (FFT)analyzer to collect data. The mass of the accelerometer and its mounting shall have minimal influence on the frequency response of the system over the selected measurement range.

3.13.3 Acceptance Tests

Prior to final acceptance, dial indicator gages shall be used to demonstrate that pump/compressor/fan and motor are aligned as specified and that the pump/compressor casings are entirely free of any piping loads.

Prior to final acceptance, vibration analysis shall verify pump/compressor/fan conformance to specifications. Vibration levels shall not be more than .075 in/sec at 1 times run speed and at pump frequency, and .04 in/sec at other multiples of run speed. Vibration data shall be provided as part of the final test data.

3.13.4 Test Records

Contractor shall prepare and maintain test records of systems tests. Records shall show test-personnel responsibilities, dates, test gage identification numbers, ambient and test temperatures, pressure ranges, rates of pressure drop, leakage rates, and other system Characteristics.

Final test reports shall be provided to the Contracting Officer. Reports shall have a cover letter/sheet clearly marked with the System name, Date, and the words "Final Test Reports - Forward to the Systems Engineer/Condition Monitoring Office/Predictive Testing Group for inclusion in the Maintenance Database."

3.14 OPERATION AND MAINTENANCE

Contractor shall submit [6] [_____] copies of the [Operation and Maintenance Manuals](#) 30 calendar days prior to testing the system involved. Data shall be updated and resubmitted for final approval no later than 30 calendar days prior to contract completion.

Operation and Maintenance Manuals shall be consistent with manufacturer's standard brochures, schematics, printed instructions, general operating procedures, and safety precautions. Test data shall be legible and of good quality.

-- End of Section --