
USACE / NAVFAC / AFCEA / NASA UFGS-26 24 16.00 40 (November 2008)

Preparing Activity: NASA Superseding
UFGS-26 24 16.00 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2009

SECTION TABLE OF CONTENTS

DIVISION 26 - ELECTRICAL

SECTION 26 24 16.00 40

PANELBOARDS

11/08

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 GENERAL REQUIREMENTS
- 1.3 SUBMITTALS

PART 2 PRODUCTS

- 2.1 PANELBOARDS
- 2.2 CIRCUIT BREAKERS
- 2.3 DIRECTORY CARD AND HOLDER
- 2.4 FILTERED PANELBOARDS
 - 2.4.1 General
 - 2.4.2 RF Shielding
 - 2.4.3 Circuit Breaker Actuators
 - 2.4.4 Terminals
 - 2.4.5 Attenuation
 - 2.4.6 Current
 - 2.4.7 Voltage
 - 2.4.8 Circuit Breakers
 - 2.4.9 RF Filters
 - 2.4.10 Filter Discharge Unit
- 2.5 FACTORY TESTING
- 2.6 PRECAUTIONARY LABEL

PART 3 EXECUTION

- 3.1 INSTALLATION
- 3.2 SITE TESTING

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-26 24 16.00 40 (November 2008)

Preparing Activity: NASA Superseding
UFGS-26 24 16.00 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2009

SECTION 26 24 16.00 40

PANELBOARDS

11/08

NOTE: This guide specification covers the requirements for power-distribution panelboards and lighting and appliance branch-circuit panelboards.

Drawings must indicate the ampere rating of panelboards, the number of bus bars, and the voltage characteristics of the system to which they are to be connected. Frame size, trip rating, number of poles, and class of molded-case branch-circuit breakers must be indicated. Interrupting rating must be shown for power distribution panelboards and for lighting and appliance branch-circuit panelboards if the latter have an interrupting rating of more than 10,000 amperes rms symmetrical.

Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide

specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ELECTRONIC INDUSTRIES ALLIANCE (EIA)

EIA 416 (1974; R 1981) Standard for Filters, for Radio Interference

EIA 46 (1987) Test Procedure for Resistance to Soldering (Vapor Phase Technique) for Surface Mount Devices

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA 250 (2008) Enclosures for Electrical Equipment (1000 Volts Maximum)

NEMA AB 1 (2002) Molded-Case Circuit Breakers, Molded Case Switches, and Circuit-Breaker Enclosures

NEMA PB 1 (2006; Errata 2008) Standard for Panelboards

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2008; AMD 1 2008) National Electrical Code - 2008 Edition

U.S. DEPARTMENT OF DEFENSE (DOD)

MIL-HDBK 232 (Rev A) Red/Black Engineering Installation Guidelines

U.S. GENERAL SERVICES ADMINISTRATION (GSA)

FED-STD-595 (Rev B; Am 1) Colors Used in Government Procurement

1.2 GENERAL REQUIREMENTS

NOTE: If Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS is not included in the project specification, applicable requirements therefrom should be inserted and the following paragraph deleted.

Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS applies to work specified in this section.

Submit [Detail Drawings](#) for the panelboards consisting of fabrication and assembly drawings for all parts of the work in sufficient detail to enable the Government to check conformity with the requirements of the contract documents. Include within drawings details of bus layout.

Ensure [Outline Drawings](#) for panelboards indicate overall physical features, dimensions, ratings, service requirements, and weights of equipment.

[Statements](#) signed by responsible officials of a manufacturer of a product, system, or material attesting that the product, system or material meet specified requirements. Statements must be dated after the award of this contract, name the project, and list the specific requirements which it is intended to address.

1.3 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes

following the "G" typically are not used for Navy,
Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force
and NASA projects, or choose the second bracketed
item for Army projects.

Government approval is required for submittals with a "G" designation;
submittals not having a "G" designation are [for Contractor Quality Control
approval.][for information only. When used, a designation following the
"G" designation identifies the office that will review the submittal for
the Government.] Submit the following in accordance with Section 01 33 00
SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Submit [Detail Drawings](#) and [Outline Drawings](#) for panelboards in
accordance with paragraph entitled, "General Requirements," of
this section.

SD-03 Product Data

Submit Manufacturer's catalog data for the following items:

[Panelboards](#)
[Directory Card and Holder](#)
[Filtered Panelboard](#)

SD-04 Samples

Ensure that [keys](#) are properly tagged and delivered to the
Contracting Officer.

SD-06 Test Reports

Submit test reports for the following tests in accordance with the
paragraph entitled, "Site Testing," of this section. Do not
energize panelboards until the recorded test data has been
submitted to and approved by the Contracting Officer.

[Continuity Tests](#)
[Insulation Tests](#)

SD-07 Certificates

Submit [Statements](#) in accordance with paragraph entitled, "General
Requirements," of this section.

SD-08 Manufacturer's Instructions

Submit Manufacturer's instructions for [Panelboards](#) including
special provisions required to install equipment components and
system packages. Special notices shall detail impedances, hazards
and safety precautions.

PART 2 PRODUCTS

2.1 PANELBOARDS

Totally enclose power-distribution panelboards and lighting and appliance branch-circuit panelboards in a steel cabinet, dead-front circuit breaker type with copper buses, surface- or flush-mounted as indicated. Ensure panelboards conform to NEMA PB 1 and NEMA AB 1. Branch circuit panels shall have buses fabricated for bolt-on type circuit breakers.

An outer door or cover, hinged on one side, shall be provided on surface-mounted panelboards to provide gutter space access. Provide a center door for circuit breaker/switch access only.

Voltage and current rating, number of phases, and number of wires shall be as indicated. Provide four-wire distribution panelboards and lighting and appliance branch-circuit panelboards with an isolated full-capacity neutral bus. Ensure panelboards are rated for [240-volt (maximum), single-phase] [120/208-volt, three-phase] [277/480-volt, three-phase], 60-hertz current.

Provide three-phase, 4-wire and single-phase, 3-wire distribution lighting and branch circuit panelboards with an isolated full-capacity bus providing spaces for single-pole circuit breakers/switches and spaces indicated as spare.

Provide panelboards with a separate grounding bus bonded to the enclosure. Grounding bus shall be a solid bus bar of rectangular cross section equipped with binding screws for the connection of equipment grounding conductors.

Each panelboard, as a complete unit, shall have a short-circuit current rating equal to or greater than the integrated equipment rating shown on the panelboard schedule or as indicated.

Ensure panelboards and main lugs or main breaker have current ratings as shown on the panelboard schedule.

Bus bar connections to the branch circuit breakers shall be the "distributed phase" or "phase sequence" type. Single-phase, three-wire panelboard busing shall be such that when any two adjacent single-pole breakers are connected to opposite phases, two-pole breakers can be installed in any location. Three-phase, four-wire busing shall be such that when any three adjacent single-pole breakers are individually connected to each of the three different phases, two- or three-pole breakers can be installed at any location. Current-carrying parts of the bus assembly shall be plated. Mains ratings shall be as shown.

Mechanical lugs furnished with panelboards shall be cast copper or copper alloys of sizes suitable for the conductors indicated to be connected thereto.

[Boxes shall have the manufacturer's standard knockouts and shall be galvanized code-gage sheet steel. Fronts shall be of code-gage sheet steel furnished with hinged doors with adjustable trim clamps for securing the fronts to the boxes.]

[Panelboard box shall be [galvanized] [rust-resistant] code-gage sheet steel without knockouts. Ensure entire panelboard front is hinged on one side with a piano hinge for the full height and has captive screws opposite

the hinged side. Where panelboards are installed flush with the walls, the installation details shall be such that the hinged front can be opened without damage to the adjacent wall surfaces. Ensure that the color of the finished coat of trim and front matches the adjacent walls except when the box is installed in electrical closets or equipment rooms, the gray finish as specified is acceptable.]

Panelboard enclosures shall be NEMA 250, Type 1. Provide enclosures with hinged fronts and corrosion-resistant steel pin-tumbler cylinder locks. Key locks alike and provide two keys for each enclosure.

Finish panelboards with [baked] [fast drying] enamel. Finish color is to be No. 61 gray conforming to FED-STD-595.

2.2 CIRCUIT BREAKERS

NOTE: Include Section 26 05 70.00 40 HIGH-VOLTAGE
OVERCURRENT PROTECTIVE DEVICES and Section
26 05 71.00 40 LOW-VOLTAGE OVERCURRENT PROTECTIVE
DEVICES in the project specification or include the
requirements herein.

Circuit breakers shall be the molded-case type as specified in Section 26 05 70.00 40 HIGH-VOLTAGE OVERCURRENT PROTECTIVE DEVICES and Section 26 05 71.00 40 LOW-VOLTAGE OVERCORRECT PROTECTIVE DEVICES. Frame and trip ratings shall be as indicated.

Interrupting rating of circuit breakers shall be as indicated. If not shown, the interrupting rating for circuit breakers in [120/208] [_____] -volt panelboards shall be not less than [10,000] [_____] amperes rms symmetrical, and that for breakers in [277/480] [_____] -volt panelboards shall be not less than [25,000] [_____] amperes rms symmetrical.

Circuit breakers shall be bolt-on type. Plug-in type is not acceptable.

Provide shunt trips where indicated.

In branch circuit panelboards, branch circuit breakers feeding convenience outlets shall have sensitive instantaneous trip settings of not more than [10] [_____] times the trip rating of the breaker to prevent repeated arcing shorts resulting from frayed appliance cords. Single-pole 15- and 20-ampere circuit breakers shall be UL listed as "Switching Breakers" at [120 volts ac] [277 volts ac]. Provide UL Class A (5-milliampere sensitivity) ground fault circuit protection on 120-volt ac branch circuit as indicated. This protection is an integral part of the branch circuit breaker that also provides overload and short-circuit protection for branch circuit wiring. Tripping of a branch circuit breaker containing ground fault circuit interruption is not to disturb the feeder circuit to the panelboard. A single-pole circuit breaker with integral ground fault circuit interruption requires no more panelboard branch circuit space than a conventional slide pole circuit breaker.

Ensure connections to the bus are bolt-on type.

When multiple wires per phase are specified, furnish the circuit breakers with connectors made to accommodate multiple wires.

Ensure circuit breaker spaces called out on the drawings are complete with mounting hardware to permit ready installation of the circuit breakers.

2.3 DIRECTORY CARD AND HOLDER

Mount a directory card on the inside of hinged fronts and doors [under glass][0.76 millimeter 0.030-inch thick minimum plastic] in a metal frame, with spaces for circuit numbers, outlets controlled, and room numbers. Where hinged fronts or doors are not required, provide the directory card [under glass][0.76 millimeter 0.030-inch thick minimum plastic] in a metal frame mounted on the left-hand side of the front trim. Directory card shall identify each branch circuit with its respective and numbered circuit breaker.

2.4 FILTERED PANELBOARDS

2.4.1 General

Design panelboards for the distribution, control, and protection of electrical circuits, providing filtering and shielding performance and, when specified, conforming to MIL-HDBK 232. (Portions of MIL-HDBK 232 are classified and will be available only on classified projects to approved companies and individuals.)

Panelboard cabinet shall be [2.7] millimeter [12]-gauge [____] steel minimum, with corrosion-resistant finish and four external mounting brackets welded to the case. Front door and trim shall be of code gage steel, with gray finish, equipped with directory, holder, adjustable trim clamps, hinges, self-latching catch, tumbler lock and key and shall bear the UL label. Provide a red diagonal strip across the outside surface of door and trim.

2.4.2 RF Shielding

Ensure circuit breaker and filter compartments are completely radio-frequency (RF) shielded and in compliance with specified shielding requirements with front door open. Case seams shall be continuous inert gas welded. Fit removable circuit breaker actuator faceplate and the filter compartment cover with corrosion-resistant RF gasketing material and install in place with suitable fasteners having a maximum spacing of [75] millimeter [3] inches [____] on center. Mount RF filter units to the internal shield wall with similar RF gasketing to ensure RF shielding integrity.

2.4.3 Circuit Breaker Actuators

Design circuit breaker operating mechanisms to maintain RF shielding effectiveness without limit to time or number of operations.

2.4.4 Terminals

Filter terminals shall be of high-temperature alumina ceramic, continuously brazed to filter case. Do not use soft solder. Ceramic terminal shall incorporate a permanently attached flexible lead, with a suitable electric lug. Incoming service connections shall be made to the filter lead at a UL-approved, flame-retardant standoff insulator, mounted in the filter compartment.

2.4.5 Attenuation

Ensure each filter provides a minimum insertion loss of [100] [_____]dB over the frequency range of [14 kilohertz (kHz) to 10 gigahertz (GHz)] [_____] . Full rated load insertion loss of [100] [_____]dB in the frequency range [14 kHz to 20 megahertz (MHz)], to [14] [_____]kHz shall be measured by a Government-approved laboratory.

2.4.6 Current

Each filter unit shall be capable of carrying its full rated current continuously without heat rise exceeding[50 degrees C 122 degrees F] [_____] above ambient temperature. Each filter shall be capable of withstanding a [100] [_____] -percent overload for [30] [_____] seconds without damage.

2.4.7 Voltage

Each filter unit shall be capable of continuous operation at its full rated voltage and withstanding an initial voltage test of twice its rated voltage without damage.

2.4.8 Circuit Breakers

Ensure circuit breakers are rated a minimum 10,000 amperes asymmetrical ac interrupting capacity, 5,000 amperes dc, and are in accordance with NEMA AB 1.

2.4.9 RF Filters

Design RF filter units to suppress and reduce the amplitude of undesired RF energy conducted by power service lines. Design RF filter units in compliance with the applicable requirements of EIA 416.

Filter cases shall be made of steel, 1.6 millimeter [16]-gauge [_____] minimum, corrosion-resistant finish with a blue lacquer over zinc chromate primer. Conductive grounding surfaces shall be either plated or made of corrosion-resistant steel. Hermetic seams are to be continuous inert gas welded; do not use soft solder. Firmly mount internal components to withstand applicable shock and vibration test requirements without damage.

Fluid impregnant shall conform to UL nonflammable classification. Internal components shall be fully impregnated and intimately immersed in the fluid to obtain the full benefit of cooling by convection flow through the liquid medium to filter case. Completely fill filter case with the fluid impregnant.

2.4.10 Filter Discharge Unit

Install a filter discharge unit for three-filtered circuits on the panelboard. Unit shall meet applicable requirements of EIA 46, and be installed in accordance with NFPA 70.

2.5 FACTORY TESTING

Test complete panelboards in accordance with UL 67.

2.6 PRECAUTIONARY LABEL

To ensure persons are aware of immediate or potential hazard in the application, installation, use, or maintenance of panelboards, each panelboard shall be conspicuously marked on the trim or dead front shield with the text (or equivalent) **DANGER** symbol. If the panel is supplied with a door, ensure the label is visible when the door is in the open position.

PART 3 EXECUTION

3.1 INSTALLATION

Install panelboards as indicated and in accordance with the manufacturer's instructions. Fully align and mount panels so that the height of the top operating handle does not exceed 1800 millimeter [72]-inches [_____] above the finished floor.

Directory-card information shall be typewritten in capital letters to indicate outlets controlled and final room numbers served by each circuit and shall be mounted in holders behind protective covering.

3.2 SITE TESTING

Each panelboard enclosure key shall be shown to operate the enclosure locks in the presence of the Contracting Officer.

Panelboards shall be given continuity and insulation tests after the installation has been completed and before the panelboard is energized.

Provide test equipment, labor, and personnel as required to perform the tests as specified. Conduct Continuity tests using a dc device with [bell] [buzzer] [_____].

Conduct insulation tests on 480-volt panelboards using a 1,000-volt insulation-resistance test set. Record readings every minute until three equal and consecutive readings have been obtained. Resistance between phase conductors and between phase conductors and ground shall be not less than 50 megohms.

Conduct insulation tests on panelboards rated 300 volts or less using a 500-volt minimum insulation-resistance test set. Record readings after 1 minute and until the reading is constant for 15 seconds. Resistance between phase conductors and between phase conductors and ground shall be not less than 25 megohms.

Record test data and include the location and identification of panelboards and megohm readings versus time.

-- End of Section --