

\*\*\*\*\*  
USACE / NAVFAC / AFCEA / NASA UFGS-23 37 13.00 40 (May 2010)  
-----  
Preparing Activity: NASA Superseding  
UFGS-23 37 13 (August 2008)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2010

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 23 - HEATING, VENTILATING, AND AIR CONDITIONING

#### SECTION 23 37 13.00 40

#### DIFFUSERS, REGISTERS, AND GRILLS

05/10

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 GENERAL REQUIREMENTS
- 1.3 PERFORMANCE REQUIREMENTS
- 1.4 SUBMITTALS

#### PART 2 PRODUCTS

- 2.1 AIR-DIFFUSION DEVICE CONSTRUCTION
- 2.2 TYPES OF AIR-DIFFUSION DEVICES
  - 2.2.1 Type DRA
  - 2.2.2 Type DRB
  - 2.2.3 Type DRC
  - 2.2.4 Type DRE
  - 2.2.5 Type DRH
  - 2.2.6 Type DP Series
  - 2.2.7 Type DLB
  - 2.2.8 Type DLS
  - 2.2.9 Type DSA
  - 2.2.10 Type GS
  - 2.2.11 Type GR
  - 2.2.12 Type GCA
  - 2.2.13 Type GCB
  - 2.2.14 Type GCD
  - 2.2.15 Type GCE
  - 2.2.16 Type GCF
  - 2.2.17 Type RS
  - 2.2.18 Type RR
  - 2.2.19 Type RCA
  - 2.2.20 Type RCB
  - 2.2.21 Type RCC
  - 2.2.22 Type RCD
  - 2.2.23 Type RCE
  - 2.2.24 Type RCF
  - 2.2.25 Type TS

2.2.26 Type TR  
2.2.27 Type TSR

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 Operations and Maintenance Manuals

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEA / NASA UFGS-23 37 13.00 40 (May 2010)  
-----  
Preparing Activity: NASA Superseding  
UFGS-23 37 13 (August 2008)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2010

\*\*\*\*\*

### SECTION 23 37 13.00 40

#### DIFFUSERS, REGISTERS, AND GRILLS 05/10

\*\*\*\*\*

NOTE: This specification covers the requirements for air-diffusion devices that are connected to ductwork or mounted in equipment], except as otherwise provided.

Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

#### PART 1 GENERAL

\*\*\*\*\*

NOTE: Identify air-diffusion devices on the drawings with symbols provided. Where deviations from standards occur, devise a new symbol within the format used herein.

Natural aluminum diffusers are unprotected unless specified to be furnished with clear acrylic or anodizing finishes. Normally, aluminum diffusers specified without further qualification are supplied with factory baked enamel finish. Steel diffusers and grills should be specified with a factory baked enamel finish.

Show type of DLB frame, bar spacing if other than specified, bar deflection, blanking if any, and type of damper on drawings.

Show frame style, width, and screw or clip fastening on drawings.

Show linear slot width and number of slots, if other than specified on drawings.

\*\*\*\*\*

## 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS (ASHRAE)

ASHRAE 113	(2009) Method of Testing for Room Air Diffusion
ASHRAE EQUIP IP HDBK	(2008; Errata 1 2010) Handbook, HVAC Systems and Equipment (IP Edition)
ASHRAE EQUIP SI HDBK	(2008; Errata 1 2010) Handbook, HVAC Systems and Equipment (SI Edition)
ASHRAE FUN IP	(2009; Errata 2010) Fundamentals Handbook, I-P Edition
ASHRAE FUN SI	(2009; Errata 2010) Fundamentals Handbook, SI Edition

## 1.2 GENERAL REQUIREMENTS

\*\*\*\*\*

NOTE: If Section 23 00 00 AIR SUPPLY, DISTRIBUTION, VENTILATION, AND EXHAUST SYSTEMS is not included in the project specification, applicable requirements therefrom should be inserted and the following paragraph deleted.

\*\*\*\*\*

Section 23 00 00 AIR SUPPLY, DISTRIBUTION, VENTILATION, AND EXHAUST SYSTEMS applies to work specified in this section.

### 1.3 PERFORMANCE REQUIREMENTS

Certify air diffusion devices having been tested and rated in accordance with ASHRAE EQUIP SI HDBK, Chapter 17; ASHRAE FUN SI, Chapter 31; ASHRAE EQUIP IP HDBK, Chapter 17; ASHRAE FUN IP, Chapter 31; and ASHRAE 113, where such certification is required.

Submit equipment and performance data for air-diffusion devices consisting of [sound data in terms of Noise Criteria (NC) index for the capacity range of the device.] [sound data in terms of sound-power level in octave bands second through eighth and Noise Criteria (NC) index for the capacity range of the device. Where room attenuation is not specified or indicated, assume 18 decibels. Where space or sound data are not specified or indicated, assume NC40.]

### 1.4 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.][for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for

the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

#### SD-01 Preconstruction Submittals

Submit the following in accordance with this section.

Material, Equipment, and Fixture Lists[; G][; G, [\_\_\_\_\_]]

Records of Existing Conditions[; G][; G, [\_\_\_\_\_]]

#### SD-02 Shop Drawings

Submit Fabrication Drawings[; G][; G, [\_\_\_\_\_]] for air-diffusion devices in accordance with this section.

Submit Installation Drawings[; G][; G, [\_\_\_\_\_]] for air-diffusion devices in accordance with the paragraph entitled, "Installation," of this section.

#### SD-03 Product Data

Submit Equipment and Performance Data[; G][; G, [\_\_\_\_\_]] for air-diffusion devices in accordance with paragraph entitled, "Performance Requirements," of this section.

#### SD-04 Samples

Submit Manufacturer's Standard Color Chart[; G][; G, [\_\_\_\_\_]] in accordance with this section.

#### SD-10 Operation and Maintenance Data

Provide manuals for the following air-diffusion devices:

Type TS Supply Troffer[; G][; G, [\_\_\_\_\_]]

Type TSR Combination Supply and Return Troffer[; G][; G, [\_\_\_\_\_]]

## PART 2 PRODUCTS

### 2.1 AIR-DIFFUSION DEVICE CONSTRUCTION

Preclude flutter, rattle, or vibration on air-diffusion device construction and mounting. Refer to Section 23 05 48 VIBRATION AND SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT for vibration isolation considerations. Modify devices and provide accessories necessary for mounting in indicated surface construction.

[ Select color from manufacturer's standard color chart which indicate the manufacturer's standard color selections and finishes for air-diffusion devices.

] [Match color with architectural background.]

[ Provide color as indicated on drawings.

] Provide supply diffusers with combination damper and equalizing grid. Ensure dampers are extracting-splitter type, except as otherwise indicated.

Ensure air-diffusion device volume and pattern adjustments can be made from the face of the device. Make volume adjustments by [removable key] [tamper-detering device].

Provide gaskets for supply-terminal air devices mounted in finished surfaces.

Include within the [material, equipment, and fixture lists](#) the manufacturer's style or catalog numbers, specification and drawing reference numbers, warranty information, and fabrication site information.

Submit [records of existing conditions](#) consisting of the results of Contractor's survey of work area conditions and features of existing structures and facilities within and adjacent to the jobsite. Commencement of work constitutes acceptance of existing conditions.

Submit [fabrication drawings](#) for air-diffusion devices consisting of fabrication and assembly details to be performed in the factory.

## 2.2 TYPES OF AIR-DIFFUSION DEVICES

### 2.2.1 Type DRA

Provide type DRA supply diffuser, round with five or more expanding cones with beaded edges to provide hemispherically diffused discharge air. Arrange cones to provide a minimum of [four] [\_\_\_\_\_] air paths which simultaneously diffuse air at [6 to 15 meter per minute 20 to 50 feet per minute \(fpm\)](#) and aspirate room air at 25 to 35 percent of discharge volume.

Provide aluminum diffuser with baked enamel finish.

Provide antismudge rings and extended cones.

### 2.2.2 Type DRB

Provide type DRB supply diffuser, round with [four] [\_\_\_\_\_] more expanding cones to provide hemispherically diffused discharge air. Arrange cones to provide a minimum of [three] [\_\_\_\_\_] air paths which simultaneously diffuse air at [6 to 15 meter per minute 20 to 50 fpm](#). Provide a pattern adjustment range from horizontal to downward projection, and any intermediate point, when mounted on exposed ductwork.

Provide aluminum diffuser with baked enamel finish.

Provide [Integral] [Separate] antismudge rings and extended cones.

### 2.2.3 Type DRC

Provide type DRC combination supply and return diffuser, round with four expanding cones. Arrange cones to provide one return air path and two supply air paths. Provide a butterfly supply-air damper and an annular return-air damper. [Provide a baked enamel finish] [Provide aluminum construction.]

[ Provide antismudge rings.

#### ]2.2.4 Type DRE

Provide type DRE supply diffuser, round with [three] [\_\_\_\_\_] expanding cones to provide discharge air paths, minimally, two-position adjustable for horizontal or vertical discharge. [Provide a baked enamel finish]

[ Provide antismudge rings.

#### ]2.2.5 Type DRH

Provide type DRH supply diffuser, half-round with [four] [\_\_\_\_\_] semiconical expanding members to discharge diffused air in a 180-degree pattern. Arrange cones to provide a minimum of [three] [\_\_\_\_\_] air paths which simultaneously diffuse air at 6 to 15 meter per minute 20 to 50 fpm. Provide opposed-blade volume control.

[ Provide a baked enamel finish.

] [Provide antismudge rings.

#### ]2.2.6 Type DP Series

Provide type DP series supply diffuser with a [square] [rectangular], perforated, hinged, face plate with [opposed blade] [splitter-damper] volume control, white baked enamel exterior finish, and black matte finish on exposed-to-view interior surface.

[ Provide one-way deflection.

] [Provide two-way opposed deflection.

] [Provide two-way diagonal deflection.

] [Provide three-way deflection.

] [Provide four-way deflection.

#### ]2.2.7 Type DLB

Provide type DLB supply diffuser, linear bar type, frame mounted, with extruded-aluminum bar and frame.

Ensure bars are [6] [1/4] [\_\_\_\_\_] millimeter [\_\_\_\_\_] inch thick by [19] [3/4] [\_\_\_\_\_] millimeter [\_\_\_\_\_] inch high, [13] [1/2] [\_\_\_\_\_] millimeter [\_\_\_\_\_] inch on center, pencilproof spacing, with zero degree bar deflection angle.

For floor- and sill-mounted diffusers provide heavy-duty reinforced construction to carry loads of not less than [490] [100] [\_\_\_\_\_] kilogram per square meter [\_\_\_\_\_] pounds per square foot.

Provide continuous length diffuser with hairline butt joints.

Provide mitered end caps where diffuser run terminates.

Provide opposed-blade type dampers.

Provide an integral, pivoted, bar-type access door where indicated.

Provide straightening grids where indicated.

#### 2.2.8 Type DLS

Provide type DLS supply diffuser, linear slot type, extruded aluminum construction, with fully adjustable integral air pattern and volume control vanes that deflect air pattern from horizontal along ceiling to straight down, or any intermediate setting and a pattern control element that permits complete blanking-off of slot.

Slot width: [19] [3/4] [\_\_\_\_\_] millimeter [\_\_\_\_\_] inch.

Provide number of slots per unit run as indicated.

Align butts in continuous runs for hairline joints.

Butt ends of diffuser against walls without mitered end caps. Provide end caps where slot terminates.

Provide exposed-to-view part of frame with anodized aluminum, and all interior exposed-to-view components with a black matte finish.

#### 2.2.9 Type DSA

Provide type DSA supply diffuser, square with [four] [\_\_\_\_\_] expanding flared members to provide radically diffused discharge air. Arrange flared members to provide a minimum of four air paths which simultaneously diffuse air at 6 to 15 meter per minute 20 to 50 fpm. Include pattern adjustments horizontal, vertical projection, and an intermediate position or range.

[ Provide a baked enamel finish.

] [Provide aluminum construction.

] [Provide antismudge rings.

] [Provide integral extended surface to fit into module of lay-in ceiling.

#### ] 2.2.10 Type GS

Provide type GS supply grill double deflection type with adjustable face bars parallel to short dimension and adjustable rear bars parallel to long dimension.

[ Provide a baked enamel finish.

] [Provide aluminum construction.

] [Provide antismudge rings.

] [Provide integral extended surface to fit into module of lay-in ceiling.

#### ] 2.2.11 Type GR

Provide type GR return grills, single deflection type with fixed face bars.

Provide grills installed in vertical surfaces with horizontal face bars set downward at 35 degrees from vertical.

Provide grills installed in horizontal surfaces with face bars straight and parallel to short dimension.

[ Provide a baked enamel finish.

][Provide aluminum construction.

][Provide antismudge rings.

][Provide integral extended surface to fit into module of lay-in ceiling.

#### ]2.2.12 Type GCA

Provide type GCA with an individually adjustable, horizontal, curved-blade grill and a one-way pattern.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.13 Type GCB

Provide type GCB with an individually adjustable, vertical, curved-blade grill and a one-way pattern.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.14 Type GCD

Provide type GCD with an individually adjustable, vertical, curved-blade grill and a two-way pattern.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.15 Type GCE

Provide type GCE with an individually adjustable, vertical and horizontal, curved-blade grill and a three-way pattern.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.16 Type GCF

Provide type GCF with an individually adjustable, vertical and horizontal, curved-blade grill and a four-way pattern.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.17 Type RS

Provide type RS supply register, double-deflection type, with adjustable

face bars parallel to short dimension and adjustable rear bars parallel to long dimension with opposed-blade type dampers.

[ Provide a baked enamel finish.

][Provide aluminum construction.

][Provide integral extended surface to fit into module of lay-in ceiling.

#### ]2.2.18 Type RR

Provide type RR return register, single-deflection type with fixed face bars with opposed-blade dampers.

Provide registers installed in vertical surfaces with horizontal face bars set downward at approximately 35 degrees from vertical.

Provide registers installed in horizontal surfaces with face bars set straight and parallel to short dimension.

[ Provide a baked enamel finish.

#### ]2.2.19 Type RCA

Provide type RCA with an individually adjustable, horizontal, curved-blade register and a one-way pattern with opposed-blade damper.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.20 Type RCB

Provide type RCB with individually adjustable, vertical, curved-blade register and a one-way pattern with opposed blade damper.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.21 Type RCC

Provide type RCC with an individually adjustable, horizontal, curved-blade register and a two-way pattern with opposed blade damper.

[ Provide a baked enamel finish.

][Provide aluminum construction.

#### ]2.2.22 Type RCD

Provide type RCD with an individually adjustable, vertical, curved-blade register and a two-way pattern with opposed blade damper.

[ Provide a baked enamel finish.

][Provide aluminum construction.

]2.2.23 Type RCE

Provide type RCE with an individually adjustable, vertical and horizontal, curved-blade register and a three-way pattern with opposed-blade damper.

[ Provide a baked enamel finish.

] [Provide aluminum construction.

]2.2.24 Type RCF

Provide type RCF with an individually adjustable, vertical and horizontal, curved-blade register and a four-way pattern with opposed-blade damper.

[ Provide a baked enamel finish.

] [Provide aluminum construction.

]2.2.25 Type TS

Provide type TS supply troffer complete assembly as specified in Section 26 51 00 INTERIOR LIGHTING and as indicated. Install air handling section of unit under this section.

2.2.26 Type TR

Provide type TR return troffer conforming to requirements for Type TS supply troffer.

2.2.27 Type TSR

Provide type TSR combination supply and return troffer assembly as specified in Section 26 51 00 INTERIOR LIGHTING and as indicated. Install air handling section of unit under this section.

PART 3 EXECUTION

3.1 INSTALLATION

Install equipment as indicated and specified and in accordance with manufacturer's recommendations.

[ Mount wall-mounted supply registers 150 millimeter 6 inches below ceiling.

] [Mount wall-mounted return registers 150 millimeter 6 inches above the finished floor.

] Submit installation drawings for air-diffusion devices. Indicate on drawings overall physical features, dimensions, ratings, service requirements, and equipment weights.

3.1.1 Operations and Maintenance Manuals

Provide operation and maintenance manuals consistent with manufacturer's standard brochures, schematics, printed instructions, general operating procedures and safety precautions.

-- End of Section --