
USACE / NAVFAC / AFCEA / NASA UFGS-05 21 23 (July 2007)

Preparing Activity: NAVFAC UFGS-05 21 00.00 20 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2011

SECTION TABLE OF CONTENTS

DIVISION 05 - METALS

SECTION 05 21 23

STEEL JOIST GIRDER FRAMING

07/07

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 REGULATORY REQUIREMENT
- 1.4 DELIVERY AND STORAGE
- 1.5 QUALITY ASSURANCE
 - 1.5.1 Drawing Requirements
 - 1.5.2 Certification of Compliance

PART 2 PRODUCTS

- 2.1 JOIST GIRDERS AND ACCESSORIES
- 2.2 PAINTING
 - 2.2.1 Shop Painting

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 Handling and Erection
 - 3.1.2 Welding
- 3.2 BEARING PLATES
- 3.3 PAINTING
 - 3.3.1 Touch-Up Painting
 - 3.3.2 Field Painting
- 3.4 VISUAL INSPECTIONS
 - 3.4.1 Erection Inspection
- 3.5 SCHEDULE

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-05 21 23 (July 2007)

Preparing Activity: NAVFAC UFGS-05 21 00.00 20 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2011

SECTION 05 21 23

STEEL JOIST GIRDER FRAMING

07/07

NOTE: This guide specification covers the requirements for steel joist girder framing.

Use Section 05 21 13 for DEEP LONGSPAN STEEL JOIST FRAMING.

Use Section 05 21 16 for LONGSPAN STEEL JOIST FRAMING.

Use Section 05 21 19 for OPEN WEB STEEL JOIST FRAMING.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

NOTE: Show the following information on the project drawings:

1. Joist girder depth, spacing, and kg kip load on each panel point, span, and slope.
2. Design loads, including uplift and lateral forces in addition to gravity (dead and live) loads.
3. Method of anchoring, framing at openings, and spacing.

4. Accessory details as applicable.

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN WELDING SOCIETY (AWS)

AWS B2.1/B2.1M (2009) Specification for Welding Procedure and Performance Qualification

AWS D1.1/D1.1M (2010) Structural Welding Code - Steel

STEEL JOIST INSTITUTE (SJI)

SJI LOAD TABLES (2005; Errata 1 2006; Errata 2 2007; Errata 3 2007) 42nd Edition Catalog of Standard Specifications Load Tables and Weight Tables for Steel Joists and Joist Girders

SJI MANUAL (2009) 80 Years of Open Web Steel Joist Construction

SJI TD 11 (2007) Technical Digest No. 11 - Design Of Lateral Load Resisting Frames Using Steel Joists And Joist Girders

SJI TD 9 (2008) Technical Digest No. 9 - Handling and Erection of Steel Joists and Joist Girders; 3rd Edition

THE SOCIETY FOR PROTECTIVE COATINGS (SSPC)

SSPC PS 14.01 (1982; E 2004) Steel Joist Shop Painting System

SSPC Paint 15 (1999; E 2004) Steel Joist Shop Primer

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1910.1200 Hazard Communication

29 CFR 1926 Safety and Health Regulations for Construction

29 CFR 1926.757 Steel Erection; Open Web Steel Joists

1.2 SUBMITTALS

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Welder qualification

Material Safety Data Sheet (MSDS) per OSHA 29 CFR 1910.1200

SD-02 Shop Drawings

Steel joist girder framing; G

SD-06 Test Reports

Erection inspection

Welding inspections

SD-07 Certificates

Accessories

Certification of Compliance

1.3 REGULATORY REQUIREMENT

All joist girder framing must conform to 29 CFR 1926.757. Secure all joist bridging and anchoring in place prior to the application of any construction loads. Distribute temporary loads so that joist capacity is not exceeded. Do not apply loads to bridging.

1.4 DELIVERY AND STORAGE

Handle, transport, and store joist girders in a manner to prevent damage affecting their structural integrity. Store all items off the ground in a well drained location protected from the weather and easily accessible for inspection and handling.

1.5 QUALITY ASSURANCE

All work must comply with the requirements set forth in 29 CFR 1926.

1.5.1 Drawing Requirements

Submit steel joist girder framing drawings. Show joist girder type and size, layout in plan, and erection details including methods of anchoring, framing at columns and/or bearing points, type and spacing of bridging, [requirements for field welding,] and details of accessories as applicable.

1.5.2 Certification of Compliance

Prior to construction commencement, submit Material Safety Data Sheet per 29 CFR 1910.1200 for steel joist girders, and certification for welder qualification, compliance with AWS B2.1/B2.1M, welding operation, and tacker, stating the type of welding and positions qualified for, the code and procedure qualified under, date qualified, and the firm and individual certifying the qualification tests.

**NOTE: Use the SJI MANUAL reference for projects
involving existing joist girder and joist systems.**

Submit [certification of compliance](#) for the following:

[[SJI MANUAL](#)
 [SJI TD 9](#)
 [SJI TD 11](#)
 [29 CFR 1926](#)
 [29 CFR 1926.757](#)

PART 2 PRODUCTS

2.1 JOIST GIRDERS AND [ACCESSORIES](#)

NOTE: When extra stiffness is desired, for comfort
or special material support, specify the allowable
deflection for that span.

Provide design data from [SJI LOAD TABLES](#) for the joist girders series
indicated.

2.2 PAINTING

2.2.1 Shop Painting

NOTE: Omit bracketed text when field painting is
not required.

Clean and prime joists in accordance with [SSPC Paint 15](#) and [SSPC PS 14.01](#),
Steel Joist Shop Painting System, using only Type I, "Red Oxide Paint."
[Finish coat of paint is specified in Section [09 90 00](#) PAINTING AND
COATING.]

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 Handling and Erection

Conform to [SJI LOAD TABLES](#) for the joist girder series indicated.

3.1.2 Welding

All welding must conform to [AWS B2.1/B2.1M](#) and [AWS D1.1/D1.1M](#).

[3.2 BEARING PLATES

NOTE: Use this paragraph for masonry or
cast-in-place concrete applications only.

Provide bearing plates to accept full bearing after the supporting members
have been plumbed and properly positioned, but prior to placing
superimposed loads. The area under the plate must be damp-packed solidly
with bedding mortar, except where nonshrink grout is indicated on the

drawings. Bedding mortar and grout must be as specified in Section
03 30 00.00 10 CAST-IN-PLACE CONCRETE.

] 3.3 PAINTING

3.3.1 Touch-Up Painting

After erection of joist girders [and joists], touch-up connections and areas of abraded shop coat with paint of the same type used for the shop coat.

[3.3.2 Field Painting

NOTE: Omit bracketed text when field painting is
not required.

Paint joists girders [and joists] requiring a finish coat in conformance with the requirements of Section 09 90 00 PAINTING AND COATING.

] 3.4 VISUAL INSPECTIONS

3.4.1 Erection Inspection

AWS D1.1/D1.1M, Section 6. Perform erection inspection and field welding inspections with AWS certified welding inspectors. Welding inspectors must visually inspect and mark welds.

3.5 SCHEDULE

NOTE: Delete this paragraph for non-metric projects.

SI dimensioning in this section is based on a mathematical conversion of inch-pound dimensions following the SJI specification SJI LOAD TABLES. The SI and I-P units for the dimensions shown are as follows.

<u>Inch-Pound Units</u>	<u>SI Units</u>
20 feet	6096 mm
30 ksi	207 MPa

-- End of Section --