
USACE / NAVFAC / AFCEA / NASA UFGS-32 31 13 (August 2010)

Preparing Activity: NASA Superseding
UFGS-32 31 13 (May 2009)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMLR dated October 2011

SECTION TABLE OF CONTENTS

DIVISION 32 - EXTERIOR IMPROVEMENTS

SECTION 32 31 13

CHAIN LINK FENCES AND GATES

08/10

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 ASSEMBLY AND INSTALLATION INSTRUCTIONS
- 1.4 DELIVERY, STORAGE, AND HANDLING
- 1.5 QUALITY ASSURANCE
 - 1.5.1 Required Report Data
 - 1.5.2 Certificates of Compliance

PART 2 PRODUCTS

- 2.1 GENERAL
- 2.2 ZINC COATING
- 2.3 FABRIC
- 2.4 TOP AND BOTTOM SELVAGES
- 2.5 POSTS [, TOP RAILS] [, BOTTOM RAILS] AND BRACES
 - 2.5.1 Composite Posts
- 2.6 LINE POSTS
- 2.7 END, CORNER, AND PULL POSTS
- 2.8 SLEEVES
- 2.9 TOP RAIL
- 2.10 CENTER RAILS BETWEEN LINE POSTS
- 2.11 [BOTTOM RAIL]
- 2.12 POST-BRACE ASSEMBLY
- 2.13 TENSION WIRE
- 2.14 STRETCHER BARS
- 2.15 POST TOPS
- 2.16 STRETCHER BAR BANDS
- 2.17 GATE POSTS
- 2.18 GATES
- 2.19 GATE HARDWARE AND ACCESSORIES
- 2.20 MISCELLANEOUS HARDWARE
- 2.21 WIRE TIES
- 2.22 CONCRETE
- 2.23 GROUT

2.24 PADLOCKS

PART 3 EXECUTION

- 3.1 GENERAL
- 3.2 EXCAVATION
- 3.3 SETTING POSTS
 - 3.3.1 Earth and Bedrock
 - 3.3.2 Concrete Slabs and Walls
 - 3.3.3 Bracing
- 3.4 CONCRETE STRENGTH
- 3.5 TOP RAILS
- 3.6 CENTER RAILS
- 3.7 BRACE ASSEMBLY
- 3.8 TENSION WIRE INSTALLATION
- 3.9 FABRIC INSTALLATION
- 3.10 STRETCHER BAR INSTALLATION
- 3.11 GATE INSTALLATION
- 3.12 TIE WIRES
- 3.13 FASTENERS
- 3.14 ZINC-COATING REPAIR
- 3.15 TOLERANCES
- 3.16 SITE PREPARATION
 - 3.16.1 Clearing and Grading
- 3.17 FENCE INSTALLATION
 - 3.17.1 Post Spacing
 - 3.17.2 Top and Bottom Tension Wire
- 3.18 ACCESSORIES INSTALLATION
 - 3.18.1 Post Caps
 - 3.18.2 Padlocks
- 3.19 GROUNDING
- 3.20 SECURITY
- 3.21 CLEANUP

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-32 31 13 (August 2010)

Preparing Activity: NASA Superseding
UFGS-32 31 13 (May 2009)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2011

SECTION 32 31 13

CHAIN LINK FENCES AND GATES 08/10

NOTE: This guide specification covers the requirements for steel fencing, including posts, fabric, gates, and miscellaneous accessories. Colored fabric and accessories may be used if required. Edit specifications to suit the project scope.

Use Section 32 31 13.53 HIGH-SECURITY CHAIN LINK FENCES AND GATES.

Use Section 32 31 26 WIRE FENCES AND GATES formerly referred to as "Farm Style Fencing" within UFGS.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date,

and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

| | |
|-----------------|--|
| ASTM A116 | (2011) Standard Specification for Metallic-Coated, Steel Woven Wire Fence Fabric |
| ASTM A153/A153M | (2009) Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware |
| ASTM A702 | (1989; R 2006) Standard Specification for Steel Fence Posts and Assemblies, Hot Wrought |
| ASTM A780/A780M | (2009) Standard Practice for Repair of Damaged and Uncoated Areas of Hot-Dip Galvanized Coatings |
| ASTM A90/A90M | (2009) Standard Test Method for Weight [Mass] of Coating on Iron and Steel Articles with Zinc or Zinc-Alloy Coatings |
| ASTM B117 | (2009) Standard Practice for Operating Salt Spray (Fog) Apparatus |
| ASTM C94/C94M | (2011a) Standard Specification for Ready-Mixed Concrete |
| ASTM F 1043 | (2011) Strength and Protective Coatings on Metal Industrial Chain-Link Fence Framework |
| ASTM F 1083 | (2010) Standard Specification for Pipe, Steel, Hot-Dipped Zinc Coated (Galvanized) Welded, for Fence Structures |
| ASTM F 567 | (2011) Standard Practice for Installation of Chain Link Fence |
| ASTM F 626 | (2008) Standard Specification for Fence Fittings |

| | |
|------------|---|
| ASTM F 883 | (2009) Padlocks |
| ASTM G 152 | (2006) Operating Open Flame Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials |
| ASTM G 153 | (2004; R 2010) Operating Enclosed Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials |
| ASTM G 154 | (2006) Standard Practice for Operating Fluorescent Light Apparatus for UV Exposure of Nonmetallic Materials |
| ASTM G 155 | (2005a) Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Non-Metallic Materials |

U.S. GENERAL SERVICES ADMINISTRATION (GSA)

| | |
|---------------|--|
| FS RR-F-191 | (Rev K) Fencing, Wire and Post Metal (and Gates, Chain-Link Fence Fabric, and Accessories) |
| FS RR-F-191/1 | (Rev F) Fencing, Wire and Post, Metal (Chain-Link Fence Fabric) |
| FS RR-F-191/2 | (Rev E) Fencing, Wire and Post, Metal (Chain-Link Fence Gates) |
| FS RR-F-191/3 | (Rev E; Am 1) Fencing, Wire and Post, Metal (Chain-Link Fence Posts, Top Rails and Braces) |
| FS RR-F-191/4 | (Rev F) Fencing, Wire and Post, Metal (Chain-Link Fence Accessories) |

1.2 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G"

designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Fence Assembly[; G][; G, [____]]

Location of Gate, Corner, End, and Pull Posts[; G][; G, [____]]

Gate Assembly[; G][; G, [____]]

Gate Hardware and Accessories[; G][; G, [____]]

Erection/Installation Drawings[; G][; G, [____]]

SD-03 Product Data

Fence Assembly[; G][; G, [____]]

Gate Assembly[; G][; G, [____]]

Gate Hardware and Accessories[; G][; G, [____]]

Recycled Material Content[; G][; G, [____]]

Zinc Coating[; G][; G, [____]]

PVC Coating[; G][; G, [____]]

Aluminum Alloy Coating[; G][; G, [____]]

Fabric[; G][; G, [____]]

Stretcher Bars[; G][; G, [____]]

Concrete[; G][; G, [____]]

SD-04 Samples

Fabric[; G][; G, [____]]

Posts[; G][; G, [____]]
Braces[; G][; G, [____]]
Line Posts[; G][; G, [____]]
Sleeves[; G][; G, [____]]
Top Rail[; G][; G, [____]]
[Bottom Rail][; G][; G, [____]]
Tension Wire[; G][; G, [____]]
Stretcher Bars[; G][; G, [____]]
Gate Posts[; G][; G, [____]]
Gate Hardware and Accessories[; G][; G, [____]]
Padlocks[; G][; G, [____]]
Wire Ties[; G][; G, [____]]

SD-07 Certificates

Certificates of Compliance[; G][; G, [____]]

SD-08 Manufacturer's Instructions

Fence Assembly[; G][; G, [____]]
Gate Assembly[; G][; G, [____]]
Hardware Assembly[; G][; G, [____]]
Accessories[; G][; G, [____]]

1.3 ASSEMBLY AND INSTALLATION INSTRUCTIONS

Submit manufacturer's [erection/installation drawings](#) and instructions that detail proper assembly and materials in the design for fence, gate, hardware and accessories.

Submit erection/installation drawings along with manufacturer's catalog data for complete [fence assembly](#), [gate assembly](#), [hardware assembly](#) and [accessories](#).

1.4 DELIVERY, STORAGE, AND HANDLING

Deliver materials to site in an undamaged condition. Store materials off the ground to provide protection against oxidation caused by ground contact.

1.5 QUALITY ASSURANCE

1.5.1 Required Report Data

Submit reports of listing of chain-link fencing and accessories regarding

weight in grams ounces for zinc coating[, thickness of PVC coating][, and chemical composition and thickness of aluminum alloy coating].

1.5.2 Certificates of Compliance

Submit certificates of compliance in accordance with the applicable reference standards and descriptions of this section for the following:

- a. Zinc coating
- b. PVC coating
- c. Aluminum alloy coating
- d. Fabric
- e. Stretcher bars
- f. Gate hardware and accessories
- g. Concrete

PART 2 PRODUCTS

2.1 GENERAL

Provide fencing materials conforming to the requirements of ASTM A116, ASTM A702, ASTM F 626, and as specified.

Submit manufacturer's data indicating percentage of recycled material content in protective fence materials, including chain link fence, fabric, and gates to verify affirmative procurement compliance.

2.2 ZINC COATING

Provide hot-dip galvanized (after fabrication) ferrous-metal components and accessories, except as otherwise specified.

Provide zinc coating of weight not less than 550 gram per square meter 1.94 ounces per square foot, as determined from the average result of two specimens, when tested in accordance with ASTM A90/A90M.

Provide zinc coating conforming to the requirements of the following:

- a. Pipe: FS RR-F-191/3 Class 1 [Grade A in accordance with ASTM F 1083] [Grade B in accordance with ASTM F 1043].
- b. Hardware and accessories: ASTM A153/A153M, Table 1
- c. Surface: ASTM F 1043
- d. External: Type B-B surface zinc with organic coating, 275 gram per square meter 0.97 ounce per square foot minimum thickness of acrylated polymer.
- e. Internal: Surface zinc coating of 275 gram per square meter 0.97 ounce per square foot minimum.

Provide galvanizing repair material that is cold-applied zinc-rich coating

conforming to ASTM A780/A780M.

2.3 FABRIC

NOTE: Coordinate type of fabric with project requirements. The four types of fabric are not necessarily equivalent. Certain security applications may require use of steel fabric only. Standard selvage treatment for fabric 1.52 m 60 inches and less is knuckled at both selvages. Fabric with heavier zinc or aluminum coating or polyvinyl chloride (PVC) coatings may be useful in highly corrosive environments.

NOTE: Choose core wire gage appropriate for the design. Gages are not be the same for all materials. Polyvinyl chloride (PVC) coating may be specified for other than security purposes when aesthetics are of prime importance and the additional cost is justified. There are different PVC-coated fabrics on the market. Variations may include: The methods of applying PVC coating, wall thickness of PVC coating, adhesion of PVC coating to wire, and cost. Take these factors into consideration when selecting a fence fabric for different environmental applications. PVC coating of fencing for certain security applications and grounded fencing requires detailed design and specifying.

FS RR-F-191 and detailed specifications as referenced and other requirements as specified.

FS RR-F-191/1; Type [I, zinc-coated steel, [_____] gage] [II, aluminum-coated steel, [_____] gage] [III, aluminum alloy, [_____] gage] [or] [IV, polyvinyl chloride (PVC) coated over zinc- or aluminum-coated steel, [_____] gage core wire size]. Mesh size, 51 mm 2 inches. Provide selvage [knuckled at one selvage and twisted and barbed at the other] [twisted and barbed at both selvages] [knuckled at both selvages]. Height of fabric, as indicated.

Provide fabric consisting of 3.8 millimeter No. 9-gage wires woven into a [25] [45] [50] millimeter [1-inch] [1-3/4-inch] [2-inch] diamond mesh, with dimensions of fabric and wire conforming to ASTM A116, ASTM A702 and ASTM F 626, with [370] [610] gram per square meter [1.20] [2.0] ounces per square foot zinc galvanizing.

Provide one-piece fabric widths for fence heights up to 3658 millimeter 12 feet.

2.4 TOP AND BOTTOM SELVAGES

Provide knuckled selvages at top and bottom for fabric with 51 millimeter 2 inch mesh and up to 1524 millimeter 60 inches high, and if over 1524 millimeter 60 inches high, provide twisted and barbed top selvage and

knuckled bottom selvage.

Knuckle top and bottom selvages for 45 millimeter and 25 millimeter 1-3/4-inch and 1-inch mesh fabric.

2.5 POSTS [, TOP RAILS] [, BOTTOM RAILS] AND BRACES

NOTE: Use as many of the options as possible consistent with functional requirements. Allow Class 3, formed steel sections as an alternative if no other requirements prohibit their use on a particular job. Certain security applications using intrusion detection sensors use steel pipe framework only. For rails and braces, use minimum sizes specified in FS RR-F-191/3 for each class and grade unless members are to be oversized.

NOTE: Steel pipe is available in two grades: A or B. Grade A is zinc-coated with 0.54 kg per square meter 1.8 ounces per square foot of zinc. Grade B consists of a zinc-coating with 0.27 kg per square meter 0.9 ounce per square foot, a chromate conversion coating, followed by a clear acrylic or polyester coating. The acrylic or polyester coatings used on Grade B pipe should not be confused with optional polyvinyl chloride (PVC) coatings available for framework. Grade A pipe which has the heavier zinc-coated interior may be desired in some coastal regions located in highly corrosive salt-laden environments to prevent rust caused by condensation inside the pipe. Grade A or Grade B pipe may be used in inland and desert areas, provided Grade B pipe meets the salt spray test.

FS RR-F-191/3 line posts; Class [1, steel pipe, Grade [A] [or] [B]] [2, aluminum pipe] [3, formed steel sections] [4, steel H sections] or [5, aluminum H sections]. End, corner, and pull posts; Class [1, steel pipe, Grade [A] [or] [B]], [2, aluminum pipe], [6, steel square sections] [or 7, aluminum square sections]. Braces [and rails]; Class [1, steel pipe, Grade [A] [or] [B]] [2, aluminum pipe] or [3, formed steel sections], in [minimum sizes listed in FS RR-F-191/3 for each class and grade] [size [____]]. [Provide PVC color coating, minimum thickness, 0.25 mm 0.10 inch.] [Steel pipe, Class 1, Grade B meeting the following performance criteria when subjected to salt spray testing in accordance with ASTM B117:

- a. Exterior [____] 1,000 hours with maximum 5 percent red rust.
- b. Interior [____] 650 hours with maximum 5 percent red rust.]

2.5.1 Composite Posts

NOTE: Provide as alternative to PVC coated fence posts, and use where corrosion is a problem. Since posts are non-conductive, fence grounding procedures

need to be detailed where grounding of the fence is required.

Produce resin reinforced posts from polyester or epoxy resin, reinforced with E-glass and filler material. Provide post that meet the ASTM F 1043 bending strength for heavy industrial fencing, and filled with 20 MPa 3,000 psi concrete. Protect posts from UV degradation by a veil of polyester cloth impregnated with resin and an acrylic based 1.46 mm 1.5 mil DFT coating system. The post can exhibit no structural failure (less than 10 percent loss of strength) as a result of exposure to moisture and UV lamps per ASTM G 152, ASTM G 153, ASTM G 155, and ASTM G 154, (3600 hours). Provide posts [green], [black], [brown] in color to match fabric. [Provide outside diameter as specified in FS RR-F-191/3 for round steel pipe.]

2.6 LINE POSTS

Minimum acceptable line posts are as follows:

Up to 1829 millimeter 6-feet high:

Grade A: DN50 1.900 inch O.D. pipe weighing 4.05 kilogram per linear meter 2.72 pounds per linear foot.

Grade B: DN60 2.375 inch O.D. pipe weighing 4.65 kilogram per linear meter 3.12 pounds per linear foot.

Over 1829 millimeter 6-feet high:

DN50 2.0 inch O.D. pipe weighing 5.44 kilogram per linear meter 3.65 pounds per linear foot.

2.7 END, CORNER, AND PULL POSTS

Provide minimally acceptable end, corner, and pull posts as follows:

Up to 1829 millimeter 6 feet high:

Grade A: DN50 2.375 inch O.D. pipe weighing 5.44 kilogram per linear meter 3.65 pounds per linear foot.

Grade B: DN60 2.375 inch O.D. pipe weighing 4.65 kilogram per linear meter 3.12 pounds per linear foot.

Over 1829 millimeter 6 feet high:

Grade A: DN70 2.875 inch O.D. pipe weighing 8.62 kilogram per linear meter 5.79 pounds per linear foot.

Grade B: DN70 2.875 inch O.D. pipe weighing 6.91 kilogram per linear meter 4.64 pounds per linear foot.

2.8 SLEEVES

Provide sleeves for setting into concrete construction of the same material as post sections, sized 25 millimeter 1-inch greater than the diameter or dimension of the post. Weld flat plates to each sleeve base to provide anchorage and prevent intrusion of concrete.

2.9 TOP RAIL

Provide [a minimum of DN40 1.660 inches O.D. pipe rails.] [Grade A weighing 3.38 kilogram per linear meter 2.27 pounds per linear foot.] [Grade B weighing 2.71 kilogram per linear meter 1.82 pounds per linear foot.] Provide expansion couplings 150 millimeter 6-inches long at each joint in top rails.

[2.10 CENTER RAILS BETWEEN LINE POSTS

NOTE: Center rails are not normally required for
fencing less than 1829 millimeter 6 feet high. Edit
as required.

For fencing over 1829 millimeter 6-feet high, provide DN40 1.660 inches O.D. pipe center rails, [Grade A weighing 3.38 kilogram per linear meter 2.27 pounds per linear foot] [Grade B weighing 2.71 kilogram per linear meter 1.82 pounds per linear foot.]

] 2.11 [BOTTOM RAIL]

[Provide [bottom rail] conforming to minimum sizes specified in FS RR-F-191/3 for each class and grade unless members are to be oversized.]

] 2.12 POST-BRACE ASSEMBLY

Provide bracing consisting of DN40 1.660 inches O.D. pipe [Grade A weighing 3.38 kilogram per linear meter 2.27 pounds per linear foot] [Grade B weighing 2.71 kilogram per linear meter 1.82 pounds per linear foot] and 10 millimeter 3/8 inch adjustable truss rods and turnbuckles.

2.13 TENSION WIRE

Provide galvanized wire, 3.7 millimeter No. 7-gage, coiled spring wire, provided at the bottom of the fabric only. Provide zinc coating that weighs not less than [370] [610] gram per square meter [1.2] [2.0] ounces per square foot.

2.14 STRETCHER BARS

Provide bars that have one-piece lengths equal to the full height of the fabric with a minimum cross section of 5 by 20 millimeter 3/16 by 3/4 inch, in accordance with ASTM A116, ASTM A702 and ASTM F 626.

2.15 POST TOPS

Provide tops that are steel, wrought iron, or malleable iron designed as a weathertight closure cap. Provide one cap for each post, unless equal protection is provided by a combination post-cap and barbed-wire supporting arm. Provide caps with an opening to permit through passage of the top rail.

2.16 STRETCHER BAR BANDS

Provide bar bands for securing stretcher bars to posts that are steel, wrought iron, or malleable iron spaced not over 381 millimeter 15 inches on

center. Bands may also be used in conjunction with special fittings for securing rails to posts. Provide bands with projecting edges chamfered or eased.

2.17 GATE POSTS

Provide a gate post for supporting each gate leaf as follows:

[Up to 1829 millimeter 6-feet wide:

DN75 2.875 inch O.D. pipe [Grade A weighing 8.62 kilogram per linear meter 5.79 pounds per linear foot.] [Grade B weighing 6.91 kilogram per linear meter 4.64 pounds per linear foot.]

] [Over 1829 millimeter 6 feet wide and up to 3962 millimeter 13 feet wide:

DN75 2.875 inch O.D. pipe [Grade A weighing 8.62 kilogram per linear meter 5.79 pounds per linear foot.] [Grade B weighing 6.91 kilogram per linear meter 4.64 pounds per linear foot.]

] [Over 3962 millimeter 13-feet and up to 5486 millimeter 18-feet wide:

Provide DN150 6.625 inch O.D. pipe weighing 28.26 kilogram per linear meter 18.97 pounds per linear foot.

] [Over 5486 millimeter 18-feet wide:

Provide DN220 8.625 inch O.D. pipe weighing 36.79 kilogram per linear meter 24.70 pounds per linear foot.

] 2.18 GATES

NOTE: The gate frames and intermediate braces indicated are adequate for gate sizes less than or equal to 2.4 m 8 feet high and 4.3 m 14 feet wide. Gate configurations larger than 2.4 m 8 feet high and 4.3 m 14 feet wide require special design consideration.

FS RR-F-191/2; Type [I, single swing] [II, double swing] [III, single cantilever sliding, wheel sliding gate] [IV, double cantilever sliding] [V, single overhead sliding] [VI, double overhead sliding] [VII, vertical lift] [VIII, special]. Shape and size of gate frame, [as indicated] [_____]. Framing and bracing members, [round] [square] of [steel] [aluminum] alloy. [Steel member finish, [zinc-coated] [or] [PVC-coated over zinc- or aluminum-coated steel].] Provide gate frames and braces of minimum sizes listed in FS RR-F-191/3 for each Class and Grade, except that steel pipe frames are a minimum of 48 mm 1.90 inches o.d., 3 mm 0.120 inches minimum wall thickness and aluminum pipe frames and intermediate braces are 47.5 mm 1.869 inches o.d. minimum, 1.4 kg per meter 0.940 lb/ft of length. Gate fabric, is as specified for fencing fabric. Coating for steel latches, stops, hinges, keepers, and accessories, [galvanized] [PVC, minimum thickness of 0.25 mm 0.010 inch.] Provide [fork] [plunger bar] type gate latches. [Special gate frames, [as indicated] [_____].] [Provide intermediate members as necessary for gate leaves more than 2.4 m 8 feet wide, to provide rigid construction, free from sag or twist.] [Provide truss rods or intermediate braces for gate leaves less than 2.4 m 8 feet

wide.] Attach gate fabric to gate frame in accordance with manufacturer's standards, except that welding is not permitted. Arrange padlocking latches to be accessible from both sides of gate, regardless of latching arrangement.

[For gate leaves up to 1829 millimeter 6-feet high or 1829 millimeter 6-feet wide, provide perimeter gate frames of DN32 1.66 inch O.D. pipe [Grade A weighing 3.38 kilogram per linear meter 2.27 pounds per linear foot.] [Grade B weighing 2.71 kilogram per linear meter 1.82 pounds per linear foot.]

] [For gate leaves over 1829 millimeter 6 feet high or 1829 millimeter 6 feet wide, provide perimeter gate frames of DN40 1.90 inch O.D. pipe [Grade A weighing 4.05 kilogram per linear meter 2.72 pounds per linear foot.] [Grade B weighing 3.40 kilogram per linear meter 2.28 pounds per linear foot.]

] Provide gate frame assembly that is welded or assembled with special malleable or pressed-steel fittings and rivets to provide rigid connections. Install fabric with stretcher bars at vertical edges; stretcher bars may also be used at top and bottom edges. Attach stretcher bars and fabric to gate frames on all sides at intervals not exceeding 381 millimeter. 15 inches. Attach hardware with rivets or by other means which provides equal security against breakage or removal.

Provide diagonal cross-bracing, consisting of 10 millimeter 3/8-inch diameter adjustable-length truss rods on welded gate frames, where necessary to obtain frame rigidity without sag or twist. Provide nonwelded gate frames with diagonal bracing.

2.19 GATE HARDWARE AND ACCESSORIES

Provide gate hardware and accessories that conforms to ASTM A116, ASTM A702, ASTM F 626, and be as specified:

Provide [malleable iron] [forged steel] [pressed steel] hinges to suit gate size, non-lift-off type, offset to permit 180-degree opening.

Provide latch that permits operation from either side of the gate, with a padlock eye provided as an integral part of the latch.

Provide stops and holders of malleable iron for vehicular gates. Provide stops that automatically engage the gate and hold it in the open position until manually released.

NOTE: Delete the following paragraph when double
gates are not required.

[Provide double gates with a cane bolt and ground-set keeper, with latch or locking device and padlock eye designed as an integral part.
]

NOTE: Delete the following paragraph if manual
sliding gates are not required.

[Provide manufacturer's standard heavy-duty track ball bearing hanger sheaves, overhead framing and supports, guides, stays, bracing, and accessories as required for easy operation of manual sliding gates.

] 2.20 MISCELLANEOUS HARDWARE

Provide miscellaneous hot-dip galvanized hardware as required.

2.21 WIRE TIES

Provide 1.6 millimeter 16-gage galvanized steel wire for tying fabric to line posts, spaced 300 millimeter 12 inches on center. For tying fabric to rails and braces, space wire ties 600 millimeter 24 inches on center. For tying fabric to tension wire, space 2.7 millimeter 0.105-inch hog rings 600 millimeter 24 inches on center.

Manufacturer's standard procedure will be accepted if of equal strength and durability.

NOTE: Polyvinyl chloride (PVC) coated ties shall be
specified when PVC-coated fence fabric is required.

FS RR-F-191/4. Provide wire ties constructed of the same material as the fencing fabric. [Provide accessories with polyvinyl (PVC) coatings similar to that specified for chain-link fabric or framework.]

2.22 CONCRETE

Provide concrete conforming to ASTM C94/C94M, and obtaining a minimum 28-day compressive strength of 20685 kilopascal 3,000 psi.

2.23 GROUT

Provide grout of proportions one part portland cement to three parts clean, well-graded sand and a minimum amount of water to produce a workable mix.

2.24 PADLOCKS

NOTE: Consult station regarding padlocks. Most
stations will provide padlocks. If Contractor
furnished padlocks are required for certain security
applications, a padlock conforming to an appropriate
Military or Agency Specification may need to be
specified. See referenced specification for types,
grades, and options available.

Provide padlocks conforming to ASTM F 883, with chain.

PART 3 EXECUTION

Provide complete installation conforming to ASTM F 567.

3.1 GENERAL

Ensure final grading and established elevations are complete prior to commencing fence installation.

3.2 EXCAVATION

Provide excavations for post footings which are [drilled holes] in virgin or compacted soil, of minimum sizes as indicated.

Space footings for line posts 3048 millimeter 10 feet on center maximum and at closer intervals when indicated, with bottoms of the holes approximately 75 millimeter 3-inches below the bottoms of the posts. Set bottom of each post not less than 915 millimeter 36-inches below finished grade when in firm, undisturbed soil. Set posts deeper, as required, in soft and problem soils and for heavy, lateral loads.

[Uniformly spread soil from excavations adjacent to the fence line or on areas of Government property, as directed.] [Remove excavated soil from Government property.

] When solid rock is encountered near the surface, drill into the rock at least 305 millimeter 12 inches for line posts and at least 457 millimeter 18 inches for end, pull, corner, and gate posts. Drill holes at least 25.4 millimeter 1 inch greater in diameter than the largest dimension of the placed post.

If solid rock is below the soil overburden, drill to the full depth required except that penetration into rock need not exceed the minimum depths specified above.

3.3 SETTING POSTS

Remove loose and foreign materials from holes and the soil moistened prior to placing concrete.

Provide tops of footings that are trowel finished and sloped or domed to shed water away from posts. Set hold-open devices, sleeves, and other accessories in concrete.

Keep exposed concrete moist for at least 7 calendar days after placement or cured with a membrane curing material, as approved.

[Grout all posts set into sleeved holes in concrete with an approved grouting material.

] [Maintain vertical alignment of posts set in concrete construction until concrete has set.

] 3.3.1 Earth and Bedrock

NOTE: Alternate drive anchor method may be
specified as an option where evidence indicates that
optional method under similar ground conditions has
satisfactory and proven performance record.

Provide concrete bases of dimensions indicated [except in bedrock]. Compact concrete to eliminate voids, and finish to a dome shape. [In bedrock, set posts with a minimum of 25.4 mm 1 inch of grout around each post. Work grout into hole to eliminate voids, and finish to a dome shape.]

[3.3.2 Concrete Slabs and Walls

NOTE: Use the following paragraph where required by the design, otherwise delete. Sleeve joints for non-removable fence sections are usually filled with lead or nonshrink grout. Removable fence sections may be useful as an economical means for providing access to equipment. Sleeve joints in removable fence sections may be a tight sliding type, or where moisture entry could be a problem, filled with pipe sulphur jointing compound.

Set posts into zinc-coated sleeves, set in concrete slab or wall, to a minimum depth of 305 mm 12 inches. Fill sleeve joint with lead, nonshrink grout, or other approved material. Set posts for support of removable fence sections into sleeves that provide a tight sliding joint and hold posts aligned and plumb without use of lead or setting material.

]3.3.3 Bracing

NOTE: Use a single diagonal truss rod for fences less than 3.7 m 12 feet high. Use two diagonal truss rods on fences 3.7 m 12 feet and higher.

Brace gate, corner, end, and pull posts to nearest post with a horizontal brace used as a compression member, placed at least 305 mm 12 inches below top of fence, and [a diagonal tension rod] [two diagonal tension rods].

3.4 CONCRETE STRENGTH

Provide concrete that has attained at least 75 percent of its minimum 28-day compressive strength, but in no case sooner than 7 calendar days after placement, before rails, tension wire, or fabric are installed. Do not stretch fabric and wires or hang gates until the concrete has attained its full design strength.

NOTE: Delete the following paragraph if the referenced section is not included.

Take samples and test concrete to determine strength as specified.

3.5 TOP RAILS

Provide top rails that run continuously through post caps or extension arms, bending to radius for curved runs. Provide expansion couplings as recommended by the fencing manufacturer.

[3.6 CENTER RAILS

Provide single piece center rails between posts set flush with posts on the fabric side, using special offset fittings where necessary.

] 3.7 BRACE ASSEMBLY

Provide bracing assemblies at end and gate posts and at both sides of corner and pull posts, with the horizontal brace located at midheight of the fabric.

Install brace assemblies so posts are plumb when the diagonal rod is under proper tension.

Provide two complete brace assemblies at corner and pull posts where required for stiffness and as indicated.

3.8 TENSION WIRE INSTALLATION

Install tension wire by weaving them through the fabric and tying them to each post with not less than 3.9 millimeter 7-gage galvanized wire or by securing the wire to the fabric with 3.5 millimeter 10-gage ties or clips spaced 610 millimeter 24 inches on center.

3.9 FABRIC INSTALLATION

Provide fabric in single lengths between stretch bars with bottom barbs placed approximately 38 millimeter 1-1/2-inches above the ground line. Pull fabric taut and tied to posts, rails, and tension wire with wire ties and bands.

Install fabric on the security side of fence, unless otherwise directed.

Ensure fabric remains under tension after the pulling force is released.

3.10 STRETCHER BAR INSTALLATION

Thread stretcher bars through or clamped to fabric 102 millimeter 4 inches on center and secured to posts with metal bands spaced 381 millimeter 15 inches on center.

3.11 GATE INSTALLATION

Install gates plumb, level, and secure, with full opening without interference. Install ground set items in concrete for anchorage as recommended by the fence manufacturer. Adjust hardware for smooth operation and lubricated where necessary.

3.12 TIE WIRES

Provide tie wires that are U-shaped to the pipe diameters to which attached. Twist ends of tie wires not less than two full turns and bent so as not to present a hazard.

3.13 FASTENERS

Install nuts for tension bands and hardware on the side of the fence opposite the fabric side. Peen ends of bolts to prevent removal of nuts.

3.14 ZINC-COATING REPAIR

Clean and repair galvanized surfaces damaged by welding or abrasion, and cut ends of fabric, or other cut sections with specified galvanizing repair material applied in strict conformance with the manufacturer's printed

instructions.

3.15 TOLERANCES

Provide posts that are straight and plumb within a vertical tolerance of 6.35 millimeter 1/4 inch after the fabric has been stretched. Provide fencing and gates that are true to line with no more than 12.7 millimeter 1/2 inch deviation from the established centerline between line posts. Repair defects as directed.

3.16 SITE PREPARATION

3.16.1 Clearing and Grading

Clear fence line of trees, brush, and other obstacles to install fencing. Establish a graded, compacted fence line prior to fencing installation.

3.17 FENCE INSTALLATION

NOTE: Certain security applications require
conformance to an applicable OPNAVINST. Use
bracketed sentences as required by the applicable
OPNAVINST.

Install fence on prepared surfaces to line and grade indicated. [Secure fastening and hinge hardware in place to fence framework by peening or welding. Allow for proper operation of components. Coat peened or welded areas with a repair coating matching original coating.] Install fence in accordance with fence manufacturer's written installation instructions except as modified herein.

3.17.1 Post Spacing

Provide line posts spaced equidistantly apart, not exceeding 3.048 m 10 feet on center. Provide gate posts spaced as necessary for size of gate openings. Do not exceed 152.4 m 500 feet on straight runs between braced posts. Provide corner or pull posts, with bracing in both directions, for changes in direction of 0.26 rad 15 degrees or more, or for abrupt changes in grade. Provide drawings showing location of gate, corner, end, and pull posts.

3.17.2 Top and Bottom Tension Wire

NOTE: Coordinate with requirements for top and
bottom rails. Specify bottom tension wire to
maintain fence alignment, except for designs
requiring bottom rail.

Install [top] [and] [bottom] tension wires before installing chain-link fabric, and pull wires taut. Place top and bottom tension wires within 203 mm 8 inches of respective fabric line.

3.18 ACCESSORIES INSTALLATION

3.18.1 Post Caps

NOTE: Coordinate with requirements for top rails or supporting arms.

[Design post caps to accommodate top rail.] Install post caps as recommended by the manufacturer.

3.18.2 Padlocks

Provide padlocks for gate openings and provide chains that are securely attached to gate or gate posts. Provide padlocks keyed alike, and provide two keys for each padlock.

[3.19 GROUNDING

NOTE: Delete this paragraph if grounding is not required. If grounding is required and lightning protection is not part of project design, the requirements in the second set of brackets will be used in lieu of those in the first set of brackets.

Provide fence grounding details when composite type posts are specified where grounding of the fence is required. Grounding requirements may be indicated on the drawings or included in this section.

Specify polyvinyl chloride coated fencing with care when grounding is a project requirement.

Ground fencing as [indicated on drawings][and specified].

[Ground all fences crossed by overhead powerlines in excess of 600 volts, and all electrical equipment attached to the fence.][Ground fences on each side of all gates, at each corner, at the closest approach to each building located within 15 m 50 feet of the fence, and where the fence alignment changes more than 15 degrees. Grounding locations can not exceed 198 m 650 feet. Bond each gate panel with a flexible bond strap to its gate post. Ground fences crossed by powerlines of 600 volts or more at or near the point of crossing and at distances not exceeding 45 m 150 feet on each side of crossing. Provide ground conductor consisting of No. 8 AWG solid copper wire. Provide copper-clad steel rod grounding electrodes 19 mm 3/4 inch by 3.05 m 10 foot long. Drive electrodes into the earth so that the top of the electrode is at least 152 mm 6 inches below the grade. Where driving is impracticable, bury electrodes a minimum of 305 mm 12 inches deep and radially from the fence, with top of the electrode not less than 610 mm 2 feet or more than 2.4 m 8 feet from the fence. Clamp ground conductor to the fence and electrodes with bronze grounding clamps to create electrical continuity between fence posts, fence fabric, and ground rods. Total resistance of the fence to ground cannot exceed 25 ohms

]] 3.20 SECURITY

NOTE: Delete this paragraph if new fencing does not
involve relocation or replacement of existing
security fencing. Depending on nature of fence
work, paragraph may need further elaboration
regarding necessary construction to maintain
perimeter.

Install new security fencing, remove existing security fencing, and perform
related work to provide continuous security for facility. Schedule and
fully coordinate work with Contracting Officer and cognizant Security
Officer.

] 3.21 CLEANUP

Remove waste fencing materials and other debris from the work site.

-- End of Section --