
USACE / NAVFAC / AFCEC / NASA UFGS-27 13 23.00 40 (November 2014)

Preparing Activity: NASA Superseding
UFGS-27 13 23.00 40 (November 2008)
UFGS-40 95 33.23 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2015

SECTION TABLE OF CONTENTS

DIVISION 27 - COMMUNICATIONS

SECTION 27 13 23.00 40

COMMUNICATIONS OPTICAL BACKBONE CABLING

11/14

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 DEFINITIONS
- 1.3 ADMINISTRATIVE REQUIREMENTS
 - 1.3.1 Pre-Installation Meetings
- 1.4 SUBMITTALS
- 1.5 QUALITY CONTROL
 - 1.5.1 Fiber Optic Cable Installer and Splicer Qualifications
 - 1.5.2 Quality Assurance Plan
 - 1.5.3 Manufacturer's Qualifications
 - 1.5.4 Fiber Optic Factory Test Plan
 - 1.5.5 Fiber Optic Field Tests Plan
- 1.6 DELIVERY, STORAGE, AND HANDLING
- 1.7 PROJECT/SITE CONDITIONS

PART 2 PRODUCTS

- 2.1 SYSTEM DESCRIPTION
 - 2.1.1 Fiber Optic Cable Design
 - 2.1.1.1 Fiber Optic Media Types
 - 2.1.1.2 Cable Length
 - 2.1.1.3 Construction
 - 2.1.2 Cable Identification Symbol
 - 2.1.3 Temperature Environment
 - 2.1.4 Splice Compatibility Test
- 2.2 EQUIPMENT
 - 2.2.1 Replacement Cable
 - 2.2.2 Splice Organizers
 - 2.2.3 Pre-Connected Cable Assembly
 - 2.2.4 Optical Patch Panel Assemblies
 - 2.2.5 Fiber Optic Terminal Cabinets
 - 2.2.6 Fiber Optic Enclosures
 - 2.2.7 Fiber Optic Terminations And Connectors
 - 2.2.8 Fiber Optic Pathway System

- 2.2.8.1 Conduit
- 2.2.9 FO Media Tags
- 2.2.10 Buried Warning and Identification Tape
- 2.2.11 Grounding Braid
- 2.3 MATERIALS
 - 2.3.1 Central Core Member
 - 2.3.2 Optical Fibers
 - 2.3.3 Fiber Primary Protective Coating
 - 2.3.4 Optical Fiber Color-Code Coating
 - 2.3.5 Loose Tube Buffering
 - 2.3.6 Colorants
 - 2.3.7 Filling Compound
- 2.4 TESTS, INSPECTIONS, AND VERIFICATIONS
 - 2.4.1 Factory FO Quality Control
 - 2.4.2 Factory Test Certificates
 - 2.4.2.1 Optical Performance
 - 2.4.2.2 Mechanical Performance
 - 2.4.3 Factory Reel Test

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 Fiber Splices
 - 3.1.2 Contractor Damage
 - 3.1.3 Buried Cable
 - 3.1.3.1 Location
 - 3.1.3.2 Field Staking
 - 3.1.3.3 Method of Cable Placement
 - 3.1.3.4 Compaction
 - 3.1.4 Underground Cable
 - 3.1.4.1 Securing Cable
 - 3.1.4.2 Bending
 - 3.1.4.3 Pulling
 - 3.1.4.4 Lubricant
 - 3.1.4.5 Damage and Defects
 - 3.1.4.6 Seal
 - 3.1.5 Cable Installation in Cable Trays
 - 3.1.6 Grounding Systems
 - 3.1.7 Direct Burial System
 - 3.1.7.1 Media Placement
 - 3.1.7.2 Identification Slabs (Markers)
 - 3.1.8 Underground Ducts
 - 3.1.8.1 Connections to Existing Maintenance Holes [and Handholes]
 - 3.1.8.2 Connections to Concrete Pads
 - 3.1.8.3 Connections to Existing Ducts
 - 3.1.9 Reconditioning of Surfaces
 - 3.1.9.1 Unpaved Surface Treatment
 - 3.1.9.2 Paving Repairs
 - 3.1.10 Cable Pulling
 - 3.1.10.1 FO Media Tensions
 - 3.1.10.2 Pulling Eyes
 - 3.1.10.3 Media in Maintenance Manholes, Handholes, and Vaults
 - 3.1.11 Aerial Media
 - 3.1.11.1 Aerial FO Media
 - 3.1.12 Grounding
- 3.2 FIELD QUALITY CONTROL
 - 3.2.1 Test Requirements
 - 3.2.1.1 Single and Multi-Mode OTDR Test
 - 3.2.1.2 End-to-End Attenuation Tests

- 3.2.1.3 End-to-End Bandwidth Tests
- 3.2.2 Field Reel Tests
 - 3.2.2.1 Reel Test Reports
- 3.2.3 Final Acceptance Tests
 - 3.2.3.1 Test Results
- 3.3 CLOSEOUT ACTIVITIES

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC / NASA UFGS-27 13 23.00 40 (November 2014)

Preparing Activity: NASA Superseding
UFGS-27 13 23.00 40 (November 2008)
UFGS-40 95 33.23 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2015

SECTION 27 13 23.00 40

COMMUNICATIONS OPTICAL BACKBONE CABLING 11/14

NOTE: This guide specification covers the requirements for requirements for fiber optic cable systems.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

**References not used in the text will automatically
be deleted from this section of the project
specification when you choose to reconcile
references in the publish print process.**

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM C338	(1993; R 2013) Standard Test Method Softening Point of Glass
ASTM D4976	(2012a) Standard Specification for Polyethylene Plastics Molding and Extrusion Materials

ELECTRONIC INDUSTRIES ALLIANCE (EIA)

ANSI/TIA-455-80C	(2003) FOTP-80 - IEC 60793-1-144 Optical fibres Part 1-44: Measurement Methods and Test Procedures - Cut-off Wavelength
TIA/EIA 455-41-A	(1993a; R 2001) FOTP-41 - Compressive Loading Resistance of Fiber Optic Cables

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE C2	(2012; Errata 2012; INT 1-4 2012; INT 5-7 2013; INT 8-10 2014; INT 11 2015) National Electrical Safety Code
---------	-------------------------------------------------------------------------------------------------------------------

INSULATED CABLE ENGINEERS ASSOCIATION (ICEA)

ICEA S-87-640	(2011) Optical Fiber Outside Plant Communications Cable; 4th Edition
---------------	-------------------------------------------------------------------------

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA 250	(2014) Enclosures for Electrical Equipment (1000 Volts Maximum)
NEMA RN 1	(2005; R 2013) Polyvinyl-Chloride (PVC) Externally Coated Galvanized Rigid Steel Conduit and Intermediate Metal Conduit
NEMA TC 2	(2013) Standard for Electrical Polyvinyl Chloride (PVC) Conduit
NEMA TC 3	(2015) Standard for Polyvinyl Chloride (PVC) Fittings for Use With Rigid PVC Conduit and Tubing
NEMA TC 6 & 8	(2013) Standard for Polyvinyl Chloride (PVC) Plastic Utilities Duct for Underground Installations

NEMA TC 9 (2004) Standard for Fittings for Polyvinyl Chloride (PVC) Plastic Utilities Duct for Underground Installation

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2014; AMD 1 2013; Errata 1 2013; AMD 2 2013; Errata 2 2013; AMD 3 2014; Errata 3-4 2014; AMD 4-6 2014) National Electrical Code

TELECOMMUNICATIONS INDUSTRY ASSOCIATION (TIA)

EIA/TIA 455-165A (1993) Standard for Mode-Field Diameter Measurement by Near-Field Scanning Technique

TIA-455-104 (1993a; R 2013) Standard for FOTP-104 Fiber Optic Cable Cyclic Flexing Test

TIA-455-175 (2003b) FOTP-175 IEC-60793-1-42: Measurement Methods and Test Procedures - Chromatic Dispersion

TIA-455-177 (2003b) FOTP-177 IEC-60793-1-43: Measurement Methods and Test Procedures - Numerical Aperture

TIA-455-33 (2005b; R 2013) Optical Cable Tensile Loading and Bending Test

TIA-455-78-B (2002) FOTP-78 Optical Fibres - Part 1-40: Measurement Methods and Test Procedures - Attenuation

TIA-455-82 (1992b) FOTP-82 Fluid Penetration Test for Fluid-Blocked Fiber Optic Cable

TIA-472D000 (2007b) Fiber Optic Communications Cable for Outside Plant Use

TIA-526-14 (2015c) OFSTP-14A Optical Power Loss Measurements of Installed Multimode Fiber Cable Plant

TIA-526-7 (2015a) OFSTP-7 Measurement of Optical Power Loss of Installed Single-Mode Fiber Cable Plant

TIA-568-C.1 (2009; Add 2 2011; Add 1 2012) Commercial Building Telecommunications Cabling Standard

TIA-568-C.3 (2008; Add 1 2011) Optical Fiber Cabling Components Standard

TIA-569 (2015d) Commercial Building Standard for Telecommunications Pathways and Spaces

TIA-590	(1997a) Standard for Physical Location and Protection of Below Ground Fiber Optic Cable Plant
TIA-758	(2012b) Customer-Owned Outside Plant Telecommunications Infrastructure Standard
TIA/EIA-455	(1998b) Standard Test Procedure for Fiber Optic Fibers, Cables, Transducers, Sensors, Connecting and Terminating Devices, and Other Fiber Optic Components
TIA/EIA-455-25	(2002c; R 2013) FOTP-25 Impact Testing of Optical Fiber Cables
TIA/EIA-455-81	(2000b) FOTP-81 Compound Flow (Drip) Test for Filled Fiber Optic Cable
TIA/EIA-472DAAA	(1993) Detail Specification for All Dielectric Fiber Optic Communications Cable for Outside Plant Use Containing Class 1a 62.5 Um Core Diameter/125 um Cladding Diameter/250 um Coating Diameter Fiber(s).
TIA/EIA-4750000-C	(1996) Generic Specifications for Fiber Optic Connectors (ANSI)
TIA/EIA-598	(2014d) Optical Fiber Cable Color Coding
TIA/EIA-604-3	(2004b; R 2014) Fiber Optic Connector Intermateability Standard (FOCIS), Type SC and SC-APC, FOCIS-3

U.S. DEPARTMENT OF AGRICULTURE (USDA)

RUS Bull 1753F-601	(1994) Specifications for Filled Fiber Optic Cables (PE-90)
--------------------	-------------------------------------------------------------

U.S. DEPARTMENT OF DEFENSE (DOD)

MIL-STD-188-176	(1996; Notice 1) Standardized Profile for Asynchronous Transfer Mode (ATM)
MIL-STD-2042	(2002; Rev B; Notice 1 2007) Fiber Optic Cable Topology Installation Standard Methods for Naval Ships

U.S. GENERAL SERVICES ADMINISTRATION (GSA)

FED-STD-595	(Rev C; Notice 1) Colors Used in Government Procurement
-------------	---------------------------------------------------------

1.2 DEFINITIONS

References in this section to cable refer to fiber optic ("FO") cable. Fiber optic cable consists of optical fibers, strength member[s], and jacketing. Associated components include optical fiber connectors, optical

patch panels, terminal bay cabinets, and splice closures as indicated.

1.3 ADMINISTRATIVE REQUIREMENTS

NOTE: If Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS is not included in the project specification, applicable requirements therefrom should be inserted and the following paragraph deleted.

Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS applies to work specified in this section.

1.3.1 Pre-Installation Meetings

Within [30] [_____] calendar days after [date of award] [date of receipt by him of notice of award], submit for the approval of the Contracting Officer [six (6)] [_____] copies of outline drawings of all equipment to be furnished under this contract, together with pre-construction and installation drawings and documents. Ensure drawings show the general arrangement and overall dimensions of the cable installation, control centers, space requirements, details of any hidden floor supports or ceiling systems and provisions for conduits for external cables. Submit the following for review and approval:

- a. Fiber Optic System Contract Drawings
- b. Detailed Shop Drawings
- c. Qualifications
- d. Quality Assurance Plan

Submit a quality assurance plan for fiber optic cable systems consisting of detailed procedures defining methods to ensure compliance to contract drawings and specifications by drawing control, inspection and procurement records, and test plan showing when and how each system will be tested, material testing, and certification records. Submit test plan to the Technical Representative for approval at least [30] [_____] calendar days prior to the start of testing.

Submit manufacturer's product data for the following items. Ensure data includes a complete list of parts, special tools, and supplies with current unit prices and source of supply:.

- a. Optical Fibers
- b. Fiber Optic Cable Design
- c. Splice Organizers
- d. Pre-Connected Cable Assembly
- e. Fiber Optic Terminal Cabinets
- f. Optical Patch Panel Assemblies

- g. Fiber Optic Media Types
- h. Fiber Optic Terminations and Connectors
- i. Fiber Optic Enclosures
- j. Fiber Optic Cable Installer and Splicer Qualifications
- k. Manufacturer's Qualifications
- l. Fiber Optic System Instructions

1.4 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project.

The Guide Specification technical editors have designated those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

An "S" following a submittal item indicates that the submittal is required for the Sustainability Notebook to fulfill federally mandated sustainable requirements in accordance with Section 01 33 29 SUSTAINABILITY REPORTING.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.][for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submittals with an "S" are for inclusion in the Sustainability Notebook, in conformance to Section 01 33 29 SUSTAINABILITY

REPORTING. Submit the following in accordance with Section 01 33 00
SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Qualifications[; G[, [____]]]

Quality Assurance Plan[; G[, [____]]]

SD-02 Shop Drawings

Fiber Optic System Contract Drawings[; G[, [____]]]

Detailed Shop Drawings[; G[, [____]]]

Record (As-Built) Drawings[; G[, [____]]]

SD-03 Product Data

Optical Fibers[; G[, [____]]]

Fiber Optic Cable Design[; G[, [____]]]

Splice Organizers[; G[, [____]]]

Pre-Connected Cable Assembly[; G[, [____]]]

Fiber Optic Terminal Cabinets[; G[, [____]]]

Optical Patch Panel Assemblies[; G[, [____]]]

Fiber Optic Media Types[; G[, [____]]]

Fiber Optic Terminations and Connectors[; G[, [____]]]

Fiber Optic Enclosures[; G[, [____]]]

SD-06 Test Reports

Factory Test Certificates[; G[, [____]]]

Single and Multi-Mode OTDR Test[; G[, [____]]]

End-to-End Attenuation Tests[; G[, [____]]]

End-to-End Bandwidth Tests[; G[, [____]]]

Fiber Optic Factory Test Plan[; G[, [____]]]

Fiber Optic Field Tests Plan[; G[, [____]]]

SD-07 Certificates

Fiber Optic Cable Installer and Splicer Qualifications[; G[, [____]]]

Manufacturer's Qualifications[; G[, [____]]]

SD-08 Manufacturer's Instructions

1.5 QUALITY CONTROL

1.5.1 Fiber Optic Cable Installer and Splicer Qualifications

Provide technicians installing FO media, splices and performing system tests who are certified and trained in accordance with an approved manufacturers training program, with a minimum of 3 years FO experience in installing equivalent FO systems. Submit data for approval to the [____] Contracting Officer. Submit FO technician qualifications for approval 30 days before splices are to be made on the cable. Certification includes the training, and experience of the individual on specific type and classification of FO media to be provided under this contract.

Contracting officer may require each person who is to perform fiber optic cable splicing to perform a minimum of one acceptable sample splice and termination. Do not incorporate sample splices and terminations in the job.

1.5.2 Quality Assurance Plan

Prepare a quality assurance plan which provides a detailed outline of all testing to be accomplished, addresses whether cladding modes have been stripped prior to testing, source wavelength (peak), spectral width full width/half maximum (FWHM), mode structure, fiber end preparation, and bandwidth measurements of fiber links both greater and less than 1 kilometer. Quality assurance plan includes, as a minimum, a schedule of when tests will be performed relative to installation milestones, specific test procedure that will be used, a list of test equipment that will be used including manufacturer, model number, range, resolution accuracy and conformance to the specified requirements.

1.5.3 Manufacturer's Qualifications

Ensure FO media manufacturer has a minimum of 3 years experience in the manufacturing, assembly, and factory testing of FO media which comply with RUS Bull 1753F-601. Ensure manufacturer provides a list of customers with 3 years of maintenance logs documenting experience with government customers.

1.5.4 Fiber Optic Factory Test Plan

Prepare and provide to the Government for review a test plan for factory and field tests of the FO media. Provide factory Optical Time Domain Reflectometer(OTDR) test data as part of the test report. Provide a list of factory test equipment. Include a FO link performance test plan. Submit the plan at least [30][____] days prior to tests for government approval. Refer to TIA-569 for performance measurement criteria. Conduct tests at all operating bandwidths. Provide calculations for optical power budget and bandwidth as required by RUS Bull 1753F-601 using test method TIA-455-78-B or TIA/EIA-455. Submit test plans and reports to the Government for review and approval.

1.5.5 Fiber Optic Field Tests Plan

Prepare and provide technicians and test equipment for field tests of FO media. Conduct OTDR reel tests at the job site prior to installation. Perform OTDR and end to end tests of all installed media. Conduct tests on

single mode fiber in accordance with TIA-526-7 for single mode fiber and EIA TIA/EIA-526-14A for multi mode fiber.

1.6 DELIVERY, STORAGE, AND HANDLING

Ship media to job site on factory reels in [_____] m [_____] -ft lengths or in factory cartons. Provide a reel drum radius no smaller than the minimum bend radius recommended by the manufacturer for the media. Wind cable on the reel so that unwinding can be done without kinking the cable. Provide 2 meters 6 1/2-feet pigtails of cable at each end of the reel readily accessible for testing. Attach a permanent label on each reel showing length, media, identification number, and date of manufacture. Provide water resistant label and ink on the labels. Apply end seals to each end of the media after testing and before terminating to prevent moisture from entering the cable while stored at the job site. Ensure reels are suitable for outside storage conditions when temperature ranges from minus 40 degrees C to plus 65 degrees C minus 40 degrees F to plus 150 degrees F, with relative humidity from zero to 100 percent. Store equipment, other than FO media, delivered and placed in storage with protection from weather, humidity and temperature variation, dirt and dust, or other contaminants.

1.7 PROJECT/SITE CONDITIONS

Ensure that the buried cable is fed through the plow into the ground at zero tension. Do not allow tension to develop in the cable.

Whenever the plow is stopped, unreel sufficient cable to guard against sudden jerks when the plow is started.

Exercise caution to ensure that the plow is not backed up while the blade is in the ground. Cable can be severely damaged by the plow backing up even a slight amount. During the plowing operation, the plow may strike a buried object or rock that would stop the equipment and necessitate removal of the plow from the ground. When this occurs, remove the plow carefully without backing up. When it is necessary to back the plow, uncover the cable a sufficient distance back from the plow for inspection by the Contracting Officer to determine if there is any damage. Immediately report any damage to the Contracting Officer. Repair or replace damages as directed by the Contracting Officer.

PART 2 PRODUCTS

2.1 SYSTEM DESCRIPTION

Provide fiber optic cables for the duct in the existing cable duct and manhole system and/or directly buried to the facility. Provide modifications as design located within the fiber optic terminal in existing facility buildings.

Provide installation methods and procedures for installing the FO media and pathway system. Include methods and procedures for installing FO media, pathway, splices, and associated hardware. Submit installation procedures and equipment list to the Contracting Officer.

NOTE: Verify design drawings provide physical location details for aerial poles, underground media routes, maintenance holes, handholes, ducts, duct

banks, pathways, cable markers, and related hardware. Show telecommunications rooms, closets, and backboards on drawings. Provide a telecommunications media schedule on the drawings with FO pair, counts, media length and pathway length. Designer should perform pathway fill, (max 40 percent), and media tension calculations for all runs. Ensure materials are listed as RUS certified for the application
<http://www.usda.gov/rus/telecom/materials/material.htm>

Ensure design drawings provide details for installation of the FO cable in accordance with EIA/TIA-590.

Provide detailed drawings for the fiber optic cable and pathway system. Provide single line schematic details of the fiber optic and pathway media, splices, and associated construction materials. Ensure drawings are in AUTOCAD.DXF or compatible format. Provide Registered Communications Distribution Designer (RCDD) approved drawings of the fiber optic system. Include drawing details of fiber optic terminations in equipment rooms. Show final configuration, including location, fiber pair count, pathway innerduct arrangement, and pathway assignment of outside plant.[Verify FO system is compatible with MIL-STD-188-176.][Design Pier FO systems for compatibility with MIL-STD-2042 and NAVSEA drawings.]

2.1.1 Fiber Optic Cable Design

2.1.1.1 Fiber Optic Media Types

Verify FO media meets all performance requirements of TIA-568-C.1, TIA-568-C.3 and the physical requirements of ICEA S-87-640 and TIA/EIA-598.

NOTE: Specify requirements for Fiber Optic media from the following selections:

Fiber Optic Media Type:
(single mode) (multi mode) (hybrid)

Fiber Count: [12][24][48][][216]

Media Optic Characteristics:
Fiber core diameter: [50]mmf [62.5]mmf or []smf
Bandwidth 850nm MHz/km: [500]50,,m [160] 62.5,,m
Bandwidth 1300nm MHz/km: [500]50,,m [500]62.5,,m
Attenuation 850nm dB: [2.5]50,,m [3.0]62.5,,m
Attenuation 1300nm dB: [0.8]50,,m [0.7]62.5,,m
Bending Radius mm: [30]50,,m [30]62.6,,m [30]smf

a. Multi Mode Fiber Media

Provide FO media with outer sheath jacket,[strength member,] ripcords, water blocking material,[optional steel shield,] core tube, and core fibers as installed in a permanent underground pathway system as shown on the construction drawings. Provide FO media with an all glass, graded index material with a nominal core diameter of [62.5][____] microns.

Provide a cladding material for the fiber which is compatible with the core. Center media transmission window at 850 and 1300 nanometer wavelengths, with attenuation at 1300 nanometers less than [2.0][____] dB per kilometer, and minimum bandwidth of 500 MHz-Km.

NOTE: Specify the number of fiber strands. The minimum number of fiber to a facility or building is 12 plus 25 percent spare capacity. Specify loose tube or tight tube design. In general gelatin filled media should be used unless tight tube is required to interface with customer terminal equipment. The loose tube construction is more appropriate where media is subject to numerous bends along the cable route. This includes aerial and long distance runs (over one Km). Tight tube design may be used for exterior direct burial in ducts below the frost line. For Navy projects the preferred underground installation is within a pathway system compliant with EIA/TIA-569. Ensure direct burial installations comply with EIA/TIA-590. Media for Defense Information System Agency (DISA) equipment connection should comply with Mil-Std-188-176.

b. Single Mode Fiber Media

Provide FO single mode media with outer sheath jacket,[strength member,] ripcords, water blocking material,[optional steel shield,] core tube, and core fibers as installed in a permanent underground pathway system as shown on the construction drawings. Provide media with all glass, dual window, graded index material with a core diameter of [____][8.7] microns. Coat fiber with a cladding material which is concentric with the core. Ensure fiber cladding diameter is a nominal 125 microns, and media has a transmission window centered at 1300 and 1550 nanometer wavelengths. Attenuation at 1550 nanometers is less than 0.5 dB per kilometer. Verify FO media complies with TIA/EIA-472DAAA, and TIA-758.

2.1.1.2 Cable Length

Ensure cable is manufactured continuous with no factory splices.

2.1.1.3 Construction

a. Number of Fibers Per Tube Per Cable

36-fiber cable and 72-fiber cable are required as follows:

- (1) Provide 36-fiber cable containing multimode and single mode fibers, with cable core configuration comprised of six loose buffer tubes, each containing six fibers. Color code six fibers in each loose buffer tube using the first colors of the standard Munsell color code, Blue, Orange, Green, Brown, Slate, and White. Color code loose buffer tubes using the standard Munsell color code, Blue, Orange, Green, Brown and Slate. Ensure sixth buffer tube is Pink. Consider single mode fibers last in configuration.
- (2) Provide 72-fiber cable containing multimode and single mode

fibers, with cable core configuration comprised of 12 loose buffer tubes, each containing six fibers. Color code six fibers in each loose buffer tube using the first colors of the standard Munsell color code, Blue, Orange, Green, Brown, Slate and White. Color code loose buffer tubes using the standard Munsell color code, Blue, Orange, Green, Brown, Slate, Red, Black, Yellow, and Violet. Ensure eleventh and twelfth buffer tubes are Blue/White and Orange/White, respectively. Consider single mode fibers last in configuration.

b. Inner Jacket

Locate buffer tubes concentrically around the cable central core member and covered with a polyethylene inner jacket. Ensure inner jacket is [high] [medium] density polyethylene in accordance with ASTM D4976. Fill space between the buffer tubes and inner jacket with a gel compound to prevent air, moisture, or water intrusion in the inner jacket.

c. Pulling Strength Member

Use a ramid type material as pulling strength members in the cable to provide pulling strength of at least [1800] [_____] newton [400] [_____] pounds for the cable during installation.

d. Cable Outer Jacket

Apply black [high] [medium] density, high-molecular weight, polyethylene materials in accordance with ASTM D4976 longitudinally over all the inner jacket and sheathing strength member to form the cable outer jacket. Ensure outer jacket is smooth, concentric, non-nutrient to fungus, and free from holes, splits, blisters, or other imperfections. Overall outside cable diameter cannot exceed [19] [_____] millimeter [0.75] [_____] -inch.

e. Metallic Armor

Provide a metallic armor shield for direct buried cable for additional tensile strength, rodent protection, and high crush and moisture resistance. Provide metallic armoring of metallic tube or steel corrugation-coated with anti-corrosion material, sealed at the longitudinal overlap.

2.1.2 Cable Identification Symbol

First of three lines on the ID symbol employ 5 characters.

First and second characters, from left to right, denotes the number of active optical fibers in the cable.

Third character is a slash.

Fourth and fifth characters denote optical transmission windows which the optical fiber can support. These windows are defined herein as follows:

- a. Fourth character is an "A" or an "O." The "A" denotes a window at a wavelength of 850 nanometers (nm) with an attenuation of 4 dB/kilometer (km) and a bandwidth of 800 MHz-km. Use an "O" character if these requirements are not met.
- b. Fifth character is a "B" or an "O." The "B" denotes a window at a

wavelength of 1,300 nanometer (nm) with an attenuation of 1.0 dB/km and a bandwidth of 1,000 MHz-km. Use an "O" character if these requirements are not met.

Two lower lines of the cable ID symbol indicate multi-mode or single mode fibers, the cable number and the fiber count:

Example:

72/OB	Identifies the number of optical fibers (72) and the optical transmission window (OB - See preceding paragraph)
FM05 : 61-120	Identifies Multi-Mode Fiber Cable 05 with MM Fibers 61 through 120.
FS05 : 13-24	Identifies Single Mode Fiber Cable 05 with SM Fibers 13 through 24.

2.1.1.3 Temperature Environment

Provide fiber optical cable compliant with the mechanical performance requirements herein while used in duct applications where the temperature varies from minus 8 degrees C to plus 38 degrees C 17.6 degrees F to 100 F. Ensure optical performance degradation is less than [five] [_____] percent of the optical performance requirements in the temperature range of minus 20 degrees C to plus 60 degrees C 4 degrees F to 140 degrees F. Do not damage fiber optical cable in storage where the temperature may vary from minus 40 degrees C to plus 65 degrees C 40 degrees F to 149 degrees F.

2.1.1.4 Splice Compatibility Test

When the material of the optic fiber is different from Corning's Class Code No. 1517 for multi-mode graded index fiber and No. 1528 for single-mode fiber, perform and document the Splice Compatibility Test with Vendor as follows:

- a. Select fiber samples from a minimum of [3] [_____] different production lots of the fiber type proposed for the job.
- b. Fabricate and measure a minimum of [10] [_____] fusion splices using fiber from the different production lots and a sample of Corning fiber, Class Code No. 1517 and No. 1528, supplied by the Government.
- c. Measure fusion splices using an Optical Time Domain Reflectometer (OTDR) operating in the region of 1250 through 1350 nm. Ensure the insertion loss of the fusion splice equals the average of two OTDR measurements, one taken with the OTDR installed on the Corning fiber, and the other with the OTDR installed on the vendor's fiber. Verify Vendor's fiber and the Corning fiber are each a minimum of 1 Km in length throughout the testing.
- d. Consider vendor's fiber compatible with the Corning fiber if the maximum splice insertion loss of each of [10] [_____] fusion splices tested measures less than 0.2 dB.

Allow a maximum of three retries on any one splice to obtain a loss of 0.2 dB or less.

Perform these tests under Government supervision.

2.2 EQUIPMENT

2.2.1 Replacement Cable

Provide not less than a 0.5 kilometer reel of each size and type of the manufacturer's furnished cable in addition to cable sections indicated.

Deliver replacement cable reels to the Government as directed by the Contracting Officer.

2.2.2 Splice Organizers

Provide fusion spliced single mode or multi-mode fibers with a protective sleeve covering, stored in an organizer with a minimum of 450 millimeter 18-inches spare coiled buffer tubing. Ensure single mode fibers are spliced last in the splice tray.

Complete a [72] [_____] fiber splice in an outer closure. Organizer assembly, with one tray containing [12] [_____] fusion splices each requires [five] [_____] extra trays, to form the section complete in the inner closure.

Fill space between the inner and outer closures with encapsulating fluid. Factory drill end plates to fit the cable(s) outer diameter.

2.2.3 Pre-Connected Cable Assembly

Provide factory assembled pre-connectorized cable assembly to interface with the patch panel bulkhead feed-through receptacle. Provide dust caps for all terminated fibers.

Ensure multi-mode fiber optic cable assembly is comprised of a single fiber connector, terminated on [three (3)] [_____] meter length of single fiber, multi-mode cable. Verify single fiber cable contains a buffered optical fiber the same as that provided in the multi-fiber cable.

Ensure single fiber optic cable assembly is comprised of a single fiber connector terminated on the [three (3)] [_____] meter length of single fiber, single mode cable. Single fiber cable contains a buffered optical fiber, the same as that provided in the multi-fiber cable. Ensure return loss for single mode connectors is a minimum of [minus 30dB] [_____].

Provide connector/cable interface on both the single and multi-mode cable assemblies able to withstand a tensile force of [110] [_____] newton [25] [_____] pounds without detrimental affects on the connector loss characteristics.

Verify each connectorized cable assembly has a loss of less than or equal to [0.5 dB] [_____].

2.2.4 Optical Patch Panel Assemblies

Provide all cable terminations in optical patch panel assemblies, with patch panel assemblies of the pre-assembled chassis type with associated rack-mounting hardware.

To facilitate the transition between outside plant cable and the

preconnectorized cable assemblies, ensure the fibers are [fusion]
[mechanical] spliced and housed in a splice tray. Position splice tray in
the optical patch panel assembly as indicated. Ensure splice attenuation
does not exceed [0.2] [_____] db. Cover splice with a protective sleeve.

2.2.5 Fiber Optic Terminal Cabinets

Provide front recess only FOT cabinets. Cabinet's frame consists of
vertical and horizontal tubular aluminum extrusions with a minimum wall
thickness of [3.81] [_____] millimeter [.150] [_____] -inches. Ensure front
to rear aluminum extruded corners are at least [3.18] [_____] millimeter
[.125] [_____] -inches thick, and rear door, top panel, and side panels are
a minimum of [1.3] [_____] millimeter [18] [_____] -gage steel. Provide
cabinet with [1.9] [_____] millimeter [14] [_____] gage steel, [7.14]
[_____] millimeter [.281] [_____] inches punched panel/chassis mounting
rails permitting recessed installation of equipment. Place cable entry and
exit holes as indicated. Verify dimensions of cabinet and associated
cabinet hardware are as indicated.

Provide gray color cabinet in accordance with FED-STD-595.

2.2.6 Fiber Optic Enclosures

Provide metallic enclosures for fiber optic data transmission equipment.
NEMA 250, type 4 enclosure. Protect the spliced fibers from moisture and
physical damage. Splice closure provides strain relief for the cable and
the fibers at splice points. Provide full documentation citing conformance
to structural parameters.

2.2.7 Fiber Optic Terminations And Connectors

FO connectors to comply with TIA/EIA-4750000-C and TIA/EIA-604-3.

2.2.8 Fiber Optic Pathway System

Provide an FO pathway system including raceway conduit, duct system, and
maintenance manholes and handholes as shown on the drawings. Provide
pathway materials compliant with TIA-569, and the following commercial
standards for construction materials, NEMA RN 1 (PVC), NEMA TC 2 (PVC),
NEMA TC 3 (PVC), NEMA TC 6 & 8, and NEMA TC 9.

2.2.8.1 Conduit

**NOTE: Delete the following paragraph and specify
the specific conduit requirements for small projects
in this section.**

[Provide conduit as specified in Section 33 71 02 UNDERGROUND ELECTRICAL
DISTRIBUTION.

]2.2.9 FO Media Tags

Provide stainless steel, 41.25 mm 1 5/8-inches in diameter 1.58 mm
1/16-inch thick, and circular in shape.

2.2.10 Buried Warning and Identification Tape

Provide color, type and depth of tape as specified in paragraph "Buried Warning and Identification Tape" in Section 31 00 00 EARTHWORK. Ensure FO media is marked and protected as required by TIA-590.

2.2.11 Grounding Braid

Provide low electrical impedance connections grounding braid from flat tin-plated copper for dependable shield bonding.

2.3 MATERIALS

Verify all materials used within a given cable are compatible with all other materials used in the same cable when such materials come into intimate contact. Ensure all cable components used have no adverse affect on optical transmission or on the mechanical integrity characteristics of the fiber placed in the cable, and all materials used are non-toxic, non-corrosive, and present no dermal hazard.

Minimum required material components applied to fiber optic cable construction are: central core member, color-coded optical fiber, color-coded loose tube buffer with gel-filling, gel-filling around loose tube, inner jacket, pulling strength members, and outer jacket. Variations in sequence and construction structural components will be considered when necessary.

2.3.1 Central Core Member

Include a central core member to serve as a cable core foundation to reduce strain on the fibers but not to serve as a pulling strength member. Ensure material of the central core member is non-metallic.

2.3.2 Optical Fibers

Provide two types of optical fibers, single-mode fiber and multi-mode fiber, within the cable as follows:

- a. Provide Single-Mode (SM) fiber of equivalent [step] [graded] index optical glass, with a fiber core diameter of approximately 8.7 micrometer. Cladding diameter is 125 plus or minus 3 micrometer with core cladding offset less than 1 micrometer. Ensure minimum tensile strength of the fiber after primary protective coating is greater than 350,000 kilopascal 50,000 psi.
- b. Provide multi--Mode (MM) fiber of the [graded] [step] index optical glass type, with a core diameter of [50] [62.5] plus or minus 3 micrometers. Cladding diameter is 125 plus or minus 3 micrometers. Ensure the core-cladding offset is less than 3 micrometer, and the minimum tensile strength of the fiber after primary protective coating is greater than 350,000 kilopascal 50,000 psi.

Softening point of the optical fiber clad material is 1630 degrees C plus or minus 50 degrees C in accordance with ASTM C338, or the optical fiber meets the requirements in paragraph SPLICE COMPATIBILITY TEST.

2.3.3 Fiber Primary Protective Coating

Coat optical fiber with suitable material to preserve the intrinsic high

tensile strength of the glass fiber. Ensure outside diameter of the coated optical fiber is 250 (plus or minus 15) micrometer. Provide coating material which is readily removable, mechanically or chemically, without damaging the optical fibers when the removal is desired.

2.3.4 Optical Fiber Color-Code Coating

Coat primary protective coated SM and MM fibers with a color-code coating for individual fiber identification. Maximum outside diameter of color-code coated fiber is less than 300 micrometer.

2.3.5 Loose Tube Buffering

Surround color-code coated fiber[s] with a loose tube buffering for protection from external mechanical and environmental influences. Fill interior of the tube with a suitable gel-fitting compound to prevent water migration. Color code loose tube buffering for the tube identification. Ensure material of the buffering tube is [PVC] [mylar] [nylon] [_____].

2.3.6 Colorants

Verify color concentrates or inks used to color code the optical fibers and the loose buffer tube are not susceptible to migration and chemical reaction with gel filling compound.

2.3.7 Filling Compound

Ensure inner jacket interior and loose tube buffer cavity contains a gel-type filling compound, of suitable viscosity so that it protects the optical fibers against the ingress of water and/or soluble chemicals, and not flow at the temperature of up to 65 degrees C 149 degrees F. Verify gel filling compound is electrically non-conducting, inert gel-type, waterproof compound, non-toxic, with no dermal hazards, and compatible chemically and mechanically with all cable components and associated splice hardware materials to which it may make contact. Ensure gel filling compound is removable, as required, using commercially available products under field-type conditions.

2.4 TESTS, INSPECTIONS, AND VERIFICATIONS

2.4.1 Factory FO Quality Control

Provide conduit factory quality tests of FO media as required by TIA-472D000.

2.4.2 Factory Test Certificates

Provide fiber optical cable complying with the following optical and mechanical test requirements.

2.4.2.1 Optical Performance

a. Multi-Mode Fibers in the Cable

Verify optical attenuation of each optical fiber in the cable (reeled) is no greater than 1.0 dB/Km at 1300 plus or minus 50 nm optical spectrum window. Measure attenuation on completed cable reel length, and normalized linearly to 1 Km.

Verify bandwidth at minus 3 dB optical power of each optical fiber in the

cable (reeled) is a bandwidth length product, gamma equals 1, greater than 1 GHz-Km at 1300 plus or minus 50 nm optical spectrum window.

Verify numerical aperture of each optical fiber is 0.2 plus or minus 0.015 at 1300 nm optical spectrum window. Ensure method of numerical aperture measurement is in accordance with TIA-455-177, at central wavelength 1300 nm nominal. When this requirement is not met, apply the fusion splice compatibility test.

b. Single-Mode Fibers in the Cable

Verify optical attenuation of each optical fiber in the cable (reeled) is no greater than 0.5 dB/Km at 1300 plus or minus 50 nm optical spectrum window. Measure attenuation on completed cable reel length, and normalized linearly to 1 Km. Ensure measurement method is in accordance with TIA-455-78-B, at central wavelength 1300 nm nominal.

Verify pulse dispersion of each optical fiber in the cable (reeled) is no greater than 3.5 picosecond/nm-Km within the emissive region of 1285-1330 nm. Ensure measurement method is in accordance with TIA-455-175.

Verify mode field diameter at 1300 nm optical spectrum window is within 10 plus or minus 1 micrometer. Ensure measurement method is in accordance with EIA/TIA 455-165A at central wavelength 1300 nm nominal. When this requirement is not met, apply the fusion splice compatibility test.

Verify cut-off wavelength for 1300 nm optical spectrum window is within 1200 plus or minus 70 nm. Ensure measurement method is in accordance with ANSI/TIA-455-80C.

2.4.2.2 Mechanical Performance

a. Minimum Bend Radius

Provide cable which withstands bending to a minimum radius of [10] [_____] times the cable outer diameter without tensile load applied, and of [20] [_____] times the cable outer diameter with maximum tensile load applied (during installation), without damage to cable components or degradation of the optical fiber performance at room temperature.

b. Tensile Strength

Provide fiber optical cable which withstands a pull force of at least [1800] newtons [400 pounds] [_____] to be applied to the pulling strength member during the installation, and a tensile load of at least [300] [_____] newtons during operation without incurring any damage or detriment to fiber optical cable and optical performance. Ensure tensile strength test is in accordance with TIA-455-33.

c. Flexing or Bending Cycles

Provide fiber optical cable which withstands at least [20] [_____] bending cycles at minimum bend radius without damage to the fiber optic cable components or degrading optical performance. Ensure cyclic flexing test is in accordance with TIA-455-104.

d. Crush Resistance

Provide minimum crush resistance of the fiber optical cable greater than

650 newton/centimeter (cm) without damage to cable components or degrading optical performance. Ensure crush resistance test is in accordance with TIA/EIA 455-41-A.

e. Impact Resistance

Provide fiber optical cable capable of withstanding [20] [_____] impacts, at five newton-meters force, without damage to cable components, or degradation of optical performance. Ensure impact resistance test is in accordance with TIA/EIA-455-25.

f. Gel Filling Compound Drip Test

Test optical cable for the ability of the gel filling compound in the interior of the inner jacket and loose tube buffer to resist flow at the temperature range of minus 40 degrees C to 60 degrees C in accordance with TIA/EIA-455-81.

g. Fluid Penetration

Provide optical cable capable of preventing the entry and axial migration of pressurized water when subjected to fluid penetration testing in accordance with TIA-455-82.

2.4.3 Factory Reel Test

Test 100 percent OTDR test of FO media at the factory prior to shipment in accordance with TIA-568-C.1 and TIA-568-C.3. Use TIA-526-7 for single mode fiber and EIA TIA/EIA-526-14A Method B for multi mode fiber measurements. Calibrate OTDR to show anomalies of 0.2 dB minimum. Provide digitized or photographic traces to the Contracting Officer.

PART 3 EXECUTION

3.1 INSTALLATION

Install and test the FO media in accordance with contract drawings, specifications, IEEE C2, NFPA 70, and TIA-590. Provide all necessary power, utility services, technicians, test equipment, calibration equipment as required to perform reel and final acceptance tests of the media. Replace all media which fails the factory or reel tests or final acceptance field tests and re-test at the contractors expense.

3.1.1 Fiber Splices

Splices are not permitted unless shown on the construction drawings.

Field test splices within 24 hours after splice installation. Test splices to demonstrate a maximum 0.2 dB loss. Provide a minimum of 2 meters 6 1/2-feet for routing and testing media. Provide [fusion] [mechanical] type outside plant fiber splices along the fiber route. Make all splice measurements at 1300 nm, plus or minus 5 nm. Mount all splices in trays. Do not increase number of splices.

Protect media ends of unspliced FO media during splicing operations. Cover completed splice with a protective sleeve heat shrink type to restore the protective properties of the fiber coating and buffering. Deviations to the splice, location and pulling plan will be permitted, upon approval by the Contracting Officer, at no additional cost to the Government.

Ensure all fiber colors are continuous from end to end. No switching or staggering of color scheme within the cable at splice points is allowed. Splice fibers in order with multi-mode fibers identified first and single mode fibers at the end.

Bring cables out of the manhole in a controlled environment to perform the fiber fusion splice operation. Complete splice by returning the cable to the manhole such that the excess cable does not impede future entrance and utilization. Secure cable at regular intervals.

3.1.2 Contractor Damage

Promptly repair indicated utility and communications lines or systems damaged during site preparation and construction. When Contractor is advised in writing of the location of a non-indicated line or system, such notice provides that portion of the line or system with "indicated" status in determining liability for damages. In every event, immediately notify the Contracting Officer of damage.

3.1.3 Buried Cable

3.1.3.1 Location

NOTE: Buried cable installation refers to the placement of cables directly in the ground without protection other than their own outer coverage (jackets). The overall buried cable installation may include manholes and hand holes, for splicing, terminating and pull-through purposes.

Verify location of the cable splice overlaps as indicated. Ensure that all cable ends are sufficiently long before cutting.

3.1.3.2 Field Staking

When staking the cable plow or trench line, place stakes at least every 30 meter 100-feet in level country and more frequently in rolling country or in dense vegetation, so that the construction force can sight at least two successive stakes at all times. Stakes should be placed at changes in direction. The beginning and end of all turns should be staked clearly. Where existing buried cable is encountered within [600] [_____] millimeter [2] [_____] -feet of the proposed line, decrease the distance between stakes to a minimum of [3] [_____] meter [10] [_____] -feet. When possible, stakes should project above the vegetation along the line. When a road or other crossings are involved, stakes should be placed at both extremes of the right-of-way.

A stake, with the appropriate number or explanation noted on it, should be used to show the location of each caution point, such as underground utility crossings and culverts; miscellaneous points, such as physical cable protection; and buried cable warning sign locations.

3.1.3.3 Method of Cable Placement

NOTE: Method used in placing the cable will depend

on the exact location of the route, obstructions encountered, soil conditions, and topography of the route. Method which best suits the local conditions and which produces the least amount of disturbance or damage to existing utilities and surrounding areas should be used. Under certain conditions, combinations of placing methods may be advantageous.

Place a warning tape above all direct buried cable.

Ensure depth of buried cable in soil measured from the top of the cable to the surface of the ground is a minimum of [800] [_____] millimeter [30] [_____] inches. When existing utilities are crossed, use hand excavation at a distance of no less than [1.3] [_____] meter [four] [_____] feet on each side of the utility.

a. Open Trench Method

- (1) Ensure trench is free of all rock and debris.
- (2) Pull cable from cable reel truck or dolly and place in the trench by hand.
- (3) Place cable in trench as soon as practical and backfill immediately to avoid cave-in, and ensure safe operational conditions.
- (4) Provide inspection closely behind the cable reel dolly and ensure that the cable lies flat on the trench bottom, and is placed at the required minimum depth.
- (5) Pull cable by hand on each end simultaneously, to remove excess slack, prior to backfilling.
- (6) Backfill trench in [150] [_____] millimeter [six] [_____] inch lifts to ensure proper fill. Compact each backfill lift with hand tamp tools. Hand tamp first lift prior to placing the cable.

b. Direct Plow Method

- (1) Ensure plow is clear of any obstruction which may damage cable and that all rollers on the tractor and on the plow turn freely and are properly located.
- (2) Hand feed cable off the reel at all times to ensure that no damage is done to the cable due to excess tension.
- (3) Closely inspect the cable for any blemish or damage, and ensure a free and continuous flow of the cable from the reel to the plow. Ensure that the cable is plowed at the minimum required depth.

3.1.3.4 Compaction

NOTE: The following method of compaction is recommended: Run the tractor track or tire along and immediately adjacent to both sides of the plow slot; fill in any ground depressions which may

develop with earth to form a mound over the center of the plow slot; and then run the tractor tire over the center slot. Different soil conditions may warrant that other methods of compaction be employed.

Compact the plow slot following the plowing or trenching of wire or cable.

3.1.4 Underground Cable

Provide inner duct assignment of individual cables as indicated. Do not place cables in ducts other than those specified.

Exercise adequate care when handling and storing reels of cable to prevent damage to the cable. Do not install cable with dents, flat spots, or other sheath distortions.

3.1.4.1 Securing Cable

Immediately after cable placement, attach a permanent identification tag as indicated to visible cable sections. Check cables to ensure that the markings are intact.

Support and secure cables and equipment as indicated. Where the specific method of support is not shown, use supports and fasteners to secure cables and equipment in position. Provide metallic supports and fasteners with a corrosion resistant finish. Rout all cables along the interior sides of manholes.

Provide two or more cable hooks per manhole.

Use clamps and straps as necessary to properly secure the cable.

3.1.4.2 Bending

Use caution when bending cable to avoid kinks or other damage to the sheath. Bend radius is as large as possible with a minimum of [250] [_____] millimeter [10] [_____] -inches. Increase minimum radius when necessary to meet cable manufacturer's recommendation. Do not rest cables against any sharp edges.

Pull and splice cable in the manner and at the locations shown.

3.1.4.3 Pulling

Attach pulling lines to both cable ends when cable is destined for bi-directional pull, and fitted with factory-installed pulling eyes. Pull cables not equipped with a pulling eye using a pulling line attached to the cable end by means of a cable grip. Do not use core hitches.

Locate and align cable reels so that the cable is paid out from the top of the reel into the duct or conduit in a long, smooth bend without twisting. Do not pull cable from the bottom of the reel. Use a cable feeder guide of proper dimensions at the mouth to guide the cable into the duct or conduit.

Set up rigging at the pulling end so that the pulling line and cable exit on a line parallel with the duct or conduit to prevent either from rubbing against the edge or mouth. Do not pull cable ends around sheave wheels. When the sheave or pulley cannot be positioned to obtain sufficient cable

end slack for proper racking and splicing with the pulling line attached to the end of the cable, a split cable grip may be used to obtain the necessary slack.

3.1.4.4 Lubricant

Use pulling lubricant to minimize pulling tension and prevent sheath damage when pulling cables into ducts and conduits. Apply lubricant to the cable sheath with a lubricator. When pulling has been completed, wipe the exposed cable ends clean of lubricant.

Ensure lubricants are compatible with and intended for use with plastic-sheathed cables. Do not allow soap and grease type lubricants.

Check all equipment and the pulling set to minimize interruptions once pulling begins. Pull cable without stopping until the required amount of the cable has been placed. When the pulling operation is halted before the pull is completed, do not release the tension of the pulling line. When pulling is resumed, overcome the inertia of the cable by increasing the tension in small steps a few seconds apart until the cable is in motion. Feed the cable from the top of the reel by rotating the reel in the feed direction at the rate of pull. Do not strip cable off the reel by pulling.

3.1.4.5 Damage and Defects

Use a tension monitoring device to ensure that the maximum pulling tension that may be applied to the cable to be pulled into a conduit section is not exceeded. Any damage to the cable due to exceeding the maximum tension will require a new cable furnished by the Contractor.

Carefully inspect cable for sheath defects or other irregularities as it is paid out from the reel. When defects are detected, stop pulling immediately and repair or replace the cable section at the discretion of the Contracting Officer. Maintain a system of communications between pulling and feed locations so that pulling can be stopped instantly, when required.

Hand guide cable through intermediate manholes and into the next duct section when making pull-throughs. Use proper rigging in the intermediate manhole to keep the pulling line and cable aligned with the exit duct to prevent the line or cable from rubbing against the edge of the duct. Set up cables in pull-through manholes and rack before the cable ends in adjacent manholes are set up and racked.

Tie cable ends pulled into manholes, vaults, or terminal locations that are not to be racked or otherwise permanently positioned immediately, in fixed positions to prevent damage to the cables and provide adequate working space.

3.1.4.6 Seal

Seal ducts or innerduct in which cable is placed with urethane foam duct seal. Insert this material between the cable and the duct or innerduct of which it is in, between the innerduct and the duct, and in all unused innerduct, in order to prevent damage to the cable sheath and to prevent the entrance of dirt or water into the manhole or vault.

Provide cables in continuous lengths as required to accomplish the required installation without splices from termination to termination, except where

field splices are specifically shown.

3.1.5 Cable Installation in Cable Trays

Do not install communication cables in the same cable tray with ac power cables.

Install cables placed in cable trays in a neat and orderly manner and not crossed or interlaced with other cables except at breakout points.

Individually retain cables in vertical trays with straps at a maximum of [1800] [_____] millimeter [6] [_____] -feet on center.

3.1.6 Grounding Systems

Ground cables at each termination point or as indicated.

3.1.7 Direct Burial System

NOTE: Specify the depth of media placement.
Designer may specify air blown fiber installed in
new or existing underground duct pending the
approval of the media manufacturer. Air blown fiber
installation and construction materials require
approval by the contracting officer.

Verify installation is in accordance with TIA-590. Under railroad tracks, paved areas, and roadways install cable in conduit encased in concrete. Slope ducts to drain. Excavate trenches by hand or mechanical trenching equipment. Provide a minimum cable cover of 610 mm 24-inches below finished grade. Ensure trenches are not less than 155 mm 6-inches wide and in straight lines between cable markers. Do not use cable plows. Provide bends in trenches with a radius of not less than [915][_____] mm [36][_____] -inches. Where two or more cables are laid parallel in the same trench, space laterally at least 75 mm 3-inches apart. When rock is encountered, remove it to a depth of at least 75 mm 3-inches below the cable and fill the space with sand or clean earth free from particles larger than 6 mm 1/4-inch. Do not unreel and pull cables into the trench from one end. Cable may be unreeled on grade and lifted into position. Provide color, type and depth of warning tape as specified in Section 31 00 00 EARTHWORK.

3.1.7.1 Media Placement

- a. Separate FO media crossing other cables or metal piping from the other cables or pipe by not less than [75][_____] mm [3][_____] -inches of well tamped earth. Do not install FO media under or above traffic signal loops.
- b. Provide media in one continuous length without splices except where splices are shown on the drawings.
- c. Do not allow bends in media which exceed the manufacturers minimum recommended radii. Do not bend media to a radius less than 10 times the outside diameter of the media.
- d. Leave a horizontal slack of approximately 915 mm 3 feet in the ground

on each end of cable runs, on each side of connection boxes, and at points where connections are brought above ground. Where cable is brought above ground, leave additional slack to make necessary connections.

3.1.7.2 Identification Slabs (Markers)

Provide a marker at each change of direction of the cable, over the ends of ducts or conduits which are installed under paved areas and roadways and over each splice. Provide concrete identification markers , approximately 500 mm 20-inches square by 150 mm 6-inches thick and stake mounted warnings meeting the requirements of REA.

3.1.8 Underground Ducts

Construct underground duct as specified in Section 33 71 02 UNDERGROUND ELECTRICAL DISTRIBUTION. Encase in concrete any ducts under roads, paved areas, or railroad tracks.

3.1.8.1 Connections to Existing Maintenance Holes [and Handholes]

For duct line connections to existing structures, break the structure wall out to the dimensions required and preserve the steel in the structure wall. Cut the steel and the duct line envelope.

3.1.8.2 Connections to Concrete Pads

For duct line connections to concrete pads, break an opening in the pad out to the dimensions required and preserve the steel in the pad. Cut the steel and extend it out to tie into the reinforcing of the duct line envelope. Chip out the opening in the pad to form a key for the duct line envelope.

3.1.8.3 Connections to Existing Ducts

Where connections to existing duct lines are indicated, excavate the lines to the maximum depth required. Cut off lines and remove loose concrete from the conduits before new concrete encased ducts are installed. Provide reinforced concrete collar, poured monolithically with the new duct line to take the shear at the joint of the duct lines.

3.1.9 Reconditioning of Surfaces

3.1.9.1 Unpaved Surface Treatment

Restore unpaved surfaces disturbed during the installation of duct or direct burial cable to their original elevation and condition. Carefully preserve existing sod and topsoil and replace after the back-filling is completed. Replace damaged sod with sod of quality equal to that removed. Where the surface is disturbed in a newly seeded area, re-seed the restored surface with the same quantity and formula of seed as that used in the original seeding.

3.1.9.2 Paving Repairs

NOTE: Choose one of the following options.

- [a. Where trenches, pits, or other excavations are made in existing roadways and in other areas of pavement where surface treatment of any kind exists, restore such surface treatment or pavement to the same thickness and to the same kind as previously existed. Ensure surface treatment or pavement matches and ties into the adjacent and surrounding existing surfaces.

]

**NOTE: Insert appropriate Section number and title
in the blank below using format per UFC 1-300-02
UNIFIED FACILITIES GUIDE SPECIFICATIONS (UFGS)
FORMAT STANDARD.**

- [b. Make paving repairs as specified in [_____].

]3.1.10 Cable Pulling

Test duct lines with a mandrel and swab out to remove foreign material before the pulling of FO media. Avoid damage to cables in setting up pulling apparatus or in placing tools or hardware. Do not step on media when entering or leaving the maintenance holes. Do not place media in ducts other than those shown without prior written approval of the Contracting Officer. Roll cable reels in the direction indicated by the arrows painted on the reel flanges. Set up media reels on the same side of the maintenance hole as the pathway section in which the media is to be placed. Level the reel and bring into proper alignment with the pathway section so that the media pays off from the top of the reel in a long smooth bend into the duct without twisting. Do not, under any circumstances roll the media off from the bottom of the reel. Check the equipment set up prior to beginning the media cable pulling to avoid an interruption once pulling has started. Use a cable feeder guide of suitable dimensions between media reel and face of duct to protect media and guide cable into the duct as it is rolled off the reel. As media is rolled off the reel, lubricate and inspect media for sheath defects. When defects are noticed, stop pulling operations and notify the Contracting Officer to determine required corrective action. Stop media pulling if reel binds or does not roll off freely. Rectify cause of binding before resuming pulling operations. Provide media lubricants recommended by the cable manufacturer. Provide 1 meter 3.3-feet of spare media in all manholes and enclosures for final termination and testing.

3.1.10.1 FO Media Tensions

Install FO media as shown on construction drawings. Provide devices to monitor media tension during installation. Do not exceed manufacturers recommended maximum FO tensions and bending radii during installation.

3.1.10.2 Pulling Eyes

Equip media 30 mm 1-1/4-inches in diameter and larger with cable manufacturer's factory installed pulling-in eyes. Provide media with diameter smaller than 30 mm 1-1/4-inches with heat shrinkable type end caps or seals on cable ends when using cable pulling grips. Do not beat rings to prevent grip from slipping into the cable sheath. Use a swivel grip of 19 mm 3/4-inch links between pulling-in eyes or grips and pulling strand.

3.1.10.3 Media in Maintenance Manholes, Handholes, and Vaults

Do not install media utilizing the shortest route, but route along those walls providing the longest route and the maximum spare cable lengths. Form cables to closely parallel walls, not to interfere with duct entrances. Support media on brackets and cable insulators at a maximum of 1220 mm 4-feet. In existing maintenance manholes, handholes, and vaults where new ducts are to be terminated, or where new media are to be installed, modify the existing installation of media, cable supports, and grounding as required with cables arranged and supported as specified for new media.

3.1.11 Aerial Media

**NOTE: Include tensioning and sag data on drawings
in tabular form.**

Provide pole installation as specified in Section 33 71 01 OVERHEAD TRANSMISSION AND DISTRIBUTION. Where physical obstructions make it necessary to pull distribution wire along the line from a stationary reel, use cable stringing blocks to support wire during placing and tensioning operations. Do not place ladders, cable coils, and other equipment on or against the distribution wire. Sag the wire in accordance with the data shown.

3.1.11.1 Aerial FO Media

Keep media ends sealed at all times using cable end caps. Take media from reel only as it is placed. During placing operations, do not bend in a radius less than 10 times the outside diameter of media. Place temporary supports sufficiently close together, and properly tension the media where necessary, to prevent excessive bending. In those instances where spiraling of media is involved, accomplish mounting of enclosures for purposes of loading, splicing, and distribution after the spiraling operation has been completed.

3.1.12 Grounding

**NOTE: Designer should verify the existence of
grounding facilities. It is essential that all
grounding facilities, new and existing, conform with
IEEE C2, NFPA 70, MIL-HDBK-419, and MIL-STD-188-124.**

Ground exposed non current carrying metallic parts of telephone equipment, media sheaths, media splices, and terminals.

3.2 FIELD QUALITY CONTROL

3.2.1 Test Requirements

Ensure test equipment used for verifying installation testing is calibrated by a certified testing company within [3] [_____] weeks of use.

3.2.1.1 Single and Multi-Mode OTDR Test

Ensure the Optical Time Domain Reflectometer (OTDR) conforms to the following minimum requirements:

- a. Operating wavelengths: [1,300] [_____] plus or minus 20 nanometers
- b. Attenuation Range (one way): minimum [15] [_____] dB at 1,300 nm
- c. Attenuation Resolution: [0.01] [_____] dB
- d. Accuracy: plus [0.5] [_____] dB

Use OTDRs with digital readout capability and a means of providing a permanent record in the form of a [strip chart] [photograph] [_____].

3.2.1.2 End-to-End Attenuation Tests

An attenuation measurement test set consists of an optical power meter and an optical power source. Provide attenuation measurement test set in accordance with the applicable National Bureau of Standards (NBS) standards for a stable optical source. Meter may be analog or digital. Include end-to-end attenuation test reading on the test reference loss. Ensure measurement test set conforms to the following minimum requirements:

- a. Operating wavelengths: [1,300] [_____] plus or minus 10 nanometers
- b. Attenuation Range: at least [30] [_____] dB at 1,300 nm
- c. Attenuation Resolution: [0.01] [_____] dB
- d. Accuracy: The accuracy of the attenuation measurement test set is plus or minus [5] [_____] percent.

Ensure optical source is capable of coupling sufficient power into the fiber so that the light received at the meter is within the meter detectability limits.

3.2.1.3 End-to-End Bandwidth Tests

Ensure bandwidth test conforms to the following minimum requirements:

- a. Operating wavelengths: [1,300] [_____] plus or minus 10 nanometers
- b. Bandwidth range: minimum [1000] [_____] megahertz
- c. Bandwidth Resolution: [1] [_____] megahertz
- d. Accuracy: plus or minus [0.5] [_____] megahertz, Measurement Method: [Swept Frequency] [_____]

As a minimum, test each fiber cable before and after installation for any faults or attenuations using an Optical Time Domain Reflectometer (OTDR). Conduct end-to-end attenuation tests after complete installation.

Clearly state all test equipment, test procedures, and testing techniques in the quality assurance plan. Conduct tests in accordance with the approved Quality Assurance Plan. Ensure all field tests are witnessed by the Contracting Officer. Give Contracting Officer at least [20] [_____]

calendar days notice prior to performing each test.

Provide each test sheet with a sign-off blank for both Contractor and the Contracting Officer. Deliver copies of the completed test forms and test results as indicated.

Record sequential cable markings along the cable on the sequential cable form, prior to and after each end of splice point, and submit for approval.

Submit test results on all installed fiber cabling before and after each pre-connectorized cable assembly splice is completed.

Maintain an accurate test record during all field tests.

3.2.2 Field Reel Tests

Perform the following tests on FO media at the job site before it is removed from the cable reel. For cables with factory installed pulling eyes, perform these tests at the factory and submit certified test results with the media. Perform OTDR tests with media on reels and compare factory and field test data.

**NOTE: The purpose of this test is to assure the
Government and the installation contractor that the
media was not damaged during shipment.**

3.2.2.1 Reel Test Reports

Provide results of reel tests to the Contracting Officer within [5][____] working days before installation is to commence. Verify results indicate reel number of the media, manufacturer, type and number of fiber tested, and recorded readings in the report. When reel tests indicate that the media does not comply with factory reel test reports remove the media from the job site and replace with compliant media.

3.2.3 Final Acceptance Tests

Perform end-to-end tests including power meter light source and OTDR tests. Perform OTDR measurements as required by TIA-568-C.1 and TIA-568-C.3. Test single mode fiber in accordance with TIA-526-7 (Optical Power Loss). Test multi mode fiber in accordance with TIA-526-14 (Optical Power Loss).

3.2.3.1 Test Results

Provide results of final acceptance tests (attenuation tests, OTDR traces, etc.), to the Contracting Officer within [5][____] working days after completion of tests.

3.3 CLOSEOUT ACTIVITIES

Submit [____] copies of the Record (As-Built) Drawings to the Contracting Officer.

-- End of Section --