
USACE / NAVFAC / AFCEC / NASA UFGS-11 44 00 (August 2017)
Change 1 - 08/18

Preparing Activity: USACE

Superseding
UFGS-11 44 00 (January 2008)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2018

SECTION TABLE OF CONTENTS

DIVISION 11 - EQUIPMENT

SECTION 11 44 00

FOOD COOKING EQUIPMENT

08/17

PART 1 GENERAL

- 1.1 SUMMARY
- 1.2 GENERAL RELATED SECTIONS AND STANDARDS
- 1.3 REFERENCES
- 1.4 SUBMITTALS

PART 2 PRODUCTS

- 2.1 EQUIPMENT AND SYSTEM STAGING
- 2.2 EXHAUST HOODS OVER COOKING EQUIPMENT
 - 2.2.1 Centrifugal Grease-Extracting Hoods
 - 2.2.1.1 Types of Hoods
 - 2.2.1.1.1 Serve-Over Shelf; Type 1
 - 2.2.1.1.2 Island; Type 2
 - 2.2.1.1.3 Wall-Mounted, Free-Standing; Type 3
 - 2.2.1.1.4 Low Ceiling; Type 4
 - 2.2.1.2 Features
 - 2.2.1.3 Automatic Washdown System
 - 2.2.1.3.1 Features of Operation
 - 2.2.1.3.2 Plumbing Components
 - 2.2.1.4 Fan Control
 - 2.2.1.5 Fire Damper
 - 2.2.1.6 Fan Control Station and Plumbing Enclosure
 - 2.2.1.7 Fire Protection Systems
 - 2.2.1.7.1 Actuating Stations
 - 2.2.1.7.2 Water Spray Fire System In Grease-Extracting Type Hood
 - 2.2.1.7.3 Alarm Connection
 - 2.2.1.8 Vapor proof Lights
 - 2.2.2 Protection
- 2.3 COMMERCIAL FOOD COOKING EQUIPMENT
 - 2.3.1 Ice Machines
 - 2.3.2 Refrigerated Beverage Vending Machines
 - 2.3.3 Refrigerators
 - 2.3.4 Freezers

- 2.3.5 Pre-Rinse Spray Valve
- 2.3.6 Baking Oven
- 2.3.7 Broiler
- 2.3.8 Deep Fryers
- 2.3.9 Griddle
- 2.3.10 Steam Cookers
- 2.3.11 Hot Food Holding Cabinets
- 2.4 PORTABLE FIRE EXTINGUISHER

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 Setting and Connecting
 - 3.1.2 Welding Field Joints
 - 3.1.3 Cleaning and Adjusting
 - 3.1.4 Installation of Hoods
- 3.2 FIELD INSPECTIONS AND TESTS
- 3.3 MANUFACTURER'S WARRANTY
- 3.4 CONTRACTOR'S WARRANTY FOR INSTALLATION

-- End of Section Table of Contents --

2. Food Service Equipment Schedule laid out in accordance with NAVSUP41, or current US Army Quartermaster Center and School equipment schedule specified design requirements.
3. Floor, wall, and ceiling penetrations.
4. Raised bases, retainer curbs, or depressions.
5. Recessed, grated floor drains required for equipment.
6. Exhaust fan curbs, supply fan curbs, exhaust duct, supply duct, and ductwork material.
7. Fire system CO2 tanks, actuating stations.
8. Hoods, plumbing enclosure housing and control panel of automatic washdown system.
9. Disconnect switches.
10. Electrical chases and raceways and plumbing chases.
11. Utility connections to building water, sanitary, electrical, and other utility systems. Convenience outlets at point of use for plug-in equipment.
12. All Contractor built-to-order items, per Food Service Equipment Schedule, shown and coordinated with the specifications.
14. Utility connections to building water, sanitary, gas, electrical, sprinkler, fire alarm, oil, compressed air, steam, and other utility systems. Convenience outlets at point of use for plug-in equipment.

1.1 SUMMARY

The work includes [furnishing and] [installing] [and modifying existing] food service cooking equipment and related work. Verify all existing dimensions, contract drawings, product data and all related conditions prior to commencing rough-in work.

1.2 GENERAL RELATED SECTIONS AND STANDARDS

NOTE: Designate plumbing fixtures as "P" items on plumbing drawings with specific requirements added to Section 22 00 00 PLUMBING, GENERAL PURPOSE.

- a. Refer to section 11 05 40 COMMON WORK RESULTS FOR FOODSERVICE EQUIPMENT for general requirements. Provide detailed Food Service Equipment Schedule as specified in Section 11 06 40.13 FOOD SERVICE EQUIPMENT

SCHEDULE.

- b. Provide detailed Food Service Equipment Schedule conforming to DOD 4000.25-1-M.
- c. Gas-burning equipment must be designed for operation with the type of gas specified and be approved by CSA, conforming to CSA C22.2 No. 109 and CSA Directory.
- d. All electrical work must conform to NFPA 70.
- e. Provide wet chemical fire extinguishing systems in accordance with Section 21 21 03.00 10 WET CHEMICAL FIRE EXTINGUISHING SYSTEM.
- e. Provide connections as part of building sprinkler system, Section 21 13 13.00 20 WET PIPE SPRINKLER SYSTEM, FIRE PROTECTION.
- f. Grease extracting type hoods that have an internal hood fire protection system do not require wet chemical fire extinguishing protection for those components of the exhaust system, and for cooking equipment protected by a UL listed internal hood fire protection system complying to NFPA 96.

1.3 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN SOCIETY OF SANITARY ENGINEERING (ASSE)

ASSE 1001 (2016) Performance Requirements for Atmospheric Type Vacuum Breakers

AMERICAN WELDING SOCIETY (AWS)

AWS A5.8/A5.8M (2011; Amendment 2012) Specification for Filler Metals for Brazing and Braze Welding

| | |
|--|--|
| AWS D1.1/D1.1M | (2015; Errata 1 2015; Errata 2 2016) Structural Welding Code - Steel |
| AWS D10.4 | (1986; R 2000) Recommended Practices for Welding Austenitic Chromium-Nickel Stainless Steel Piping and Tubing |
| AWS D9.1/D9.1M | (2018) Sheet Metal Welding Code |
| CSA GROUP (CSA) | |
| CSA C22.2 No. 109 | (1981; R 2013) Commercial Cooking Appliances |
| CSA Directory | (updated continuously online) Product Index |
| NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) | |
| NFPA 10 | (2018; TIA 18-1) Standard for Portable Fire Extinguishers |
| NFPA 54 | (2018) National Fuel Gas Code |
| NFPA 70 | (2017; ERTA 1-2 2017; TIA 17-1; TIA 17-2; TIA 17-3; TIA 17-4; TIA 17-5; TIA 17-6; TIA 17-7; TIA 17-8; TIA 17-9; TIA 17-10; TIA 17-11; TIA 17-12; TIA 17-13; TIA 17-14; TIA 17-15; TIA 17-16; TIA 17-17) National Electrical Code |
| NFPA 96 | (2017; TIA 17-1) Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations |
| NSF INTERNATIONAL (NSF) | |
| NSF/ANSI 169 | (2012) Special Purpose Food Equipment and Devices |
| NSF/ANSI 2 | (2015) Food Equipment |
| NSF/ANSI 4 | (2016) Commercial Cooking, Rethermalization and Powered Hot Food Holding and Transportation Equipment |
| NSF/ANSI 51 | (2012) Food Equipment Materials |
| NSF/ANSI 52 | (2017) Supplemental Flooring |
| SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION (SMACNA) | |
| SMACNA 1767 | (2001) Kitchen Ventilation Systems & Food Service Equipment Fabrication & Installation Guidelines, 1st Edition |
| SMACNA 1966 | (2005) HVAC Duct Construction Standards Metal and Flexible, 3rd Edition |

U.S. DEPARTMENT OF DEFENSE (DOD)

DOD 4000.25-1-M (2006) MILSTRIP - Military Standard
Requisitioning and Issue Procedures

U.S. DEPARTMENT OF ENERGY (DOE)

Energy Star (1992; R 2006) Energy Star Energy
Efficiency Labeling System (FEMP)

U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA)

EPA WaterSense (2006) WaterSense Water Efficiency
Labeling System

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1910 Occupational Safety and Health Standards

29 CFR 1910-SUBPART D Walking - Working Surfaces

UNDERWRITERS LABORATORIES (UL)

UL 1598 (2008; Reprint Oct 2012) Luminaires

UL 197 (2010; Reprint Jan 2018) UL Standard for
Safety Commercial Electric Cooking
Appliances

UL 489 (2016) UL Standard for Safety Molded-Case
Circuit Breakers, Molded-Case Switches and
Circuit-Breaker Enclosures

UL 710 (2012; Reprint Mar 2017) UL Standard for
Safety Exhaust Hoods for Commercial
Cooking Equipment

UL 763 (2018) UL Standard for Safety
Motor-Operated Commercial Food Preparing
Machines

UL Electrical Appliance (2012) Electrical Appliance and
Utilization Equipment Directory

1.4 SUBMITTALS

**NOTE: Review Submittal Description (SD) definitions
in Section 01 33 00 SUBMITTAL PROCEDURES and edit
the following list to reflect only the submittals
required for the project.**

**The Guide Specification technical editors have
designated those items that require Government
approval, due to their complexity or criticality,
with a "G." Generally, other submittal items can be
reviewed by the Contractor's Quality Control
System. Only add a "G" to an item, if the submittal**

is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

The "S" following a submittal item indicates that the submittal is required for the Sustainability eNotebook to fulfill federally mandated sustainable requirements in accordance with Section 01 33 29 SUSTAINABILITY REPORTING. Locate the "S" submittal under the SD number that best describes the submittal item.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.] [information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submittals with an "S" are for inclusion in the Sustainability eNotebook, in conformance to Section 01 33 29 SUSTAINABILITY REPORTING. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Contractor's Field Verification Data

SD-02 Shop Drawings

Detail Drawings; G[, [_____]]

Schedule; G[, [_____]]

Exhaust Hoods Over Cooking Equipment; G[, [_____]]

Utilities; G[, [_____]]

Custom Fabricated Equipment; G[, [_____]]

Installation Instructions and Diagrams

SD-03 Product Data

Commercial Food Cooking Equipment; G[, [_____]]

Exhaust Hoods Over Cooking Equipment; G[, [____]]

[Energy Star label for Ice Machine; S]

[Energy Star label for Refrigerated Beverage Vending Machine; S]

[Energy Star label for Refrigerator; S]

[Energy Star label for Freezer; S]

[Energy Star label for Baking Oven; S]

[Energy Star label for Deep Fryer; S]

[Energy Star label for Griddle; S]

[Energy Star label for Steam Cooker; S]

[Energy Star label for Hot Food Holding Cabinet; S]

[EPA WaterSense label for Pre-Rinse Spray Valve; S]

SD-06 Test Reports

Field Test Reports

Exhaust Hood Air-Balance Report

SD-07 Certificates

NSF Certification

UL Certification

SD-08 Manufacturer's Instructions

Commercial Food Cooking Equipment

Exhaust Hoods over Cooking Equipment

SD-10 Operation and Maintenance Data

Commercial Food Cooking Equipment, Data Package 2; G[, [____]]

Submit in accordance with Section 01 78 23 OPERATION AND
MAINTENANCE DATA.

SD-11 Closeout Submittals

Manufacturer's Warranty

Contractor's Warranty for Installation

PART 2 PRODUCTS

2.1 EQUIPMENT AND SYSTEM STAGING

NOTE: Indicate the configuration and layout for all food preparation equipment, with interior elevations and equipment identified by number. Show "Food Service Equipment Schedule" on the drawings using the same identification numbers and as indicated on the current US Army Quartermaster Center and School equipment schedule. Ensure that all Contractor built-to-order items, per Food Service Equipment Schedule", are shown and coordinated with the specifications.

Designer must coordinate with other sections for final connection of equipment.

Details of particular equipment and installations are provided on Naval Food Service Division drawings. Use these NAVFSD drawings as a basis for the project details. Contact Supported Command to assist with identification of kitchen equipment necessary to meet mission requirements.

Indicate on drawings the location of each manual activation station.

- a. Submit detail drawings, as specified, including insulation and utility requirements for all food cooking equipment, custom fabricated equipment, along with equipment schedule. Drawings scale 1:50 1/4 inch minimum. Schedule in the same format as the equipment schedule on the drawings.
- b. Include coordination of delivery through existing finished opening and vertical handling limitations within the building. Advise the Contracting Officer of all discrepancies prior to ordering equipment. Submit Contractor's Field Verification Data prior to the preconstruction meeting.
- c. Provide rough-in and connect utilities to equipment in accordance with requirements specified in other sections of this specification and in accordance with the physical dimensions, capacities, manufacturer's instructions, and other requirements of the equipment furnished. Submit all installation instructions and diagrams.

2.2 EXHAUST HOODS OVER COOKING EQUIPMENT

NOTE: Seismic restraints for kitchen hoods must conform to Guidelines for Seismic Restraints of Kitchen Equipment (SMACNA Los Angeles Chapter). See Appendix 1 of SMACNA Fabrication Guidelines. Include requirement in seismic zones 3 and 4.

Hood design will be in accordance with NFPA 96, ASHRAE, and the ACGIH Industrial Ventilation Handbook. Designer will indicate type, size, shape,

make-up air, and detail of hoods and the required standard cubic meters per second cubic feet per minute, meters per second feet per minute (velocity), static pressure, and duct collar size for exhaust/make-up air on the drawings. Grease extracting automatic washdown hoods will be specified for new construction. Filter type hoods may be used in existing facilities where conditions prevent the use of grease extractor hoods.

Conform to NFPA 96 and UL 710. Conform to SMACNA 1966. [Provide seismic restraints in accordance with SMACNA 1767.] The hood must not vary from design listing of air requirements or static pressure by more than five percent. Fabricate from 1.2 mm 18 gage thick stainless steel. Run electrical wiring in conduit or raceways. When total hood length is more than 3600 mm 12 feet long, provide hoods individually complete in all respects, of approximately equal length less than 3600 mm 12 feet long, and mounted end to end.

2.2.1 Centrifugal Grease-Extracting Hoods

Fabricate in factory. Provide high-velocity type with average throat inlet air velocity of [5] [_____] mps [1,000] [_____] fpm and duct velocity of [9] [_____] mps [1,800] [_____] fpm. Provide air inlet above and parallel to equipment for full length of hood. Provide hood which will remove 95 percent of extraneous matter in air with non-removable grease-extracting baffles located in plenum chamber. The use of filters, cartridges, rotating parts, removable parts, or constantly running water is not acceptable.

2.2.1.1 Types of Hoods

**NOTE: Delete types not indicated for the project.
If a type is not used, state "not used" at the
subparagraph, to avoid renumbering.**

Provide the following hood types as indicated:

2.2.1.1.1 Serve-Over Shelf; Type 1

Provide over [charbroilers,] [fryers,] [_____,] [and] [griddles] on serving lines. Mount hood 1370 to 1450 mm 54 to 57 inches above finished floor.

2.2.1.1.2 Island; Type 2

Provide over [steam-jacketed kettles,] [fry pans,] [ovens,] [broilers,] [_____,] [and] [steamers] located remote from walls. Mount at height indicated.

2.2.1.1.3 Wall-Mounted, Free-Standing; Type 3

Provide over [ranges,] [_____,] [broilers,] [doughnut fryers,] [griddles,] [ovens,] [steam-jacketed kettles,] [and] [fryers] located along wall. Mount at height indicated.

2.2.1.1.4 Low Ceiling; Type 4

Provide over [_____] [and] [_____] where low ceiling restricts installation of Type 1, 2, or 3.

2.2.1.2 Features

Provide the following:

- a. Automatic washdown system.
- b. Fan control.

NOTE: Delete references to fire dampers in air
inlet if fire dampers are included in exhaust
ductwork connecting to hood.

- c. Damper controls.
- d. Fan control station and plumbing enclosure.
- e. Fire protection system, for hoods over [tilting frying pans,]
[charbroilers,] [fryers,] [griddles,] [doughnut fryers,] [_____,]
[deep-fat fryers,] [and] [broilers].
- f. Vapor-proof lights.

2.2.1.3 Automatic Washdown System

Provide system that automatically washes internal portions of hood for an adjustable period of between 0 and 15 minutes. Provide for activation by time clock or upon operation of fire damper.

2.2.1.3.1 Features of Operation

- a. Shut off supply and exhaust fans, if running, at beginning of cleaning cycle.
- b. Subject accumulated contaminates on internal surfaces with water at [60] [82] degrees C [140] [180] degrees F and a water pressure of 0.275 MPa 40 psi. Provide pressure reducing valve.
- c. [Pump] [Inject] detergent into hot water supply line to create wash-water.
- d. Provide scrubbing action by directing wash-water through manifolds and then through spray nozzles placed so that all internal surfaces are reached with streams of wash-water.
- e. Collect wash-water and grease within hood and pipe to outside of hood to point indicated for indirect connection to building plumbing system.
- f. End wash cycle by timer.

2.2.1.3.2 Plumbing Components

Provide brass or stainless steel spray heads or nozzles and stainless steel

distribution manifold in each hood. Provide the following in fan control station and plumbing enclosure:

| | |
|-----------------------------|----------------------|
| Water solenoid valve | |
| Shut-off valve | |
| Shock absorber | |
| Pressure gage | |
| Temperature gage | |
| Line strainer | |
| Vacuum breaker | conform to ASSE 1001 |
| Detergent reservoir | 3 L 1 gallon minimum |
| Detergent [pump] [injector] | |
| Check valve | |
| Timer | |
| Pressure reducing valve | |

2.2.1.4 Fan Control

Locate in fan control station and plumbing enclosure. Provide delay-time starter on starter leg of exhaust fan so supply fan starts first and run 5 seconds before exhaust fan starts, to insure the required balance in exhausted and make-up air flow. Provide the following operations:

- a. Interconnection with washdown system to effect shutoff.

NOTE: Delete references to fire dampers in air inlet if fire dampers are included in exhaust ductwork connecting to hood.

- b. Interconnection with fire dampers to effect shutoff of fans.
- c. Operation by time clock.
- d. Operation by manual push buttons labeled "start" and "stop".

2.2.1.5 Fire Damper

NOTE: Delete references to damper if fire dampers are included in exhaust ductwork connecting to hood.

Provide mechanically driven damper and damper control. Activate by

heat-sensing thermostat set to react to temperature of 176 degrees C 350 degrees F in exhaust duct at hood. Activation of damper must cause the following additional actions:

- a. Shut off exhaust and supply fans of hood.
- b. Shut off fuel source and electric power to equipment under hood.
- c. Initiate automatic washdown system.

2.2.1.6 Fan Control Station and Plumbing Enclosure

NOTE: Do not locate control cabinet for hoods on serving line tray slide support walls or on drop wall above serving line tray slide.

Provide flush-mounted enclosure. Wire and plumb in factory. Include the following:

- a. Plumbing components of washdown system.
- b. Components required for fan control, including manual push buttons and interlocks with other systems.
- c. Components required to operate fire protection system.
- d. Time clock capable of being programmed by the week to operate fan system and automatic washdown system and of maintaining time cycle after being overridden by manual push buttons.
- e. Labeled light indicating when exhaust fan and supply fan are operating.
- f. Labeled light indicating when automatic washdown system is operating.

2.2.1.7 Fire Protection Systems

NOTE: Select fire protection system based on cost and local regulations. If kitchen cannot tolerate time lost for clean-up in event of dry chemical release, or if kitchen return air is tied into building system return air, do not use that system. Ensure that actuating systems are indicated on drawings.

Provide a pre-engineered [[dry] [wet] chemical system in accordance with Division 21, Section 21 23 00.00 20 DRY CHEMICAL FIRE EXTINGUISHING FOR KITCHEN CABINET] [[liquid foam system] [water spray system] in accordance with NFPA 96]. [Include water spray in plenum of hood.] Include micro-switch for electric power and fuel shut off to equipment under hood and a fuel shut-off and reset button. Exposed piping under hood and surface nozzles to be stainless steel or chrome plated. Paint exposed piping running to hood with rust-inhibiting aluminum paint. Provide electrical wiring, contactors, shunt breakers, electrical control for gas valves, and other electrical components required to install fire systems in accordance with Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM.

2.2.1.7.1 Actuating Stations

Provide manual actuating station and remote manual actuating station as indicated. Clearly label actuating station as "Hood Fire Protection" and specific device protected.

2.2.1.7.2 Water Spray Fire System In Grease-Extracting Type Hood

**NOTE: If water spray system is specified, make sure
it is compatible with building sprinkler system.**

Include wall-mounted control panel with pilot lights for indicating when system is operational, not operational, and on fire alert. Provide audible fire alarm, unions, hand valve, valve switch, and pressure switch. Include duct nozzles and plenum nozzles. Provide water pipe to control panel and from control panel to hood. Provide connections as part of building sprinkler system, Section 21 13 13.00 20 WET PIPE SPRINKLER SYSTEM, FIRE PROTECTION.

2.2.1.7.3 Alarm Connection

**NOTE: If exhaust hood fire system is to be
connected to building alarm system, the work must be
included in other sections and coordinated.**

Provide capability to signal operational readiness and to generate electronic signal when hood fire system is activated. Provide connection point for building alarm system. Provide system to connection point and connect in accordance with Section [____][28 31 74.00 20 INTERIOR FIRE ALARM SYSTEM].

2.2.1.8 Vapor proof Lights

Provide,[at Type 2 and Type 3 hoods,] incandescent or fluorescent lights in accordance with UL 1598 or UL 1598. Locate switches for operating hood lights on face of hood in lower [right] [____] corner.

2.2.2 Protection

Protect each exhaust hood system that serves cooking equipment, associated exhaust hood system ducts, and all cooking equipment served by the exhaust hood system with a wet chemical fire extinguishing system.

2.3 COMMERCIAL FOOD COOKING EQUIPMENT

**NOTE: The following commercial food cooking
equipment must meet FEMP/ Energy Star energy
efficiency requirements:**
 Beverage Vending Machines (Often Vendor supplied
 and installed)
 Fryers
 Griddles
 Hot Food Holding Cabinets

Ice-Machines Air-Cooled
Ice-Machines Water Cooled
Ovens
Refrigerators
Freezers
Steam Cookers
The following item must meet EPA Watersense
requirements
Pre-Rinse Spray Valves (WaterSense)

Cooking equipment selected will have as a minimum
the efficiency rating determined in under
"Energy-Efficient Products" at . Indicate the
equipment operating characteristics, including rated
energy efficiency, on the drawings.

All commercial cooking equipment must conform to 29 CFR 1910, CSA, NSF, UL
and other related standards as stated herein and in Section 11 05 40 COMMON
WORK RESULTS FOR FOODSERVICE EQUIPMENT. All equipment must bear NSF
Certification and UL Certification labels.

- a. Supply all gas fueled appliances with installed automatic shut-off
device(s), as well as manual shut-offs device conforming to NFPA 96.
In accordance with NFPA 54, equip gas burners and pilots located in
enclosed compartments with automatic shut off of gas supply if burners
fail to ignite, or pilot is extinguished.
- [b. Provide electrical cooking appliances conforming to UL 197, UL 489,
UL 763, and UL Electrical Appliance.
- c. Provide specialty cooking equipment conforming to the requirements of
NSF/ANSI 169, NSF/ANSI 2, NSF/ANSI 4, and NSF/ANSI 51. Floor areas
adjacent to cooking areas must conform to NSF/ANSI 52 and
29 CFR 1910-SUBPART D.]

2.3.1 Ice Machines

[____]. Provide ice machine that is Energy Star labeled. Provide data
identifying Energy Star label for ice machine.

2.3.2 Refrigerated Beverage Vending Machines

**NOTE: Vending Machines are often Vendor furnished
and installed. Keep the bracketed text below if
vending machines are part of the project
requirements.**

[[____]. Provide refrigerated beverage vending machine that is Energy
Star labeled. Provide data identifying Energy Star label for refrigerated
beverage vending machine.]

2.3.3 Refrigerators

[____]. Provide refrigerator that is Energy Star labeled. Provide data
identifying Energy Star label for refrigerator.

2.3.4 Freezers

[____]. Provide freezer that is Energy Star labeled. Provide data identifying Energy Star label for freezer.

2.3.5 Pre-Rinse Spray Valve

[____]. Provide pre-rinse spray valve that is WaterSense labeled. Provide data identifying EPA WaterSense label for pre-rinse spray valve.

2.3.6 Baking Oven

[____]. Provide baking oven that is Energy Star labeled. Provide data identifying Energy Star label for baking oven.

2.3.7 Broiler

[____]

2.3.8 Deep Fryers

[____]. Provide deep fryer that is Energy Star labeled. Provide data identifying Energy Star label for deep fryer.

2.3.9 Griddle

[____]. Provide griddle that is Energy Star labeled. Provide data identifying Energy Star label for griddle.

2.3.10 Steam Cookers

[____], [3][4][5][6] pan. Provide steam cooker that is Energy Star labeled. Provide data identifying Energy Star label for steam cooker.

2.3.11 Hot Food Holding Cabinets

[____]. Provide hot food holding cabinet that is Energy Star labeled. Provide data identifying Energy Star label for hot food holding cabinet.

2.4 PORTABLE FIRE EXTINGUISHER

Provide [wall mount for] portable fire extinguisher conforming to NFPA 10, within [____] feet of cooking area.

PART 3 EXECUTION

3.1 INSTALLATION

Do not install items that show visual evidence of biological growth.

Perform installation in accordance with the manufacturer's printed instructions. Refer to section 11 05 40 COMMON WORK RESULTS FOR FOODSERVICE EQUIPMENT for detailed installation, project closeout, and warranty requirements. Lay out work in advance to prevent damage to building, piping, wiring, or equipment as a result of cutting for installation.

3.1.1 Setting and Connecting

Install equipment plumb and level. Except for mobile and adjustable-leg equipment, securely anchor and attach items and accessories to walls, floors, or bases with stainless steel bolts. Flash food service cabinets located in wall openings to the walls with 0.9 mm 20 gage thick stainless steel. Seal around equipment flashing and flanges, at walls, floor, and ceiling in accordance with Section 07 92 00 JOINT SEALANTS. Provide continuous fillers without opening.

3.1.2 Welding Field Joints

Weld stainless steel by the electric fusion method. Provide where required by and in accordance with AWS A5.8/A5.8M, AWS D1.1/D1.1M, AWS D10.4, AND AWS D9.1/D9.1M. Accomplish brazing with silver solder for joining copper tubing to brass and bronze connection fitting and for no other purpose.

3.1.3 Cleaning and Adjusting

Test and adjust equipment for proper operation. Test rotating components and motors for proper rotation. Lubricate moving parts if suggested by manufacturer's literature. Prior to acceptance of project, clean and sanitize equipment both inside and outside.

3.1.4 Installation of Hoods

Install hoods in accordance with NFPA 96 to remain free from vibration under all conditions of operation.

3.2 FIELD INSPECTIONS AND TESTS

Inspect equipment, fixtures, and material after installation for compliance with the applicable standards. Upon completion of inspection perform operational tests on each piece of equipment to determine that equipment and components, including controls, safety devices, and attachments, operate as specified and are properly installed and adjusted. Test all water, drain, gas, steam, oil, refrigerant, and liquid carrying components for leaks. Notify the Contracting Officer 14 calendar days prior to testing. Submit Field Test Reports and [_____] copies of the Exhaust Hood Air-Balance Report to the Contracting Officer.

3.3 MANUFACTURER'S WARRANTY

Submit all manufacturers' signed warranties to Contracting Officer prior to final commissioning and acceptance.

3.4 CONTRACTOR'S WARRANTY FOR INSTALLATION

Submit contractor's warranty for installation to the Contracting Officer prior to final commissioning and acceptance.

-- End of Section --