

\*\*\*\*\*

USACE / NAVFAC / AFCEC

UFGS-33 11 23 (November 2009)

Change 1 - 08/17

-----

Preparing Activity: NAVFAC

Superseding

UFGS-33 11 23 (August 2008)

UFGS-33 23 00.00 20 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2024

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 33 - UTILITIES

#### SECTION 33 11 23

#### NATURAL GAS AND LIQUID PETROLEUM PIPING

11/09, CHG 1: 08/17

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 RELATED REQUIREMENTS
- 1.3 SUBMITTALS
- 1.4 QUALITY ASSURANCE
  - 1.4.1 Welder's Qualifications
  - 1.4.2 PE Welder's Qualifications
  - 1.4.3 Safety Standards
- 1.5 DELIVERY, STORAGE, AND HANDLING

#### PART 2 PRODUCTS

- 2.1 MATERIALS AND EQUIPMENT
- 2.2 PIPE AND FITTINGS
  - 2.2.1 Aboveground and Within Buildings and Vaults
  - 2.2.2 Underground Polyethylene (PE)
  - 2.2.3 Risers
  - 2.2.4 Transition Fittings
- 2.3 SHUTOFF VALVES, BELOW GROUND
  - 2.3.1 Metallic Ball Valves
  - 2.3.2 PE Ball or Plug Valves
- 2.4 VALVES, ABOVEGROUND
  - 2.4.1 Shutoff Valves, Sizes Larger Than 50 Millimeters 2 Inches
  - 2.4.2 Shutoff Valves, Sizes 50 Millimeters 2 Inches and Smaller
  - 2.4.3 Line Appliance Pressure Regulator and Shutoff Valve
  - 2.4.4 Service Regulators
  - 2.4.5 Earthquake Automatic Gas Shutoff Valve
- 2.5 GAS METER
  - 2.5.1 Utility Monitoring and Control System (UMCS) / Energy Monitoring and Control (EMCS) or Automatic Meter Reading Interfaces
  - 2.5.2 Measurement Configuration
- 2.6 GAS EQUIPMENT CONNECTORS

- 2.7 VALVE BOX
- 2.8 CASING
- 2.9 BURIED UTILITY WARNING AND IDENTIFICATION TAPE
- 2.10 HANGERS AND SUPPORTS
- 2.11 WELDING FILLER METAL
- 2.12 PIPE-THREAD TAPE
- 2.13 BOLTING (BOLTS AND NUTS)
- 2.14 GASKETS
- 2.15 IDENTIFICATION FOR ABOVEGROUND PIPING
- 2.16 (LIQUEFIED PETROLEUM GAS) LPG CONTAINERS AND ACCESSORIES

## PART 3 EXECUTION

- 3.1 INSTALLATION
  - 3.1.1 Excavating and Backfilling
  - 3.1.2 Piping
    - 3.1.2.1 Cleanliness
    - 3.1.2.2 Aboveground Steel Piping
    - 3.1.2.3 Buried Plastic Lines
    - 3.1.2.4 Connections to Existing Pipeline
    - 3.1.2.5 Wrapping
  - 3.1.3 Valves
    - 3.1.3.1 Stop Valve and Shutoff Valve
  - 3.1.4 Gas Service Installation
    - 3.1.4.1 Service Line
    - 3.1.4.2 Service Regulator
    - 3.1.4.3 Gas Meter
  - 3.1.5 Pipe Sleeves
  - 3.1.6 Piping Hangers and Supports
  - 3.1.7 Final Connections
    - 3.1.7.1 Domestic Water Heaters
    - 3.1.7.2 Kitchen Equipment
- 3.2 FIELD QUALITY CONTROL
  - 3.2.1 Metal Welding Inspection
  - 3.2.2 PE Fusion Welding Inspection
  - 3.2.3 Pressure Tests
  - 3.2.4 System Purging
- 3.3 SCHEDULE

-- End of Section Table of Contents --

\*\*\*\*\*

USACE / NAVFAC / AFCEC

UFGS-33 11 23 (November 2009)

Change 1 - 08/17

-----

Preparing Activity: NAVFAC

Superseding

UFGS-33 11 23 (August 2008)

UFGS-33 23 00.00 20 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2024

\*\*\*\*\*

### SECTION 33 11 23

#### NATURAL GAS AND LIQUID PETROLEUM PIPING

11/09, CHG 1: 08/17

\*\*\*\*\*

NOTE: This guide specification covers the requirements for exterior and interior fuel gas piping.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

\*\*\*\*\*

\*\*\*\*\*

NOTE: This guide specification is intended for use when specifying buried polyethylene piping of up to **200 mm 8 inches** in nominal pipe size at pressures and other conditions governed by ASME B31.8, "Gas Transmission and Distribution Piping Systems," and aboveground steel piping both outside (up to **1.50 meters 5 feet** beyond exterior walls) and within buildings in compliance with NFPA 54, "Fuel Gas Piping."

\*\*\*\*\*

\*\*\*\*\*

NOTE: The following information must be shown on the project drawings:

1. Layout and location of piping.
2. Location of appurtenances, valves, etc.
3. Details of method of mounting piping.
4. Capacity of pressure regulators
5. Location and capacity of LP gas containers.

\*\*\*\*\*

## PART 1 GENERAL

### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

#### AMERICAN GAS ASSOCIATION (AGA)

AGA ANSI B109.1	(2000) Diaphragm Type Gas Displacement Meters (Under 500 cubic ft./hour Capacity)
AGA ANSI B109.2	(2000) Diaphragm Type Gas Displacement Meters (500 cubic ft./hour Capacity and Over)
AGA ANSI B109.3	(2019) Rotary-Type Gas Displacement Meters
AGA ANSI B109.4	(2016) Self-Operated Diaphragm-Type Natural Gas Service Regulators for Nominal Pipe Size 1½ inches (32 mm) and Smaller with Outlet Pressures of 2 psig (13.8 kPa) and Less
AGA XR0603	(2006; 8th Ed) AGA Plastic Pipe Manual for Gas Service

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

ANSI Z21.41/CSA 6.9	(2023) Quick-Disconnect Devices for Use with Gas Fuel Appliances
ANSI Z21.45	(1995) Flexible Connectors of Other Than All-Metal Construction for Gas Appliances
ANSI Z21.69/CSA 6.16	(2015; R 2020) Connectors for Movable Gas Appliances

AMERICAN SOCIETY OF CIVIL ENGINEERS (ASCE)

ASCE 25-16	(2016) Earthquake-Activated Automatic Gas Shutoff Devices
------------	---

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

ASME B1.1	(2024) Unified Inch Screw Threads (UN, UNR, and UNJ Thread Form)
ASME B1.20.1	(2013; R 2018) Pipe Threads, General Purpose (Inch)
ASME B16.3	(2021) Malleable Iron Threaded Fittings, Classes 150 and 300
ASME B16.5	(2020) Pipe Flanges and Flanged Fittings NPS 1/2 Through NPS 24 Metric/Inch Standard
ASME B16.9	(2018) Factory-Made Wrought Buttwelding Fittings
ASME B16.11	(2022) Forged Fittings, Socket-Welding and Threaded
ASME B16.33	(2024) Manually Operated Metallic Gas Valves for Use in Gas Piping Systems Up to 175 psi, (Sizes NPS 1/2 Through NPS 2)
ASME B16.38	(2023) Large Metallic Valves for Gas Distribution Manually Operated, NPS 2 1/2 (DN 65) to NPS 12 (DN 300), 125 psig 8.6 bar) Maximum
ASME B16.39	(2020) Standard for Malleable Iron Threaded Pipe Unions; Classes 150, 250, and 300
ASME B16.40	(2019) Manually Operated Thermoplastic Gas Shutoffs and Valves in Gas Distribution Systems
ASME B18.2.1	(2012; R 2021) Square, Hex, Heavy Hex, and Askew Head Bolts and Hex, Heavy Hex, Hex Flange, Lobed Head, and Lag Screws (Inch Series)

ASME B18.2.2	(2022) Nuts for General Applications: Machine Screw Nuts, and Hex, Square, Hex Flange, and Coupling Nuts (Inch Series)
ASME B31.8	(2022; Supplement 2022) Gas Transmission and Distribution Piping Systems
ASME BPVC SEC VIII D1	(2019) BPVC Section VIII-Rules for Construction of Pressure Vessels Division 1

ASTM INTERNATIONAL (ASTM)

ASTM A53/A53M	(2024) Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless
ASTM A193/A193M	(2024) Standard Specification for Alloy-Steel and Stainless Steel Bolting Materials for High-Temperature Service and Other Special Purpose Applications
ASTM A194/A194M	(2024) Standard Specification for Carbon Steel, Alloy Steel, and Stainless Steel Nuts for Bolts for High-Pressure or High-Temperature Service, or Both
ASTM D2513	(2018a) Standard Specification for Polyethylene (PE) Gas Pressure Pipe, Tubing, and Fittings
ASTM D2683	(2020) Standard Specification for Socket-Type Polyethylene Fittings for Outside Diameter-Controlled Polyethylene Pipe and Tubing

MANUFACTURERS STANDARDIZATION SOCIETY OF THE VALVE AND FITTINGS INDUSTRY (MSS)

MSS SP-58	(2018) Pipe Hangers and Supports - Materials, Design and Manufacture, Selection, Application, and Installation
-----------	--

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 54	(2024) National Fuel Gas Code
NFPA 58	(2024; TIA 24-2) Liquefied Petroleum Gas Code

SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION (SMACNA)

SMACNA 1981	(2008) Seismic Restraint Manual Guidelines for Mechanical Systems, 3rd Edition
-------------	--

U.S. DEPARTMENT OF DEFENSE (DOD)

MIL-STD-101	(2014; Rev C) Color Code for Pipelines and for Compressed Gas Cylinders
-------------	---

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

49 CFR 192 Transportation of Natural and Other Gas by Pipeline: Minimum Federal Safety Standards

49 CFR 195                                      Transportation of Hazardous Liquids by Pipeline

## 1.2 RELATED REQUIREMENTS

Section 23 03 00.00 20 BASIC MECHANICAL MATERIALS AND METHODS applies to this section, with additions and modifications specified herein.

### 1.3 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-03 Product Data

Valve Box

Pressure Regulator

Gas Equipment Connectors

Valves

Warning and Identification Tape

Risers

Transition Fittings

Gas meter

[ LPG Containers and Accessories]

SD-07 Certificates

Welder's Qualifications

PE Welder's Qualifications

Welder's Identification Symbols

SD-08 Manufacturer's Instructions

PE Pipe and Fittings

Submit manufacturer's installation instructions and  
manufacturer's visual joint appearance chart.

#### 1.4 QUALITY ASSURANCE

##### 1.4.1 Welder's Qualifications

Comply with [ASME B31.8](#). The steel welder must have a copy of a certified [ASME B31.8](#) qualification test report. The PE welder must have a certificate from a PE pipe manufacturer's sponsored training course. Contractor must also conduct a qualification test. Submit each [welder's identification symbols](#), assigned number, or letter, used to identify work of the welder. Affix symbols immediately upon completion of welds. Welders making defective welds after passing a qualification test must be given a requalification test and, upon failing to pass this test, must not be permitted to work this contract.

##### 1.4.2 PE Welder's Qualifications

Prior to installation, Contractor must have supervising and installing personnel trained by a PE pipe manufacturer's sponsored course of not less than one week duration, or present proof satisfactory to the Contracting Officer that personnel are currently working in the installation of PE gas distribution lines.

##### 1.4.3 Safety Standards

[49 CFR 192](#) [and [49 CFR 195](#)].



## 1.5 DELIVERY, STORAGE, AND HANDLING

Handle, transport, and store plastic pipe and fittings carefully. Plug or cap pipe ends during transportation or storage to minimize dirt and moisture entry. Do not subject to abrasion or concentrated external loads. Discard PE pipe sections and fittings that have been damaged.

## PART 2 PRODUCTS

### 2.1 MATERIALS AND EQUIPMENT

Conform to NFPA 54 and with requirements specified herein. Supply piping to appliances or equipment must be at least as large as the inlets thereof.

### 2.2 PIPE AND FITTINGS

#### 2.2.1 Aboveground and Within Buildings and Vaults

\*\*\*\*\*  
NOTE: For steam electric generation stations,  
industrial and institutional plants, and central  
heating plants, use Schedule 80 black steel piping  
in accordance with ANSI B31.1 for threaded joints.  
\*\*\*\*\*

- a. Pipe: Black steel in accordance with ASTM A53/A53M, Schedule [40] [80], threaded ends for sizes 50 mm 2 inches and smaller; otherwise, plain end beveled for butt welding.
- b. Threaded Fittings: ASME B16.3, black malleable iron.
- c. Socket-Welding Fittings: ASME B16.11, forged steel.
- d. Butt-Welding Fittings: ASME B16.9, with backing rings of compatible material.
- e. Unions: ASME B16.39, black malleable iron.
- f. Flanges and Flanged Fittings: ASME B16.5 steel flanges or convoluted steel flanges conforming to ASME BPVC SEC VIII D1. Flange faces must have integral grooves of rectangular cross sections which afford containment for self-energizing gasket material.

#### 2.2.2 Underground Polyethylene (PE)

PE pipe and fittings are as follows:

- a. Pipe: ASTM D2513, 690 kPa (gage) 100 psig working pressure, Standard Dimension Ratio (SDR), the ratio of pipe diameter to wall thickness, 11.5 maximum.
- b. Socket Fittings: ASTM D2683.
- c. Butt-Fusion Fittings: ASTM D2513, molded.

#### 2.2.3 Risers

Manufacturer's standard riser, transition from plastic to steel pipe with 0.18 to 0.30 mm 7 to 12 mil thick epoxy coating. Use swaged gas-tight

construction with O-ring seals, metal insert, and protective sleeve. Provide [remote bolt-on or bracket] [or] [wall-mounted] riser supports [as indicated].

#### 2.2.4 Transition Fittings

\*\*\*\*\*  
NOTE: Choose the applicable options from the following.  
\*\*\*\*\*

- [ a. Steel to Plastic (PE): As specified for "riser" except designed for steel-to-plastic with tapping tee or sleeve. Coat or wrap exposed steel pipe with heavy plastic coating.
- ][b Plastic to Plastic: [Manufacturer's standard slip-on PE mechanical coupling, molded, with stainless-steel ring support, O-ring seals, and rated for 1035 kPa (gage) 150 psig gas service.] [Manufacturer's standard fused tapping (PE-to-PE) tee assembly with shut-off feature.]

#### ]2.3 SHUTOFF VALVES, BELOW GROUND

##### ]2.3.1 Metallic Ball Valves

\*\*\*\*\*  
NOTE: Choose this paragraph or the paragraph (below) PE BALL OR PLUG VALVES.  
\*\*\*\*\*

[ASME B16.33] [or] [ASME B16.38] corrosion-resisting steel, with threaded or flanged ends. Provide polytetrafluoroethylene (PTFE) seats.

##### ][2.3.2 PE Ball or Plug Valves

\*\*\*\*\*  
NOTE: PE ball or plug valves: Class 1 location means not more than 10 living units, homes and separate living units within apartment buildings, along a 1600 meters one mile length of pipeline; Class 2 location means not more than 46 living units, along a 1600 meters one mile length of pipeline; Class 3 location means not more than 20 persons normally congregating in any one building or outdoor location; and Class 4 location means any location where Class 1 to 3 population densities are exceeded. The Class 4 class factor also applies where there are buildings of more than three stories.  
\*\*\*\*\*

ASME B16.40 and ASTM D2513, Class C materials (PE 2306 or PE 3406), strength rating of Class [1 location with class factor of 0.32] [2 location with class factor of 0.25] [3 location with class factor of 0.25] [4 location with class factor of 0.20], and SDR matching PE pipe dimensions and working pressure.

#### ]2.4 VALVES, ABOVEGROUND

[ Provide lockable valves where indicated.

#### 2.4.1 Shutoff Valves, Sizes Larger Than 50 Millimeters 2 Inches

\*\*\*\*\*  
NOTE: Choose one of the options below.  
\*\*\*\*\*

\*\*\*\*\*  
NOTE: Do not use cast-iron material for valve body  
or gas-meter body in seismic zones 3 and 4.  
\*\*\*\*\*

[ [Cast-iron] [or] [steel] body ball valve with flanged ends in accordance with ASME B16.38. Provide PTFE seats.

] [Cast-iron body plug valve in accordance with ASME B16.38, nonlubricated, wedge-mechanism or tapered lift plug, and flanged ends.

#### 2.4.2 Shutoff Valves, Sizes 50 Millimeters 2 Inches and Smaller

\*\*\*\*\*  
NOTE: Choose one of the options below.  
\*\*\*\*\*

[ [Bronze] [Steel] body ball valve in accordance with ASME B16.33, full port pattern, reinforced PTFE seals, threaded ends, and PTFE seat.

] [[Bronze] [Steel] body plug valve in accordance with ASME B16.33, straightway, taper plug, regular pattern with a port opening at least equal to the internal pipe area or round port full bore pattern, non-lubricated, PTFE packing, flat or square head stem with lever operator, 860 kPa (gage) 125 psig rating, threaded ends.

#### 2.4.3 Line Appliance Pressure Regulator and Shutoff Valve

Provide regulators conforming to [ANSI Z21.18/CSA 6.3 for appliances] [ANSI Z21.78/CSA 6.20 for combination gas controls for gas appliances] [, and ANSI Z21.80/CSA 6.22 for line pressure regulators]. Provide shutoff valves conforming to [ANSI Z21.15/CSA 9.1 for manually controlled gas shutoff valves] [and] [ANSI Z21.21/CSA 6.5 for automatic shutoff valves for gas appliances].

#### 2.4.4 Service Regulators

- a. Provide ferrous bodied pressure regulators for individual service lines, capable of reducing distribution line pressure to pressures required for users. Provide service regulators conforming to AGA ANSI B109.4 CGA-6.18-M95 with full capacity internal relief[ and overpressure shutoff]. Set pressure relief at a lower pressure than would cause unsafe operation of any connected user.
- b. Adjust regulators for liquified petroleum gas to 2.5 to 3 kPa 10 to 12 inches of water column, with pressure relief set at 4 kPa 16 inches of water column.
- c. Provide regulator(s) having a single port with orifice diameter no greater than that recommended by the manufacturer for the maximum gas flow rate at the regulator inlet pressure. Provide regulator valve vent of resilient materials designed to withstand flow conditions when pressed against the valve port, capable of regulating downstream

pressure within limits of accuracy and limiting the buildup of pressure under no-flow conditions to 50 percent or less of the discharge pressure maintained under flow conditions. Provide a self-contained service regulator, and pipe not exceeding exceed 50 mm 2 inch size.

#### 2.4.5 Earthquake Automatic Gas Shutoff Valve

\*\*\*\*\*  
**NOTE: Provide this earthquake protective feature primarily for seismic zones 3 and 4.**  
\*\*\*\*\*

ASCE 25-16 and UL listed or AGA listed or International Association of Plumbing and Mechanical Officials (IAPMO) listed. The valve may be either pendulum or ball construction with [remote [, pneumatic] [electronic] [or] [electric]] actuator.

#### 2.5 GAS METER

\*\*\*\*\*  
**NOTE: Do not use cast-iron material for valve body or gas-meter body in seismic zones 3 and 4.**  
\*\*\*\*\*

[AGA ANSI B109.1] [AGA ANSI B109.2] [AGA ANSI B109.3] [pipe] [pedestal] mounted, [diaphragm] or [bellow] [style], [cast-iron] [enamel coated steel] [aluminum] case. [Provided with a strainer immediately upstream]. Provide [diaphragm-type meter conforming to AGA ANSI B109.1 for required flow rates less than 500 cfh, or AGA ANSI B109.2, for flow rates 500 cfh and above] [rotary-type displacement meter conforming to AGA ANSI B109.3] as required by local gas utility supplier. Provide combined [odometer-type] register totalizer index, UV-resistant index cover, water escape hole in housing, and means for sealing against tampering. Provide temperature-compensated type meters sized for the required volumetric flow rate and suitable for accurately measuring and handling gas at pressures, temperatures, and flow rates indicated. Provide meters with over-pressure protection as specified in 49 CFR 192 and ASME B31.8. Provide meters that are tamper-proof [with] [frost protection] [fungus protection][seismic protection]. Provide meters with a pulse switch initiator capable of operating up to speeds of 500 maximum pulses per minute with no false pulses and requiring no field adjustments. Provide not less than one pulse per 2.83 cubic meters 100 cubic feet of gas. Minimum service life must be 30,000,000 cycles.

##### 2.5.1 Utility Monitoring and Control System (UMCS) / Energy Monitoring and Control (EMCS) or Automatic Meter Reading Interfaces

Provide gas meters capable of interfacing the output signal, equivalent to volumetric flow rate, with the existing UMCS / EMCS for data gathering in units of cubic meters cubic feet. Provide meters that do not require power to function and deliver data. Output signal must be either a voltage or amperage signal that can be converted to volumetric flow by using an appropriate scaling factor.

##### 2.5.2 Measurement Configuration

For buildings that already have a gas meter with a pulse output, ensure that the pulse output is connected to a data gathering device (i.e.

electric meter). For buildings where a natural gas meter already exists but does not have a pulse output, add a pulse kit to the existing meter and tie the output to a data gathering device. If the existing gas meter will not accept a pulse kit or if no meter exists a new natural gas meter must be installed, also requiring a pulse output to a data gathering device. Ensure the pulse frequency and electronic characteristics are compatible with the existing data gathering device, if any.

## 2.6 GAS EQUIPMENT CONNECTORS

- a. Flexible Connectors: ANSI Z21.45.
- b. Quick Disconnect Couplings: ANSI Z21.41/CSA 6.9.
- c. Semi-Rigid Tubing and Fittings: ANSI Z21.69/CSA 6.16.

## 2.7 VALVE BOX

Provide [street valve box with cast-iron cover and two-piece 130 mm 5 1/4 inch shaft-slip valve box extension] [rectangular concrete valve box, sized large enough for removal of valve without removing box]. Cast the word "Gas" into the box cover. Use valve box for areas as follows:

- a. Roads and Traffic Areas: Heavy duty, cast iron cover.
- b. Other Areas: Standard duty, concrete cover.

[ c. Airfields and Special Loadings: As detailed.

## 2.8 CASING

Where indicated at railroad or other crossing, provide ASTM A53/A53M, galvanized pipe, Schedule 40 [, with extruded polyethylene coating].

## 2.9 BURIED UTILITY WARNING AND IDENTIFICATION TAPE

Provide detectable aluminum-foil plastic-backed tape or detectable magnetic plastic tape manufactured specifically for warning and identification of buried piping. Tape must be detectable by an electronic detection instrument. Provide tape in rolls, 75 mm 3 inch minimum width, color-coded yellow for natural gas, with warning and identification imprinted in bold black letters continuously and repeatedly over entire tape length. Warning and identification must be "CAUTION BURIED GAS PIPING BELOW" or similar wording. Use permanent code and letter coloring unaffected by moisture and other substances contained in trench backfill material.

## 2.10 HANGERS AND SUPPORTS

MSS SP-58.

## 2.11 WELDING FILLER METAL

ASME B31.8.

## 2.12 PIPE-THREAD TAPE

Antiseize and sealant tape of polytetrafluoroethylene (PTFE).

## 2.13 BOLTING (BOLTS AND NUTS)

Stainless steel bolting; ASTM A193/A193M, Grade B8M or B8MA, Type 316, for bolts; and ASTM A194/A194M, Grade 8M, Type 316, for nuts. Dimensions of bolts, studs, and nuts must conform with ASME B18.2.1 and ASME B18.2.2 with coarse threads conforming to ASME B1.1, with Class 2A fit for bolts and studs and Class 2B fit for nuts. Bolts or bolt-studs must extend through the nuts and may have reduced shanks of a diameter not less than the diameter at root of threads. Bolts must have American Standard regular square or heavy hexagon heads; nuts must be American Standard heavy semifinished hexagonal.

## 2.14 GASKETS

Fluorinated elastomer, compatible with flange faces.

## 2.15 IDENTIFICATION FOR ABOVEGROUND PIPING

MIL-STD-101 for legends and type and size of characters. For pipes 19 mm 3/4 inch od and larger, provide printed legends to identify contents of pipes and arrows to show direction of flow. Color code label backgrounds to signify levels of hazard. Make labels of plastic sheet with pressure-sensitive adhesive suitable for the intended application. For pipes smaller than 19 mm 3/4 inch od, provide brass identification tags 40 mm 1 1/2 inches in diameter with legends in depressed black-filled characters.

## [2.16 (LIQUEFIED PETROLEUM GAS) LPG CONTAINERS AND ACCESSORIES

\*\*\*\*\*  
NOTE: The maximum size permitted under DOT specifications is 0.50 cubic meter 1,000 pounds water capacity. Fuse plugs may be used in addition to the spring-loaded safety relief valves for aboveground ASME containers of 4 1/2 cubic meters 1,200 gallons water capacity or less.  
\*\*\*\*\*

NFPA 58, [DOT] [or] [ASME] containers with appurtenances, system working pressure, minimum design pressure, that is LPG vapor pressure at 38 degrees C 100 degrees F, and water capacity as indicated. Provide containers with piping and fittings, [fuse plugs], [hose and flexible hose connectors], [gas-air mixer], strainer, and marking conforming to NFPA 58.

## ]PART 3 EXECUTION

### 3.1 INSTALLATION

\*\*\*\*\*  
NOTE: To assist the designer in selecting the proper documents for a specific project, the following scope in accordance with documents is provided:  
  
1. NFPA 54 Scope: "1.1.1 Applicability: ... Coverage of piping systems extends from the point of delivery to the connections with each gas utilization device. For other than indicated liquified petroleum gas systems, the point of

delivery is the outlet of the service meter assembly, or the outlet of the service regulator or service shutoff valve when no gas meter is provided. For undiluted liquified petroleum gas systems, the point of delivery is the outlet of the first stage pressure regulator..."

2. ASME B31.8 Scope: "802.11... This code covers the design, fabrication, installation, inspection, testing and safety aspects of operation and maintenance of gas transmission and distribution systems, including gas pipelines, gas compressor stations, gas metering and regulation stations, gas mains, and service lines up to the outlet of the customer's meter set assembly....802.14 This code does not apply to...(c) piping beyond the outlet of the customers meter set assembly..."

\*\*\*\*\*

Install gas piping, appliances, and equipment in accordance with NFPA 54. [Install distribution piping in accordance with ASME B31.8.] [Install and store liquefied petroleum gas piping, appliances, and equipment in accordance with NFPA 58.]

#### 3.1.1 Excavating and Backfilling

Perform excavating and backfilling of pipe trenches as specified in Section 31 00 00 EARTHWORK. Place pipe directly in trench bottom and cover with minimum 75 mm 3 inches of sand to top of pipe. If trench bottom is rocky, place pipe on a 75 mm 3 inch bed of sand and cover as above. Provide remaining backfilling. Coordinate provision of utility warning and identification tape with backfill operation. Bury utility warning and identification tape with printed side up at a depth of 305 mm 12 inches below the top surface of earth or the top surface of the subgrade under pavements.

#### 3.1.2 Piping

Cut pipe to actual dimensions and assemble to prevent residual stress. [Provide supply connections entering the buildings as indicated.] Within buildings, run piping parallel to structure lines and conceal in finished spaces. Terminate each vertical supply pipe to burner or appliance with tee, nipple and cap to form a sediment trap. To supply multiple items of gas-burning equipment, provide manifold with inlet connections at both ends.

##### 3.1.2.1 Cleanliness

Clean inside of pipe and fittings before installation. Blow lines clear using 550 to 690 kPa (gage) 80 to 100 psig clean dry compressed air. Rap steel lines sharply along entire pipe length before blowing clear. Cap or plug pipe ends to maintain cleanliness throughout installation.

##### 3.1.2.2 Aboveground Steel Piping

Determine and establish measurements for piping at the job site and accurately cut pipe lengths accordingly. For 50 mm 2 inch diameter and smaller, use threaded or socket-welded joints. For 65 mm 2 1/2 inch diameter and larger, use flanged or butt-welded joints.

- a. Threaded Joints: Where possible use pipe with factory-cut threads, otherwise cut pipe ends square, remove fins and burrs, and cut taper pipe threads in accordance with [ASME B1.20.1](#). Provide threads smooth, clean, and full-cut. Apply anti-seize paste or tape to male threads portion. Work piping into place without springing or forcing. Backing off to permit alignment of threaded joints will not be permitted. Engage threads so that not more than three threads remain exposed. Use unions for connections to [valves] [meters] for which a means of disconnection is not otherwise provided.
- b. Welded Joints: Weld by the shielded metal-arc process, using covered electrodes and in accordance with procedures established and qualified in accordance with [ASME B31.8](#).
- c. Flanged Joints: Use flanged joints for connecting welded joint pipe and fittings to valves to provide for disconnection. Install joints so that flange faces bear uniformly on gaskets. Engage bolts so that there is complete threading through the nuts and tighten so that bolts are uniformly stressed and equally torqued.
- d. Pipe Size Changes: Use reducing fittings for changes in pipe size. Size changes made with bushings will not be accepted.
- e. Painting: Paint new ferrous metal piping, including supports, in accordance with Section [09 90 00](#) PAINTS AND COATINGS. Do not apply paint until piping tests have been completed.
- f. Identification of Piping: Identify piping aboveground in accordance with [MIL-STD-101](#), using adhesive-backed or snap-on plastic labels and arrows. In lieu of labels, identification tags may be used. Apply labels or tags to finished paint at intervals of not more than [15 meters 50 feet](#). Provide two copies of the piping identification code framed under glass and install where directed.

#### 3.1.2.3 Buried Plastic Lines

Provide totally PE piping. Prior to installation, obtain printed instructions and technical assistance in proper installation techniques from pipe manufacturer.[ When joining new PE pipe to existing pipe line, ascertain what procedural changes in the fusion process is necessary to attain optimum bonding.]

- a. Jointing Procedures: Use jointing procedures conforming to [AGA XR0603](#) and [49 CFR 192](#) that have been qualified by test in accordance with 49 CFR 192.283 and proven to make satisfactory joints. Personnel make joints in plastic pipe must be qualified in accordance with 49 CFR 192.285, under the submitted and approved procedure by making a satisfactory specimen joint that passes the required inspection and test. Joints in plastic pipe must be inspected by a person qualified by 49 CFR 192.287 under the applicable procedure. Certificates that qualify the applicable procedures, joining personnel, and inspectors must be submitted and approved and must be on file with the Contracting Officer prior to making these joints.
- b. PE Piping: Prior to installation, Contractor must have supervising and installing personnel, certified in accordance with paragraph WELDER'S QUALIFICATIONS. Provide fusion-welded joints except where transitions have been specified. Use electrically heated tools,



thermostatically controlled and equipped with temperature indication. (Where connection must be made to existing plastic pipe, contractor must be responsible for determination of compatibility of materials and procedural changes in fusion process necessary to attain maximum integrity of bond.)

- c. Laying PE Pipe: Bury pipe 600 mm 24 inches below finish grade [or deeper when indicated]. Lay in accordance with manufacturer's printed instructions.

#### 3.1.2.4 Connections to Existing Pipeline

When making connections to live gas mains, use pressure tight installation equipment operated by workmen trained and experienced in making hot taps. For connections to existing underground pipeline or service branch, use transition fittings for dissimilar materials.

#### 3.1.2.5 Wrapping

Where connection to existing steel line is made underground, tape wrap new steel transition fittings and exposed existing pipe having damaged coating. Clean pipe to bare metal. Initially stretch first layer of tape to conform to the surface while spirally half-lapping. Apply a second layer, half-lapped and spiraled as the first layer, but with spirals perpendicular to first wrapping. Use 0.025 mm 10 mil minimum thick polyethylene tape. In lieu of tape wrap, heat shrinkable 0.025 mm 10 mil minimum thick polyethylene sleeve may be used.

#### 3.1.3 Valves

Install valves approximately at locations indicated. Orient stems vertically, with operators on top, or horizontally. [Provide support for valves to resist operating torque applied to PE pipes.]

##### 3.1.3.1 Stop Valve and Shutoff Valve

Provide stop valve on service branch at connection to main and shut-off valve on riser outside of building.

#### 3.1.4 Gas Service Installation

[Gas service line, service regulator and gas company meter must be installed in accordance with Section 33 51 15 NATURAL-GAS / LIQUID PETROLEUM GAS DISTRIBUTION PIPELINES. ]Installations must be in accordance with 49 CFR 192 and ASME B31.8. Contractor must submit and use only tested and approved work procedures. Contractor must use only welders and jointers who have been recently qualified by training and test for joining and installing the gas pipe material used on this job. The finished product must be inspected by a person qualified to inspect joints made by the particular procedures used to make joints.

\*\*\*\*\*

**NOTE: This section specifies service line, service regulator, and gas company meter. These components must be installed in accordance with 49 CFR 192 and ASME B31.8 to allow gas systems to be accepted by Utility Privatization Contractors.**

**These installations are also specified in Section**

**33 51 15 NATURAL-GAS / LIQUID PETROLEUM GAS DISTRIBUTION PIPELINES.** If that section is not included in the contract documents, delete the reference statement above and include the paragraphs below in this specification.

Where project documentation includes Section **33 51 15 NATURAL-GAS / LIQUID PETROLEUM GAS DISTRIBUTION PIPELINES**, delete the paragraphs below and include the reference statement above.

\*\*\*\*\*

#### [3.1.4.1 Service Line

Install service line, branch connection to the main, and riser in accordance with **49 CFR 192** and **ASME B31.8**. Provide a minimum of **485 mm 18 inches** cover or encase the service line so that it is protected. Install service line so that no undue stress is applied to the pipe, connection, or riser. Install approved riser and terminate with an approved isolation valve, EFV and automatic shutoff device. After laying of pipe and testing, backfill the trench in accordance with Section **31 00 00 EARTHWORK**.

Where steel pipe is used as service line, install corrosion prevention coating and cathodic protect for the steel service line. Where connected to an existing cathodically protected steel pipe, ensure electrical continuity from the riser to the branch connection to the main. Install a dielectric fitting on the riser to prevent electrical continuity to the above ground piping.

Where plastic pipe is used as the service line, make joints in accordance with procedures qualified by test. Personnel joining plastic pipe must be qualified by making a satisfactory specimen joint that passes the required inspection and test listed in 49 CFR 192.285. Inspection must be made by inspectors qualified in evaluating joints made under the specific joining procedure, as required by 49 CFR 192.287.

#### 3.1.4.2 Service Regulator

Install service regulator in accordance with **49 CFR 192** and **ASME B31.8** and this specification ensuring that the customer's piping is protected from over pressurization should the service regulator fail. A 3/8 inch tapped fitting equipped with a plug must be provided on both sides of the service regulator for installation of pressure gauges for adjusting the regulator. For inside installations, route the regulator vent pipe through the exterior wall to the atmosphere, and seal building penetrations for service line and vent. Terminate the regulator vent so that it is protected from precipitation and insect intrusion, so that it is not submerged during floods, and so that gas escaping will not create a hazard or enter the building through openings.

#### 3.1.4.3 Gas Meter

Install shutoff valve, meter set assembly, and service regulator on the service line [outside the building] [inside the building, a minimum of **one meter 3 feet** from any potential ignition source], 18 inches above the [ground] [finished floor] on the riser. An insulating joint (dielectric connection) must be installed on the inlet side of the meter set assembly and service regulator and must be constructed to prevent flow of electrical current.

### 3.1.1.5 Pipe Sleeves

[Comply with Section 07 84 00 FIRESTOPPING. ]Where piping penetrates concrete or masonry wall, floor or firewall, provide pipe sleeve poured or grouted in place. Make sleeve of steel or cast-iron pipe of such size to provide 6 mm 1/4 inch or more annular clearance around pipe. Extend sleeve through wall or slab and terminate flush with both surfaces. Pack annular space with oakum, and caulk at ends with silicone construction sealant.

### 3.1.1.6 Piping Hangers and Supports

\*\*\*\*\*  
NOTE: In seismic zone 3 or 4, provide seismic restraints in accordance with SMACNA Seismic Restraint Mnl.  
\*\*\*\*\*

Selection, fabrication, and installation of piping hangers and supports must conform with MSS SP-58, unless otherwise indicated.[ Provide seismic restraints in accordance with SMACNA 1981.]

### 3.1.1.7 Final Connections

Make final connections to equipment and appliances using rigid pipe and fittings, except for the following:

#### 3.1.1.7.1 Domestic Water Heaters

Connect with AGA-Approved semi-rigid tubing and fittings.

#### 3.1.1.7.2 Kitchen Equipment

Install AGA-Approved gas equipment connectors. Connectors must be long enough [to permit movement of equipment for cleaning] [and] [to afford access to coupling].

## 3.2 FIELD QUALITY CONTROL

### 3.2.1 Metal Welding Inspection

\*\*\*\*\*  
NOTE: To assist the designer in selecting the proper documents for a specific project, the following scope in accordance with documents is provided:

1. NFPA 54 Scope: "1.1.1 Applicability: ... Coverage of piping systems extends from the point of delivery to the connections with each gas utilization device. For other than indicated liquified petroleum gas systems, the point of delivery is the outlet of the service meter assembly, or the outlet of the service regulator or service shutoff valve when no gas meter is provided. For undiluted liquified petroleum gas systems, the point of delivery is the outlet of the first stage pressure regulator..."

2. ASME B31.8 Scope: "802.11... This code covers the design, fabrication, installation, inspection, testing and safety aspects of operation and maintenance of gas transmission and distribution systems, including gas pipelines, gas compressor stations, gas metering and regulation stations, gas mains, and service lines up to the outlet of the customer's meter set assembly....802.14 This code does not apply to....(c) piping beyond the outlet of the customers meter set assembly..."

\*\*\*\*\*

Inspect for compliance with [NFPA 54] [and] [ASME B31.8] and 49 CFR 192. Replace, repair, and then re-inspect defective welds.

### 3.2.2 PE Fusion Welding Inspection

Visually inspect butt joints by comparing with, manufacturer's visual joint appearance chart. Inspect fusion joints for proper fused connection. Replace defective joints by cutting out defective joints or replacing fittings. Inspect 100 percent of all joints and reinspect all corrections. Arrange with the pipe manufacturer's representative in the presence of the Contracting Officer to make first time inspection.

### 3.2.3 Pressure Tests

\*\*\*\*\*

NOTE: To assist the designer in selecting the proper documents for a specific project, the following scope in accordance with documents is provided:

1. NFPA 54 Scope: "1.1.1 Applicability: ... Coverage of piping systems extends from the point of delivery to the connections with each gas utilization device. For other than indicated liquified petroleum gas systems, the point of delivery is the outlet of the service meter assembly, or the outlet of the service regulator or service shutoff valve when no gas meter is provided. For undiluted liquified petroleum gas systems, the point of delivery is the outlet of the first stage pressure regulator..."

2. ASME B31.8 Scope: "802.11... This code covers the design, fabrication, installation, inspection, testing and safety aspects of operation and maintenance of gas transmission and distribution systems, including gas pipelines, gas compressor stations, gas metering and regulation stations, gas mains, and service lines up to the outlet of the customer's meter set assembly....802.14 This code does not apply to....(c) piping beyond the outlet of the customers meter set assembly..."

\*\*\*\*\*

Use test pressure of 1 1/2 times maximum working pressure, but in no case less than 350 kPa (gage) 50 psig. Do not test until every joint has set

and cooled at least 8 hours at temperatures above 10 degrees C 50 degrees F. Conduct testing before backfilling; however, place sufficient backfill material between fittings to hold pipe in place during tests. Test system gas tight in accordance with [NFPA 54] [or] [ASME B31.8]. Use clean dry air or inert gas, such as nitrogen or carbon dioxide, for testing. Systems which may be contaminated by gas must first be purged as specified. Make tests on entire system or on sections that can be isolated by valves. After pressurization, isolate entire piping system from sources of air during test period. Maintain test pressure for at least 8 hours between times of first and last reading of pressure and temperature. Take first reading at least one hour after test pressure has been applied. Do not take test readings during rapid weather changes. Provide temperature same as actual trench conditions. There must be no reduction in the applied test pressure other than that due to a change in ambient temperature. Allow for ambient temperature change in accordance with the relationship  $PF + 101.32 = (P_1 + 101.32) (T_2 + 273) / T_1 + 273$   $PF + 14.7 = (P_1 + 14.7) (T_2 + 460) / T_1 + 460$ , in which "T" and "PF" represent Centigrade Fahrenheit temperature and gage pressure, respectively, subscripts "1" and "2" denote initial and final readings, and "PF" is the calculated final pressure. If "PF" exceeds the measured final pressure (final gage reading) by 3 1/2 kPa 1/2 psi or more, isolate sections of the piping system, retest each section individually, and apply a solution of warm soapy water to joints of each section for which a reduction in pressure occurs after allowing for ambient temperature change. Repair leaking joints and repeat test until no reduction in pressure occurs. In performing tests, use a test gage calibrated in 7 kPa one psi increments and readable to 3 1/2 kPa 1/2 psi.

#### 3.2.4 System Purging

\*\*\*\*\*

**NOTE:** To assist the designer in selecting the proper documents for a specific project, the following scope in accordance with documents is provided:

1. NFPA 54 Scope: "1.1.1 Applicability: ... Coverage of piping systems extends from the point of delivery to the connections with each gas utilization device. For other than indicated liquified petroleum gas systems, the point of delivery is the outlet of the service meter assembly, or the outlet of the service regulator or service shutoff valve when no gas meter is provided. For undiluted liquified petroleum gas systems, the point of delivery is the outlet of the first stage pressure regulator..."

2. ASME B31.8 Scope: "802.11... This code covers the design, fabrication, installation, inspection, testing and safety aspects of operation and maintenance of gas transmission and distribution systems, including gas pipelines, gas compressor stations, gas metering and regulation stations, gas mains, and service lines up to the outlet of the customer's meter set assembly....802.14 This code does not apply to....(c) piping beyond the outlet of the customers meter set assembly..."

\*\*\*\*\*

After completing pressure tests, and before testing a gas contaminated line, purge line with nitrogen at junction with main line to remove all air and gas. Clear completed line by attaching a test pilot fixture at capped stub-in line at building location and let gas flow until test pilot ignites. Procedures must conform to [NFPA 54] [and] [ASME B31.8].

-CAUTION-
Failure to purge may result in explosion within line when air-to-gas is at correct mixture.

### 3.3 SCHEDULE

Some metric measurements in this section are based on mathematical conversion of inch-pound measurement, and not on metric measurement commonly agreed to by the manufacturers or other parties. The inch-pound and metric measurements shown are as follows:

<u>Products</u>	<u>Inch-Pound</u>	<u>Metric</u>
a. [_____]	[_____]	[_____]

-- End of Section --