
USACE / NAVFAC / AFCEC

UFGS-23 51 43.02 20 (April 2006)

Change 1 - 11/24

Preparing Activity: NAVFAC

Replacing without change

UFGS-15862N (September 1999)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2024

SECTION TABLE OF CONTENTS

DIVISION 23 - HEATING, VENTILATING, AND AIR CONDITIONING (HVAC)

SECTION 23 51 43.02 20

ELECTROSTATIC DUST COLLECTOR OF FLUE GAS PARTICULATES

04/06, CHG 1: 11/24

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 DEFINITIONS
- 1.3 DESCRIPTION
 - 1.3.1 Electrostatic Dust Collector Layout and Component Drawings
 - 1.3.2 Hopper Heater Drawings
 - 1.3.3 Dust Collection System
- 1.4 PERFORMANCE
- 1.5 OPERATING EXPERIENCE REQUIREMENTS
 - 1.5.1 Equipment
 - 1.5.2 Experience Required
 - 1.5.3 List of Prior Installations Contents
- 1.6 MODEL TEST
 - 1.6.1 Precipitator Model Tests Reports
 - 1.6.2 Reports
- 1.7 SUBMITTALS
- 1.8 DELIVERY AND STORAGE
- 1.9 DESIGN CRITERIA
 - 1.9.1 Boiler Data
 - 1.9.2 Mechanical Collector Data
 - 1.9.3 Inlet Gas Conditions
 - 1.9.4 Precipitator Data
 - 1.9.5 Breeching
 - 1.9.6 Coordination
 - 1.9.7 Electrostatic Dust Collector System
- 1.10 AMBIENT ENVIRONMENT IN VICINITY OF ELECTRICAL EQUIPMENT
- 1.11 MISCELLANEOUS
- 1.12 DELIVERY OF MODEL

PART 2 PRODUCTS

- 2.1 MATERIALS
- 2.2 STRUCTURAL SUPPORTS

- 2.3 ELECTRICAL REQUIREMENTS
 - 2.3.1 Electrical Scope of Work
 - 2.3.1.1 Material and Workmanship
 - 2.3.1.2 Electrical Supply Voltage
 - 2.3.1.3 Transformers
 - 2.3.2 Equipment Enclosure Heaters
 - 2.3.2.1 Equipment Enclosure Nameplates
 - 2.3.2.2 Equipment Enclosure Grounding
 - 2.3.2.3 Insulation and Weatherproofing
 - 2.3.2.4 Wiring
 - 2.3.3 Transformer-Rectifier (T-R) Set
 - 2.3.3.1 Rectifier
 - 2.3.3.2 Grounding Switches
 - 2.3.3.3 Transformer Oil
 - 2.3.4 Control Cabinet
 - 2.3.4.1 Arc Suppression Within the Precipitator
 - 2.3.4.2 Auxiliary Alarm
 - 2.3.4.3 Pushbutton Stations
 - 2.3.4.4 Redundant Protective Devices
 - 2.3.5 High Voltage System Wiring and Support Insulators
 - 2.3.6 High-Voltage Leads
 - 2.3.7 High Voltage Insulators
 - 2.3.8 High Voltage Insulator and Pressurizing System Heaters
 - 2.3.9 Discharge Electrodes and Collecting Surfaces
 - 2.3.10 Rappers
 - 2.3.10.1 Rapper Controls
 - 2.3.10.2 Rapper Control System
 - 2.3.10.3 Rapper Disconnects
 - 2.3.10.4 Rapper High Voltage Spikes
 - 2.3.10.5 Rapper Annunciation
 - 2.3.11 Annunciation and Indication
 - 2.3.11.1 Off-Limit Conditions
 - 2.3.11.2 Annunciator
 - 2.3.12 Electrical Service Outlets
- 2.4 HOUSING
 - 2.4.1 Penthouse
 - 2.4.2 Insulation Materials
 - 2.4.3 Casing Materials
- 2.5 HOPPERS
 - 2.5.1 Hopper Accessories
 - 2.5.2 Hopper Vibrators
 - 2.5.3 Hopper Heater System
 - 2.5.3.1 Hopper Heater System Design
 - 2.5.3.2 Hopper Heater Controls
 - 2.5.4 Fly Ash Level Alarms
 - 2.5.4.1 Temperature Range Requirement
 - 2.5.4.2 Cesium Source Safety Systems
 - 2.5.4.3 Hopper Level Indicator
 - 2.5.4.4 Alarm System
- 2.6 ACCESS
 - 2.6.1 Walkways
 - 2.6.2 Doors
 - 2.6.3 Platforms, Walkways, and Ladders
 - 2.6.4 Maintenance
 - 2.6.5 Hot Dip Galvanizing
 - 2.6.6 Gas Distribution Devices
 - 2.6.7 Interlocks
- 2.7 FABRICATION
- 2.8 PAINTING

PART 3 EXECUTION

- 3.1 FACTORY INSPECTION
- 3.2 INSTALLATION
- 3.3 MANUFACTURER'S FIELD REPRESENTATIVE
- 3.4 FIELD TESTS AND INSPECTIONS
 - 3.4.1 Delivery Inspection
 - 3.4.2 Post Installation Inspection
 - 3.4.3 Performance Tests
- 3.5 IDENTIFICATION
- 3.6 INSULATION INSTALLATION
 - 3.6.1 General Insulation Requirements
 - 3.6.2 Block and Mineral Fiberboard Insulation Installation
 - 3.6.3 Mineral Fiber Blanket Insulation Installation
 - 3.6.4 Housing Hot Roof
- 3.7 PROTECTION FROM INSULATION MATERIALS
- 3.8 CASING INSTALLATION
 - 3.8.1 Structural Steel Grid System
 - 3.8.2 Access Openings
 - 3.8.3 Weatherproofing
 - 3.8.4 Convection Stops
 - 3.8.5 Casing Attachment
- 3.9 HEATER INSTALLATION
- 3.10 WIRE NUMBERS
- 3.11 GALVANIC CORROSION PREVENTION
- 3.12 PAINTING
- 3.13 SCHEDULE

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC UFGS-23 51 43.02 20 (April 2006)
Change 1 - 11/24

Preparing Activity: NAVFAC Replacing without change
UFGS-15862N (September 1999)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2024

SECTION 23 51 43.02 20

ELECTROSTATIC DUST COLLECTOR OF FLUE GAS PARTICULATES 04/06, CHG 1: 11/24

NOTE: This guide specification covers the requirements for furnishing, installing, adjusting, and testing of electrostatic precipitator(s).

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

NOTE: The precipitator(s) is intended to be used for flue gas particulate removal and collection associated with coal-fired boilers and refuse-fired waste disposal incinerators. Coal-fired boilers applicable to this specification are those designed with capacities ranging between 3.78 and 31.5 kilogram of steam per second 30,000 and 250,000 pounds of steam per hour. The incinerators applicable to this specification are those designed for burning municipal-type waste having firing capacities between 454 kilogram per hour 1,000 pounds per hour and 182 Mg 200 tons per day. For engineering and design assistance on precipitators applied close to or outside these capacities, contact:

Commanding Officer (ESC Code 433)
NAVFAC Engineering Service Center
560 Center Drive
Port Hueneme, CA 93043-4340
Telephone: (805) 982-4984

There are probably no precipitator manufacturers
that can meet all the specifications. Discretion
must be exercised to determine which deviations are
acceptable.

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the
publications cited in the text of the guide
specification. The publications are referred to in
the text by basic designation only and listed in
this paragraph by organization, designation, date,
and title.

Use the Reference Wizard's Check Reference feature
when you add a Reference Identifier (RID) outside of
the Section's Reference Article to automatically
place the reference in the Reference Article. Also
use the Reference Wizard's Check Reference feature
to update the issue dates.

References not used in the text will automatically
be deleted from this section of the project
specification when you choose to reconcile
references in the publish print process.

The publications listed below form a part of this specification to the
extent referenced. The publications are referred to within the text by
the basic designation only.

AMERICAN INSTITUTE OF STEEL CONSTRUCTION (AISC)

AISC 360 (2016) Specification for Structural Steel
Buildings

AMERICAN WELDING SOCIETY (AWS)

AWS D1.1/D1.1M (2020; Errata 1 2021) Structural Welding
Code - Steel

ASTM INTERNATIONAL (ASTM)

ASTM A36/A36M (2019) Standard Specification for Carbon
Structural Steel

ASTM A123/A123M (2024) Standard Specification for Zinc
(Hot-Dip Galvanized) Coatings on Iron and
Steel Products

ASTM A242/A242M	(2024) Standard Specification for High-Strength Low-Alloy Structural Steel
ASTM A276/A276M	(2024) Standard Specification for Stainless Steel Bars and Shapes
ASTM A325	(2014) Standard Specification for Structural Bolts, Steel, Heat Treated, 120/105 ksi Minimum Tensile Strength
ASTM A325M	(2014) Standard Specification for Structural Bolts, Steel, Heat Treated, 830 MPa Minimum Tensile Strength (Metric)
ASTM A490	(2014a) Standard Specification for Structural Bolts, Alloy Steel, Heat Treated, 150 ksi Minimum Tensile Strength
ASTM A490M	(2014a) Standard Specification for High-Strength Steel Bolts, Classes 10.9 and 10.9.3, for Structural Steel Joints (Metric)
ASTM A580/A580M	(2023) Standard Specification for Stainless Steel Wire
ASTM B209	(2014) Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate
ASTM B209M	(2014) Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate (Metric)
ASTM C533	(2017; R 2023) Standard Specification for Calcium Silicate Block and Pipe Thermal Insulation
ASTM C592	(2022a) Standard Specification for Mineral Fiber Blanket Insulation and Blanket-Type Pipe Insulation (Metal-Mesh Covered) (Industrial Type)
ASTM C612	(2014; R 2019) Standard Specification for Mineral Fiber Block and Board Thermal Insulation
ASTM D877/D877M	(2019) Standard Test Method for Dielectric Breakdown Voltage of Insulating Liquids Using Disk Electrodes
ASTM D923	(2007) Standard Practice for Sampling Electrical Insulating Liquids

INSTITUTE OF CLEAN AIR COMPANIES (ICAC)

ICAC EP-1	(2000) Terminology for Electrostatic Precipitators
ICAC EP-6	(1968) Pilot Electrostatic Precipitators

ICAC EP-7 (2004) Electrostatic Precipitator Gas Flow Model Studies

ICAC EP-8 (1993) Structural Design Criteria for Electrostatic Precipitator Casings

ICAC EP-10W (2008) Bid Specification Information Requirements and Bid Evaluation Form for Electrostatic Precipitators

INTERNATIONAL ELECTROTECHNICAL COMMISSION (IEC)

IEC 60309-3 Pin and Sleeve Devices

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA ICS 1 (2022) Standard for Industrial Control and Systems: General Requirements

NEMA ICS 2 (2000; R 2020) Industrial Control and Systems Controllers, Contactors, and Overload Relays Rated 600 V

NEMA ICS 6 (1993; R 2016) Industrial Control and Systems: Enclosures

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2023) National Electrical Code

SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION (SMACNA)

SMACNA 1793 (2012) Architectural Sheet Metal Manual, 7th Edition

SOCIETY FOR PROTECTIVE COATINGS (SSPC)

SSPC PS 12.01 (2002; E 2004) One Coat Zinc-Rich Painting System

SSPC SP 1 (2015) Solvent Cleaning

SSPC SP 6/NACE No.3 (2007) Commercial Blast Cleaning

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

40 CFR 60 Standards of Performance for New Stationary Sources

1.2 DEFINITIONS

Electrostatic precipitator terminology must be in accordance with ICAC EP-1 except for the following:

- a. Aspect Ratio: Effective treatment length divided by effective collection plate height.

- b. Collection Surface Area: Area of vertical grounded plates parallel to the gas flow. The area of components in walkways, hoppers, discharge electrical surfaces, inlet plenums, and outlet plenums must be excluded. Exclude area of plates above or below the uniform gas flow.
- c. Effective Collection Plate Height: Vertical height of the grounded collection plate in contact with the flue gas.
- d. Effective Treatment Length: Horizontal length of the grounded collection plates parallel to the gas flow in a single passage in the direction of gas flow. Exclude walkways, inlet plenums, and outlet plenums.
- e. Specific Collection Area: Total grounded collection surface area, in square meter feet, divided by maximum gas flow rate.
- f. Rigid Frame Type: Typical design in which the discharge electrodes are fastened in a support frame of welded horizontal and vertical masts suspended from four support insulators.
- g. Hot Roof: Top section of the precipitator casing between the penthouse and the gas stream.
- h. Penthouse Roof: The walking surface on top of the penthouse; that is, the raised pattern plate that covers the top of the penthouse casing insulation.
- i. Plate Spacing: Center to center spacing of the grounded collecting electrode surfaces.

1.3 DESCRIPTION

NOTE:

1. If fly ash conditioning or removal prior to the precipitator is included in the design, the system should be described.

2. If it is anticipated that the efficiency of the precipitator will be increased by the addition of field(s) in the future, this should be described.

3. If it is desired that the inlet and outlet breeching be furnished and/or designed by the collector manufacturer, it should be described.

4. Specify the ESP location and breeching tie points.

Provide electrostatic precipitator(s) of the rigid frame type designed in accordance with ICAC EP-1, ICAC EP-10W, ICAC EP-6, ICAC EP-7, and ICAC EP-8 to remove fly ash from flue gas produced by a [pulverized coal-fired boiler] [spreader stoker-fired boiler] [underfeed stoker-fired boiler] [refuse-fired waste disposal incinerator]. Provide precipitator(s) suitable for [indoor] [outdoor] installation. Locate the precipitator(s) in the flue gas system between the [_____] and the [_____].

1.3.1 Electrostatic Dust Collector Layout and Component Drawings

Drawings must indicate the kind, size, arrangement, weight of each component, and breakdown for shipment; the external connections, location of local controls, remote control panels, anchorages, and supports required; the dimensions needed for installation and correlation with other materials and equipment; seismic structural calculations; and foundation and loading information. Supply drawings for each component showing design and assembly. Provide schematics of all electrical and pneumatic circuits used. Submission must include, but must not be limited to the following details:

- a. Transformer-rectifier equipment.
- b. High voltage switches and disconnects.
- c. High voltage fuses and circuit breakers.
- d. Control systems.
- e. Ground lugs.
- f. Protection against electrolysis.
- g. Graphic display panel indicating power components.
- h. Lubrication locations.
- i. Electrodes and collecting surfaces.
- j. Platforms, walkways, stairways, and ladders which will be required for operation, inspection, testing, and maintenance, and furnished with the precipitator.
- k. Location of field welds, in conformance to AWS D1.1/D1.1M.

1.3.2 Hopper Heater Drawings

Provide layout drawings, wiring diagrams, and control schematics diagrams. Layout drawings must show each hopper face including control zones.

1.3.3 Dust Collection System

Submit a full description of the system proposed, including arrangement, operation, and maintenance of the discharge electrodes and collecting surfaces. Indicate planned rapping cycle and performance test details and sampling location. Describe electrodes and collecting surfaces.

1.4 PERFORMANCE

NOTE:

1. Select either a collection efficiency or outlet dust loading condition, whichever is more stringent.

2. The stack emission or efficiency requirements must comply with (a) weight emission standards; (b) opacity regulations; and (c) community standards for

visible emissions. Compliance with existing emission codes may not satisfy the opacity regulation. Similarly, opacity regulations may not be as demanding as community standards. A specific quantitative emission rate must be selected on the basis of the goals established.

3. Stack opacity is influenced by particle size makeup. For example, with pulverized coal-fired boilers, about 45 percent of the ash particles are below 10 microns in size; for a cyclone-fired boiler, about 70 percent are below 10 microns; for a stoker-fired boiler, about 25 percent are below 10 microns. A visually acceptable stack for these three options might require residuals of 0.046 g/m³ 0.02 gr per acf, 0.023 g/m³ 0.01 gr per acf, and 0.092 g/m³ 0.04 gr per acf, respectively.

4. If it is determined that a spare or additional precipitator section is desirable to increase reliability, the specification should be modified so that the performance can be met with any one section out of service.

The precipitator must operate at a [dust collection efficiency of not less than [_____] percent] [dust loading at the precipitator outlet of not more than [_____] grams per liter grains per standard cubic foot], as measured using EPA method 5, when operating continuously at the maximum continuous rating of flue gas flow conditions and dust loading specified in paragraph entitled "Inlet Gas Conditions." The collection efficiency must not be limited because of variations in dust resistivity levels. Flue gas conditioning by injection of sulfur-trioxide, ammonia, or other substance must not be an acceptable method of achieving performance.

1.5 OPERATING EXPERIENCE REQUIREMENTS

1.5.1 Equipment

Provide dust collectors which meets all of the operating experience requirements listed below.

1.5.2 Experience Required

NOTE: Allow only operating experience treating flue gas from the equipment specified in paragraph entitled "Design Criteria" and of the approximate L/s acfm, temperature and inlet grain loading as that specified in paragraph entitled "Inlet Gas Conditions."

The manufacturer has constructed not less than three electrostatic precipitators each at a separate facility, treating flue gas from [a refuse-fired waste disposal incinerator] [a coal-fired boiler] with [automatic] [manual] combustion control. Each precipitator must have performed satisfactorily, normal maintenance or downtime of the associated [boiler] [incinerator] [dust collector] included, for a period of not less

than 2 years treating at least [_____] L/s acfm of inlet gas at a temperature of at least [_____] degrees C F, with inlet dust loading of at least [_____] grams per liter grains per acf and outlet dust loading of at most [_____] grams per liter grains per acf.

1.5.3 List of Prior Installations Contents

Submit a certificate from the manufacturer containing the information outlined below within 30 days after award and prior to commencement of installation. Information to be contained in the certificate must include:

- a. A list of at least three installations at separate facilities meeting the requirements set forth above.
- b. Owner, location, point of contact, and phone number of each such installation.
- c. Date of owner acceptance of each such installation.
- d. Design inlet gas volume, L/s acfm; inlet gas temperature, degrees C F; inlet dust loading, grams per liter grains per acf; and outlet dust loading, grams per liter grains per acf.
- e. Type of [coal-fired boiler] [refuse-fired waste disposal incinerator].

1.6 MODEL TEST

NOTE: Generally, the complete gas system is included in the model test.

The precipitator manufacturer or a Contracting Officer approved independent modeling and testing lab must perform a three dimensional model test of not less than 1:100 1/8 scale. Hold all model dimensions to within plus or minus 1.50 mm 1/16 inch. The precipitator manufacturer or testing lab must have at least five years experience in conducting electrostatic precipitator model tests. (The five years of experience is required prior to proposal submittal.) The test must determine the gas flow patterns in accordance with ICAC EP-7 procedures, the potential areas of dust accumulation using sifted bleached wheat flour and neutral buoyancy bubbles, velocity distribution, and potential pressure drop reductions through the precipitator, nozzles, and breeching. Model breeching and particulate control equipment from [_____] to [_____]. Include precipitator hoppers, collection plates, distribution devices, turning vanes, anti-sneak baffles and internal bracing and supports. Simulate the cyclones to represent the adversely affected gas flow distribution from the cyclones. Perform flow and dust distribution tests at 30, 50, 75, 100, and 125 percent of maximum continuous flow rating. Notify the Contracting Officer of test dates in writing not less than 14 calendar days before tests are to begin.

1.6.1 Precipitator Model Tests Reports

NOTE: Include other test locations of concern based on the preliminary breeching design. These may include inlets to induced draft fans and stacks as well as bypass breeching.

Complete model testing and have approved by the Contracting Officer prior to submittal of drawings. Provide reports within 30 days of test completion. Include a scale drawing of the model showing actual dimensions and a scale drawing of the full-size installation showing modifications made and devices added to the breeching and transitions as a result of the model study. Include uniform gas velocity diagrams and histograms, indicating the root mean square velocity deviation, standard deviation, and mean velocity, at strategic locations which must include, but not be limited to, the following:

- a. Inlet to electrostatic precipitator.
- b. Outlet of electrostatic precipitator.

Provide a complete explanation of the test procedures including flow rates, pressures, sample calculations and assumptions prior to testing. List and justify deviations in dynamic or geometric similitude by the model from the full-size installation. The test report must recommend breeching configuration changes, gas flow vaning, straightening or other gas distribution devices in the system required to meet **ICAC EP-7** requirements and gas distribution specified in paragraph entitled "Gas Distribution Devices." Incorporate devices required for specified gas distribution and modifications necessary to the proposed breeching, that result from model testing, into the final breeching design. Recommend the location of test ports, the location and type of flow distribution devices in stack, and the location of gas flow instrumentation points and monitors. Provide a complete listing of pressure drop data taken at each pressure tap during each test run and also include data from runs before and after the addition of supplemental flow distribution devices that correct distribution problems identified by initial runs. Locate pressure tap as required to accurately determine the pressure drop across critical breeching components and the effect of the additional distribution devices on the pressure drop. Submit with the report a complete set of photographs and videotape recordings of model during air flow test.

1.6.2 Reports

For **precipitator inspection**, submit report of the factory service engineer's inspection within 15 calendar days after the inspection stating his findings including the acceptability of the precipitator for field performance tests. Submit **air load test** report with the precipitator inspection report. With performance test reports, certify that instruments were calibrated and readings indicated are true. Include certification that computations required for testing are accurate, that acceptable methods were used, and that the equipment performed in accordance with the requirements. For **precipitator calibration**, include certification that computations required for testing are accurate, and that acceptable methods were used.

1.7 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification

technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G". Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Electrostatic dust collector

Hopper heater

SD-03 Product Data

Warning signs

SD-05 Design Data

Dust collection system

SD-06 Test Reports

Precipitator model tests

Hopper heater module voltage tests

Precipitator inspection

Air load test

Performance tests

Precipitator calibration

SD-07 Certificates

List of prior installations

SD-10 Operation and Maintenance Data

Electrostatic dust collector system, Data Package 3

Submit in accordance with Section 01 78 23 OPERATION AND MAINTENANCE DATA.

1.8 DELIVERY AND STORAGE

Ship equipment completely factory assembled, except when the physical size, arrangement, or configuration of the equipment, or shipping limitations, makes the shipment of completely assembled equipment impracticable, in which case assemble the equipment and ship as stated in the Contractor's proposal. Provide storage and protection of delivered equipment in accordance with manufacturer's recommendations.

1.9 DESIGN CRITERIA

1.9.1 [Boiler Data

NOTE: Select the applicable paragraph(s) from the following:

NOTE: Include ash analysis if available. Specify range of properties for coal.

NOTE: Insert appropriate Section number and title in the blanks below using format per UFC 1-300-02.

Provide electrostatic precipitator(s) for operation with [the boiler(s) specified in [_____] [boiler(s) manufactured by [_____] , Type [_____] , Model No. [_____]]. The boiler is a [new] [existing] [pulverized coal-fired] [spreader stoker-fired] [underfeed stoker-fired] boiler rated [_____] kilogram per second pounds per hour of steam at [_____] kPa psi, having a gross heat input of [_____] kilowatt millions Btu per hour, and utilizing coal with the following properties:

a. Proximate analysis, as received, percent by weight:

Range	
Moisture	[_____]

Range	
Ash	[_____]
Volatile Matter	[_____]
Fixed Carbon	[_____]
Sulfur, percent by weight	[_____]
Heating Value, Btu per pound	[_____]

b. Ultimate analysis, as received, percent by weight:

Range	
Moisture	[_____]
Carbon	[_____]
Hydrogen	[_____]
Sulfur	[_____]
Nitrogen	[_____]
Oxygen	[_____]
Ash	[_____]

The expected range of boiler steam output will be between [_____] and [_____] **kilogram per second pounds per hour**. Boiler combustion is controlled [manually] [automatically]. The standby fuel is [_____.]

[Incinerator Data

NOTE: The standard classifications of wastes are as follows:

CLASSIFICATION					
<u>Type</u>	<u>Description</u>	<u>Principle Components</u>	<u>Noncombustible Solids (Max. Percent by Weight</u>	<u>Moisture Content (Max. Percent)</u>	<u>Heating Value (kJ per kg)</u>
0	Trash	Highly combustible waste, paper, wood, cardboard cartons, including up to 10 percent treated paper, plastic or rubber scrap, commercial and industrial sources	5	10	19,805
1	Rubbish	Combustible waste paper, cartons, rags, wood scraps, combustible floor sweepings, domestic, commercial, and industrial sources	10	25	15,145
2	Refuse	Rubbish and garbage; residential sources	7	50	10,019
3	Garbage	Animal and vegetable waste, restaurants, hotels, markets; institutional, commercial, and industrial sources	5	70	5825
4	Animal solids and organic wastes	Carcasses, organs, solid organic wastes; hospital, laboratory, abattoirs, animal pounds, and similar sources	5	85	2330
Loose Paper			-	-	23,300
Loose Wood			-	-	23,300
Classified Material		Highly-combustible waste, paper, cardboard cartons including up to 10 percent plastics and	-	-	16,310 to 23,300

CLASSIFICATION					
<u>Type</u>	<u>Description</u>	<u>Principle Components</u>	<u>Noncombustible Solids (Max. Percent by Weight)</u>	<u>Moisture Content (Max. Percent)</u>	<u>Heating Value (Btu per Pound)</u>
0	Trash	Highly combustible waste, paper, wood, cardboard cartons, including up to 10 percent treated paper, plastic or rubber scrap, commercial and	5	10	8,500
1	Rubbish	Combustible waste paper, cartons, rags, wood scraps, combustible floor sweepings, domestic, commercial, and industrial sources	10	25	6,500
2	Refuse	Rubbish and garbage; residential sources	7	50	4,300
3	Garbage	Animal and vegetable waste, restaurants, hotels, markets; institutional, commercial, and industrial sources	5	70	2,500
4	Animal solids and organic wastes	Carcasses, organs, solid organic wastes; hospital, laboratory, abattoirs, animal pounds, and similar sources	5	85	1,000
Loose Paper			-	-	10,000
Loose Wood			-	-	10,000
Classified Material		Highly-combustible waste, paper, cardboard cartons including up to 10 percent plastics and treated paper	-	-	7,000 to 10,000

Include ash analysis if available. Classified material contents description may change as plastic use increases. Check incinerator Institute of America for latest information.

NOTE: Insert appropriate Section number and title
in the blanks below using format per UFC 1-300-02.

Provide electrostatic precipitator(s) for operation with [the incinerator(s) specified in [____]] [incinerator(s) manufactured by [____]]. The incinerator is a [new] [existing] installation capable of burning [____] [kilogram per second pounds per hour] [Mg tons per day] of Type [0], [1], [2], [3], [4], [loose paper] [loose wood] [classified material] wastes. The expected range of incinerator operation will be between [[____] and [____]] [kilogram per second pounds per hour] [Mg tons per day] of wastes. Incinerator combustion is controlled [manually] [automatically]. The auxiliary fuel is [____].

11.9.2 Mechanical Collector Data

NOTE: Use this paragraph only when a combination of mechanical cyclone-type dust collector and electrostatic precipitator is selected. An assumed efficiency range of 35 percent to 70 percent is typical. For existing cyclones testing may be necessary to determine efficiency.

Provide the electrostatic precipitator(s) with [the mechanical cyclone-type dust collector(s) specified in Section 23 51 43.01 20 MECHANICAL CYCLONE DUST COLLECTOR OF FLUE GAS PARTICULATES [mechanical cyclone-type dust collector(s) manufactured by [____], Type [____], Model No. [____]].] The mechanical cyclone-type dust collector [is specified to have] [was designed for] an overall collection efficiency of [____] percent. The contractor must assume that the cyclone may be operating at any point in the efficiency range of [____] to [____] percent.

1.9.3 Inlet Gas Conditions

NOTE:

1. To properly apply their equipment, the precipitator manufacturer must know the expected inlet gas conditions. For new equipment this information can be best supplied by the boiler manufacturer, incinerator manufacturer, and mechanical cyclone-type dust collector manufacturer.

2. In determining the inlet gas conditions for existing installations, source testing should be performed to determine the gas flow and contents. Gas volume determinations should be made EPA Methods 1-4 in 40 CFR, Part 60, Appendix A. For particulate size distribution an actual sample should be taken and analyzed in accordance with ASME PTC 28, "Determining the Properties of Fine Particulate Matter." For particulate loading only, use EPA

Method 5 or 17.

3. For new installations, the inlet gas conditions should be obtained from the manufacturer. If this is not possible, the gas contents must be estimated. When estimates are made, the emission factors and handbook data should be taken from U.S. Environmental Protection Agency Publication no. AP-42, entitled "Compilation of Air Pollutant Emission Factors," with the latest supplements. Correction for expected combustible content should be made. Source testing should be conducted in accordance with the applicable portion of EPA 40 CFR 60, Appendix A or applicable local standard.

NOTE: Supply excess air percentage for incinerator applications.

Provide electrostatic precipitator(s) for entire operating range of gas conditions from the [boiler(s)] [incinerator(s)] [mechanical cyclone-type dust collector] specified above. The electrostatic precipitator inlet gas conditions must be:

	<u>Maximum</u>	<u>Minimum</u>	<u>Peak</u>
a. Inlet gas volume, L/s:	[_____]	[_____]	[_____]
b. Inlet gas temperature, degrees C:	[_____]	[_____]	[_____]
c. Inlet gas density, kg per cubic meter:	[_____]	[_____]	[_____]
d. Inlet gas moisture, percent by weight:	[_____]	[_____]	[_____]
e. Inlet dust loading, grams per liter:	[_____]	[_____]	[_____]
f. Altitude above sea level, meter:		[_____]	
g. Particle size distribution:			

<u>Size, Microns</u>	<u>Maximum Percent by Weight Less Than Particle Size</u>
60	[_____]
40	[_____]
30	[_____]
20	[_____]
15	[_____]
10	[_____]
7.5	[_____]
1.0	[_____]
1.0	[_____]

		<u>Maximum</u>	<u>Minimum</u>
h. Fly ash density, for hopper volume design, kg per cubic meter		[_____]	[_____]
i. Fly ash density for weight determination, kg per cubic meter (compacted)		[_____]	[_____]
j. Excess Air (range)		[_____]	[_____]
	<u>Maximum</u>	<u>Minimum</u>	<u>Peak</u>
a. Inlet gas volume, acfm:	[_____]	[_____]	[_____]
b. Inlet gas temperature, degrees F:	[_____]	[_____]	[_____]
c. Inlet gas density, pounds per acf:	[_____]	[_____]	[_____]
d. Inlet gas moisture, percent by weight:	[_____]	[_____]	[_____]
e. Inlet dust loading, grains per acf:	[_____]	[_____]	[_____]
f. Altitude above sea level, ft:		[_____]	

	<u>Maximum</u>	<u>Minimum</u>	<u>Peak</u>
a. Inlet gas volume, acfm:	[_____]	[_____]	[_____]
g. Particle size distribution:			

<u>Size, Microns</u>	<u>Maximum Percent by Weight Less Than Particle Size</u>
60	[_____]
40	[_____]
30	[_____]
20	[_____]
15	[_____]
10	[_____]
7.5	[_____]
1.0	[_____]

	<u>Maximum</u>	<u>Minimum</u>
h. Fly ash density, for hopper volume design, pounds per cubic foot	[_____]	[_____]
i. Fly ash density for weight determination, pounds per cubic foot (compacted)	[_____]	[_____]
j. Excess Air (range)	[_____]	[_____]

Verify data in the field and design the precipitator(s) to operate efficiently over the entire range of inlet gas conditions.

1.9.4 Precipitator Data

NOTE:

1. If a spare or additional precipitator section is included, the following should be added to the collection efficiency: "with one section out of service."
2. As a general rule, use four fields.
3. Usually a minimum of two electrically isolatable bus section per field is used.
4. Maximum velocity through precipitator is in the

range of 1.22-2.13 m/s 4-7 fps.

5. Minimum specific collecting area is in the range of 69 to 98 square meter per 1000 L/s 350 to 500 square feet per 1000 acfm.

6. Minimum aspect ratio should be at least 1.5.

7. Minimum hopper storage should be at least 12 hours.

8. Usually a 55 degree hopper valley angle is used. If the ash is "sticky" as for western coal, or if moisture content is high, a 65 degree angle should be used.

9. Minimum casing design pressure and vacuum is usually 3735 Pa 15 inches WC.

10. Minimum design for dust on plates should be based on 6 mm 1/4 inch of dust on all internal surfaces assuming a dust weight of 640-1600 kg/m³ 40-100 lb/ft³.

Apply the following construction criteria to each of the electrostaticprecipitator(s). Base applicable criteria on flow conditions at maximum continuous rating specified in paragraph entitled "Inlet Gas Conditions."

- a. Minimum required collection efficiency, percent [_____]
- b. Minimum number of fields in direction of gas flow [_____]
- c. Minimum effective treatment time, seconds [_____]
- d. Minimum effective treatment length, meter feet [_____]
- e. Minimum number of electrically isolatable bus sections per mechanical field [_____]
- f. Maximum collection area per electrically separate bus sections, square meter feet [_____]
- g. Maximum number of electrically separate bus sections per transformer-rectifier [_____]
- h. Maximum number of gas passages per bus section [_____]
- i. Minimum number of transformer-rectifier sets per mechanical field [_____]
- j. Gas velocity minimum through precipitator, m/s fps[_____]
- k. Minimum specific collecting area, square meter per 305 cubic meter feet per 1000 acfm [_____]
- l. Maximum vertical height of discharge electrodes, meter feet[_____]

- m. Maximum vertical height of collecting electrodes, meter feet [_____]
- n. Range of plate spacing, mm inches [_____] to [_____]
- o. Minimum discharge electrode cross-sectional area, square mm inches [_____]
- p. Maximum horizontal length of each electrical field, meter feet [_____]
- q. Minimum aspect ratio [_____]
- r. Maximum pressure from [_____] to [_____] Pa inches watergauge [_____]
- s. Minimum hopper storage capacity, each hopper, hours [_____]
- t. Minimum hopper storage capacity, each hopper, cubic meter feet [_____]
- u. Minimum hopper valley angle, degrees from horizontal [_____]
- v. Minimum number of hoppers for each electrical field [_____]
- w. Minimum casing design pressure at [_____] degrees C F, Pa inches water gage [_____]
- x. Minimum casing design vacuum at [_____] degrees C F, Pa inches Hg [_____]
- y. Minimum casing design temperature, degrees C F [_____]
- z. Minimum insulator design temperature, degrees C F [_____]
- aa. Minimum design wind load, kg per square meter pounds per square foot [_____]
- ab. Minimum design snow load, kg per square meter pounds per square foot [_____]
- ac. Minimum design live load, kg per square meter pounds per square foot [_____]
- ad. Minimum design load for dust on internal surfaces, kg pounds [_____]

1.9.5 Breeching

Provide breeching, stiffeners, bracing, supports, hangers, supporting steel, expansion joints and heat insulation between the [_____] and [_____]. Design the breeching to withstand internal pressures between plus 3735 to minus 6225 Pa 15 to minus 25 inch water gage. Include turning vanes in breeching as recommended by the report on model test. Provide self-cleaning type breeching to prevent dust accumulation. Provide expansion joints to give the breeching sufficient flexibility under thermal changes. Provide suitable supports and guides to eliminate transverse loading of flexible expansion joints.

1.9.6 Coordination

Coordinate design parameters and controls of precipitator between precipitator manufacturer and manufacturers of equipment which will interface with, or affect, system operation. Design the precipitator for

operation with the [boiler] [incinerator] [and the mechanical cyclone type dust collection] specified to assure that the collection efficiency specified is attained.

1.9.7 Electrostatic Dust Collector System

Submit operation and maintenance data for electrostatic dust collector system in accordance with Section 01 78 23 OPERATION AND MAINTENANCE DATA.

1.10 AMBIENT ENVIRONMENT IN VICINITY OF ELECTRICAL EQUIPMENT

Guarantee that electrical equipment mounted external to the precipitator housing must perform satisfactorily during normal operation of the [boiler] [incinerator] at loads within its rated limits and during start-up and shutdown, with an ambient environment of [[_____] to [_____] degrees C F and [[_____] to [_____] percent relative humidity, and exposure, including solar effects. Electrical equipment must include the following:

- a. Motors, motor starters, controllers, and controls
- b. Transformer-rectifiers
- c. Rapper coils
- d. Insulators
- e. High voltage bus
- f. Raceway and conductors interconnecting precipitator electrical equipment
- g. Pressure switches
- h. Heater contactors.

1.11 MISCELLANEOUS

Provide installation complete in accordance with this specification and as shown and include the following:

- a. Wiring, conduits, fittings, supports, and grounding of electrical equipment in accordance with Division 26, "Electrical."
- b. Special tools and devices required for operating, adjusting, repairing, and maintaining the air pollution control with their accessories.
- c. Warning signs, of an approved permanent type, where required for the safety of operating personnel.
- d. Bronze grounding lugs outside each access door into the precipitator.

1.12 DELIVERY OF MODEL

The model used for testing must remain the property of the Government. Deliver the model including a support table to the Contracting Officer within six months after Government acceptance of the full size units.

PART 2 PRODUCTS

2.1 MATERIALS

Parts exposed to the flue gas of materials having physical suitable for the service and able to withstand the abrasive and chemical action of the flue gas and fly ash. Make parts subject to deterioration easily accessible for inspection, maintenance, or replacement. The materials used must conform to the following:

NOTE: Use ASTM A242/A242M steel when material is
subjected to continuous temperatures of 204 degrees C
400 degrees F or higher.

a. Housing plate and stiffeners: [ASTM A242/A242M, Type 1]

NOTE: Use ASTM A242/A242M steel when material is
subjected to continuous temperatures of 204 degrees C
400 degrees F or higher.

b. Hoppers: [ASTM A242/A242M, Type 1] [ASTM A276/A276M]

NOTE: Use ASTM A242/A242M steel when material is
subjected to continuous temperatures of 204 degrees C
400 degrees F or higher.

c. Discharge electrodes: [ASTM A242/A242M, Type 1]

NOTE: Use ASTM A242/A242M steel when material is
subjected to continuous temperatures of 204 degrees C
400 degrees F or higher.

d. Collecting surfaces: [ASTM A242/A242M, Type 1]

NOTE: Use ASTM A242/A242M steel when material is
subjected to continuous temperatures of 204 degrees C
400 degrees F or higher.

e. Gas distribution devices: [ASTM A242/A242M, Type 1]

NOTE: Use ASTM A242/A242M steel when material is
subjected to continuous temperatures of 204 degrees C
400 degrees F or higher.

f. Structural and miscellaneous steel: [ASTM A242/A242M, Type 1]

2.2 STRUCTURAL SUPPORTS

NOTE: Use 6 mm 1/4 inch thick steel for
temperatures over 260 degrees C 500 degrees F.
Detail structural supports on drawings.

Provide steel support structures for the precipitator as [indicated] [specified herein]. Provide the precipitator with column extensions or stubs to project from the precipitator internal support system to the support structure. Provide column extensions or stubs of adequate length to provide clearance between the precipitator casing and hoppers and the support frame beams. Provide sufficient clearance to permit the insulation and casing to be installed and to accommodate the extremes of displacement caused by thermal expansion. Support precipitator components from the precipitator internal support system. Provide additional grid steel required at the unit for support of precipitator components. Anchor the precipitator on its centerlines and allow to expand in both directions. Provide slide plates for installation between the precipitator free support points and the support structure. [Design the precipitator supports for seismic probability zone [3][4] in accordance with Section 22 05 48.00 20 MECHANICAL SOUND VIBRATION AND SEISMIC CONTROL.] Fabrication and erection of structural steel must conform to AISC 360.

2.3 ELECTRICAL REQUIREMENTS

2.3.1 Electrical Scope of Work

The work covered by this section consists of providing, adjusting, testing, and placing in operation electrical equipment and materials which are an integral part of the electrostatic precipitator provided under this section.

2.3.1.1 Material and Workmanship

Material and workmanship in factory assembled equipment, unless indicated or specified otherwise, must conform to Division 26, "Electrical." Include interconnecting conduit and wire, grounding, and the electrical connection of the mechanical equipment to the electrical power circuit under Division 26, "Electrical."

2.3.1.2 Electrical Supply Voltage

Provide supply voltage of [_____] volt, three phase and [_____] volt, single phase, 60 hertz. Balance single phase loads on three phase systems. Except as specified herein, design all equipment for energization from a [_____] volt, single phase, 60 hertz electrical supply.

2.3.1.3 Transformers

Supply transformers and accessory equipment as required to convert the [[_____] volt, three phase] [[_____] volt, single phase], 60 hertz electrical supply to those voltages required.

2.3.2 Equipment Enclosure Heaters

Provide outdoor equipment enclosures with space heaters to prevent condensation of moisture within the equipment enclosures. Space the

heaters away and thermally insulate from close painted surfaces. Control the heaters by an adjustable thermostat set to deenergize the heaters when the temperature rises to 35 degrees C 95 degrees F, and to energize the heaters when the temperature decreases to 29 degrees C 85 degrees F. The space heaters must not interfere with normal entrance of cables into the enclosures or equipment within the enclosure.

2.3.2.1 Equipment Enclosure Nameplates

Provide equipment enclosures and associated switches, indicating lights, meters, and devices with nameplates.

2.3.2.2 Equipment Enclosure Grounding

Provide equipment enclosures with a ground bus and connectors in accordance with National Electrical Code. Connect electrical equipment to the grounding system specified in Division 26, "Electrical."

2.3.2.3 Insulation and Weatherproofing

NOTE: Use this paragraph only when equipment is exposed to the atmosphere.

Insulate and weatherproof electrical enclosures exposed to the atmosphere. The enclosures must conform to specification for insulation and enclosure for roof housing in paragraph entitled "Housing."

2.3.2.4 Wiring

Wiring design and installation must be in accordance with NFPA 70 and as specified.

2.3.3 Transformer-Rectifier (T-R) Set

NOTE: T-R voltage should be 50 KV DC average as a minimum. Sump must be covered and piped to an oil-water separator if penthouse is not covered by a weather enclosure.

Enclose the high voltage rectifying equipment in the sealed transformer case to form a single enclosure. The enclosure must meet the requirements of NEMA Type 3R construction as described in NEMA ICS 6. Provide oil-filled, air-cooled type transformer designed and shielded for precipitator service. Equip the transformer case with, at a minimum, the following items: connection box, grounding connection, filling connection, drain and sampling valves, thermometer, oil and vacuum gages, and high temperature alarm. Provide sump to contain the oil which may leak from the transformer. Provide rectifier with concentric pipe and guard conductors between power supply and precipitator. Voltage supply must be rated for [_____] volts. T-R capacity must be [_____] KVA maximum. T-R output voltage rating must be [_____] kV minimum. T-R must operate at 60 percent to 100 percent of its current rating at normal operating conditions.

2.3.3.1 Rectifier

Provide oil immersed, solid state silicone type rectifier. Mount within the transformer case and equip with necessary surge equalizers and suppressors. Arrange interior parts to facilitate circulation of oil for adequate cooling.

2.3.3.2 Grounding Switches

Provide each transformer-rectifier set with a five-position grounding switch to permit grounding of both bushings; full-wave power to one bushing, grounding of the other bushing and vice versa; half-wave power to both bushings. Provide a bus duct between the power supply and the precipitator. Do not connect more than two bus sections to a single transformer-rectifier set; connect each bus section to a single bushing and connect each bushing to only one bus section.

2.3.3.3 Transformer Oil

Provide insulating mineral oil, PCB free, kV rated with required dielectric rating. Sample the oil after installation and test in accordance with [ASTM D923](#) and [ASTM D877/D877M](#). If the oil does not meet the ASTM specification, dry and filter until it meets or exceeds the requirements.

2.3.4 Control Cabinet

Provide controls for the high voltage precipitator supply in control cabinets and include all regulating devices. Provide control cabinets that are completely wired, self-ventilated, free standing, and enclosed in a grounded casing. Maintain cabinet at positive pressure using a fan powered by a 120 volt, single-phase motor with a power output of not less than [\[0.093 kW\]](#) [\[1/8 hp\]](#) [\[_____\]](#). Filter pressurizing air with a filter that is not less than 98.5 percent efficient for dust particles one micron or larger. Equip control cabinet and T-R with a safety key interlock. Construct the control cabinet in accordance with NEMA Type 12 as defined in [NEMA ICS 6](#). Each controller must conform to [NEMA ICS 1](#) and [NEMA ICS 2](#) and contain, but not be limited to, the following:

- a. Completely automatic solid state controller which will maintain a preset spark rate, maximum current, and maximum voltage; silicon controlled rectifiers driven by transistorized automatic controls with auxiliary manual capability. Provide the reactor in conjunction with the T-R set with a nominal impedance of 40 percent and additional taps at 50 percent and 60 percent impedance. Provide easily accessible taps to facilitate changing of tap position. The reactor must hold inductance within 5 percent at 2.5 times rated current at 40 percent impedance.
- b. Full range control on both manual and automatic. Field adjustments to the automatic control must be maximum current, maximum voltage, and spark rate set point.
- c. Indicators, meters, and protection.
- d. High voltage start and stop pushbuttons.
- e. Thermal line breaker with undervoltage coil and adjustable magnetic trip.

- f. Transformer primary AC voltmeter.
- g. Transformer primary AC ammeter.
- h. Precipitator DC milliammeter.
- i. Precipitator DC voltmeter.
- j. Precipitator spark rate meter.
- k. High temperature alarm indicator for T-R oil temperatures.
- l. Auxiliary contacts for the attachment of a portable oscilloscope in order to observe both voltage and current wave forms on the high tension electrodes.
- m. Inverse time over current relay for units rated higher than 300 milliamperes.
- n. Static regulator to limit precipitator current during automatic control.
- o. Alarm circuit interlock which opens when transformer primary circuit is energized.
- p. Fused control disconnect for circuit breaker undervoltage coil and automatic control.
- q. Manual automatic control select switch.
- r. Thyristors with heat sink sized for operation without thyristor fan.
- s. Automatic voltage control unit.
- t. Three position selector switch with indicating lights; "LOCAL-MANUAL," "LOCAL-AUTO," and "REMOTE-AUTO" positions.
- u. Adjustable memory.
- v. Visual annunciator for each of the following conditions:
 - (1) T-R overload, one each transformer-rectifier.
 - (2) T-R undervoltage, one each transformer-rectifier.
 - (3) T-R high voltage short circuit and open circuit, one each transformer-rectifier.
 - (4) T-R open circuit, one each transformer-rectifier.
 - (5) High temperature indicator for T-R oil temperatures.

2.3.4.1 Arc Suppression Within the Precipitator

Controls must prevent or minimize sparking. The device must suppress an arc within 1/2 cycle and recover within two cycles to initial voltage before arc. Recovery rate must be adjustable.

2.3.4.2 Auxiliary Alarm

Wire the control enclosure so that an isolated contact will close and alarm the local annunciator when any of the white indicating lights are illuminated for any of the T-R controls specified in paragraph entitled "Control Cabinet." Similarly provide an isolated contact to close and to alarm the local annunciator when any T-R control is not in the "REMOVE-AUTO" position.

2.3.4.3 Pushbutton Stations

NOTE: Require these indicator lights if remote indication is required.

Wire the start pushbuttons to function only when the three position selector switch is in the "LOCAL-MANUAL" or "LOCAL-AUTO" positions. In addition to shutting down the T-R, the stop pushbutton must clear all alarm outputs, except the output indicating that T-R control is not remote. Startup, whether by local pushbutton or remote control, must arm the alarm system. Provide remote control so that all T-R sets which have their three-position selector switches in the "REMOTE-AUTO" position may be stopped by pushbutton station on the main control panel. Provide output contacts for remote indication of the status of T-R which are in the "REMOTE-AUTO" mode. Provide indicating lights for each precipitator on the auxiliary boiler control panel as follows:

- a. Green -- all units off.
- b. Red -- all units on.

NOTE: Require amber light if sequential startup is required.

- c. Amber - startup in progress.

2.3.4.4 Redundant Protective Devices

Provide redundant protective devices on controller connections to the transformer unit secondary circuit.

2.3.5 High Voltage System Wiring and Support Insulators

NOTE: Use this paragraph for "bus-duct" wiring.

Provide wiring materials and insulators, including insulators for discharge electrode supports, required to electrically connect the T-R to the discharge electrodes. The high voltage lead from the rectifier to the discharge electrodes must consist of a conductor in metal enclosed weatherproof bus duct. Furnish the bus duct complete with necessary insulators, duct supports and fittings, and supply formed to exact length ready for bolting to the equipment.

2.3.6 High-Voltage Leads

NOTE: Use this paragraph for "pipe" wiring.

Completely enclose high voltage leads to the precipitator in a grounded 16 gage minimum thickness sheet metal guard. The conductor must be 20 mm 3/4 inch diameter, Schedule 40 iron pipe. Include equipment for the introduction of clean purging air in and around the support bushings to prevent dust buildup on the insulators. The high voltage conductor pipe must have a union immediately connected to the T-R set so the T-R can be easily isolated from the precipitator. Connect the conductor pipe to the high voltage electrode frame by a removable wire lead.

2.3.7 High Voltage Insulators

Provide a minimum of four insulating support bushings for each electrical bus section. Compression-load the high tension insulators and install outside of the contaminated gas stream. Provide insulators of materials suitable for the temperature. Provide best process electrical glazed ceramic high density 85 percent alumina for temperatures below 454 degrees C 850 degrees F. Provide adequate access for removal and reinstallation of high voltage insulators. Provide four pad-eyes above each high voltage bus frame to facilitate lifting of the frame for precipitator maintenance. Attach pad-eyes to support beams. Each pad-eye and support beam must be capable of supporting the entire weight of its respective high voltage bus frame. Provide other means for lifting high voltage bus frames if acceptable to Contracting Officer.

2.3.8 High Voltage Insulator and Pressurizing System Heaters

Provide a heating and pressurizing/purging system for the high voltage bus duct insulators and the discharge electrode support insulators. Furnish control devices to automatically energize the heaters, as required, when the temperature of the insulating support bushings falls below [107 degrees C] [225 degrees F] [_____] and deenergize the heaters when the temperature reaches [121 degrees C] [250 degrees F] [_____]. The system must maintain an insulator temperature of 107 degrees C 225 degrees F when the precipitator is off line. Provide sufficient pressure to prevent the infiltration of dust and moisture laden air into the penthouse and to keep the inside of the high voltage insulators free from the flue gas. Supply a minimum of 47.20 L/s 100 acfm of heated, filtered air for each insulator. Direct the purge air downward in swirl pattern across the inside surface of each insulator. Provide a purge air filter of the disposable or cleanable type with a filter efficiency of not less than 98.5 percent for dust particles of one micron or larger. Provide remote annunciation for malfunctions of the heating and pressurizing system as specified in paragraph entitled "Annunciation and Indication." Provide pressurizing fans, complete with electric motor, automatic backflow prevention dampers, inlet filters, and a relief device for filter bypass in case of blocked filters. Furnish a minimum of two fans for each pressurizing system. Provide pressurizing fans of equal capacity and requiring the same size motors. Upon loss of any one fan, the remaining fans must automatically pressurize the system as required to ensure continued normal operation of the precipitator. Provide a control system consisting of necessary relays, pressure switches, flow switches, and control devices. Factory mount control devices, except those requiring local mounting, and wire in an indoor NEMA ICS 6, Type 12 floor-mounted

control enclosure. Provide each fan discharge duct with an airflow switch for use in fan control. Furnish locally mounted NEMA ICS 6, Type 4 combination starters for the fans. Mount an "AUTO-ON" selector switch for each fan on the door of its associated local combination starter. Mount indicating lights for system status on the starter door. Provide each fan control circuit with a two-position, "AUTO-ON," selector switch. Provide a single normally open contact, which will close upon start up of the induced draft fans, when the selector switch is in the "AUTO" position. Provide relays as required to multiply this signal. Electrically isolate output contacts for controls motor starters.

2.3.9 Discharge Electrodes and Collecting Surfaces

Provide rigid frame type discharge electrodes. Rigid electrode, or weighted wire design precipitators are not acceptable. The discharge electrodes in each passageway must run in a vertical direction and must be supported by a welded pipe, tube, or channel frame. Provide the frame with vertical pipe, tube, or channel supports spaced at a maximum interval of 1.22 meters four feet. Also provide the frame with horizontal pipe, tube, or channel supports spaced at a maximum interval of 1.22 meters four feet. The electrodes must have a cross-sectional area of not less than 16 square mm 0.025 square inches and not more than 64.52 square mm 0.10 square inches. Fabricate collecting surface from rolled seamless sheet of not less than 16 gage thickness. Collecting surface plate spacing must be not less than 280 mm 11 inches or greater than 330 mm 13 inches. Support discharge electrodes and collecting surfaces as required to maintain proper alignment during operation. Support each main discharge electrode bus section support frame by four alumina support insulators. Design collecting surfaces so that deflection from a plane surface will not exceed plus or minus 6 mm 1/4 inch about any axis. Design and construct discharge electrodes and collecting surfaces to be readily located and aligned within plus or minus 6 mm 1/4 inch of the normal design position. Assemble the collecting surfaces at the factory. Factory assembled modules which can be shipped to the field for erection may be provided. Provide high voltage frames with sway braces or other devices as required to prevent swaying. Incorporate gas baffles into the collecting plates to provide a gas flow quiescent zone and to provide stiffening.

2.3.10 Rappers

Provide falling hammer collecting surface and discharge electrode rappers with individual hammers for each plate and frame. Design plate rappers for sequential rapping to prevent simultaneous rapping of plates and provide a minimum of 27 N.m 20 foot pounds of rapping force per plate. Design discharge electrode rappers for sequential rapping to prevent simultaneous rapping of frames and provide a minimum of 12.24 N.m 9 foot pounds of rapping force per frame. Provide solid steel rapper drive shafts with a minimum diameter of 50 mm 2 inches. Provide magnetic impulse gravity return gas distribution plate rappers with individual rappers for each plate or screen.

2.3.10.1 Rapper Controls

Rapper controls must have adjustments for independent field repeat intervals and for independent field rest time.

2.3.10.2 Rapper Control System

Provide a rapper control system conforming to NEMA ICS 1 and NEMA ICS 2

consisting of necessary devices for the complete control of each rapper system. Factory install and wire the system for [indoor] [outdoor] installation in a NEMA [12] [3R] cabinet as described in NEMA ICS 6 and locate in [control house] [control room] [roof]. Provide outdoor mounted units finish painted for outdoor service, wind braced for [_____] km miles per hour wind and completely weatherproofed.

2.3.10.3 Rapper Disconnects

Provide disconnecting switches for individual rapper groups to deenergize for servicing.

2.3.10.4 Rapper High Voltage Spikes

Provide the rapper system with surge suppressors and other devices as required to eliminate high voltage spikes.

2.3.10.5 Rapper Annunciation

Provide remote annunciation for malfunctions of the rapping system as follows:

"White" light for rappers not operating (power failure).

2.3.11 Annunciation and Indication

2.3.11.1 Off-Limit Conditions

Provide annunciator and indication equipment for individual annunciation and indication of the following off-limit conditions:

- a. T-R control trouble.
- b. T-R overload, one each transformer-rectifier.
- c. T-R undervoltage, one each transformer-rectifier.
- d. T-R open circuit, one each transformer-rectifier.
- e. T-R not in remote, one each transformer-rectifier.
- f. Penthouse or insulator compartment air pressure low.
- g. Loss of penthouse pressurizing airflow.
- h. Rapper control failure, one each rapper control enclosure.
- i. Low hopper temperature.
- j. Insulator temperature below [107 degrees C] [225 degrees F][_____].
- k. Purge air filter clogged.

2.3.11.2 Annunciator

Provide annunciator with a station for each alarm input plus a minimum of 25 percent spare stations. Provide sufficient stations for annunciation such that the items of equipment that failed can be easily identified. Provide a backlighted window for each station with an engraved legend that

will be readable by a [standing] [sitting] operator at the operating station. The unit must be complete with test, audible silence, flasher reset, and lamp reset pushbuttons and audible device. Incorporate an adjustable time delay relay in the annunciator audible device circuit to cause automatic silencing of the device after a manually selected time period. The annunciator stations must, however, remain lighted until the trouble is cleared. Provide solid-state type annunciator, suitable for 120 volts AC power supply with not less than 125 volts DC applied to the trouble contacts. Include one electrically isolated contact per window for remote annunciation. Provide positive oriented logic, 120 volts AC or 125 volts DC power supply for trouble contacts, and two lamps wired in parallel circuit per indicating window. Design annunciator alarm contacts to accept field contacts which close on alarm condition. Do not use contacts which open on alarm condition. Provide an auxiliary isolated contact for each station. The auxiliary contact action must follow that of the field contact. Provide cover-mounted annunciator, test, audible silence, flasher reset, lamp reset, and acknowledge pushbuttons on a NEMA ICS 6, Type 12 enclosure. Mount and wire the following devices inside the enclosure:

- a. Annunciator audible device.
- b. Fuse and fuse holder for annunciator power supply.
- c. Fuse and fuse holder for the audible device.
- d. Terminal blocks for connections to all external circuits.

2.3.12 Electrical Service Outlets

Provide a 20 amp, 110 VAC duplex ground fault NEMA 5 20R terminal duplex interrupter receptacle within 2.44 meters 8 feet of access doors except doors in the hot-roof and gas distribution plates. The receptacles on each precipitator level must be on a separate circuit. Ground fault interrupters must test and reset at the receptacle. Wire receptacles to provide individual receptacle protection such that no other receptacles are interrupted by an individual receptacle trip. The receptacle must interrupt at 5 plus or minus 1 milliamp ground fault current. Provide specification grade or better receptacles and protect by weather tight covers. Provide a CS 6369 (Alpha Configuration) 50 amp, 3 pole, 4 wire, 120/250 VAC twist type receptacle in a FS box with a weatherproof cover (Hubbell SR-50 or approved equal - item may be provided as an integral assembly or as individual components) inside each weather enclosure on separate circuits. Provide a weatherproof 100 amp, 3 pole, 4 wire, 120/250 VAC, pin ad sleeve receptacle conforming to IEC 60309-3 within 15 meters 50 feet of each stack base and each precipitator base. Provide each of the 50 amp receptacles with an individual 50 amp, 208 VAC service. Provide each of the 100 amp receptacles with an individual 100 amp 208 VAC service.

2.4 HOUSING

Construct the precipitator housing, including inlet and outlet nozzles, of minimum 6 mm 1/4 inch thick steel plate and attach to appropriate structural steel supporting members. Plumb the housing within 10 mm 3/8 inch measured at top, bottom, and tie points, side to side, and front to rear. The top of the precipitator support must be flat within 1.50 mm 1/16 inch for area of support foot and at elevation within 3.18 mm 1/8 inch. Make provisions, including expansion joints if required, to allow for any

expansion, differential expansion, and contraction that may occur. Design the expansion provisions to prevent escape of gas or inflow of ambient air. Provide a minimum of 1.50 meters 5 feet of vertical clearance inside the housing above the discharge electrodes and collecting surface frames to afford access for inspection and maintenance. Locate walkways internal to the housing between electrical fields, at the inlet to the first field, at the outlet to the last field, and as otherwise required to provide access to equipment located within the housing which may require inspection or maintenance. Provide access to internal walkways by two access openings located on opposite sides of the precipitator for each internal walkway. Access openings must align directly with internal walkways and must be unobstructed. The walkways must provide a minimum passageway clearance of 762 mm 30 inches. Provide the housing with insulated, hinged, quick opening, access, inspection, and cleanout doors with gastight seals as required for proper operation and maintenance. Provide a minimum of one door above each bus section. The minimum access opening size must be 460 by 600 mm 18 by 24 inches for rectangular openings and 600 mm 24 inches diameter for round openings. Provide key interlocks for openings through which personnel may come in contact with high voltage equipment to prevent opening before the electrical supply is deenergized. The housing must be of all welded construction. Minimize the use of flanged or bolted joints. Use only where bolted assembly is required for adjustment or removal. Prevent structural members from acting as radiators, thereby reducing internal corrosion. The difference between the inside wall temperature at any point and the inlet gas temperature must be less than 22 degrees C 40 degrees F.

2.4.1 Penthouse

Provide a penthouse to enclose the high voltage system support insulators. Enclose the entire top of the housing. Design the penthouse to withstand the effects of differential thermal expansion between the precipitator housing and the penthouse. Design the expansion provisions to assure an airtight penthouse. Weld gas tight. Check for leaks using smoke candles or other method approved by the Contracting Officer. Repair leaks by welding or repair of mechanical seals. Do not use caulking. Provide a minimum of 2 insulated, hinged, quick-opening access doors on the penthouse roof; one at each end of the roof. Provide penetrations, openings and hatches in or on the penthouse roof with mechanical seals or weld to provide a gas tight and watertight seal. Install calcium silicate insulation conforming to ASTM C533 over 12 gage steel pines stud welded on 610 mm 2 foot centers on the penthouse roof. Hold in place by 65 mm 2 1/2 inch square speed washers and closely fit around penetrations. Construct top surface of 6 mm 1/4 inch thick raised pattern plate conforming to ASTM A242/A242M, Type I to form a continuous walking surface. Provide support to bear not less than 488 kg per square meter 100 pounds per square foot live load. Provide additional support for equipment placed on the roof. Seal joints by continuous fillet or complete penetration groove welds as applicable. Weld appurtenances similarly to the plate. Provide top penetrations with a 50 mm two inch minimum extension above the plate and similarly weld to the plate. Slope the top surface to allow water runoff and to prevent pooling. Extend top surface at least 25 mm one inch beyond side insulation. Provide a 80 mm 3 inch fascia of 6 mm 1/4 inch steel conforming to ASTM A242/A242M plate as a rain barrier. Provide a 80 mm 3 inch kickplate of 6 mm 1/4 inch steel conforming to ASTM A242/A242M plate around the perimeter of the top surface and provide adequate drain holes to permit water runoff. Provide a safety rail on the top perimeter. Manufacture top surfaces of appurtenant structures with 6 mm 1/4 inch steel conforming to ASTM A242/A242M raised pattern floor plate in

a manner similar to that specified herein including soffit and fascia dimensions. Aluminum casing materials must conform to ASTM B209M ASTM B209.

2.4.2 Insulation Materials

NOTE: For operating temperature range of 94 to 260
degrees C 201 to 500 degrees F use minimum thickness
of 115 mm 4 1/2 inches. For operating temperatures
261 degrees C 501 degrees F and above use minimum
thickness of 140 mm 5 1/2 inches.

Insulate the precipitator housing, penthouse, and hoppers with ASTM C612 mineral fiber block or ASTM C592 mineral fiber blanket insulation. Insulate the roof with ASTM C533 calcium silicate block. Minimum insulation thicknesses must be as follows:

- a. Housing [_____] mm inches
- b. Hoppers [_____] mm inches
- c. Hot Roof [_____] mm inches
- d. Penthouse [_____] mm inches.

2.4.3 Casing Materials

Casing except top surface casing, which might serve as personnel walking surface, must be 1.27 mm 0.050 inch thick stucco embossed, 100 mm 4 inch rib, unpainted aluminum panel. Aluminum casing must be ASTM B209M ASTM B209.

2.5 HOPPERS

Construct hopper plate of [Type 316 stainless steel conforming to ASTM A276/A276M] [structural steel conforming to ASTM A242/A242M Type 1] and a minimum 6 mm 1/4 inch thick. Provide hoppers with ASTM A242/A242M baffles to prevent flue gas from bypassing the electrostatic field. Hoppers must span no more than one electrical field. Provide hoppers with untapered fillet plates, constructed of cold rolled minimum 10-gage ASTM A276/A276M Type 316 stainless steel, in each corner. Extend the fillet plates the full length of the corner. Seal weld the fillet plates to the hopper walls. Provide closure plates at the top of the hopper at each corner to prevent flow into the area between the fillet plate and the hopper corner. Steel reinforcements not in contact with the gas or ash may be either ASTM A276/A276M Type 316 stainless steel or ASTM A242/A242M structural steel. If the latter is used, select welding rods specifically for the service and submit to the Contracting Officer for approval. Provide protection of rods against moisture.

2.5.1 Hopper Accessories

Provide key interlocked access doors on each hopper on both sides of any hopper baffle. Doors must be in accordance with the requirements specified herein. Hoppers must have adequate flexibility for vibrators. Provide each hopper with two 100 mm 4 inch poke holes with a tee wash connection and screwed caps. Position poke holes to permit downward thrusts into the hopper. Provide a special plate reinforced "pounding

area" on each hopper face for external manual vibrating. Each pounding plate must be 300 by 300 by 25 mm 12 by 12 by 1 inch thick ASTM A36/A36M plate steel. Provide a work platform with stairs to each pounding area for units with pounding areas more than 1.50 meters five feet above ground. Do not insulate pounding plate. Finish insulation at this discontinuity. Provide a minimum 200 mm 8 inch diameter flanged fly ash outlet connection on each hopper to accept the fly ash transportation system equipment. Provide access hatch not less than 200 by 200 mm 8 by 8 inches for cleanout within 200 mm 8 inches above flange.

2.5.2 Hopper Vibrators

Provide each hopper with two vibrators set at the mid-height and on opposite sides. Interface vibrator controls with ash collection system to provide automatic vibrator operation only at the inception and during an evacuation cycle. Provide manual override control for hopper vibrators and evacuation system in hopper area and enclose in (a) case(s) to prevent accidental energization of systems. Place a warning over the vibrator manual control with the following inscription:

"WARNING: VIBRATOR CONTROL. DO NOT ACTIVATE UNLESS HOPPER EVACUATION SYSTEM IS OPERATING."

2.5.3 Hopper Heater System

Provide a hopper heater system for each precipitator.

2.5.3.1 Hopper Heater System Design

Provide the system complete with all material required for mounting. The system must provide a 139 degrees C 250 degree F rise in temperature in the hopper, in the vicinity of the heaters, during offline and startup conditions. Size the system to provide a hopper skin temperature of not less than 177 degrees C 350 degree F when the insulation is in place during minimum ambient temperatures specified in Section 23 07 00 THERMAL INSULATION FOR MECHANICAL SYSTEMS. Design the system with a minimum heating safety factor of 1.1 and a minimum wind heat loss factor of 1.12. Design the system to provide maximum heater coverage between hopper stiffeners utilizing modular heaters and flexible blanket or tape heaters for the hopper throat heating. Heater modules must cover not less than 33 percent of the hopper area. Cover the bottom portion of the hopper to the maximum extent possible, and extend at least 70 percent up the hopper height. Provide a two zone system. Comprise the lower zone of heaters located on the bottom one-third of hopper height including the throat heater; the upper zone must include the remaining hopper heaters. Use flexible electric heating blankets or tapes, capable of withstanding 427 degrees C 800 degree F, where modular equipment will not fit. Provide only equipment designed to withstand natural and induced vibrations, plus shock loadings normally experienced during operation of the precipitator and ancillary equipment including manual rapping of the strike plates. Provide an individually, thermostatically controlled hopper heater system with adjustable setpoint and include power, control, and alarm components. Locate the low temperature and control thermocouples in the lower portion of each heater zone. Heater voltage must be 480 volts AC. Control voltage must be 120 volts AC.

- a. Hopper Heater Module Design: Provide self-contained, modular heaters. Provide hopper heater modules which have a flexible heating face to conform to the irregularities of the hopper surface, providing

contact between the heaters and the hopper, and providing maximum heat transfer. Provide low watt density design modules with a maximum of 0.0047 watts per square mm 3 watts per square inch of resistance element and with a minimum of six parallel resistance paths per heater. Continuous blanket type elements must be deemed to meet the multipath requirement. Each module must have dual heating elements. Both elements must function during startup and offline conditions. To reduce power consumption and cycling while maintaining the hopper temperature during online operating conditions, controls must automatically switch off one element in the lower zone and both elements in the upper zone without affecting the remaining element's operation. The hopper throat blanket heater must have a single heating element and must remain on during startup, offline, and online operating conditions. Each heating element in the module must be capable of being operated at and must be rated at 2690 watts per square meter 250 watts per square foot, but must be designed to operate at 2152 watts per square meter 200 watts per square foot. Size wiring, circuits, and controls for 2690 watts per square meter 250 watts per square foot. Total power density must be not less than 4303 watts per square meter 400 watts per square foot of heater module surface. Construct heating elements of 600 series stainless steel alloy or ni-chrome encased in a 20 gage minimum thickness aluminum or aluminized-steel mounting pan or casing. Provide two sets of heater pigtails for each module, one set of pigtails for each element and circuit. Provide multistrand copper pigtail and interconnecting wires with high temperature (454 degrees C 850 degree F) insulation. Furnish heater pigtails with strain relief constructed to prevent damage to the heater modules due to rough handling. Provide pigtails of sufficient length to reach the terminal box. Splices are not permitted in pigtails from modules, tapes, or blankets to the terminal box. Perform hopper heater module voltage tests for each module, blanket, or tape for electrical integrity at 1,000 volts. Provide heating modules with metal labels firmly attached to the module listing the wattage and voltage of the module. Construct heating modules and mounting hardware of high temperature materials capable of withstanding 454 degrees C 850 degrees F. Insulate heating modules with high temperature woven glass cloth or mineral fiber. Mica or magnesium oxide insulated heaters are not acceptable.

- b. Hopper Heater Installation: Heater modules must provide maximum contact between the heaters and the hopper wall.

2.5.3.2 Hopper Heater Controls

NOTE: Use these paragraphs for local control only.

NOTE: Use these paragraphs for master control only.

Control each hopper heater zone thermostatically with adjustable setpoint and provide complete including power, control and alarm components. Provide 120 volt AC adjustable type thermostats for monitoring hopper temperature and locate in NEMA ICS 6, Type 4 enclosures. For thermostatic control of the hopper heater system, provide a Master Hopper Heater Control Panel for each precipitator, a Local Hopper Heater Control Panel for each hopper, and a Local Hopper Heater Zone Terminal Box for each

zone. Provide materials, tools, and labor required for connections of circuits and wiring between local hopper heater zone terminal boxes, local hopper heater control panels, and the master hopper heater control panels.

NOTE: Use these paragraphs for local control only.

- a. Local Hopper Heater Zone Terminal Box: Provide hot-dipped galvanized **NEMA ICS 6**, Type 4 hopper heater terminal boxes with terminal blocks for connection of heater pigtails and thermostat leads on each hopper for each hopper zone. Provide a sufficient number of terminals to connect the heater pigtails and thermocouples for each hopper zone.

NOTE: Use these paragraphs for local control only.

- b. Local Hopper Heater Control Panel: Provide each precipitator with a local hopper heater control panel at each hopper. Locate at a regularly accessed area near each hopper. For each zone, provide each local hopper heater control panel with: terminal blocks for power, control, and alarm circuits, one control temperature thermostat, one low temperature alarm thermostat, magnetic contactor and alarm relay with two normally open contacts, and auxiliary relays for automatic operation of the heater system. Provide a 3-pole fused switched main disconnect device and a fused control transformer having a 120-volt AC secondary for each local hopper heater control panel. Provide thermostats with a set point range of **38 to 260 degrees C 100 to 500 degrees F**. Measure hopper skin temperature using ungrounded, type J thermocouples. Provide each local hopper heater control panel cover with the following devices:

- (1) "START UP," "ON LINE," "OFF," "AUTO" selector switch.
- (2) 120 V "ON" red light with integral transformers, one each zone.
- (3) 120 V "LO TEMP" alarm white light with integral transformer, one each zone.
- (4) Device and enclosure nameplates.

Wire the selector switch for the following system operation:

- (1) "START UP": Upper and lower zones all elements on (includes throat heater).
- (2) "ON LINE": Single element lower zone on (includes throat heater).
- (3) "OFF": All elements off.
- (4) "AUTO": Control functions transfer to Master Hopper Heater Control Panel.

NOTE: Use these paragraphs for master control only

c. Master Hopper Heater Control Panel: Provide panels containing relays, contactors, circuit breakers, control transformers, and other devices required for complete control of each precipitator hopper heater system. Locate Master Hopper Heater Control Panels with precipitator controls in the control room. Factory install and wire the panel components in a NEMA ICS 6, Type 12 enclosure and include the following:

- (1) A main circuit breaker.
- (2) A circuit breaker and contactor alarm relay with two normally open contacts for each hopper zone. The contactor must have a 120-volt operating coil.
- (3) "START UP," "ON LINE," "OFF," selector switch for each hopper.
- (4) 120 V red "ON" light and 120 V white "LO TEMP alarm light with integral transformers for each hopper zone.
- (5) Auxiliary relays and equipment required for operation of the heating and alarm systems.
- (6) Device and enclosure nameplates.
- (7) Fused control transformer having a 120 volt AC secondary.

2.5.4 Fly Ash Level Alarms

Provide each hopper with a fly ash level alarm utilizing nuclear type detectors. The detectors must be single point gamma source and detection units. Provide the detectors complete with separately mounted electronic units including local high level indicating light and relays for use with annunciation system herein specified. Provide relays rated at 10 amperes, 120 volts AC, or 125 volts DC continuous duty. Provide dustproof switch housing for hoppers and mount at one easily accessible location. Locate alarm indicators and detector and source electronics at the hopper control panel. Provide detector that is explosion proof, waterjacketed, and able to withstand vibration and temperatures up to 427 degrees C 800 degrees F. Provide the source with a lockable shutter mechanism operated by an external handle to totally isolate the beam when in the closed position. Furnish electrical wiring schematics. Electrical supply must be 120 volts, single phase, 60 hertz. Provide two sensors for each hopper--one at the alarm level and one at the empty level. Locate alarm level at the 50 percent hopper capacity level.

2.5.4.1 Temperature Range Requirement

Level reproducibility must be within one inch. Outdoor components must operate between minus 40 and 93 degrees C 40 and 200 degrees F.

2.5.4.2 Cesium Source Safety Systems

Provide Cesium 137 source for each hopper. Design source head with a spring return off system in the event of remote cable actuator failure. Interlock source with hopper access doors to prevent entry into hopper unless source has been secured. Hopper access door key must only open one pair of hopper doors.

2.5.4.3 Hopper Level Indicator

Hopper level signals, based on hopper level status indicator system, must report to a microprocessor through a coaxial cable system. Provide each hopper with two indicators, one for full and one for empty. A flashing light must indicate a wall buildup. Loss of power for any period of time must not require a recalibration. Provide NEMA ICS 6, Type 4 enclosure for microprocessor.

2.5.4.4 Alarm System

Incorporate each group of detector units for a single electrostatic precipitator into the unit alarm system for its respective precipitator so that a high level in any hopper must indicate as part of the unit alarm system.

2.6 ACCESS

2.6.1 Walkways

Provide walkways for inspection and maintenance of discharge electrode hanger points. Access doors and external walkways must make routine inspection tours readily performable. Connect walkways, including roof, by stairways. Interconnect walkways at each level by walkways at the same level. Provide caged ladders as a means of secondary egress connecting all levels.

2.6.2 Doors

Provide every access door with a corresponding exterior walkway connected to the general system of platforms and walkways. Provide insulated, hinged, quick opening access, inspection, and clean out doors with gastight seals. Access doors, including hopper doors, and mechanical and electrical components must be easily accessible from the walkway or provide with a permanent steel ladder or stairway to facilitate maintenance. Provide internal and external handholds at all access doors to facilitate entry.

2.6.3 Platforms, Walkways, and Ladders

Shop fabricate walkways, stairways, and ladders. Provide access to openings in both the precipitator and hoppers. Provide walkways in the casing interior as specified in paragraph entitled "Housing." Provide walkways, platforms, stairways, ladders, handrails, and kickplates on the penthouse roof and housing roof, as applicable, and as specified in paragraph entitled "Penthouse." Design platforms, ladders, and walkways support steel for live load specified herein. Design platforms to support a 488 kg per square meter 100 pound per square foot live load. Construct external walkways and platforms of steel conforming to ASTM A242/A242M raised pattern floor plate.

2.6.4 Maintenance

NOTE: Provide 227 kg 500 pound crane unless T/R
sets are to be replaced with the crane. If used for
T/R replacement, size for T/R weight.

Provide jib crane as required to remove roof-mounted equipment. Load limits must be [_____] kg pounds and the jib crane must be properly signed for safety showing maximum load permitted.

2.6.5 Hot Dip Galvanizing

Hot dip galvanize platforms, walkways, stairways, ladders, handrails, and kickplates after fabrication in accordance with ASTM A123/A123M. Minimum galvanized coating per surface must not be less than [_____] kg per square meter ounces/square foot.

2.6.6 Gas Distribution Devices

Provide the precipitator with inlet and outlet screens or baffles required to obtain proper gas distribution across the face of the precipitator as determined by model test study. Gas distribution devices must contain removable 915 by 610 mm 3 by 2 feet panels on each screen or baffle for access between screens. Provide the precipitator with internal gas baffles as required to prevent gases from bypassing the treatment zone. Gas distribution velocities across the inlet to the precipitator must have a root-mean-square deviation of no more than 15 percent and no flow must exceed 125 percent of average flow velocity.

2.6.7 Interlocks

Provide a key type safety interlock system with sequential key arrangement on the precipitator housing and penthouse access doors, inlet and outlet nozzle access doors, rectifier enclosure access doors, transformer-rectifier grounding switch, hopper level indicator sources, hopper access doors, and control unit circuit breakers. No high voltage equipment must be accessible without properly locking out the power supply and grounding the high voltage equipment. Keys must not be able to be removed from the locks when access doors are open.

2.7 FABRICATION

Perform shop fabrication and assembly of steel structures in conformance with AISC Specifications, Codes and Standards. Field welding must be shielded metal arc or submerged arc. Shop welding must be shielded-metal arc, submerged arc, flux-core arc, or gas metal arc. Perform welding in conformance with the requirements of the AWS D1.1/D1.1M and AISC Specifications. Shop connections must be welded, riveted, or bolted with high-strength bolts at the Contractor's option and as allowed by the seismic code. Unless restricted by consideration of clearance or seismic design criteria, show field connections as bolted friction type using ASTM A325M ASTM A325 or ASTM A490M ASTM A490 bolts and design to conform to AISC specification for "Structural Joints Using ASTM A325M ASTM A325 or ASTM A490M ASTM A490 Bolts." Form and weld handrails and do not exceed 6 feet from center-to-center of posts. Grind welds smooth and even with the surface of the pipe, remove weld splatter. Carefully form transitions at corners where change of direction of elevation occurs as required to provide continuous handrail. Clear columns or other vertical or horizontal projections by at least 80 mm 3 inches. Furnish plates and additional items as required for fastening to supporting members. Extend kickplates 100 mm 4 inches above top of grating and install at the edge of uncovered openings and at the edge of walkways and platforms. Construct kickplates to allow water run-off. Shop fabricate as complete as possible and within standard industry practice. Leave large pieces unassembled only to the extent necessary for shipment.

2.8 PAINTING

Steel surfaces must be dry and clean before painting. Remove grease, oils, and contaminants as outlined in SSPC SP 1. Remove weld spatter and grind burrs smooth on cut edges and rough welds. Blast-clean surfaces after fabrication, in accordance with SSPC SP 6/NACE No.3 and profile depth of 0.038 to 0.051 mm 1.5 to 2.5 mils. Before any rust bloom forms, apply one coat, dry film thickness of 0.076 mm 3 mils, of any of the organic zinc-rich primers meeting the requirements of SSPC PS 12.01, with a minimum of 82 percent zinc in the dry film. Apply primer in accordance with manufacturer's recommendations. Apply primer to steel surfaces except the areas within 50 mm two inches adjacent to field welds and surfaces specified to be hot-dip galvanized.

PART 3 EXECUTION

3.1 FACTORY INSPECTION

Any material or equipment used in the manufacture of the precipitator and found to be defective during inspection at the manufacturer's plant must be either corrected or replaced as approved by the Contracting Officer before shipment. Acceptance at the factory must not constitute final acceptance.

3.2 INSTALLATION

**NOTE: Revise this paragraph as necessary when it is
desired to have the precipitator manufacturer
install the equipment furnished.**

The contractor must install the equipment specified herein on foundations or structural-steel framework shown on the drawings or as specified elsewhere herein. Installation must be in accordance with the manufacturer's recommendations.

3.3 MANUFACTURER'S FIELD REPRESENTATIVE

**NOTE: The period of instruction should be reduced
only if the operating personnel have significant
experience on identical equipment.**

The contractor must provide the services of a field representative(s) specifically trained by the manufacturer to assist installers of their equipment. The field representative(s) must be at the erection site during installation including unloading, hauling, storing, cleaning, erecting, and testing. The field representative(s) must supervise the adjustment of all controls, control devices, and components supplied with the precipitator as necessary to place the precipitator in successful operation. The field representative(s) must instruct the plant operators in the operation, care, and maintenance of the equipment. Provide a minimum of 10 working days advance notice to the Contracting Officer prior to scheduling these instructions. Provide a total of [20] [_____] days instruction including [6] [_____] round trips to the jobsite. Provide training by field representative in precipitator theory and design,

start-up, shut-down, operation, performance monitoring, performance evaluation, problem diagnosis, maintenance, inspection methods, safety, operations and maintenance plans.

3.4 FIELD TESTS AND INSPECTIONS

3.4.1 Delivery Inspection

Materials and equipment must be inspected in accordance with the Contract Clauses. Inspections may be made to assure that equipment and installation comply with local and government requirements for equipment and safety as well as applicable specifications.

3.4.2 Post Installation Inspection

A factory service engineer employed by the precipitator manufacturer must inspect the precipitator after installation is completed and prior to startup to verify that the unit is installed in conformance with the manufacturer's recommendations. Perform an air load test with precipitator readings recorded.

3.4.3 Performance Tests

Perform field performance tests by an independent testing organization acceptable to the Contracting Officer. Provide written notice to the Contracting Officer, at least 20 calendar days before scheduled test date, stating that equipment is being scheduled for test. Perform a trial run of 30 days minimum before actual test (operate boiler at least 60 to 90 percent load) to ensure that associated systems required for the test are ready. Perform boiler tune-up to optimum efficiency prior to performance test. The Contractor and the manufacturer's factory service engineer must witness the test. Perform tests in accordance with applicable state or local methods. If no such methods or adaptations are required, then perform the tests in accordance with EPA 40 CFR 60, Appendix A, Methods 1-5, 9 and 17. Perform tests at the maximum continuous rating for the inlet gas conditions specified in paragraph entitled "Inlet Gas Conditions" and, if applicable, at other operating conditions that are required for approval by the appropriate regulatory agency. Test the precipitator for efficiency by simultaneous testing of precipitator inlet and outlet emissions. Conduct the efficiency tests after the precipitator has been in operation for at least 45 days.

3.5 IDENTIFICATION

Fasten an aluminum, brass, or corrosion-resistant steel nameplate to the equipment in a readily visible location by means of stainless steel Series 300 rivets or sheet metal screws. The nameplate must contain data such as the manufacturer's name, and model or series number. Indent or emboss the information in the metal. Offset the nameplate a sufficient amount to avoid being covered by insulation.

3.6 INSULATION INSTALLATION

3.6.1 General Insulation Requirements

Apply insulation with interruptions to permit access doors, inspection doors, flanges, and other special features to be opened or removed for inspection or maintenance without disturbing the insulation. Provide boxouts around code stamping symbols and nameplates. Install double

thickness insulation with the joints of the two layers staggered. Fill cracks, voids, and depressions in layers of insulation with suitable insulating cements before application of another layer of insulation or jacket application. Provide expansion joints in the insulation as required to allow for thermal expansion movements which might cause cracks or tears in the insulation. Install insulation between stiffeners and over stiffeners so that stiffeners are completely insulated. Install additional insulation or casing spacers between stiffeners so that a level surface is achieved. The intent of this insulating procedure is to prevent a direct metal path between the precipitator inside and ambient air. Securely wire and lace in place insulation using number 14 dead soft Type 302 stainless steel wire, conforming to [ASTM A580/A580M](#).

3.6.2 Block and Mineral Fiberboard Insulation Installation

Secure block and mineral fiberboard insulation in place with insulation lugs spaced on not greater than [300 by 460 mm 12 by 18 inch](#) centers. Provide stud type lugs welded in place. Reinforce blocks on the exterior face with expanded metal if necessary to prevent sagging or cutting of the insulation by the lacing wire. Securely wire block and mineral fiberboard insulation of the specified thickness in place over the entire surface by means of wire threaded through the lugs both ways, pulled tight with the ends of the wire loops twisted together with pliers, bent over, and carefully pressed into the surface of the insulation.

3.6.3 Mineral Fiber Blanket Insulation Installation

Secure mineral fiber blanket insulation in place with speed washers and impaling pins spaced on centers not exceeding [300 mm 12 inches](#). Provide mineral fiber blanket insulation with expanded metal reinforcement on the outer surface and wire mesh or expanded metal on the inner surface. Tightly butt sections of the blankets together and securely tie for maximum sealing at joints. Secure the blanket at joints to prevent peeling or bulging away from blanket edges. Do not reduce the design thickness of insulation when applying speed washers.

3.6.4 Housing Hot Roof

Install calcium silicate insulation conforming to [ASTM C533](#) over 12 gage steel pins stud welded on [610 mm two foot](#) centers to the surface to be insulated. Hold the insulation in place by [65 mm 2 1/2 inch](#) square speed washers and closely fit around penetrations. Construct top surfaces of steel conforming to [ASTM A242/A242M](#) raised pattern plate not less than [6 mm 1/4 inch](#) thick and suitably support to bear [488 kg per square meter 100 pounds per square foot](#) live load. Seal joints by continuous fillet or complete penetration groove welds as applicable. Weld appurtenances similarly to the plate. Provide top penetrations with a [50 mm 2 inch](#) minimum extension above the plate and similarly weld to the plate.

3.7 PROTECTION FROM INSULATION MATERIALS

Protect equipment and structures from damage from insulation materials. After completion of the work, clean, repair, and restore equipment and structures to their original state. Repair any casing which becomes corroded, discolored, or otherwise damaged by replacing of casing or other means acceptable to the Contracting Officer.

3.8 CASING INSTALLATION

3.8.1 Structural Steel Grid System

Install casing over exterior insulated surfaces on an aluminized structural steel grid system of subgirts designed, furnished, and installed by the contractor. Provide subgirts of sufficient size, gage, and depth to provide adequate support and a smooth exterior surface and weld to the equipment and structural support surfaces. Provide subgirts of sufficient depth to provide for application of the full thickness of insulation over the stiffeners, access doors, flanges, ribs, and other surfaces having uneven contours to provide a smooth finished surface. Provide subgirts on vertical and bottom surfaces at a maximum spacing of 1.22 meters 4 feet on centers. Provide subgirts on roof surfaces at a maximum spacing of 610 mm two feet on centers. Provide a roof surface system that will transmit an external 114 kg 250 pound walking load from the casing to the structural steel grid system without compression of the insulation material.

3.8.2 Access Openings

Closely fit insulation to fittings around access doors and other penetrations through the insulation. Neatly frame and flash to make weathertight and to create a pleasing appearance. Provide insulated hinged or lift-off doors designed for convenient opening or removal at nameplates, code stampings, nonprojecting connections, and access openings. Pitch access openings for water runoff and have flashing at door head as shown in SMACNA 1793.

3.8.3 Weatherproofing

Install casing with proper overlap to make the installation weathertight. Fabricate and fit the casing to ensure a neat appearance. Provide closures, flashings, and seals required. Provide the open ends of fluted sections with tightfitting closure pieces. Suitably form and install flashing so that water cannot enter and wet the insulation. Design and install flashing to readily drain any water that might enter. Weatherproof joints or openings in casing which cannot be effectively sealed from entry of moisture by application of an aluminum-pigmented sealer manufactured for this type of service.

3.8.4 Convection Stops

Provide steel channel or Z-girt convection stops on all vertical surfaces over 3.66 meters 12 feet tall. The maximum interval between convection stops must be 3.66 meters 12 feet.

3.8.5 Casing Attachment

NOTE: If a separate insulation section is part of
this specification, add a note to that section to
indicate that insulation of the precipitator is
covered by this section.

Attach aluminum casing to the steel structural members by means of Number 14 stainless steel Series 300 self-tapping screws on 305 mm 12 inch centers. Fasten vertical laps and flashing by means of 20 mm 3/4 inch

Number 14 stainless steel Series 300 sheet metal screws on 305 mm 12 inch centers. Provide exposed screws with aluminum or stainless steel backed neoprene washers preassembled to screws. Do not compress insulation below nominal thickness when installing screws.

3.9 HEATER INSTALLATION

Thoroughly clean hopper surfaces prior to heater module, tape, or blanket installation. Install the heater module so the module surface contacts the hopper wall to the maximum extent possible. Provide heaters with necessary mounting hardware, channels, and brackets. Install throat heaters so the heater conforms to the surface of the throat and contacts the throat to the maximum extent possible. Do not overlap throat heaters. Hold throat heaters in place with high temperature (454 degrees C 850 degrees F) glass tape or other means acceptable to the Contracting Officer. Completely cover the throat heater with the glass tape prior to lagging.

3.10 WIRE NUMBERS

Provide wire numbers on both ends of each wire appearing on the elementary diagram. Use space terminals for terminations. Markers must be white plastic sleeves with black letters.

3.11 GALVANIC CORROSION PREVENTION

To prevent galvanic corrosion, prevent permanent contact of aluminum casing with copper, copper alloy, tin, lead, nickel, or nickel alloy including Monel metal. Where it is necessary to attach the casing to carbon steel or low alloy steel, paint the steel with zinc chromate primer. Then paint with aluminum paint suitable for surface temperatures encountered. Do not use lead base paint.

3.12 PAINTING

Provide field painting of those surfaces of the following equipment not in contact with the flue gas stream: precipitators, cyclones, fans, and breeching. Field paint as specified in Section 09 90 00 PAINTS AND COATINGS. Paint other equipment provided in this section; either field paint with paint systems conforming to Section 09 90 00 PAINTS AND COATINGS or paint with factory or shop painting systems conforming to the requirements specified in Section 23 03 00.00 20 BASIC MECHANICAL MATERIALS AND METHODS.

3.13 SCHEDULE

Some metric measurements in this section are based on mathematical conversion of inch-pound measurements, and not on metric measurements commonly agreed on by the manufacturers or other parties. The inch-pound and metric measurements shown are as follows:

<u>Products</u>	<u>Inch-Pound</u>	<u>Metric</u>
a. [_____]	[_____]	[_____]

-- End of Section --