

\*\*\*\*\*

USACE / NAVFAC / AFCEC

UFGS-14 92 00 (February 2009)

Change 1 - 02/15

-----

Preparing Activity: USACE

Superseding

UFGS-14 92 00 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2025

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 14 - CONVEYING EQUIPMENT

##### SECTION 14 92 00

##### PNEUMATIC-TUBE SYSTEM

02/09, CHG 1: 02/15

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SYSTEM DESCRIPTION
  - 1.2.1 General Requirements
  - 1.2.2 Electrical Work
- 1.3 SUBMITTALS
- 1.4 DELIVERY, STORAGE, AND HANDLING
- 1.5 EXTRA MATERIALS

#### PART 2 PRODUCTS

- 2.1 STANDARD PRODUCTS
- 2.2 ENERGY EFFICIENCY
- 2.3 CARRIER TUBING
  - 2.3.1 Tubing
  - 2.3.2 Bends
  - 2.3.3 Fittings
- 2.4 POWER UNITS
- 2.5 AUTOMATIC CENTRAL-CONTROL CENTER
  - 2.5.1 Operation of the System
  - 2.5.2 Control Program
  - 2.5.3 Computer Circuits and Keyboard
    - 2.5.3.1 Cathode Ray Tube
    - 2.5.3.2 Keyboard
    - 2.5.3.3 Printer
    - 2.5.3.4 Alarm Module
- 2.6 STORAGE AREAS
- 2.7 AUTOMATIC SWITCHING EQUIPMENT
- 2.8 SUBSTATION EQUIPMENT
  - 2.8.1 Receiving Units
  - 2.8.2 Sending Units
  - 2.8.3 Carrier Storage Receptacle
  - 2.8.4 Station Control Panel

- 2.8.4.1 Operating Controls and Indicators
- 2.8.4.2 Non-operating Requirements
- 2.8.5 Directory
- 2.9 CARRIERS
  - 2.9.1 Access
  - 2.9.2 Carrier Inserts
- 2.10 SYSTEM TESTER

PART 3 EXECUTION

- 3.1 EXAMINATION
- 3.2 INSTALLATION
  - 3.2.1 Sound Insulation
  - 3.2.2 Hangers and Supports
  - 3.2.3 Installation of Tubing
  - 3.2.4 Firewall Penetrations
- 3.3 PAINTING AND FINISHING
- 3.4 ACCESS PANELS
- 3.5 ACOUSTIC COUPLER
- 3.6 FRAMED INSTRUCTIONS
- 3.7 MANUFACTURER'S FIELD SERVICES
- 3.8 FIELD TRAINING
- 3.9 TESTS

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC UFGS-14 92 00 (February 2009)  
Change 1 - 02/15  
-----  
Preparing Activity: USACE Superseding  
UFGS-14 92 00 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2025

\*\*\*\*\*

### SECTION 14 92 00

#### PNEUMATIC-TUBE SYSTEM 02/09, CHG 1: 02/15

\*\*\*\*\*

NOTE: This guide specification covers the requirements for computer controlled pneumatic tube system.

Adhere to [UFC 1-300-02 Unified Facilities Guide Specifications \(UFGS\) Format Standard](#) when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

\*\*\*\*\*

## PART 1 GENERAL

### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature

to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM A123/A123M (2024) Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA MG 00001 (2024) Motors and Generators

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2026) National Electrical Code

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

PL 109-58 Energy Policy Act of 2005 (EPAct05)

## 1.2 SYSTEM DESCRIPTION

### 1.2.1 General Requirements

Provide a pneumatic-tube system which is computer controlled and designed with not less than [\_\_\_\_\_] separate zones interconnected to permit automatic unattended transmission of carriers from any station to any other station. Design and locate system components in such a manner that in the event of a defect occurring, components may readily be removed and replaced. Provide full access type carriers[, capable of handling 1000 ml I.V. bottles or 1000 ml I.V. bags]. Other system characteristics are as follows:

- a. Future capacity of not less than [\_\_\_\_\_] stations without the need for modifications to the central control and existing station control.
- b. Each zone capable of serving not less than [\_\_\_\_\_] stations even though a fewer number may be indicated in a given zone at this time.
- c. [Stations within a zone connected to the storage lanes via a single line and diverter unit.] Control spacing, direction, [storage,] and path of the carriers.
- d. Destination selection by means of push buttons or rotary dials on the station control panel.
- e. Carriers taking the shortest route to their destinations. A central exchanger is not required. [Perform carrier processing between zones through the central storage lanes.]

- f. Carriers routed by means of diverters or in-line transfer units.
- g. Carrier rejections indicated at the dispatching station for non-existing, signed-off, or malfunctioning station destinations. Do not use reject station.
- h. Failure of one station must not interfere with the normal functioning of any other station. Failure of any diverter will shut down that section of the system. Failure of an in-line sensor except zero-level sensor must not shut down that section of the system.
- i. Automatic sequencing of sending and receiving carriers.
- j. Each zone [and the central storage lanes] act independently with separate power units as required.
- k. Automatic recovery of a carrier will be required only after a transaction has been initiated and a failure occurs that prevents the completion. In such a case the carrier in process will be either returned to its source station or processed to the destination station after the failure has been repaired and cleared.
- l. Selection of the shortest, most direct routing of all carriers to their destinations.
- m. Complete "route proofing" of transaction paths before acceptance of the carrier to assure all components in the routing are operating.
- n. Intra-zone transactions must take the most direct path within the zone.
- o. Self-adjusting priority within the system to load balance according to traffic.
- p. Carriers may be positioned in senders simultaneously and destination selected on the station control panel.
- q. Deliver carriers in transit at the time a power failure occurs to their selected destinations upon restoration of power.
- r. Direct processing of simultaneous, multiple transactions to assure maximum operational efficiency of the system.
- s. Deliver carriers in transit at the time of station sign-off to their destination.
- t. Reject carriers addressed to any non-existing or signed off station.
- u. Automatic time clock sign off to allow any station to be automatically signed-off.
- v. Preventive overload feature at station receiver. Carriers will not be dispatched to a station that is overloaded.
- w. Automatic redistribution of empty carriers to return empty carriers to the locations with the greatest need.
- x. Automatic purge by zone or system.

- y. Each completed transaction, alarm condition that occurs and sign off schedule automatically printed out on printer.

### 1.2.2 Electrical Work

Provide electrical motor-driven equipment specified herein complete with motors, motor starters and controls complying with NEMA MG 00001. Provide electrical equipment and wiring in accordance with Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM. Electrical characteristics are as indicated. Provide extension to equipment from junction box and all control wiring as specified in this section and complying with NFPA 70. Provide motor starters under this section complete with properly sized thermal-overload protection in each phase and other appurtenances necessary for the motor control specified. Size each motor to drive the equipment at the specified capacity without exceeding the nameplate rating of the motor when operating at proper electrical system voltage. Provide control and protective or signal devices required for the operation specified and wiring required for controls and devices but not shown on the electrical plans.

### 1.3 SUBMITTALS

\*\*\*\*\*

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the

"G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Pneumatic-Tube System

SD-03 Product Data

Pneumatic-Tube System

Materials and Equipment

Spare Parts

Pneumatic-Tube System

Tests

SD-06 Test Reports

Tests

SD-07 Certificates

Energy Efficiency

SD-10 Operation and Maintenance Data

Operating and Maintenance Instructions; G, [\_\_\_\_\_]

1.4 DELIVERY, STORAGE, AND HANDLING

Protect all equipment delivered and placed in storage from the weather, humidity and temperature variation, dirt and dust, or other contaminants.

1.5 EXTRA MATERIALS

Submit **spare parts** data for each different item of materials and equipment specified, after approval of the detail drawings and not later than [\_\_\_\_\_] months prior to the date of beneficial occupancy. Include a complete list of parts and supplies, with current unit prices and source of supply.

PART 2 PRODUCTS

2.1 STANDARD PRODUCTS

Provide **Materials and Equipment** which are the standard products of a manufacturer regularly engaged in the manufacture of the products and that essentially duplicate items that have been in satisfactory use for at least 2 years prior to bid opening. Provide equipment supported by a service organization that is, in the opinion of the Contracting Officer, reasonably convenient to the site. Submit a complete list of equipment and material, including manufacturer's descriptive data and technical literature, performance charts and curves, catalog cuts, and installation instructions.

## 2.2 ENERGY EFFICIENCY

\*\*\*\*\*

NOTE: Selected equipment must conform to efficiency requirements as defined in Public Law (PL) 109-58 - "Energy Policy Act of 2005 (EPAct05)" for energy efficiency procurement and as specified by FEMP and ENERGY STAR. Equipment selected will have as a minimum the efficiency rating determined in under "Energy-Efficient Products" at <http://www1.eere.energy.gov/femp/procurement>. Equipment having a lower efficiency may be specified if the designer determines the equipment to be more life-cycle cost effective. Indicate the equipment operating characteristics, including rated energy efficiency, on the drawings.

\*\*\*\*\*

Provide products that meet or exceed the specified energy efficiency requirements of FEMP designated or Energy Star qualified products. Submit documentation certifying that product conforms to PL 109-58 by meeting or exceeding Energy Star or FEMP efficiency requirements as defined at "Energy-Efficient Products" at <http://www.energystar.gov>. Indicate Energy Efficiency Rating. Indicate Energy Efficiency Rating.

## 2.3 CARRIER TUBING

### 2.3.1 Tubing

Provide tubing for carrier transmission lines consisting of [152.4] [101.6] [1.613] mm OD [[6] [4] in] [16 U.S. gauge] OD galvanized electric welded steel with flash removed, conforming to ASTM A123/A123M. Size air lines as required for proper system operation.

### 2.3.2 Bends

Provide bends of the same material as straight tubing, formed on the centerline to a radius of not less than 1200 mm 4 feet, free from wrinkles or distortion. Make joints between sections with sleeve couplings, bolted couplings or bell end tubing. When bends are cut for offsets and small angle turns, squarely cut the ends. File and straighten by mandreling. Do not use expanded bends.

### 2.3.3 Fittings

Provide fittings that are cast iron, cast aluminum or fabricated steel with the inside fitting snugly on the tubing. Provide box connectors, close elbows, tees, coupling sleeves and other fittings required for proper installation of the system.

## 2.4 POWER UNITS

Provide power units for each zone and for lanes when required that are capable of operating all lines simultaneously and producing an average carrier speed of 7.6 m/s 25 fps. Design power units for floor or ceiling mounting. Provide a timer or similar device to shut the unit off after a predetermined time without carrier movement. Provide power units complete



with vibration isolators, intake and exhaust mufflers, intake and exhaust piping, screen box, air valves if required, and designed for easy access.

## 2.5 AUTOMATIC CENTRAL-CONTROL CENTER

### 2.5.1 Operation of the System

Provide a solid state memory computer to control the system. The computer must perform logic, control, supervisory and alarm functions and provide permanent storage for system operating program. Provide program memory protection during power loss. Provide interface controls to transmit operating data to and from stations. Keyboard must request information and must simulate operation of components throughout entire system. Print transactions and failures.

### 2.5.2 Control Program

The control program is the property of the user. Allow the user to add, delete, and/or relocate components of the system, onsite, without the need for a new program or programming assistance.

### 2.5.3 Computer Circuits and Keyboard

Provide modular interface circuits, monitor and keyboard consisting of solid state components throughout. For ease of maintenance, provide readily removable circuit modules.

#### 2.5.3.1 Cathode Ray Tube

Video Display Monitor to display in English language data for the following functions:

- a. Failure Location - Zone, [central storage lane,] station, power unit or transfer unit.
- b. Failure Type - Mechanical, electrical or component position.
- c. Present transactions - Station carrier is leaving from and station carrier is going to, backlog per station or zone [and carrier in storage lanes].
- d. Carrier Distribution - Number of carriers assigned to each station, number of carriers presently at each station.
- e. Station sign-off schedule.
- f. Failure Action - Locate where carrier is and corrective action to be taken.
- g. System History Display - Show all system traffic for the past 24-hour period with totals for stations, zones, and the entire system. This display must be automatically printed.

#### 2.5.3.2 Keyboard

The keyboard must be interactive with the video monitor to perform the following functions:

- a. Request video monitor displays listed above.

- b. Simulate components for trouble shooting. Make simulation of all components to determine the malfunctioning unit.

#### 2.5.3.3 Printer

\*\*\*\*\*

**NOTE:** Selected printers are required to meet performance requirements specified by Energy Star. Information on the requirements can be found at [http://www.energystar.gov/ia/partners/product\\_specs/program\\_reqs/Imaging\\_Eq](http://www.energystar.gov/ia/partners/product_specs/program_reqs/Imaging_Eq). As of September 6, 2012, the specific performance requirements were as follows:

Printer	Standard	High Performance IJ, DT, DS, EP, SI, TT	TEC
		IJ, Impact	OM
	Large or Small	DT, DS, EP, Impact, IJ, SI, TT	OM

These are referenced in Energy Star Program Requirements for Residential Air Source Heat Pump (ASHPs) and Central Air Conditioner Equipment, Volume 4.1. These specifications conform to the efficiency requirements as defined in Public Law (PL) 109-58 - "Energy Policy Act of 2005 (EPAct05)" for energy efficiency procurement and as specified by ENERGY STAR. Equipment selected will have as a minimum the efficiency rating determined in under "Energy-Efficient Products" at <http://www1.eere.energy.gov/femp/procurement>.

Equipment having a lower efficiency may be specified if the designer determines the equipment to be more life-cycle cost effective. Indicate the equipment operating characteristics, including rated energy efficiency, on the drawings. A list of compliant products can be found at [http://downloads.energystar.gov/bi/qplist/image equip\\_prod\\_list.xls?be70-acf](http://downloads.energystar.gov/bi/qplist/image equip_prod_list.xls?be70-acf)

\*\*\*\*\*

Provide [Energy Star compliant ]laser jet printer with at least 128 MB of random access memory, 1200 dots per inch resolution, and support normal and postscript fonts and drivers. Type face supported must be True Type fonts. Printer must support HP PCL 6, HP PCL 5e and Post Script emulation. Equip printer with 10/100 Base Ethernet card, a serial and parallel port. Provide all Ethernet connectivity cables, power cables and printer drivers with the printer. Equip printer with at least two paper drawers. Each drawer must have a capacity of at least 600 sheets of standard paper.

#### 2.5.3.4 Alarm Module

Provide an alarm module for remote audio-visual signaling of system alarms. The alarm module must have a "Press to Silence" button. The alarm must automatically activate should a system alarm condition occur.

### 2.6 STORAGE AREAS

\*\*\*\*\*  
**NOTE: Storage areas will be deleted if a single zone system is specified.**  
\*\*\*\*\*

Design Storage Areas to initially serve [\_\_\_\_\_] zones. Storage must be expandable to a maximum of [\_\_\_\_\_] storage lanes without the need to replace the initial unit. Storage area must consist of storage lanes connected directly to every other zone in the system.

### 2.7 AUTOMATIC SWITCHING EQUIPMENT

Automatically orient diverters to route carriers to or from intermediate stations. Provide air or electro-mechanically operated units designed to accommodate two or more stations or sublevels and enclosed in sheet metal housing with access panels. Design diverter so that when a carrier does not clear the diverter completely, no other carrier can be routed to that diverter.

### 2.8 SUBSTATION EQUIPMENT

Enclose substation equipment in a self-supporting "rough-in" recessed type enclosure. Install the operating components after the adjacent walls have been finished. Factory paint exposed sheet metal surfaces. Provide stainless steel, brushed aluminum or chrome plated bright metal parts.

#### 2.8.1 Receiving Units

Provide down receive, air cushion, soft delivery type units. Design carrier receiver tray to receive and store carriers to the front of the received tray. Full carrier capacity must cause audible alarm to sound or the reject light to illuminate.

#### 2.8.2 Sending Units

Units must be up-send in conjunction with the receiving unit.

#### 2.8.3 Carrier Storage Receptacle

Storage receptacle must store not less than four carriers and must be integral with the terminal front.

#### 2.8.4 Station Control Panel

##### 2.8.4.1 Operating Controls and Indicators

Include the following operating controls and indicators:

- a. Carrier destination selectors, "Carrier Accepted" signal, "Send" buttons.

- b. "Carrier Rejected" signal when a carrier cannot be dispatched because of destination sign off, an alarm condition, a nonexistent selection or an overloaded station.
- c. "Carrier in Receiver" to indicate a carrier is in the receiving unit when the carrier is not visible.
- d. "Cancellation Button."

#### 2.8.4.2 Non-operating Requirements

Include the following:

- a. "Operating Instructions" display.
- b. Independent carrier dispatch and receive functions.
- c. The memory within the programmable microprocessor available to all stations.
- d. Request to dispatch handled immediately on a local or central control basis.

#### 2.8.5 Directory

Provide station consisting of a framed directory or photo plate clearly showing the location, name, and number of each station in the system. Provide a glass or plastic cover for the framed directory.

### 2.9 CARRIERS

Furnish four carriers for each station in the system. Carriers less than [82.6 x 381.0] [114.3 x 381.0] mm [3-1/4 x 15] [4-1/2 x 15] inch inside dimensions are not acceptable. Provide carriers that are capable of transporting 1000 ml I.V. bottles.

#### 2.9.1 Access

Provide carriers that are side opening, full access type, bi-directional.

#### 2.9.2 Carrier Inserts

Furnish foam lining for transporting fragile items for [\_\_\_\_\_] of the total system carriers [and furnish [\_\_\_\_\_] of the total system carriers with foam lining for transporting 1000 ml I.V. bottles].

#### 2.10 SYSTEM TESTER

Provide system tester with the ability to test any station, transfer unit, or blower with onsite verification of malfunctions. A portable test device which supplements the control center may be used.

## PART 3 EXECUTION

### 3.1 EXAMINATION

After becoming familiar with all details of the work, verify all dimensions in the field, and advise the Contracting Officer of any discrepancy before performing the work.

### 3.2 INSTALLATION

Install the **pneumatic-tube system** as indicated and as recommended by the manufacturer. Submit diagrams, instructions, and other sheets proposed for posting.

- a. Submit detail drawings containing complete wiring and schematic diagrams and any other details required to demonstrate that the system has been coordinated and will properly function as a unit. Show proposed layout and anchorage of equipment and appurtenances, and equipment relationship to other parts of the work including clearance for maintenance and operation.
- b. Submit [six] [\_\_\_\_] copies of design manual consisting of manufacturer's standard literature. Identify the operational requirements for the system and explain the theory of operation, design philosophy, and specific functions. Include a description of hardware and software functions, interfaces, and requirements for all system operating modes. Describe all equipment provided, including general description and specifications.

#### 3.2.1 Sound Insulation

Deaden the sound of tubing and bends run over patient rooms or offices by applying a **38.1 mm 1-1/2 inch** thick layer of **24 kg/cubic meter 1-1/2 pcf** density fiberglass insulation with a dust cover and taped joints over the tubing. Do not extend sound insulation material no less than **1.5 meters 5 feet** outside the patient rooms or offices. Provide insulation conforming to EPA requirements in conformance with Section **01 33 29 SUSTAINABILITY REQUIREMENTS AND REPORTING**.

#### 3.2.2 Hangers and Supports

Space hangers and supports on **3 meters 10 foot** centers for horizontal runs of tubing. Support vertical runs at every floor. Support each horizontal bend and in-line component. Hangers for one or two lines of tubing must be **10 mm 3/8 inch** plated and threaded rods attached to row clamps. Form hangers for three or more lines with row clamps or **38.1 mm 1-1/2 inch** channels laid flat against the bottom of the tubing and support by no less than two rods spaced no more than **900 mm 3 feet** apart. Row clamps must maintain centerlines of horizontal runs of multiple tubes straight and level and spaced apart in a consistent configuration.

#### 3.2.3 Installation of Tubing

Make joints airtight by methods recommended by the manufacturer. Install lines where indicated and securely hold in place and brace against any motion caused by the passage of carriers. Install tubing passing through openings in floors suitable sleeves or slots, stuff with **25 mm 1 inch** fiberglass blanket and seal on both ends with a continuous bead of nonhardening mastic at least **6.4 mm 1/4 inch** deep.

#### 3.2.4 Firewall Penetrations

Where holes are required in fire and smoke walls for the passage of tubing and other accessories, fill the annular space between pipe and hole with a UL approved fireproof material. Seal penetrations through fire rated walls as specified in Section **07 84 00 FIRESTOPPING**.

### 3.3 PAINTING AND FINISHING

Furnish field-applied paint as specified in Section 09 90 00 PAINTS AND COATINGS.

### 3.4 ACCESS PANELS

Provide access panels as specified in Section 08 31 00 ACCESS DOORS AND PANELS.

### 3.5 ACOUSTIC COUPLER

\*\*\*\*\*  
**NOTE: Delete acoustic coupler if manufacturer has a service organization conveniently located to the site.**  
\*\*\*\*\*

Provide an acoustic coupler that will permit the facility to have direct communications with the manufacturer for one year. Provide a communication tie-in to a cathode ray tube (CRT) at the manufacturer's facility through the handset of an ordinary telephone and the acoustic coupler at the facility. The coupler will be used to examine or modify computer memory and may command any system component and determine its status.

### 3.6 FRAMED INSTRUCTIONS

Post framed instructions under glass or in laminated plastic, including wiring and control diagrams showing the complete layout of the entire system where directed. Prepare condensed operating instructions explaining preventive maintenance procedures, methods of checking the system for normal safe operation, and procedures for safely starting and stopping the system in typed form, frame as specified above and post beside the diagrams. Post the framed instructions before acceptance testing of the systems.

### 3.7 MANUFACTURER'S FIELD SERVICES

Provide the services of a manufacturer's representative who is experienced in the installation, adjustment, and operation of the equipment specified. Supervise the installation, adjustment, and testing of the equipment.

### 3.8 FIELD TRAINING

Provide a field training course for designated operating and maintenance staff members. Provide training for a total period of [\_\_\_\_\_] hours of normal working time and start after the system is functionally complete but prior to final acceptance tests. Cover all of the items contained in the [Operating and Maintenance Instructions](#). Submit [six] [\_\_\_\_\_] complete copies of operation manual outlining the step-by-step procedures required for system startup, operation, and shutdown. Include the manufacturer's name, model number, service manual, parts list, and brief description of all equipment and their basic operating features. Submit [six] [\_\_\_\_\_] complete copies of maintenance manual listing routine maintenance procedures, possible breakdowns and repairs, and troubleshooting guide. Include piping layout, equipment layout, simplified wiring and control

diagrams of the system as installed. Operation and maintenance manuals must be approved prior to the training course.

### 3.9 TESTS

\*\*\*\*\*  
**NOTE: If a single zone system is specified, delete  
subparagraphs "c," "e," and "f" below.**  
\*\*\*\*\*

Submit test plan and procedures, not later than [\_\_\_\_\_] days prior to the start of testing. Explain in detail, step-by-step, actions and expected results to demonstrate compliance with the requirements of this specification, and the methods for simulating the necessary conditions of operation to demonstrate performance of the system. Conduct tests in accordance with the approved test procedures to determine that the system is functional, operational and installed in accordance with the specifications. Notify the Contracting Officer in writing [\_\_\_\_\_] days prior to conducting tests. Conduct the following test:

- a. Computer simulation and interrogation.
- b. Consecutive dispatching to random stations within the zone.
- c. Consecutive dispatching to random stations outside the zone.
- d. Multi-station dispatching within the zone where all dispatchers are loaded with carriers, random stations selected and dispatching begins.
- e. Multi-station dispatching outside the zone where all dispatchers are loaded with carriers, random stations selected and dispatching begins.
- f. Two stations in each zone will be randomly selected to dispatch carriers into other zones.

Submit test reports in booklet form showing all field tests performed to adjust each component and all field tests performed to prove compliance with the specified performance criteria, upon completion of installation and testing of the installed system. Indicate the final position of controls.

-- End of Section --