
USACE / NAVFAC / AFCEC UFGS-26 29 01.00 10 (November 2022)

Preparing Activity: USACE

Superseding
UFGS-26 29 01.00 10 (November 2008)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2025

SECTION TABLE OF CONTENTS

DIVISION 26 - ELECTRICAL

SECTION 26 29 01.00 10

ELECTRIC MOTORS, 3-PHASE VERTICAL INDUCTION TYPE

11/22

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUMMARY
- 1.3 SUBMITTALS
- 1.4 QUALITY ASSURANCE
 - 1.4.1 Corrosion Prevention and Finish Painting
 - 1.4.1.1 Fastenings and Fittings
 - 1.4.1.2 Corrosion-Resisting Materials
 - 1.4.1.3 Corrosion-Resisting Treatments
 - 1.4.1.4 Frames
 - 1.4.1.5 Cores
 - 1.4.1.6 Shafts
 - 1.4.1.7 Finish Painting
 - 1.4.2 Government Study
- 1.5 DELIVERY, STORAGE, AND HANDLING
 - 1.5.1 Impact Recorder
 - 1.5.2 Long Term Storage
- 1.6 RELATED REQUIREMENTS

PART 2 PRODUCTS

- 2.1 NAMEPLATES
- 2.2 GUARDS AND PROTECTIVE ENCLOSURES
- 2.3 MOTORS
 - 2.3.1 Rating
 - 2.3.2 Operating Characteristics
 - 2.3.2.1 Torques
 - 2.3.2.2 Locked-Rotor Current
 - 2.3.2.3 Starting Capabilities
 - 2.3.2.4 Duty Cycle
 - 2.3.2.5 Balance
 - 2.3.2.6 Noise

- 2.3.2.7 Efficiency
- 2.3.3 Frames and Brackets
 - 2.3.3.1 Stator Frame
 - 2.3.3.2 Supporting Bracket
 - 2.3.3.3 Overspeed Alternate
 - 2.3.3.4 Antireverse Device Alternate
 - 2.3.3.5 Eyebolts
- 2.3.4 Cores
- 2.3.5 Insulated Windings
- 2.3.6 Thermal Protection
- 2.3.7 Winding Heaters
 - 2.3.7.1 Heating Element
 - 2.3.7.2 Sheath
 - 2.3.7.3 Insulation
 - 2.3.7.4 Terminals
- 2.3.8 Shafts
- 2.3.9 Bearings
 - 2.3.9.1 Loading
 - 2.3.9.2 Thrust Bearings
 - 2.3.9.3 Guide Bearings
 - 2.3.9.4 Lubrication
 - 2.3.9.5 Bearing Housings
 - 2.3.9.6 Cooling
 - 2.3.9.7 Rating
 - 2.3.9.8 Shaft Currents
- 2.4 SURGE PROTECTION
 - 2.4.1 Surge Capacitors
 - 2.4.2 Surge Arresters
 - 2.4.3 Space Heater
- 2.5 MOTOR TERMINALS AND BOXES
 - 2.5.1 Stator Terminal Box
 - 2.5.2 Stator Terminals
 - 2.5.3 Grounding
 - 2.5.4 Accessory Leads and Boxes
- 2.6 WRENCHES, TOOLS, AND SPECIAL EQUIPMENT
- 2.7 FACTORY TESTS
 - 2.7.1 Complete Test
 - 2.7.1.1 Excitation Test
 - 2.7.1.2 Impedance Test
 - 2.7.1.3 Performance Test
 - 2.7.1.4 Speed-Torque Test
 - 2.7.1.5 Temperature Test
 - 2.7.1.6 Insulation Resistance-Temperature Test
 - 2.7.1.7 Cold and Hot Resistance Measurement
 - 2.7.1.8 Dielectric Test
 - 2.7.1.9 Sound Level Test
 - 2.7.1.10 Vibration Measurement
 - 2.7.1.11 Conformance Tests
 - 2.7.2 Check Test
 - 2.7.2.1 Routine Test
 - 2.7.2.2 Cold Resistance Measurement
 - 2.7.2.3 Insulation Resistance and Winding Temperature
 - 2.7.2.4 Conformance Test
 - 2.7.2.5 Vibration
 - 2.7.3 Form Wound Coil Test
 - 2.7.4 Winding Space Heater Test

PART 3 EXECUTION

3.1 FIELD QUALITY CONTROL

3.1.1 Visual and Mechanical Inspection

3.1.2 Electrical Tests

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC UFGS-26 29 01.00 10 (November 2022)

Preparing Activity: USACE

Superseding
UFGS-26 29 01.00 10 (November 2008)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated October 2025

SECTION 26 29 01.00 10

ELECTRIC MOTORS, 3-PHASE VERTICAL INDUCTION TYPE 11/22

NOTE: This guide specification covers the requirements for procurement of 3-phase vertical induction motors for driving storm-water pumps for local flood-control pumping stations. This section was originally developed for USACE Civil Works projects.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

PART 1 GENERAL

NOTE: This section covers motors with special features of construction which are considered necessary to provide maximum insurance against failures where the motors are to be operated only for short periods of time, at infrequent intervals, and at locations where the average relative humidity of the air is high. Where operating characteristics or features of motor construction differ from this specification but are considered desirable, this specification may be modified accordingly. The

designer must also consider unusual service conditions such as direct exposure to the sun, vermin infestation, or high altitude.

In adapting this specification to any project, the form and phraseology will be changed as necessary to properly specify the work contemplated. When deviations from this specification are considered necessary, prior approval from HQ USACE will be obtained.

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN BEARING MANUFACTURERS ASSOCIATION (ABMA)

ABMA 9 (2015) Load Ratings and Fatigue Life for Ball Bearings

ABMA 11 (2014; R 2020) Load Ratings and Fatigue Life for Roller Bearings

ASTM INTERNATIONAL (ASTM)

ASTM A123/A123M (2024) Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products

ASTM A153/A153M (2023) Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware

ASTM B344 (2020; R 2025) Standard Specification for Drawn or Rolled Nickel-Chromium and

Nickel-Chromium-Iron Alloys for Electrical Heating Elements

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE 43 (2013) Recommended Practice for Testing Insulation Resistance of Rotating Machinery

INTERNATIONAL ELECTRICAL TESTING ASSOCIATION (NETA)

NETA ATS (2025) Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA MG 00001 (2024) Motors and Generators

U.S. ARMY CORPS OF ENGINEERS (USACE)

EM 385-1-1 (2024) Safety -- Safety and Occupational Health (SOH) Requirements

1.2 SUMMARY

The work under this section includes providing all labor, equipment, and material and performing all operations required to design, manufacture, assemble, test, and package and deliver the vertical induction motors for driving pumps specified under Section 35 45 01 VERTICAL PUMPS, AXIAL-FLOW AND MIXED-FLOW IMPELLER TYPE.

- a. Supply motors complete with all accessories, spare parts, tools, and manufacturer's data and instructions as specified herein.
- b. Submit complete instructions for the proper installation, inspection, and maintenance of the machines provided for this particular service. Submit instruction manuals to the Contracting Officer not later than the date the equipment is shipped from the manufacturer's plant. In the instructions, include a cross-sectional drawing indicating the major component parts of the motor and the procedure for disassembly.
- c. With the instruction manual, submit a complete list of renewal parts with prices for each different rating of motor.

1.3 SUBMITTALS

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Long Term Storage; G, [_____]

Antireverse Device Alternate; G, [_____]

SD-02 Shop Drawings

Motors; G, [_____]

SD-03 Product Data

Insulated Windings; G, [_____]

Duty Cycle; G, [_____]

Motors; G, [_____]

Government Study

Spare Parts

SD-06 Test Reports

Starting Capabilities

Factory Tests

Acceptance Checks And Tests; G, [_____]

SD-07 Certificates

Efficiency

Factory Tests

SD-10 Operation and Maintenance Data

Instructions; G, [_____]

1.4 QUALITY ASSURANCE

1.4.1 Corrosion Prevention and Finish Painting

The equipment provided under these specifications will be subjected to severe moisture conditions. Design the equipment to render it resistant to corrosion from such exposure. The general requirements to be followed to mitigate corrosion are specified below. Any additional special treatment or requirement considered necessary for any individual items is specified under the respective item. However, other corrosion-resisting treatments that are the equivalent of those specified herein may, with the approval of the Contracting Officer, be used.

1.4.1.1 Fastenings and Fittings

Where practicable, all screws, bolts, nuts, pins, studs, springs, washers, and other similar fittings must be of corrosion-resisting material or must be treated in an approved manner to render them resistant to corrosion.

1.4.1.2 Corrosion-Resisting Materials

Corrosion-resisting steel, copper, brass, bronze, copper-nickel, and nickel-copper alloys are acceptable corrosion-resisting materials.

1.4.1.3 Corrosion-Resisting Treatments

Hot-dip galvanizing must be in accordance with [ASTM A123/A123M](#) or [ASTM A153/A153M](#) as applicable. Other corrosion-resisting treatments may be used if approved by the Contracting Officer.

1.4.1.4 Frames

Clean rust, grease, millscale, and dirt from motor frames, end bells, covers, conduit boxes, and any other parts, if of steel, and if they will be coated during the process of insulating the windings. Then treat and rinse in accordance with manufacturer's standard process. If any of the above-listed parts are not coated during the process of insulating the windings then, in addition to the above, give the parts one coat of primer and then two coats of manufacturer's standard moisture-resistant coating, processed as required.

1.4.1.5 Cores

Thoroughly clean and immediately prime the assembled motor core by applying a minimum of two coats of a moisture-resisting and oil-resisting insulating compound. Give air gap surfaces a minimum of one coat.

1.4.1.6 Shafts

Clean rust, grease, and dirt from exposed surfaces of motor shafts.

Except for bearing surfaces, give motor shafts one coat of a zinc molybdate or equivalent primer and two coats of a moisture-proof coating, each cured as required. Shafts of a corrosion-resisting steel may be used in lieu of the above treatment.

1.4.1.7 Finish Painting

NOTE: If severely moist conditions exist, a separate paint system should be specified using Section 09 97 02 PAINTING: HYDRAULIC STRUCTURES, system 21, epoxy finish or equivalent. When such painting is specified, care must be taken to specify a paint that will adhere to and not be injurious to the protective painting provided under these specifications.

Finish painting of all equipment must be in accordance with the standard practice or recommendation of the manufacturer for the installed conditions, as approved by the Contracting Officer.

1.4.2 Government Study

NOTE: Item d. may be used only when the pump and motor are furnished under the same procurement.

Submit the specified data. Supply to the Government, for completion of its Motor Torque and Accelerating Time Studies (MTATS), the following data:

- a. Complete equivalent circuit data referred to the stator with friction, windage, and stray load losses.
- b. Current, power factor, and torque versus speed (0-100 percent, inclusive, in 1 percent increments up to 95 percent and in 0.1 percent increments above 95 percent) and load (0-125 percent, inclusive, in 25 percent increments) as a function of line voltage (from 80 percent to 110 percent, inclusive, in 5 percent increments), for rated and 90 percent of rated voltage at starter. Only tabulated data will be required.
- c. Load inertia, Wk2 of motor rotating parts, pound-feet.
- [d. Load inertia, Wk2 of pump rotating parts (wet), pound-foot2.]

1.5 DELIVERY, STORAGE, AND HANDLING

Ship each motor in the vertical position with the rotor blocked inside the stator to prevent damage to the bearings. Securely mount the motor on a skid or pallet of ample size. Box all small parts or elements. Perform the skid mounting and boxing in a manner which will prevent damage or distortion to the motor during loading, shipment, unloading, indoor storage, and subsequent handling. Provide weatherproof covers as necessary to protect the motor and appurtenances during shipment. [Furnish for unloading and handling at the destination any eyebolts, special slings, strongbacks, or other devices used in loading the equipment at the manufacturer's plant, and these items must become the property of the

Government.]

[1.5.1 Impact Recorder

Ship each motor with a three-way temporary impact recorder to measure magnitude and direction of longitudinal (Y), lateral (X), and vertical (Z) impacts suffered during shipment. If the recorder indicates impacts equal to or greater than limits determined by the Contractor prior to shipment for any of the three directions specified herein, inspect and test motor to determine extent of damage, if any, and repair or replace any damaged equipment.

]1.5.2 Long Term Storage

NOTE: Include this paragraph only
when there is no available Government storage.

Store all provided equipment provided for [_] [days][months]. The storage site must meet the manufacturer's recommendations for indoor storage. The equipment will be subject to periodic inspection by the Government to ensure that proper storage conditions are maintained. Submit the storage site description, location, description of environmental controls, and means of access.

]1.6 RELATED REQUIREMENTS

Section 26 08 00 APPARATUS INSPECTION AND TESTING applies.

PART 2 PRODUCTS

2.1 NAMEPLATES

Provide nameplates for each motor with motor characteristics in accordance with NEMA MG 0001. Nameplates must include rated voltage, rated full-load amperes, rated horsepower, service factor, number of phases, RPM at rated load, frequency, code letter, locked-rotor amperes, duty rating, insulation system designation, and maximum ambient design temperature.

2.2 GUARDS AND PROTECTIVE ENCLOSURES

For all moving, energized, or other parts where accidental contact might be hazardous to personnel, equip with adequate guards, rails, or other suitable enclosures to prevent accidental contact. For all lubrication fittings, pipe to convenient locations where fittings can be serviced.

2.3 MOTORS

NOTE: For weak source (high Thevenin source impedance), the electric utility must be contacted to determine starting restrictions, maximum inrush, or voltage dip limits. This is especially critical for motors over 75kW 100 hp. The designer must then perform a Motor Torque and Accelerating Time Study (MTATS) to evaluate the motor starting torque and voltage dip requirement. The selection of a reduced voltage starter must then be based on the

electric utility requirements and the motor pump arrangement.

NEMA MG 00001, Part 31, covers definite purpose inverter-fed polyphase motors rated 5000 horsepower or less at 7200 volts or less. If the designer determines the need to specify inverter-duty motors; due to constant torque requirements, a speed range beyond standard duty nameplate, where speed synchronization or other reasons, the designer must ensure the motor meets specifications in NEMA MG 00001 Part 31.

The motors to be supplied under these specifications must be of the vertical shaft type as required by the pump manufacturer, normal or low starting torque, low starting current, squirrel-cage induction type, designed for full voltage starting, of drip-proof construction, and conforming to the applicable requirements of NEMA MG 00001, except as hereinafter specified.

- a. Submit equipment foundation dimensions; outline drawings with weights, nameplate data, and details showing method of mounting and anchoring the motor. Obtain Contracting Officer's approval in writing prior to the commencement of manufacture of motors.
- b. Submit complete descriptive specification of each type and size motor provided, with necessary cuts, photographs, and drawings to clearly indicate the construction of the motor, the materials and treatments used to prevent corrosion of parts, bearing construction, and type of insulation used on all windings.
- c. Submit all information required for selection of protective and control equipment and for operational setting, such as, but not limited to, normal and maximum operation temperature for windings and bearings, overload trip setting for motor at pump maximum head condition and starting times for starting at rated and 90 percent starter voltage.

2.3.1 Rating

NOTE: NEMA MG 00001, Parts 10 and 20, cover medium and large induction motors, respectively. Any motor specified by speed and horsepower will be included in either Part 10 or Part 20. References to both parts are listed in some cases, as either or both parts may apply to a particular project.

Consult the local electric utility for the expected voltage unbalance that will be present. If the value exceeds 1 percent, ask the utility to furnish their plans to improve the voltage unbalance. Use NEMA MG 00001 to derate the motor if the voltage unbalance exceeds 1 percent. Voltage unbalance must not exceed 5 percent. Consult motor manufacturers for voltage unbalance limits whenever motors have specified limits on locked-rotor currents, particularly the 500-percent limit.

Wind each motor for three-phase, 60-Hz, alternating current, and for the respective operating voltage listed below:

| PLANT | PUMP | SERVICE | MOTOR OPERATING VOLTAGE |
|---------|---------|---------|-------------------------|
| [_____] | [_____] | [_____] | [_____] |
| [_____] | [_____] | [_____] | [_____] |

Design the motor for operation in a 40 degrees C 105 degrees F ambient temperature, and all temperature rises must be above this ambient temperature. The rated horsepower of the motor must be not less than 110 percent of the determined maximum load requirement of the pump. [Supply voltage unbalance will be [_] percent, and the motor must provide the indicated horsepower after the voltage unbalance derating of NEMA MG 00001 paragraph 20.24.]Motors must have a service factor of 1.0 or must be applied using a service factor of 1.0 if standard service factor is greater than 1.0. The temperature rise above the ambient temperature for continuous rated full-load conditions and for the class of insulation used must not exceed the values given in NEMA MG 00001, paragraph 12.42 or paragraph 20.8.

2.3.2 Operating Characteristics

2.3.2.1 Torques

NOTE: The "Operating Characteristics" specified are to limit the locked-rotor current to a value sufficiently low to permit full-voltage starting. Manufacturer's standard is to limit locked-rotor current to 600 percent of design full-load current. However, if local conditions are such that lower starting current is desirable, the locked-rotor current may be specified not to exceed 500 percent of the design full-load current. When 500 percent is specified, the breakdown torque of 150 percent of full-load torque will be used. The designer will note that these percentages are for design full-load current at rated power factor and will vary based on actual load and supply conditions. Designer should consult local utility for actual requirements for limitations on inrush currents. When inrush current cannot be sufficiently limited by motor design, a reduced voltage starter will be used.

When reduced voltage starting is required, closed transition autotransformer type reduced voltage starters should be used. These starters provide the most flexibility during installation since both input voltage and inrush current may be adjusted.

This specification is not meant to limit the selection of a reduced voltage starter to only autotransformer type. The use of a wye-delta or solid-state type starter may be appropriate in

certain situations. The reduced starter cost for use of other than autotransformer type starters must be weighed against the increased cost in motor designs; however each design should be evaluated for the most suitable type starter. All reduced voltage starters will reduce the motor starting torque, so the designer should evaluate the load characteristics to ensure that motor torque will be sufficient under all starting conditions. If reduced-kVA starters are required, EM 1110-2-3105 should be consulted for further guidance and possible pump design considerations.

Starting torque must be sufficient to start the pump to which the motor will be connected under the maximum conditions specified, but in no case must the starting torque be less than 60 percent of full-load torque. Breakdown torque must be not less than [200] [150] percent of full-load torque.

2.3.2.2 Locked-Rotor Current

NOTE: The objective of this specification is to limit the locked-rotor current to a value sufficiently low to permit full-voltage starting. The motor horsepower rating is to be a minimum of 110 percent of the maximum pump load at a service factor of 1.0. Manufacturer's standard is to limit locked-rotor current to 600 percent of full load current. However, local utilities may have additional limitations on inrush currents and should be consulted to supply information required in this paragraph. Motor design will permit some reduction in inrush current in which case 500 percent should be used. If this is not sufficient, reduced-voltage starting should be used. The inrush current limit should be specified whenever possible. The requirements for locked-rotor current (inrush) must be coordinated with power factor and efficiency requirements below.

The locked-rotor current must not exceed [600] [500] percent of normal full-load running current. [The locked-rotor current must not exceed [_____] amps at 90 percent of rated voltage during any point in the starting cycle under worst case starting conditions. For reduced voltage starting, apply the above criteria to supply side of the starter.]

2.3.2.3 Starting Capabilities

NOTE: Frequency of starting must always be considered in motor applications. The starting capabilities to be met by all motors are set forth below. However, the actual motor duty cycle should be specified in paragraph DUTY CYCLE, along with the requirement for the special motor starting nameplate. Undoubtedly, these starting capabilities

will be adequate in most cases since the actual load inertia, WK2 of the pumps is much less than the NEMA values, the load torque is low, and the frequency of starting (number of starts per unit of time) is low. When the frequency of starting is several times per hour, or the load torque is high, a thorough study and perhaps a modified motor may be required. To ensure that all requirements of the specifications are met, submittal of the operating data should be required. It is possible that with higher starting frequencies the rotor may have to operate at temperatures higher than typical, so that modifications would be required.

Large motors, on the basis of the load torque characteristics and the load inertia Wk2 listed in NEMA MG 00001, paragraphs 20.10 and 20.11, must as a minimum be capable of making the starts required in NEMA MG 00001, paragraph 20.12. Smaller motors must conform to the requirements in NEMA MG 00001, paragraph 12.54. Submit certified test reports, when available, of tests previously performed on motors of each type and size specified or calculated data to substantiate the motor's capability to conform to the specified requirements.

2.3.2.4 Duty Cycle

Submit an analysis to verify that the motor, when operated in accordance with the duty cycle specified, will not undergo injurious temperature rise. If the duty cycle cannot be met with a standard NEMA design motor, the motor manufacturer must provide a description of proposed modifications to provide such compliance. Each motor, when operating at rated voltage and frequency and on the basis of the connected pump load inertia Wk2 and the speed-torque characteristics of the load during starting conditions as furnished by the pump manufacturer, must be capable of performing on a continuous basis the following motor duty cycle without injurious temperature rise: [operation at rated load over a period of approximately [_____] [hours] [days]] [a running period at rated load of not less than [_____] [minutes] [hours] and a standstill period of not less than [_____] [minutes] [hours].] Provided on each motor a starting information nameplate setting forth the starting capabilities. This nameplate must also include the minimum time at standstill and the minimum running time prior to an additional start.

2.3.2.5 Balance

The balance for each motor when measured in accordance with NEMA MG 00001, Part 7, must not exceed the values specified. [Each motor's characteristics must meet the provisions of Section 35 45 01 VERTICAL PUMPS, AXIAL-FLOW AND MIXED-FLOW IMPELLER-TYPE.]

2.3.2.6 Noise

NOTE: The Department of Defense (DoD) considers hazardous noise exposure of personnel as equivalent to 85 decibels or greater A-weighted sound pressure level (dBA) for 8 hours in any one 24-hour period. On the assumption that pumping plant operating personnel may be exposed to noise levels approaching

or exceeding that defined by the DOD as hazardous, the motor noise limit should be specified not to exceed 85 dBA. The additional cost of providing motors meeting this requirement should be investigated and weighed against an alternate of providing a room to isolate these personnel from the noise exposure.

All motors must operate at a noise level less than 85 decibels A-weighted mean sound pressure level (dBA). Determine noise in accordance with NEMA MG 00001 Part 9. The specified noise limit applies for a reference distance of one meter for free-field conditions.

2.3.2.7 Efficiency

NOTE: The Energy Policy Act of 2007 (as amended) requires NEMA MG 00001 premium efficiency for many general purpose electric motors up to 200 HP. Close-coupled pump motors up to 200 HP and NEMA Design B motors from 200 HP up to 500 HP must be NEMA MG 00001 energy efficient.

Energy efficient: NEMA MG 00001, Table 12.11

Premium efficient: NEMA MG 00001, Table 12.12

The tested full load efficiency must meet or exceed the minimum value listed in NEMA MG 00001 Table 12.[11][12]. The nameplate full load efficiency must meet or exceed the nominal value listed in NEMA MG 00001 Table 12[11][12].

2.3.3 Frames and Brackets

Frames and end brackets must be of cast iron, cast steel, or welded steel. The mounting ring, unless otherwise approved, must be built integral with the frame or lower end bracket and arranged for direct mounting on the pump, or station floor, or as required by the installation conditions. Treatment against corrosion must be as specified in paragraph QUALITY ASSURANCE.

2.3.3.1 Stator Frame

The stator frame must be rigid and sufficiently strong to support the weight of the upper bearing bracket load, the weight of the stator core and windings, and to sustain the operating torques without perceptible distortion. Support the stator frame, if not directly mounted on the pump, on a motor base or drive pedestal which in turn will be supported on sole plates or other suitable structure installed in the concrete foundation constructed as part of the pumping station structure. Provide the motor base or drive pedestal with bolts and dowels for fastening to the sole plates or supporting structure for preserving the alignment.

2.3.3.2 Supporting Bracket

The upper bracket supporting the thrust bearing and upper guide bearings must have sufficient strength and rigidity to support the weight of the entire rotating element of the motor, together with the pump impeller and

shaft, and the hydraulic thrust of the pump impeller.

[2.3.3.3 Overspeed Alternate

**NOTE: NEMA MG 00001 paragraphs 12.48 and 20.44
specify that overspeeds are for emergencies lasting
no longer than two minutes. Using this option will
add costs due to requirements well beyond standard
limits.**

Design each motor to withstand indefinitely, without injury, the maximum overspeed to which the motor will be subjected when the pump to which it is connected is acting as a hydraulic turbine under the maximum head with the pump discharge pipe open.

]2.3.3.4 Antireverse Device Alternate

Installed as an integral part of the motor a self-actuated backstop device or antireversing ratchet, to prevent reverse rotation of the pump due to loss of power or failure of the electric prime mover. Submit the design of the device for approval by the Contracting Officer. The design must have sufficient capacity to prevent reverse rotation with a back-flow through the pump due to a [___] foot differential head. If the device requires a lubrication system, provide an oil reservoir independent of the one used for the thrust bearing and complete with visible oil level gauge and 120-volt a.c. rated high and low level contacts. Terminate all electrical leads in the accessory terminal box specified in paragraph MOTOR TERMINALS AND BOXES. The lubricant for the antireverse device must contain a corrosion inhibitor. Show the type and grade of lubricant on a special nameplate attached to the frame adjacent to the lubricating filling device.

2.3.3.5 Eyebolts

Provide eyebolts, lugs, or other approved means for assembling, dismantling, and removing the motor, if required, from above using an overhead crane. Provide with the motor all lifting devices required for use in conjunction with the crane.

2.3.4 Cores

The cores for the stators and rotors must be built up of separately punched thin laminations of low-hysteresis loss, nonaging, annealed, electrical silicon steel, assembled under heavy pressure, and clamped in such a manner as to ensure that the assembled core is tight at the top of the teeth of the laminated core. Properly insulate laminations from each other. Use only laminations free from burrs, and remove all burrs or projecting laminations from the slots of the assembled cores. Cores must be keyed, dovetailed, or otherwise secured to the shaft or frame in an approved manner. Treatment against corrosion must be as specified in paragraph QUALITY ASSURANCE.

2.3.5 Insulated Windings

**NOTE: If motor temperature rise is of particular
concern, the designer may specify Class F insulation**

with a Class B temperature rise instead of Class F insulation with 110 percent continuous overload factor. Use final sentence of item f. only when the pump and motor are furnished under the same procurement.

All motors must have a nonhygroscopic, sealed, fungus-resisting insulation of a type designed and constructed to withstand severe moisture conditions, and insofar as practicable, to operate after long periods of idleness without previous drying out. All windings and connections must be of the sealed type as defined in NEMA MG 00001 paragraph 1.27.2. If, in the opinion of the Contracting Officer, the insulation proposed is not of the quality specified, the motors will not be accepted. Submit motor design curves and motor speed-torque curves, as specified. Unless otherwise approved, completely assemble insulated windings in the motor core before impregnating with the insulating compound. The compound must consist of 100 percent solid resin.

- a. Impregnation of the windings with the insulating compound must be by vacuum impregnation method followed by baking. Repeat the procedure as often as necessary to fill in and seal over the interstices of the winding, but in no case must the number of dips and bakes be less than two dips and bakes when the vacuum method of impregnation is used. The completed stator must be of a type that is capable of passing the submerged or sprayed water test, as applicable, required by NEMA MG 00001 paragraph 12.62 and 20.18.
- b. Random wound coils may be used on motors supplied in NEMA frame size 445 TP and smaller. The components of the insulation system and the conductor insulation of the coils must be Class F insulation with a 1.15 service factor as defined in NEMA MG 00001 paragraph 1.66. After winding, encapsulate the completely wound stator with an insulating resin as defined in NEMA MG 00001 paragraph 1.27.1.
- c. Use form wound coils on motors supplied in NEMA frames larger than 445 TP. The components of the insulation system and the coil insulation of the rectangular conductors must conform to Class F insulation with a 110 percent continuous overload factor as defined in NEMA MG 00001, paragraph 1.66. The completed stator windings and connections must be of the sealed type as defined in NEMA MG 00001 paragraph 1.27.2.
- d. Insulation to ground must be processed on the coil. Slot tubes or cells are not acceptable. The insulation must be of adequate thickness and breakdown strength throughout the length of the coil. Use mica in the slot portion, and mica must be of adequate thickness to withstand the dielectric tests specified in paragraph FACTORY TESTS. Form wound coils must be of such uniformity that the stator windings on motors of equal ratings must be alike, in shape and size, and be interchangeable.
- e. Submit motor design (characteristic) curves or tabulated data (test or calculated), indicating the speed, power factor, efficiency, current, and kilowatt input, all plotted or tabulated against torque or percent load as abscissa. The base value must be given whether ANSI or IEEE standard system is used. Provide the maximum allowable reverse rotation speed for the motor.
- f. Submit [pump and] motor speed-torque curves for the pump starting

operation. Plot the motor speed-torque curves for the following values of voltage at the motor terminals: The output of the [closed transition auto-transformer-type reduced voltage] [_____] starter supplied at rated and 90 percent of rated motor voltage [and connected on its 65 percent and 80 percent taps]. [Plot the pump torque curve for starting and accelerating against maximum head. Furnish computations to demonstrate that the motor furnished will carry the pump load under all the foregoing conditions.]

- g. Coils of all windings must be fully braced so that vibration is virtually eliminated during repeated starts as required by the duty cycle specified as well as during normal operation. If a tied system is used it must be such that no tie depends upon the integrity of any other tie within the system.

2.3.6 Thermal Protection

For motors rated 6000 hp or greater, provide resistance temperature detectors (two per phase) in accordance with NEMA MG 00001, paragraph 20.27. Detectors must have a copper resistance element having a resistance of 10 ohms at 25 degrees C 76 degrees F. Terminate leads on the terminal blocks specified in paragraph MOTOR TERMINALS AND BOXES. For motors rated less than 6000 hp, embed resistance temperature detectors (one per phase) in the windings. The detectors with all necessary additional equipment, as required, must prevent motor operation when the critical temperature is reached. Terminate all outgoing wiring on the terminal blocks specified in paragraph MOTOR TERMINALS AND BOXES.

2.3.7 Winding Heaters

NOTE: The inclusion or omission of "Winding Space Heaters" will depend upon the decision reached after giving due consideration to the problem of prevention of moisture condensation on the station equipment. If winding space heaters are not required, this paragraph, including all subparagraphs, must be deleted.

Wrap heaters around the winding end turns. Designate heaters for operation on 120 volts, 1-phase, 60 Hz, alternating current and of sufficient capacity or wattage that, when energized, they will hold the temperature of the motor windings approximately 10 degrees C above the ambient temperature. Design heaters for continuous operation and to withstand at least 10 percent overvoltage continuously. The rate of heat dissipation must be uniform throughout the effective length of the heater. Heaters installed around the winding end turns must consist of the required turns of heating cable wrapped around the end turns and secured in place before the winding is impregnated.

2.3.7.1 Heating Element

Heating element must conform to the requirements of ASTM B344 for an 80 percent nickel and 20 percent chromium alloy.

2.3.7.2 Sheath

Sheath must be of a corrosion-resisting, nonoxidizing metal and must have

a wall thickness not less than 0.625 mm 0.025 inch.

2.3.7.3 Insulation

Insulation must be a granular mineral refractory material, highly resistant to heat, and must have a minimum specific resistance of 1,000 megohms per inch cubed at 535 degrees C 1,000 degrees F. Insulation for the heating cable (winding wraparound type) type heaters must be suitable for a conductor temperature of 180 degrees C 356 degrees F.

2.3.7.4 Terminals

Terminals of the heater, including the leads, must be watertight. Provide heater terminals with leads suitable for making connections to the drip-proof terminal box provided in paragraph MOTOR TERMINALS AND BOXES. [The terminal box must be readily accessible through the crating so that winding heaters can be energized while motors are in storage.]

2.3.8 Shafts

NOTE: Hollow shaft pumps must be used whenever possible, since they are more readily adjusted. Pumps requiring large motors (above 746 kW 1,000 hp) are limited by the available motors. The exact motor capabilities and sources of supply must be investigated when using hollow shafts with motors above 746 kW 1,000 hp. Solid shafts must be used only when the available motor designs require their use.

Shafts must be made of high grade steel, finished all over, and of ample size to drive the pumps under maximum load conditions. Shafts must be of [hollow] [solid] types as required by the pump manufacturer. See paragraph QUALITY ASSURANCE for treatment against corrosion. Coordinate the connection with the pump shaft.

2.3.9 Bearings

2.3.9.1 Loading

Bearings must be capable of withstanding all stresses incidental to the normal operation of the unit [and the maximum speed of the pumping unit when operating in the reverse direction].

2.3.9.2 Thrust Bearings

NOTE: If the thrust requirements exceed the standard published ratings of commercially available anti-friction thrust bearings, plate-type bearings should be used. Should this condition exist, a specification for plate-type bearings may be obtained from CDR USACE (DAEN-CWE-E) WASH DC 20314.

Thrust bearings must be of the antifriction type of either the ball or roller type. Do not use tandem or series bearing assemblies.

Antifriction bearings must conform to the requirements of ABMA 9 and ABMA 11.

2.3.9.3 Guide Bearings

Guide bearings must be of the sleeve or antifriction type of either the ball or roller type or a combination of sleeve and antifriction bearings.

2.3.9.4 Lubrication

Bearings must be either oil or grease lubricated, and the lubricant used must contain a corrosion inhibitor. Show the type and grade of lubricant used on a special nameplate which must be attached to the frame of the motor adjacent to the bearing lubricant filling device. In addition to the quantity of lubricant required to fill each motor's lubricating system initially, provide spare lubricant in sufficient quantity to purge and refill each motor's lubricating system.

2.3.9.5 Bearing Housings

Bearing housings must be of a design and method of assembly that will permit ready removal of the bearings, prevent escape of lubricant and entrance of foreign matter, and protected by the lubricant when the motor is idle. Except for prelubricated antifriction bearings of an approved type, provide suitable means to apply and drain the lubricant. For oil-lubricated bearing housings, provide readily visible oil-level indicator gauges.

2.3.9.6 Cooling

All bearings must be self-cooling unless otherwise specifically approved by the Contracting Officer. If the use of cooling is approved, the means employed must, unless otherwise approved by the Contracting Officer, require no auxiliary pumping equipment; and provide suitable means to indicate the bearing temperature, actuate an alarm when the bearing temperature is above normal, and actuate a device to shut down the motor when the maximum safe operating temperature of the bearing is reached. Cooling coils must be of copper tubing and designed for the operating pressure used to circulate the cooling water. Cooling water temperature will be [_____] degrees C.

2.3.9.7 Rating

Antifriction bearings must be rated on the basis of a minimum life factor of 8,800 hours, based on the life expectancy of 90 percent of the group, unless otherwise approved by the Contracting Officer.

2.3.9.8 Shaft Currents

Insulate or otherwise protect bearings against the damaging effects of shaft currents.

2.4 SURGE PROTECTION

2.4.1 Surge Capacitors

**NOTE: To obtain the most reliable protection for
2,300- and 4,000-volt motors, surge capacitors and**

arresters, mounted at the motor terminals, should be specified. In addition, it is recommended that station-type arresters be installed on the line side of the supply transformers. For 480-volt systems, surge protection is not generally warranted if the station system is connected to the utility line through a transformer which has adequate surge protection on the high side. Each 480-volt installation should be investigated, however, to determine whether surge protection is required, especially where excessive switching voltages may occur or where the lightning incidence rate is high.

Provide a three-pole capacitor unit, equipped with built-in discharge resistors and using a non-polychlorinated biphenyl (PCB) insulating medium, in the main terminal box. Each pole must be rated [0.5 microfarad and [2,400] [4,160] volts line-to-line] [1.0 microfarad and 650 volts line-to-line]. Provide removable bus links for motor testing. These links must be treated to resist corrosion, designed to maintain a positive contact, and have low contact resistance.

2.4.2 Surge Arresters

NOTE: Arrester maximum continuous operating voltage (MCOV) rating must be 3,000 volts line-to-ground for 2,400-volt systems and for effectively grounded 4,160-volt systems, 4,500 volts line-to-ground operating voltage for ungrounded or resistance-grounded 4,160-volt systems, or other ratings as required. An effectively grounded system is defined as one in which X_0/X_1 is positive and less than 3 and R_0/X_1 must be positive and less than 1 for all system conditions at the point of application of the surge arrester.

In the main terminal box, provide surge arresters of the station type with porcelain tops. The arresters must be of the metal-oxide type rated [3,000] [4,500] [_____] volts maximum continuous operating voltage (MCOV) line-to-ground. Provide removable bus links for motor testing. These links must be treated to resist corrosion, designed to maintain a positive contact, and have low contact resistance.

2.4.3 Space Heater

If recommended by the surge protection manufacturer, provide a space heater of adequate capacity and rated 120 volts. Space heaters must have a maximum watt density of 20 watts per square inch.

2.5 MOTOR TERMINALS AND BOXES

2.5.1 Stator Terminal Box

Supply drip-proof cast iron or steel conduit terminal boxes, treated as specified for frames in paragraph QUALITY ASSURANCE, for housing the stator lead connections [surge capacitors] [and surge arresters]. Boxes must have adequate space to facilitate the installation and maintenance of

cables and equipment. Boxes must have a [bolted] [hinged securable] cover providing unrestricted access, be mounted on the motor frame, and have an auxiliary floor supporting structure, when required, supplied by the motor manufacturer. Conduit entrance must be from the bottom. Design the boxes to permit removal of motor supply leads when the motor is removed. [Provide a "HIGH VOLTAGE - [_____] VOLTS" warning sign on the cover of the box.] [When looking down on the motor/pump assembly, the terminal box must be located between [_____] degrees and [_____] degrees clockwise from the discharge elbow of the pump.]

2.5.2 Stator Terminals

Insulated terminal leads must receive a treatment equal to that of the motor winding. Bring leads out of the stator frame and provide with terminal lugs for connection to the motor supply wiring.

2.5.3 Grounding

In the stator terminal box, provide a ground bus and means for external connection to the station grounding system when surge protection is provided.

2.5.4 Accessory Leads and Boxes

Bring terminal leads for motor winding space heaters, [surge protection equipment space heater], [resistance temperature detectors] [thermistors] and any other auxiliary equipment into conveniently located terminal boxes. Provide terminal leads with terminal blocks for extension by others. The terminal boxes must be drip-proof and treated as specified for frames in paragraph QUALITY ASSURANCE. All auxiliary wiring must be stranded copper conductors with 600-volt flame-retardant insulation, except temperature detector leads may be in accordance with the manufacturer's standard practice. Legibly and accurately identify all wiring and terminals.

2.6 WRENCHES, TOOLS, AND SPECIAL EQUIPMENT

Provide all nonstandard and special equipment required for dismantling, reassembly, and general maintenance of the motor units. Provide one complete set of lifting attachments such as detachable eyebolts or special slings for handling various parts with a hoist.

2.7 **FACTORY TESTS**

NOTE: The designer should carefully consider whether to allow the Contracting Officer to waive these tests. Decision should be based on expertise in the field within the Division or District.

Give one motor of each rating type, selected at random by the Contracting Officer, a complete test. Give the remaining motors a check test.

- a. Submit test reports recording all data obtained during the tests specified to the Contracting Officer for each motor used. Test reports must include performance curves indicating the results of subparagraph COMPLETE TEST below.

- b. Submit certified results of a "Complete Test" for duplicate equipment. It will be accepted in lieu of the "Complete Test" as specified in subparagraph COMPLETE TEST below for equipment of the respective rating and type.
- c. No substitute will be accepted for the "Check Test." The base value must be given whether ANSI or IEEE standard system is used. All complete tests must be [witnessed by the Contracting Officer] [unless waived in writing].

2.7.1 Complete Test

A complete test of a motor must include the following:

2.7.1.1 Excitation Test

Including a plot of volts as abscissa versus amperes and watts as ordinates.

2.7.1.2 Impedance Test

Including a plot of volts as abscissa versus amperes and watts as ordinates.

2.7.1.3 Performance Test

Including a plot of torque or percent load as abscissa versus efficiency, power factor, amperes, watts, and RPM or percent slip as ordinates.

2.7.1.4 Speed-Torque Test

Pony brake or other equivalent method. Including a plot of torque in foot-pounds as abscissa versus speed in RPM as ordinate.

2.7.1.5 Temperature Test

Made on completion of paragraph c above. (If screens are provided over openings, test will be made with screens removed and by thermometer).

2.7.1.6 Insulation Resistance-Temperature Test

Perform the test after a heat run, readings being taken at approximately 10 degrees C intervals. Determine temperature by the resistance method. Plot test result values on semilogarithmic graphs, the insulation resistance values as logarithmic ordinates, and the temperature values as uniform abscissas. For comparison purposes, on the same sheet with the insulation resistance-temperature test curve, plot a curve indicating the safe operating value of insulation resistance.

2.7.1.7 Cold and Hot Resistance Measurement

2.7.1.8 Dielectric Test

2.7.1.9 Sound Level Test

In accordance with EM 385-1-1.

2.7.1.10 Vibration Measurement

In accordance with NEMA MG 00001 Part 7.

2.7.1.11 Conformance Tests

In accordance with NEMA MG 00001 paragraph [12.62][12.63][20.18].

2.7.2 Check Test

A check test of a motor must include the following:

2.7.2.1 Routine Test

Test in accordance with NEMA MG 00001 paragraph [12.55][20.16.2][31.6.2].

2.7.2.2 Cold Resistance Measurement

2.7.2.3 Insulation Resistance and Winding Temperature

Insulation resistance and winding temperature at time the insulation resistance was measured.

[2.7.2.4 Conformance Test

In accordance with NEMA MG 00001 paragraph [12.62][12.63][20.18].

]2.7.2.5 Vibration

Vibration measurement in accordance with NEMA MG 00001 Part 7.

2.7.3 Form Wound Coil Test

Test all form wound coils, either before or after they are placed in the slots, for short circuits between turns of the individual coils by applying a high frequency voltage of not less than 75 percent of the voltage for which the machine is insulated, or by applying a surge test voltage of equivalent value to the terminals of each coil. Equivalent surge voltage must be a wave whose peak value is equal to 1.06 times the voltage for which the motor is insulated.

2.7.4 Winding Space Heater Test

NOTE: Include this test only where winding space heaters are specified.

At the factory, test each winding space heater unit for successful operation and dielectric strength.

PART 3 EXECUTION

3.1 FIELD QUALITY CONTROL

Perform the following acceptance checks and tests in accordance with NETA ATS section 7.15.1.

3.1.1.1 Visual and Mechanical Inspection

- (1) Compare equipment nameplate data with drawings and specifications.
- (2) Inspect physical and mechanical condition.
- (3) Inspect anchorage, alignment, and grounding.
- (4) Inspect air baffles, filter media, stator winding, stator core, rotor, cooling fans, slip rings, brushes, brush rigging, and bearings.
- (5) Inspect bolted electrical connections for high resistance using a low-resistance ohmmeter. Correct values which deviate by more than 50 percent of the lowest value.
- (6) Verify the application of appropriate lubrication and lubrication systems.
- (7) Verify that resistance temperature detector (RTD) circuits conform to drawings.

3.1.1.2 Electrical Tests

- (1) Perform insulation-resistance tests in accordance with IEEE 43. Test duration must be [10 minutes][one minute]. The [polarization index][dielectric-absorption ratio] must be at least [2.0][1.4].
- (2) Perform insulation-resistance test on insulated bearings in accordance with manufacturer's published data.
- (3) Test surge protection devices.
- (4) Test motor starter.
- (5) Perform resistance tests on resistance temperature detector (RTD) circuits.
- (6) Verify operation of machine space heater.

... -- End of Section --