



E-S1: Building Meter Installation Sheet Per Building-Example

Repair New Update Replacement

Serial # :	13076962	MFG:	LANDIS & GYR	Voltage:	120/208
Meter # :	90359550	Form:	8S /9S	Current:	
Facility:	Bldg 535	Class:	20	Wires:	4W
Pole Mount:	N/A	CT Ratio:	400/5	Delta/Wye:	WYE
Nearest Facility:		VT Ratio:	N/A	AMR Meter:	YES
		Multiplier:	80	KWH Read.:	START: 00000

Location Description: Located on pad-mount transformer for Building 535

Old Meter Information (if applicable)

Serial # :	7517047	MFG:	LANDIS & GYR	Voltage:	120/208
Meter # :	90043246	Form:	8S/9S	Current:	
Facility:	Bldg 535	Class:	20	Wires:	4W
Pole Mount:	N/A	CT Ratio:	400/5	Delta/Wye:	WYE
Nearest Facility:		VT Ratio:	N/A	AMR Meter:	YES
				KWH Read.:	END: 03535

Remarks:

1. New AMR meter installed on 4-11-08 at 1530 because old meter would not communicate.
2. Meter display worked. Meter is working properly.

Additional Work Required

PERFORMED BY:

DATE: