



NOTES:

1. USE THIS MINIMUM ACCEPTABLE CONFIGURATION IF THERE IS NOT THE 3' PREFERRED HORIZONTAL SPACING BETWEEN THE ELECTRIC AND GAS METERS.
2. THE 36" MINIMUM SPACING MEASURED ALONG THE DIAGONAL BETWEEN THE GAS METER AND ELECTRIC METER IS REQUIRED.
3. THIS CONFIGURATION IS TYPICALLY USED ON FACILITY WALLS WITH EXTERIOR OBSTRUCTIONS THAT LIMIT INSTALLATION SPACING.

OUTSIDE METER INSTALLATION ON WALL – ACCEPTABLE DISTANCE TO GAS METER

REVISED:

07 MAY 2008

METER PLATE

E-M203