



NOTES:

1. USE THIS MINIMUM ACCEPTABLE CONFIGURATION IF THERE IS NOT THE 914mm PREFERRED HORIZONTAL SPACING BETWEEN THE ELECTRIC AND GAS METERS.
2. THE 914mm MINIMUM SPACING MEASURED ALONG THE DIAGONAL BETWEEN THE GAS METER AND ELECTRIC METER IS REQUIRED.
3. THIS CONFIGURATION IS TYPICALLY USED ON FACILITY WALLS WITH EXTERIOR OBSTRUCTIONS THAT LIMIT INSTALLATION SPACING.

OUTSIDE METER INSTALLATION ON WALL – ACCEPTABLE DISTANCE TO GAS METER

REVISED:

13 JANUARY 2011

METER PLATE

E-M203-SI